

EPA Certification Test Report

The following models are EPA certified under the following attached test report: **F2450**

| | <u>Model #</u> |
|-----------------|----------------|
| Wood Stoves | F2450 |
| Wood Inserts | N/A |
| Wood Fireplaces | N/A |
| Pellet Stoves | N/A |
| Pellet Inserts | N/A |

Full US Environmental Protection Agency (“EPA”) certification test reports have been reported to the EPA. Test reports may contain sensitive, confidential business information which has been specifically excluded and/or redacted from this publicly posted test report.

Fireplace Products International, Ltd.

Project # 19-460

Model: F2450

Type: Wood-Fired Room Heater

March 7, 2019

Revised: February 28, 2022

**ASTM E3053 Standard Test
Method for Determining
Particulate Matter Emissions from
Wood Heaters Using Cordwood
Test Fuel (EPA ALT-125)**

Contact: Mr. Dave Lal
6988 Venture Street
Delta, BC V4G 1H4
Canada
dlal@regency-fire.com
(604)-946-5155

Prepared by: Sebastian Button,
Laboratory Supervisor



**11785 SE Highway 212 – Suite 305
Clackamas, OR 97015-9050
(503) 650-0088**

WWW.PFSTECO.COM

Revision Summary

Date: 3/7/2019 – Original Issue

Date: 2/28/2022 – The following revisions were made per a request from EPA:

- The “Test Run Narrative” section was edited to clarify that test run 3 was appropriate and valid, see page 9.

- Added a drawing of the Firebox to the main body of the report, see page 12.

- Updated drawing of firebox in Appendix D, the previous version showed overall dimensions without firebrick and baffling.

- The Owner’s Manual in Appendix B was updated to include information on the longest firebox dimensions and information on use of CO monitors, see pages 211 and 235 of the Non-CBI report.

Contents

- Affidavit 3
- Introduction 4
 - Notes 4
- Wood Heater Identification and Testing 5
- Test Procedures and Equipment 6
- Results 7
 - Summary Table 7
 - Test Run Narrative 8
 - Run 1 8
 - Run 2 8
 - Run 3 8
- Test Conditions Summary 9
 - Appliance Operation and Test Settings 9
 - Settings & Run Notes 9
- Appliance Description 10
 - Appliance Dimensions 10
- Firebox Volume Dimensions 11
- Test Fuel Properties 14
- Sampling Locations and Descriptions 15
 - Sample Points 15
- Sampling Methods 16
- Analytical Methods Description 16
- Calibration, Quality Control and Assurances 16
- Appliance Sealing and Storage 16
 - Sealing Label 16
 - Sealed Unit 17
- List of Appendices 18

Affidavit

PFS-TECO was contracted by Fireplace Products International Ltd. (FPI) to provide testing services for the F2450 Wood-Fired Room Heater per ASTM E3053, *Standard Test Method for Determining Particulate Matter Emissions from Wood Heaters Using Cordwood Test Fuel*, which was approved for use under EPA ALT-125. All testing and associated procedures were conducted at PFS-TECO's Portland Laboratory beginning on 2/27/2019 and ending on 2/28/2019. PFS-TECO's Portland Laboratory is located at 11785 SE Highway 212 – Suite 305, Clackamas, Oregon 97015. Testing procedures followed ASTM E3053 with the exception of caveats described in EPA ALT-125. Particulate sampling was performed per ASTM E2515, *Standard Test Method for Determination of Particulate Matter Emissions Collected by a Dilution Tunnel*, with the exception of caveats described in EPA ALT-125. A copy of EPA ALT-125 is included in Appendix A for reference, as required by the approval letter.

PFS-TECO is accredited by the U.S. Environmental Protection Agency for the certification and auditing of wood heaters pursuant to subpart AAA of 40 CFR Part 60, New Source Performance Standards for Residential Wood Heaters and subpart QQQQ of 40 CFR Part 60, Standards of Performance for New Hydronic Heaters and Forced Air Furnaces, Methods 28R, 28WHH, 28 WHH-PTS, and all methods listed in Sections 60.534 and 60.5476. PFS-TECO holds EPA Accreditation Certificate Numbers 4 and 4M (mobile). PFS-TECO is accredited by IAS to ISO 17020:2012 "Criteria for Bodies Performing Inspections", and ISO 17025:2005 "Requirements for Testing Laboratories." PFS-TECO is also accredited by Standards Council of Canada to ISO 17065:2012 "Requirements for Bodies Operating Product Certification Systems."

The following people were associated with the testing, analysis and report writing associated with this project.



Sebastian Button, Laboratory Supervisor

Introduction

FPI-Regency Fireplaces Products of Delta, BC, contracted with PFS-TECO to perform EPA certification testing on F2450 Wood-Fired Room Heater. All testing was performed at PFS-TECO's Portland Laboratory. Testing was performed by Mr. Sebastian Button.

Notes

- Prior to start of testing, 50 hours of conditioning was performed per ASTM E3053.
- Prior to start of testing, the dilution tunnel was cleaned with a steel brush.
- Front filters were changed on sample train A at one hour for all 3 test runs.
- A total of 3 test runs were performed in accordance with ASTM E3053, no anomalies occurred, no additional tests performed, see Run Narrative section for further detail on each run.

Wood Heater Identification and Testing

- Appliance Tested: **F2450**
- Serial Number: **Un-serialized Prototype – PFS Tracking Number 0022**
- Manufacturer: **FPI-Regency Fireplace Products**
- Catalyst: **No**
- Heat exchange blower: **Optional**
- Type: **Wood Stove**
- Style: **Pedestal**
- Date Received: **Thursday, February 21, 2019**
- Testing Period – Start: **Wednesday, February 27, 2019** Finish: **Thursday, February 28, 2019**
- Test Location: **PFS-TECO Portland Laboratory, 11785 SE HWY 212 - Suite 305, Clackamas, OR 97015**
- Elevation: **≈131 Feet above sea level**
- Test Technician(s): **Sebastian Button**
- Observers: **Radu Costei and Dave Lal of FPI.**

Test Procedures and Equipment

All Sampling and analytical procedures were performed by Sebastian Button. All procedures used are directly from ASTM E3053 and ASTM E2515. See the list below for equipment used. See Appendix C submitted with this report for calibration data.

Equipment List:

| Equipment ID# | Equipment Description |
|---------------|--|
| 041 | Rice Lake 3'x3' floor scale w/digital weight indicator |
| 050 | Digiweigh DWP12i Platform Scale |
| 053 | APEX XC-60 Digital Emissions Sampling Box A |
| 054 | APEX XC-60 Digital Emissions Sampling Box B |
| 055 | APEX Ambient sampling box |
| 057 | California Analytical ZRE CO2/CO/O2 IR ANALYZER |
| 064 | Digital Barometer |
| 109A/B | Troemner 100mg/200mg Audit Weights |
| 107 | Sartorius Analytical Balance |
| 051 | 10 lb audit weight |
| 090 | Dewalt Tape Measure |
| 092 | Digital Calipers |
| 095 | Anemometer |
| 111 | Microtector |
| 115 | Delmhorst Wood Moisture Meter |
| CC700832 | Gas Analyzer Calibration Span Gas |
| CC170624 | Gas Analyzer Calibration Mid Gas |

Results

The weighted average emissions rate for the 3 run test series was measured to be **2.26 g/hr** with a Higher Heating Value efficiency of **73.3%**. The average CO emission rate for the 3 tests was **1.85 g/min.** The FPI F2450 Wood-Fired Room Heater meets the 2020 cordwood PM emission standard of ≤ 2.5 g/hr per CFR 40 part 60, §60.532 (c).

Detailed individual run data can be found in Appendix A submitted with this report.

Summary Table

| | High Fire Test | Low Fire Test | Medium Fire Test |
|---|----------------|---------------|------------------|
| Date | 2/27/2019 | 2/27/2019 | 2/28/2019 |
| Run Number | 1 | 2 | 3 |
| PM Emission Rate (g/hr) | 5.78 | 1.81 | 0.96 |
| Burn Rate (kg/hr) | 4.38 | 1.01 | 1.17 |
| Heat Output (BTU/hr) | 53,563 | 14,179 | 16,405 |
| HHV Efficiency (%) | 71.2 | 73.9 | 73.7 |
| LHV Efficiency (%) | 76.1 | 79.1 | 78.9 |
| CO Emissions (g/MJ output) | 3.80 | 5.90 | 4.74 |
| CO Emissions (g/kg dry fuel) | 54.01 | 87.10 | 69.72 |
| CO Emissions (g/min) | 3.58 | 1.47 | 1.37 |
| First Hour Emission Rate (g/hr) | 9.84 | 2.92 | 5.65 |
| Weighting Factor (%) | 20 | 40 | 40 |
| Weighted particulate emission average of 3 test runs: 2.26 grams per hour. | | | |
| Weighted average HHV efficiency of 3 test runs: 73.3%. | | | |
| Average CO emission rate for 3 test runs: 1.85 grams per minute | | | |

Test Run Narrative

Run 1

Run 1 was performed on 2/27/2019 as a high fire test run per ASTM E3053. Emissions sampling began from a cold start ignition of kindling and start-up fuel. The test fuel load was loaded 27 minutes into the test. Testing was completed when 90% of the test fuel load was consumed. Total test time was 124 minutes, main test fuel load burn time was 97 min. The particulate emissions rate from kindling ignition to test completion was 5.78 g/hr. The burn rate of the test fuel load was 4.38 kg/hr. The main test load portion of the run had an overall HHV efficiency of 71.2%. The train A front filter was changed at 1 hr. All test results were appropriate and valid. There were no anomalies and all test criteria were met.

Run 2

Run 2 was performed on 2/27/2019 as a low fire test run per ASTM E3053. The overall test duration was 573 minutes. The burn rate for the test run was 1.01 kg/hr. The particulate emissions rate for the test run was 1.81 g/hr. The run had an overall HHV efficiency of 73.9%. The train A front filter was changed at 1 hr. All test results were appropriate and valid. There were no anomalies and all test criteria were met.

Run 3

Run 3 was performed on 2/28/2019 as a medium fire test run per ASTM E3053. The overall test duration was 490 minutes. The burn rate for the test run was 1.17 kg/hr, therefore the medium fire category requirements were met, less than the mid-point of the high and low burn rates (2.69 kg/hr). The particulate emissions rate for the test run was 0.96 g/hr. The run had an overall HHV efficiency of 73.7%. The train A front filter was changed at 1 hr. All test results were appropriate and valid. There were no anomalies and all criteria were met.

Test Conditions Summary

Testing conditions for all runs fell within allowable specifications of ASTM E3053 and ASTM E2515. A summary of facility conditions, fuel burned, and run times is listed below.

| Runs | Ambient (°F) | | Relative Humidity (%) | | Average Barometric Pressure (In. Hg.) | Preburn Fuel Weight (lbs) | Test Fuel Weight (lbs) | Test Fuel Moisture (%DB) | Test Run Time (Min) |
|------|--------------|------|-----------------------|------|---------------------------------------|---------------------------|------------------------|--------------------------|---------------------|
| | Pre | Post | Pre | Post | | | | | |
| 1 | 71 | 74 | 8.1 | 9.1 | 29.78 | 7.2 ¹ | 21.4 | 20.7 | 124 ² |
| 2 | 75 | 76 | 9.1 | 8.1 | 29.77 | 21.4 | 26.0 | 22.0 | 573 |
| 3 | 74 | 69 | 10.1 | 9.3 | 29.97 | 21.6 | 25.9 | 22.5 | 490 |

¹This is the weight of the kindling and startup fuel

²Total test time was 127 min, high fire test load burn duration was 97 min.

Appliance Operation and Test Settings

The appliance was operated according to procedures as described in the Operations Manual, found in Appendix B submitted with this report. Detailed run information can be found in Appendix A submitted with this report.

Settings & Run Notes

| | Pre-Burn Air Setting | Test Run Air and Fan Settings |
|--------------|--|--|
| Run 1 | N/A – Cold Start Ignition | Air control set to high fire test setting (1.975 in ² opening), blower off for first 20 min, then set to high. |
| Run 2 | Air control set to High Fire Setting in accordance with ASTM E3053 | Air control set to low fire test setting (0.322 in ² opening), blower off for first 30 min, then set to low. |
| Run 3 | Air control set to High Fire Setting in accordance with ASTM E3053 | Air control set to medium fire test setting (0.447 in ² opening), blower off for first 20 min, then set to low. |

Appliance Description

Model(s): F2450

Appliance Type: Wood-Fired Room Heater

Firebox Volume: 2.24 ft³

Air Introduction System: Primary Air enters the firebox from the front bottom of the appliance and is channeled up the sides on the appliance and down through the air wash, as well as through a pilot air opening in the front of the firebox. Primary air is controlled via a damper arm located below the ashlip which moves left (open) to right (closed). Secondary air is pulled through a fixed opening in to rear bottom of the appliance and channeled up through 4 secondary air tubes. Dimensions on all these features can be found in Appendix D.

Baffles: A pair of mating 9.437" x 15.0" x 0.984" vermiculite panels mate together to form a baffle which rests on top of the secondary air tubes.

Refractory Insulation: The firebox is lined with 1" thick firebrick.

Flue Outlet: 6-inch exhaust outlet located on the top of the appliance.

Catalytic Combustor: N/A

Fan: The F2450 is optionally offered with a convection fan that attached to the bottom rear of the appliance.


Appliance Dimensions

F2450 Unit Dimensions

| Height | Width | Depth | Firebox Volume | Weight |
|---------|-------|--------|----------------------|---------|
| 32.125" | 24" | 24.75" | 2.24 ft ³ | 330 lbs |

Appliance design drawings can be found in Appendix D submitted with the CBI copy of this report.

Firebox Volume Dimensions



Appliance Front



Appliance Left



Appliance Right



Appliance Rear



Test Fuel Properties

Test fuel used was Maple cordwood, split and air-dried to the specified moisture content range. Typical fuel loads are pictured below:

Typical Kindling Load



Typical Startup Load



Typical High Fire Load





Typical Low Fire Load



Sampling Locations and Descriptions

Sample ports are located 16.5 feet downstream from any disturbances and 1 foot upstream from any disturbances. Flow rate traverse data was collected 12 feet downstream from any disturbances and 5.5 feet upstream from any disturbances. (See below).

Sample Points



Sampling Methods

ASTM E2515 was used in collecting particulate samples. The dilution tunnel is 6 inches in diameter. All sampling conditions per ASTM E2515 were followed. No alternate procedures were used with the exception of caveats described in ALT-125: Pall TX40 Emfab filters were used, filter temperatures were maintained between 80 and 90°F for all tests, filters were weighed in pairs where applicable, and no sampling intervals fell outside of proportional rates of +/- 10%.

Analytical Methods Description

All sample recovery and analysis procedures followed ASTM E2515 procedures. At the end of each test run, filters, O-Rings and probes were removed from their housings, dessicated for a minimum of 24 hours, and then weighed at 6 hour intervals to a constant weight per ASTM E2515-11 Section 10.

Calibration, Quality Control and Assurances

Calibration procedures and results were conducted per EPA Method 28R, ASTM E2515-11 and ASTM E3053. Test method quality control procedures (leak checks, volume meter checks, stratification checks, proportionality results) followed the procedures outlined.

Appliance Sealing and Storage

Upon completion of testing, the appliance was secured with metal strapping and the seal below was applied, the appliance was then returned to the manufacturer’s location at: 6988 Venture St, Delta, BC V4G 1H4, Canada, for archival.

Sealing Label

ATTENTION:

THIS SEAL IS NOT TO BE BROKEN WITHOUT PRIOR AUTHORIZATION FROM THE UNITED STATES ENVIRONMENTAL PROTECTION AGENCY.

THIS APPLIANCE HAS BEEN SEALED INACCORDANCE WITH REQUIREMNTS OF 40CFR PART 60 SUBPART AAA §60.535 (a)(2)(vii)

REPORT # _____

DATE SEALED _____

MANUFACTURER _____

MODEL # _____

Sealed Unit



List of Appendices

The following appendices have been submitted electronically in conjunction with this report:

Appendix A – Test Run Data, Technician Notes, Sample Analysis, and Alternate Test Method Approval

Appendix B – Labels and Manuals

Appendix C – Equipment Calibration Records

Appendix D – Design Drawings (CBI Report Only)

Appendix E – Manufacturer QAP (CBI Report Only)

Conditioning Data

| | |
|--------------|------------------|
| Client: FPI | Job #: 19-460 |
| Model: F2450 | Tracking #: 0022 |
| Date(s): | Technician: SJB |

| Elapsed Time (hrs) | Scale Reading (lbs) | Average: | 291.5 | 71.0 | N/A |
|--------------------|---------------------|---------------------|-----------|--------------|--------------------|
| | | Weight Change (lbs) | Flue (°F) | Ambient (°F) | Catalyst Exit (°F) |
| 0 | 27.0 | - | 377 | 70 | N/A |
| 1 | 16.2 | -10.8 | 397 | 70 | N/A |
| 2 | 8.5 | -7.7 | 376 | 73 | N/A |
| 3 | 5.1 | -3.4 | 258 | 72 | N/A |
| 4 | 3.8 | -1.3 | 192 | 71 | N/A |
| 5 | 2.8 | -1.0 | 192 | 70 | N/A |
| 6 | 1.9 | -0.9 | 184 | 69 | N/A |
| 7 | 1.0 | -0.9 | 186 | 68 | N/A |
| 8 | 26.3 | 25.3 | 407 | 71 | N/A |
| 9 | 14.8 | -11.5 | 400 | 70 | N/A |
| 10 | 7.6 | -7.2 | 353 | 71 | N/A |
| 11 | 4.5 | -3.1 | 252 | 71 | N/A |
| 12 | 3.3 | -1.2 | 210 | 70 | N/A |
| 13 | 2.3 | -1.0 | 196 | 72 | N/A |
| 14 | 1.4 | -0.9 | 184 | 67 | N/A |
| 15 | 26.7 | 25.3 | 418 | 69 | N/A |
| 16 | 15.4 | -11.3 | 385 | 70 | N/A |
| 17 | 7.6 | -7.8 | 374 | 74 | N/A |
| 18 | 4.6 | -3.0 | 263 | 73 | N/A |
| 19 | 3.4 | -1.2 | 207 | 69 | N/A |
| 20 | 2.3 | -1.1 | 206 | 69 | N/A |
| 21 | 1.4 | -0.9 | 194 | 67 | N/A |
| 22 | 26.8 | 25.4 | 364 | 73 | N/A |
| 23 | 17.4 | -9.4 | 424 | 74 | N/A |
| 24 | 9.9 | -7.5 | 355 | 75 | N/A |
| 25 | 5.6 | -4.3 | 286 | 72 | N/A |
| 26 | 4.0 | -1.6 | 213 | 71 | N/A |
| 27 | 2.9 | -1.1 | 204 | 69 | N/A |
| 28 | 2.0 | -0.9 | 184 | 69 | N/A |
| 29 | 1.0 | -1.0 | 188 | 68 | N/A |
| 30 | 0.3 | -0.7 | 181 | 68 | N/A |
| 31 | 26.0 | 25.7 | 383 | 72 | N/A |
| 32 | 17.8 | -8.2 | 318 | 72 | N/A |
| 33 | 10.2 | -7.6 | 355 | 73 | N/A |
| 34 | 5.8 | -4.4 | 261 | 73 | N/A |
| 35 | 4.2 | -1.6 | 191 | 74 | N/A |
| 36 | 25.9 | 21.7 | 402 | 75 | N/A |
| 37 | 16.7 | -9.2 | 335 | 74 | N/A |
| 38 | 9.2 | -7.5 | 372 | 77 | N/A |
| 39 | 5.5 | -3.7 | 244 | 76 | N/A |
| 40 | 4.3 | -1.2 | 202 | 74 | N/A |
| 41 | 3.3 | -1.0 | 191 | 74 | N/A |
| 42 | 2.8 | -0.5 | 181 | 73 | N/A |
| 43 | 26.4 | 23.6 | 403 | 71 | N/A |
| 44 | 18.9 | -7.5 | 290 | 69 | N/A |
| 45 | 12.5 | -6.4 | 336 | 69 | N/A |
| 46 | 7.6 | -4.9 | 270 | 70 | N/A |
| 47 | 5.1 | -2.5 | 209 | 70 | N/A |
| 48 | 26.0 | 20.9 | 432 | 65 | N/A |
| 49 | 15.2 | -10.8 | 475 | 67 | N/A |
| 50 | 7.0 | -8.2 | 405 | 68 | N/A |

WOOD HEATER TESTING SUMMARY

SECTION 1 – Model Identification

Model Name(s)/Number(s)
Manufacturer
Address 1
Address 2
Appliance Category(s) (Free-standing, Insert, etc.)
Usable Firebox Volume - ft³
Catalytic/Non-Cat
Convection Air Fan (No, Standard, Optional)

F2450
FPI - Regency Fireplaces Products
6988 Venture St.
Delta, BC V4G 1H4
Free-standing
2.24
Non-Cat
Optional

SECTION 1B – Laboratory Information

Testing Laboratory
Address 1
Address 2
ISO/Accreditation Info
Dates Tested
Test Methods/Standards
Dilution Tunnel Inside Diameter - in.
Fliter Diameter - mm
Filter Material

PFS-TECO
11785 SE Hwy 212 Ste 305
Clackamas, OR 97015
ISO 17025
2/27/2019 - 2/28/2019
ASTM E3053 (ALT-125), ASTM E2515
6.00
47
Pall Type TX40

Test Configuration Photographs



Stove Front



Stove Left



Stove Right



Typical Kindling Load



Typical Start-up Load



Typical High Fire Load



Typical High Fire Coal Bed



Typical Low/Med Fire Load



Typical Low Fire Coal Bed

SECTION 2 – Test Conditions Summary

Model Name(s)/Number(s)
 Usable Firebox Volume - ft³
 Convection Air Fan (No, Standard, Optional)
 Test Run #
 Date Tested
 Test Run Category (L, M, H)
 Average Barometric Pressure - in Hg
 Max. Observed Ambient Temp - °F
 Min. Observed Ambient Temp - °F
 Max. Observed Filter Temp - °F
 Test Run Air Settings
 Primary (measured up from minimum)
 Secondary (measured up from minimum)
 Convection Air Fan Setting
 Test Fuel Load
 Cordwood Fuel Species
 Specific Gravity (from Table 1)
 Higher Heating Value - Btu/lb (from Annex A1)
 Nom. Test Fuel Load Piece Length - in.
 Number of Test Fuel Pieces
 Test Fuel Weight
 Kindling - As Fired lb
 Kindling Wt. - As % of Test Fuel Load
 Kindling Moisture - % DB
 Kindling - kg DB
 SU Fuel - As Fired lb
 SU Fuel Wt. - As % of Test Fuel Load
 SU Fuel Moisture - % DB
 SU Fuel - kg DB
 Test Fuel Load - As Fired lb
 Ave. Test Fuel Load MC % DB
 Test Fuel Load - kg DB
 Test Fuel Loading Density - lb/ft³
 Residual SU Fuel Wt. - As Fired lb
 Residual SU Fuel Wt. - As % of Test Fuel Load
 Test Run Duration - minutes
 Test Run Duration - h
 Run Duration of High Fire Load Only - minutes
 Run Duration of High Fire Load Only - h
 Test Fuel Load Wt. at End of Test - As Fired lb
 Total Total Fuel Burned - kg DB
 % Test Fuel Load Wt. at End of Test

| | | | |
|-----------|-----------|-----------|--|
| F2450 | | | |
| 2.24 | | | |
| Optional | | | |
| 1 | 2 | 3 | |
| 2/27/2019 | 2/27/2019 | 2/28/2019 | |
| H | L | M | |
| 29.78 | 29.77 | 29.97 | |
| 76 | 77 | 74 | |
| 71 | 68 | 69 | |
| 87 | 87 | 87 | |
| | | | |
| Maximum | Minimum | 0.792" | |
| Fixed | Fixed | Fixed | |
| High | Low | Low | |
| | | | |
| Maple | Maple | Maple | |
| 0.6 | 0.6 | 0.6 | |
| 8587 | 8587 | 8587 | |
| 17 | 17 | 17 | |
| 6 | 5 | 5 | |
| | | | |
| 3.02 | na | na | |
| 14% | na | na | |
| 10% | na | na | |
| 1.25 | na | na | |
| 4.19 | na | na | |
| 20% | na | na | |
| 20% | na | na | |
| 1.58 | na | na | |
| 21.37 | 25.96 | 25.88 | |
| 20.7% | 22.0% | 22.5% | |
| 8.03 | 9.67 | 9.58 | |
| 9.54 | 11.59 | 11.55 | |
| 2.20 | na | na | |
| 10% | na | na | |
| 124 | 573 | 490 | |
| 2.07 | 9.55 | 8.17 | |
| 97 | na | na | |
| 1.62 | na | na | |
| 2.1 | 0 | 0 | |
| 8.91 | 9.67 | 9.58 | |
| 9.8% | 0.0% | 0.0% | |

SECTION 3 – Test Run Results Summary

Model Name(s)/Number(s)
 Usable Firebox Volume - ft³
 Convection Air Fan (No, Standard, Optional)
 Test Run #
 Date Tested
 Test Run Category
 Burn Rate - kg/h DB
 Burn Rate - As % of Low to High Midpoint
 Burn Duration - h
 Heat Output - Btu/h
 Average Dilution Tunnel Flow Rate - dscfm
 Average Sample Flow Rates - dscfm
 Train 1
 Train 2
 Total PM Emissions - g
 Train 1
 Train 2
 Average
 PM Emission Train Precision - %
 PM Emission Train Precision - g/kg
 PM Emission Rate - g/h
 Total CO Emissions - g
 CO Emissions Rate - g/h
 Overall Efficiency - CSA B415.1-10
 % HHV Basis
 % LHV Basis

| | | | |
|----------|---------|---------|--|
| F2450 | | | |
| 2.24 | | | |
| Optional | | | |
| 1 | 2 | 3 | |
| 2/27/19 | 2/27/19 | 2/28/19 | |
| H | L | M | |
| 4.38 | 1.01 | 1.17 | |
| na | na | 44% | |
| 2.07 | 9.55 | 8.17 | |
| 53,563 | 14,179 | 16,405 | |
| 171.08 | 176.61 | 178.73 | |
| | | | |
| 0.151 | 0.154 | 0.150 | |
| 0.147 | 0.151 | 0.148 | |
| | | | |
| 12.23 | 17.40 | 7.79 | |
| 11.65 | 17.25 | 7.84 | |
| 11.940 | 17.325 | 7.815 | |
| 2.4% | 0.4% | -0.3% | |
| 0.07 | 0.02 | -0.01 | |
| 5.78 | 1.81 | 0.96 | |
| 347 | 843 | 669 | |
| 215 | 88 | 82 | |
| | | | |
| 71.2 | 73.9 | 73.7 | |
| 76.1 | 79.1 | 78.9 | |

SECTION 4 - Weighted Average Summary

Model Name(s)/Number(s)
 Usable Firebox Volume - ft₃
 Convection Air Fan (No, Standard, Optional)
 Average for Each Test Run Category
 Burn Rate - kg/h DB
 PM Emission Rate - g/h
 CO Emissions Rate - g/h
 Overall Efficiency - CSA B415.1-10
 % HHV Basis
 % LHV Basis
 Heat Output - Btu/h
 Category Weighting

| | | |
|----------|-------|-------|
| F2450 | | |
| 2.24 | | |
| Optional | | |
| L | M | H |
| 1.01 | 1.17 | 4.38 |
| 1.81 | 0.96 | 5.78 |
| 88.3 | 81.9 | 214.6 |
| | | |
| 73.9 | 73.7 | 71.2 |
| 79.1 | 78.9 | 76.1 |
| 14200 | 16400 | 53600 |
| 40% | 40% | 20% |

ASTM E 3053 Weighted Averages
 PM Emission Rate - g/h
 CO Emissions Rate - g/h
 Overall Efficiency - CSA B415.1-10
 % HHV Basis
 % LHV Basis
 Heat Output Range - Btu/h

| |
|----------------|
| |
| 2.26 |
| 111.0 |
| |
| 73.3 |
| 78.4 |
| 14200 to 53600 |

Emission testing instructions F2450

Volume: 2.24 cu.ft.

Low and Medium

High before Low and Medium – no sampling. Air set to High Setting

Fan on high at 20 min after loading main fuel load

Kindling – 3.0lb

Startup fuel – 4.0lb

Procedure

Start with a couple pieces of crumbled paper in between and 2 lbs kindling. Adjust the door opening for less smoke and establish a good fire. Keep the door open in that position for 2 – 3 min.

At ~0.8lb load the remainder of the kindling fuel and 1.5lbs of start-up fuel, keep door open slightly ajar for 2 minutes.

At ~1lb load remaining SU fuel and keep door open slightly ajar for 2 minutes.

At low end of coal bed range load the high load. Close the door right away.

At 20 min turn on the fan on high.

Around 6 lbs adjust the load. Lift the unburned pieces out from the coals and bring unburned pieces to center front to ensure full charcoalization.

Around 4 lbs, when everything is burned, and almost no flames left rake the coals, zero the scale and follow the standard loading procedure.

Low and Medium test load

Load heavier logs to the sides.

Keep the door open a couple seconds so there is a strong fire going.

Air adjustment

Medium

Set the air to medium air setting within 3-4 min.

Fan on low at 20 min

Low

At 4-5 min, turn air down to medium setting, at 13-14 min set to Low setting.

Fan on low at 30 min.

WOOD STOVE TEST DATA PACKET
ASTM E3053/E2515



Run 1 Data Summary

Client: FPI
Model: F2450
Job #: 19-460
Tracking #: 0022
Test Date: 2/27/2019

A handwritten signature in black ink, appearing to be "JL", is written over a horizontal line.

Techician Signature

3/4/2019

Date

TEST RESULTS - ASTM E3053 / ASTM E2515

Client: FPI

Model: F2450

Run #: 1

Job #: 19-460

Tracking #: 0022

Technician: SJB

Date: 2/27/2019

| | |
|---------------------------|-------------|
| Burn Rate (kg/hr): | 4.38 |
|---------------------------|-------------|

| | Ambient Sample | Sample Train A | Sample Train B | 1st Hour Filter |
|---|----------------|----------------|----------------|-----------------|
| Total Sample Volume (ft ³) | 15.005 | 18.725 | 18.214 | 8.947 |
| Average Gas Velocity in Dilution Tunnel (ft/sec) | 16.76 | | | |
| Average Gas Flow Rate in Dilution Tunnel (dscf/hr) | 10264.9 | | | |
| Average Gas Meter Temperature (°F) | 73.9 | 91.7 | 91.2 | 85.5 |
| Total Sample Volume (dscf) | 14.747 | 17.999 | 17.452 | 8.697 |
| Average Tunnel Temperature (°F) | 134.0 | | | |
| Total Time of Test (min) | 124 | | | |
| Total Particulate Catch (mg) | 0.1 | 10.5 | 9.7 | 8.4 |
| Particulate Concentration, dry-standard (g/dscf) | 0.0000068 | 0.0005834 | 0.0005558 | 0.0009659 |
| Total PM Emissions (g) | 0.14 | 12.23 | 11.65 | 9.84 |
| Particulate Emission Rate (g/hr) | 0.07 | 5.92 | 5.64 | 9.84 |
| Emissions Factor (g/kg) | - | 1.37 | 1.30 | - |
| Difference from Average Total Particulate Emissions (g) | - | 0.29 | 0.29 | - |
| Difference from Average Emissions Factor (g/kg) | - | 0.03 | 0.03 | - |

| Final Average Results | |
|----------------------------------|-------|
| Total Particulate Emissions (g) | 11.94 |
| Particulate Emission Rate (g/hr) | 5.78 |
| Emissions Factor (g/kg) | 1.34 |
| HHV Efficiency (%) | 71.2% |
| LHV Efficiency (%) | 76.1% |
| CO Emissions (g/min) | 3.58 |

| Quality Checks | Requirement | Observed | Result |
|----------------------------------|---|--------------------------|----------------------------------|
| Dual Train Precision | Each train within 7.5% of average emissions (in grams), or emission factors within 0.5 g/kg | See Above | OK |
| Filter Temps | >80 °F, <90 °F | Min: 81 / Max: 87 | OK |
| Face Velocity | < 30 ft/min | 12.7 | OK |
| Leakage Rate | Less than 4% of average sample rate | 0 cfm | OK |
| Ambient Temp | 55-90 °F | Min: 71 / Max: 76 | OK |
| Negative Probe Weight Evaluation | <5% of Total Catch | Probe Catch Not Negative | OK |
| Pro-Rate Variation | 90% of readings between 90-110%; none greater than 120% or less than 80% | See Data Tabs | CHECK 10 MIN. INTERVAL PRO-RATES |

B415.1 Efficiency Results

Manufacturer: FPI
Model: F2450
Date: 02/27/19
Run: 1
Control #: 19-460
Test Duration: 97
Output Category: High

Test Results in Accordance with CSA B415.1-09

| | HHV Basis | LHV Basis |
|---------------------------------|-----------|-----------|
| Overall Efficiency | 71.2% | 76.1% |
| Combustion Efficiency | 96.2% | 96.2% |
| Heat Transfer Efficiency | 74.0% | 79.1% |

| | | | |
|---------------------------|--------|--------|----------------|
| Output Rate (kJ/h) | 56,465 | 53,563 | (Btu/h) |
| Burn Rate (kg/h) | 3.98 | 8.76 | (lb/h) |
| Input (kJ/h) | 79,352 | 75,274 | (Btu/h) |

| | | | |
|----------------------------------|-------|-------|---------------|
| Test Load Weight (dry kg) | 6.43 | 14.17 | dry lb |
| MC wet (%) | 17.16 | | |
| MC dry (%) | 20.72 | | |
| Particulate (g) | 11.94 | | |
| CO (g) | 347 | | |
| Test Duration (h) | 1.62 | | |

| Emissions | Particulate | CO |
|-------------------------|-------------|--------|
| g/MJ Output | 0.13 | 3.80 |
| g/kg Dry Fuel | 1.86 | 54.01 |
| g/h | 7.39 | 214.73 |
| g/min | 0.12 | 3.58 |
| lb/MM Btu Output | 0.30 | 8.84 |

| | |
|-----------------------------|------|
| Air/Fuel Ratio (A/F) | 8.78 |
|-----------------------------|------|

VERSION:

2.2

12/14/2009

HIGH FIRE FUEL LOAD DATA - ASTM E3053

Client: FPI
 Model: F2450
 Run #: 1

Job #: 19-460
 Tracking #0022
 Technician: SJB
 Date: 2/27/2019

Nominal Loading Density (lbs/ft³, wet basis): 10
 Usable Firebox Volume (ft³): 2.24
 Target Load Weight (lbs): 22.40
 Total Load Weight Range (lbs): 21.30 to 23.50
 Core Load Weight Range (lbs): 10.10 to 14.60
 Remainder Load Weight Range (lbs): 7.80 to 12.30
 Core Load Piece Range (lbs): 3.40 to 5.60
 Remainder Load Piece Range (lbs): 2.20 to 12.30
 Max Allowable Kindling Weight (lbs): 4.27
 Max Allowable Start-up Fuel Weight (lbs): 6.41

CORE LOAD DATA

| Piece # | Length (in) | Weight (lbs) | Within Spec? | Fuel Piece Moisture Readings (%DB) | | | | Within Spec? | Dry Weight | |
|---------------------|-------------|--------------|--------------|------------------------------------|------|------|------|--------------|------------|------|
| | | | | 1 | 2 | 3 | Ave. | | lbs | kg |
| 1 | 17.00 | 3.44 | In Range | 23.8 | 22.4 | 22.1 | 22.8 | In Range | 2.80 | 1.27 |
| 2 | 17.00 | 4.32 | In Range | 22.9 | 22.1 | 19.4 | 21.5 | In Range | 3.56 | 1.61 |
| 3 | 17.00 | 4.61 | In Range | 18.6 | 19.4 | 19.8 | 19.3 | In Range | 3.87 | 1.75 |
| Core Load Wt. (lbs) | | 12.37 | In Range | | | | | | | |

REMAINDER LOAD DATA (1 to 3 Pieces)

| Piece # | Length (in) | Weight (lbs) | Within Spec? | Fuel Piece Moisture Readings (%DB) | | | | Within Spec? | Dry Weight | |
|----------------------|-------------|--------------|--------------|------------------------------------|------|------|------|--------------|------------|------|
| | | | | 1 | 2 | 3 | Ave. | | lbs | kg |
| 1 | 17.00 | 3.22 | In Range | 19.3 | 19.5 | 18.7 | 19.2 | In Range | 2.70 | 1.23 |
| 2 | 17.00 | 2.25 | In Range | 25.2 | 23.4 | 24.6 | 24.4 | In Range | 1.81 | 0.82 |
| 3 | 17.00 | 3.53 | In Range | 19.4 | 18.3 | 19.1 | 18.9 | In Range | 2.97 | 1.35 |
| Remainder Load (lbs) | | 9.00 | In Range | | | | | | | |

Total Load Weight (lbs): 21.37 In Range
 Core Load % of Total Weight: 58% In Range 45-65%
 Remainder % of Total Weight: 42% In Range 35-55%
 Total Load % of Target Weight: 95% In Range 95-105%
 Actual Fuel Loading Density (lb/ft³): 9.5
 Total Load Average Moisture Content (%DB): 20.7 In Range 19-25%
 Total Load Average Moisture Content (%WB): 17.2
 Total Test Load Weight (dry basis): 17.70 lbs 8.03 kg

KINDLING AND START-UP FUEL

| Kindling Weight (lbs) | Within Spec? | Kindling Moisture Readings (%DB) | | | | Within Spec? | Dry Weight | |
|-----------------------|--------------|----------------------------------|----|----|------|--------------|------------|------|
| | | 1 | 2 | 3 | Avg. | | lbs | kg |
| 3.02 | In Range | 10 | 10 | 10 | 10.0 | In Range | 2.75 | 1.25 |

| Start-up Fuel Wt. (lb) | Within Spec? | Start-up Moisture Readings (%DB) | | | | Within Spec? | Dry Weight | |
|------------------------|--------------|----------------------------------|------|------|------|--------------|------------|------|
| | | 1 | 2 | 3 | Avg. | | lbs | kg |
| 4.19 | In Range | 19.3 | 22.4 | 18.7 | 20.1 | In Range | 3.49 | 1.58 |

TEST FUEL LOADING RANGE

Allowable Residual Start-up Fuel Range (lb): 2.1 to 4.3
 Actual Residual Start-up Fuel Weight (lb): 2.2 In Range

TEST END POINT

High Fire Test Run End Point Range: 1.9 to 2.4 lb
 Actual Fuel Load Ending Weight (lb): 2.1 In Range

Total Weight All Fuel Added: 28.58 lbs, wet basis Total Weight All Fuel Burned (dry basis): 19.64 lbs
 23.94 lbs, dry basis 8.91 kg
 10.86 kg, dry basis

DILUTION TUNNEL & MISC. DATA - ASTM E3053 / E2515

Client: FPI
 Model: F2450
 Run #: 1
 Test Start Time: 9:25
 Test Type: High Fire

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

Recording Interval (min): 1
 Total Sampling Time (min): 124
 High Fire Test Load Time (min): 27

Meter Box γ Factor: 1.004 (A)
 Meter Box γ Factor: 1.000 (B)
 Meter Box γ Factor: 0.999 (Ambient)

Induced Draft Check (in. H₂O): 0
 Smoke Capture Check (%): 100%
 Date Flue Pipe Last Cleaned: 2/25/2019

| | Pre-Test | Post Test | Avg. |
|------------------------------|------------------------|-----------|-------|
| Barometric Pressure (in. Hg) | 29.73 | 29.82 | 29.78 |
| Relative Humidity (%) | 8.1 | 9.1 | |
| Room Air Velocity (ft/min) | 0 | 0 | |
| Scale Audit (lbs) | 10.0 | 10.0 | |
| Ambient Sample Volume: | 15.005 ft ³ | | |

Sample Train Post-Test Leak Checks

| | | | | |
|-----------|-------|-------|-----|--------|
| (A) | 0.000 | cfm @ | -13 | in. Hg |
| (B) | 0.000 | cfm @ | -15 | in. Hg |
| (Ambient) | 0.001 | cfm @ | -14 | in. Hg |

DILUTION TUNNEL FLOW**Traverse Data**

| Point | dP (in H ₂ O) | Temp (°F) |
|--------|--------------------------|-----------|
| 1 | 0.040 | 85 |
| 2 | 0.064 | 85 |
| 3 | 0.068 | 85 |
| 4 | 0.046 | 85 |
| 5 | 0.046 | 85 |
| 6 | 0.064 | 85 |
| 7 | 0.068 | 85 |
| 8 | 0.048 | 85 |
| Center | 0.070 | 85 |

Dilution Tunnel H₂O: 2.00 percent
 Tunnel Diameter: 6 inches
 Pitot Tube Cp: 0.99 [unitless]
 Dilution Tunnel MW(dry): 29.00 lb/lb-mole
 Dilution Tunnel MW(wet): 28.78 lb/lb-mole
 Tunnel Area: 0.1963 ft²

V_{strav}: 16.07 ft/sec
 V_{scnt}: 17.88 ft/sec
 F_p: 0.899 [ratio]

Initial Tunnel Flow: 176.1 scf/min

Static Pressure: -0.200 in. H₂O

TEST FUEL PROPERTIES**ASTM 3053-17 - Table A1.1 Fuel Properties by Fuel Species**

| Select Fuel Type | Species | %C | %H | %O | %Ash | MJ/kg | BTU/lb |
|------------------|---------------------------------------|-------|------|-------|------|-------|--------|
| | Ash, White | 49.70 | 6.90 | 43.00 | 0.30 | 20.75 | 8927 |
| | Beech | 48.70 | 5.80 | 44.70 | 0.60 | 18.80 | 8088 |
| | Birch, Sweet | 49.80 | 6.50 | 43.40 | 0.30 | 20.12 | 8656 |
| | Birch, Yellow | 49.80 | 6.50 | 43.40 | 0.30 | 20.12 | 8656 |
| | Doug Fir (Coast, Interior West/North) | 48.73 | 6.87 | 43.90 | 0.50 | 19.81 | 8522 |
| | Doug Fir (Interior South) | 48.73 | 6.87 | 43.90 | 0.50 | 19.81 | 8522 |
| | Elm, Rock | 50.40 | 6.60 | 42.30 | 0.70 | 20.49 | 8815 |
| | Elm, Soft | 50.40 | 6.60 | 42.30 | 0.70 | 20.49 | 8815 |
| | Gum, Red | 50.88 | 6.06 | 41.57 | 1.28 | 19.72 | 8478 |
| | Larch, Western | 50.54 | 6.36 | 42.40 | 0.70 | 17.58 | 7558 |
| X | Maple, Hard | 50.64 | 6.02 | 41.74 | 1.35 | 19.96 | 8587 |
| | Maple, Sugar | 50.64 | 6.02 | 41.74 | 1.35 | 19.96 | 8587 |
| | Oak, Red | 49.50 | 6.62 | 43.70 | 0.20 | 20.20 | 8690 |
| | Oak, White | 50.40 | 6.59 | 42.70 | 0.20 | 20.50 | 8819 |
| | Pine, Southern | 52.60 | 7.00 | 40.10 | 1.31 | 22.30 | 9587 |
| | Pine, Southern Long Leaf | 52.60 | 7.02 | 40.10 | 1.30 | 22.30 | 9594 |
| | Other | | | | | | |

WOODSTOVE PREBURN DATA

Client: FPI
Model: F2450
Run #: 1

Job #: 19-460
Tracking #: 0022
Technician: SJB
Date: 2/27/2019

High Fire Test Begins from Cold Start, No Preburn is Performed

BOX A TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 1

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 0 | 0.000 | | 0.070 | 0.00 | 79 | -0.11 | | 1.9 | | 83 | 76 | 84 | 71 |
| 1 | 0.112 | 0.112 | 0.070 | 2.21 | 79 | -1.94 | 73 | 1.7 | -0.2 | 92 | 230 | 84 | 71 |
| 2 | 0.350 | 0.238 | 0.070 | 2.30 | 79 | -0.62 | 159 | 1.2 | -0.5 | 118 | 456 | 85 | 71 |
| 3 | 0.495 | 0.145 | 0.070 | 2.29 | 79 | -0.03 | 96 | 1.1 | -0.1 | 111 | 419 | 86 | 71 |
| 4 | 0.646 | 0.151 | 0.070 | 2.23 | 79 | -0.15 | 100 | 1.0 | -0.1 | 107 | 410 | 85 | 71 |
| 5 | 0.791 | 0.145 | 0.070 | 2.24 | 79 | -2.75 | 96 | 0.8 | -0.2 | 106 | 401 | 84 | 71 |
| 6 | 0.941 | 0.150 | 0.070 | 2.23 | 79 | -1.82 | 99 | 0.7 | -0.1 | 105 | 380 | 83 | 71 |
| 7 | 1.085 | 0.144 | 0.070 | 2.22 | 79 | -1.35 | 95 | 0.6 | -0.1 | 104 | 364 | 84 | 71 |
| 8 | 1.237 | 0.152 | 0.070 | 2.27 | 79 | -2.75 | 100 | 0.6 | 0 | 103 | 344 | 85 | 71 |
| 9 | 1.381 | 0.144 | 0.070 | 2.14 | 80 | -0.49 | 96 | 2.7 | 2.1 | 120 | 357 | 86 | 71 |
| 10 | 1.521 | 0.140 | 0.070 | 2.25 | 80 | -2.41 | 95 | 2.4 | -0.3 | 135 | 480 | 85 | 71 |
| 11 | 1.674 | 0.153 | 0.070 | 2.28 | 80 | -2.16 | 102 | 2.2 | -0.2 | 121 | 451 | 81 | 71 |
| 12 | 1.823 | 0.149 | 0.070 | 2.27 | 80 | -0.16 | 100 | 2.1 | -0.1 | 119 | 471 | 84 | 71 |
| 13 | 1.968 | 0.145 | 0.070 | 2.25 | 80 | -1.78 | 97 | 1.8 | -0.3 | 118 | 479 | 86 | 71 |
| 14 | 2.119 | 0.151 | 0.070 | 2.22 | 81 | -2.59 | 101 | 1.7 | -0.1 | 118 | 488 | 86 | 72 |
| 15 | 2.264 | 0.145 | 0.070 | 2.22 | 81 | -1.79 | 97 | 1.6 | -0.1 | 120 | 516 | 85 | 72 |
| 16 | 2.416 | 0.152 | 0.070 | 2.31 | 81 | -1.17 | 102 | 1.4 | -0.2 | 122 | 528 | 83 | 72 |
| 17 | 2.564 | 0.148 | 0.070 | 2.29 | 82 | -2.16 | 99 | 1.2 | -0.2 | 122 | 509 | 84 | 72 |
| 18 | 2.716 | 0.152 | 0.070 | 2.29 | 82 | -2.79 | 101 | 1.0 | -0.2 | 122 | 499 | 84 | 72 |
| 19 | 2.863 | 0.147 | 0.070 | 2.27 | 82 | -0.72 | 98 | 0.9 | -0.1 | 121 | 484 | 86 | 72 |
| 20 | 3.013 | 0.150 | 0.070 | 2.26 | 82 | -0.21 | 100 | 0.8 | -0.1 | 120 | 469 | 86 | 71 |
| 21 | 3.160 | 0.147 | 0.070 | 2.30 | 83 | -2.86 | 98 | 0.7 | -0.1 | 120 | 461 | 84 | 72 |
| 22 | 3.308 | 0.148 | 0.070 | 2.23 | 83 | -3.22 | 101 | 3.2 | 2.5 | 146 | 521 | 84 | 72 |
| 23 | 3.451 | 0.143 | 0.070 | 1.92 | 83 | -4.13 | 97 | 3.2 | 0 | 144 | 586 | 84 | 72 |
| 24 | 3.549 | 0.098 | 0.070 | 0.91 | 84 | -1.41 | 66 | 3.0 | -0.2 | 138 | 580 | 84 | 72 |
| 25 | 3.696 | 0.147 | 0.070 | 2.26 | 84 | -0.65 | 99 | 2.6 | -0.4 | 137 | 593 | 86 | 72 |
| 26 | 3.842 | 0.146 | 0.070 | 2.22 | 84 | -0.03 | 98 | 2.4 | -0.2 | 137 | 602 | 86 | 72 |
| 27 | 3.991 | 0.149 | 0.070 | 2.22 | 85 | -1.41 | 100 | 21.4 | 19 | 136 | 602 | 85 | 73 |
| 28 | 4.136 | 0.145 | 0.070 | 2.22 | 85 | -0.7 | 100 | 23.8 | 2.4 | 168 | 685 | 84 | 73 |
| 29 | 4.285 | 0.149 | 0.070 | 2.21 | 85 | -0.66 | 102 | 22.9 | -0.9 | 155 | 618 | 84 | 73 |
| 30 | 4.431 | 0.146 | 0.070 | 2.21 | 85 | -2.74 | 99 | 22.6 | -0.3 | 150 | 652 | 84 | 73 |
| 31 | 4.581 | 0.150 | 0.070 | 2.35 | 86 | -0.78 | 102 | 22.2 | -0.4 | 150 | 670 | 86 | 73 |
| 32 | 4.730 | 0.149 | 0.070 | 2.25 | 86 | -0.91 | 101 | 21.8 | -0.4 | 150 | 685 | 86 | 73 |

BOX A TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 1

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 33 | 4.879 | 0.149 | 0.070 | 2.16 | 86 | -1.42 | 101 | 21.6 | -0.2 | 151 | 691 | 85 | 73 |
| 34 | 5.025 | 0.146 | 0.070 | 2.21 | 87 | -4.5 | 99 | 21.2 | -0.4 | 151 | 697 | 84 | 73 |
| 35 | 5.178 | 0.153 | 0.070 | 3.34 | 87 | 0 | 104 | 20.8 | -0.4 | 152 | 702 | 82 | 73 |
| 36 | 5.347 | 0.169 | 0.070 | 2.31 | 87 | -0.69 | 115 | 20.4 | -0.4 | 153 | 707 | 83 | 73 |
| 37 | 5.495 | 0.148 | 0.070 | 2.27 | 88 | -1.52 | 100 | 20.1 | -0.3 | 153 | 705 | 85 | 73 |
| 38 | 5.647 | 0.152 | 0.070 | 2.25 | 88 | -1.29 | 103 | 19.8 | -0.3 | 153 | 704 | 86 | 74 |
| 39 | 5.794 | 0.147 | 0.070 | 2.22 | 88 | -2.87 | 100 | 19.6 | -0.2 | 155 | 710 | 86 | 74 |
| 40 | 5.943 | 0.149 | 0.070 | 2.20 | 88 | -2.78 | 101 | 19.1 | -0.5 | 154 | 710 | 85 | 73 |
| 41 | 6.093 | 0.150 | 0.070 | 2.35 | 89 | -0.44 | 101 | 18.8 | -0.3 | 154 | 713 | 84 | 73 |
| 42 | 6.246 | 0.153 | 0.070 | 2.34 | 89 | -0.42 | 104 | 18.6 | -0.2 | 155 | 714 | 84 | 73 |
| 43 | 6.400 | 0.154 | 0.070 | 2.35 | 89 | -0.33 | 104 | 18.1 | -0.5 | 155 | 719 | 84 | 73 |
| 44 | 6.550 | 0.150 | 0.070 | 2.30 | 89 | -2.98 | 102 | 17.8 | -0.3 | 155 | 720 | 85 | 73 |
| 45 | 6.703 | 0.153 | 0.070 | 2.32 | 90 | -2.3 | 103 | 17.5 | -0.3 | 156 | 725 | 86 | 73 |
| 46 | 6.851 | 0.148 | 0.070 | 2.31 | 90 | -3.07 | 100 | 17.1 | -0.4 | 156 | 724 | 86 | 74 |
| 47 | 7.005 | 0.154 | 0.070 | 2.29 | 90 | -0.39 | 104 | 16.8 | -0.3 | 156 | 725 | 85 | 74 |
| 48 | 7.156 | 0.151 | 0.070 | 2.27 | 90 | -1.64 | 102 | 16.6 | -0.2 | 155 | 721 | 84 | 73 |
| 49 | 7.309 | 0.153 | 0.070 | 2.27 | 91 | -3.01 | 103 | 16.1 | -0.5 | 154 | 715 | 84 | 75 |
| 50 | 7.457 | 0.148 | 0.070 | 2.27 | 91 | -2.43 | 100 | 15.8 | -0.3 | 154 | 712 | 84 | 74 |
| 51 | 7.608 | 0.151 | 0.070 | 2.26 | 91 | -0.44 | 102 | 15.7 | -0.1 | 154 | 709 | 85 | 74 |
| 52 | 7.756 | 0.148 | 0.070 | 2.23 | 91 | -0.44 | 100 | 15.4 | -0.3 | 154 | 707 | 86 | 75 |
| 53 | 7.906 | 0.150 | 0.070 | 2.25 | 92 | -2.68 | 101 | 15.0 | -0.4 | 154 | 701 | 86 | 75 |
| 54 | 8.054 | 0.148 | 0.070 | 2.24 | 92 | -2.03 | 100 | 14.6 | -0.4 | 153 | 699 | 85 | 75 |
| 55 | 8.204 | 0.150 | 0.070 | 2.22 | 92 | -3.19 | 101 | 14.4 | -0.2 | 153 | 695 | 85 | 75 |
| 56 | 8.354 | 0.150 | 0.070 | 2.20 | 92 | -1.26 | 101 | 14.0 | -0.4 | 153 | 694 | 84 | 74 |
| 57 | 8.501 | 0.147 | 0.070 | 2.21 | 92 | -3.14 | 99 | 13.7 | -0.3 | 153 | 689 | 84 | 75 |
| 58 | 8.651 | 0.150 | 0.070 | 2.21 | 93 | -2.31 | 101 | 13.4 | -0.3 | 152 | 684 | 84 | 75 |
| 59 | 8.798 | 0.147 | 0.070 | 2.19 | 93 | -2.03 | 99 | 13.1 | -0.3 | 152 | 685 | 86 | 75 |
| 60 | 8.947 | 0.149 | 0.070 | 2.19 | 93 | -1.69 | 100 | 12.8 | -0.3 | 151 | 681 | 86 | 75 |
| 61 | 9.107 | 0.160 | 0.070 | 2.78 | 93 | 0 | 107 | 12.6 | -0.2 | 151 | 678 | 84 | 75 |
| 62 | 9.264 | 0.157 | 0.070 | 2.21 | 93 | -2.64 | 105 | 12.2 | -0.4 | 150 | 679 | 84 | 75 |
| 63 | 9.411 | 0.147 | 0.070 | 2.17 | 94 | -0.06 | 98 | 11.9 | -0.3 | 150 | 676 | 84 | 75 |
| 64 | 9.564 | 0.153 | 0.070 | 2.37 | 94 | -2.63 | 102 | 11.8 | -0.1 | 150 | 676 | 84 | 75 |
| 65 | 9.716 | 0.152 | 0.070 | 2.36 | 94 | -0.6 | 101 | 11.4 | -0.4 | 149 | 672 | 85 | 75 |

BOX A TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 1

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 66 | 9.870 | 0.154 | 0.070 | 2.36 | 94 | -0.19 | 103 | 11.1 | -0.3 | 149 | 669 | 86 | 75 |
| 67 | 10.026 | 0.156 | 0.070 | 2.35 | 94 | -2.7 | 104 | 10.8 | -0.3 | 149 | 670 | 86 | 75 |
| 68 | 10.175 | 0.149 | 0.070 | 2.34 | 95 | -0.22 | 99 | 10.6 | -0.2 | 148 | 669 | 85 | 75 |
| 69 | 10.330 | 0.155 | 0.070 | 2.33 | 95 | -0.58 | 103 | 10.2 | -0.4 | 148 | 667 | 84 | 75 |
| 70 | 10.481 | 0.151 | 0.070 | 2.33 | 95 | -2.89 | 101 | 10.0 | -0.2 | 148 | 662 | 84 | 76 |
| 71 | 10.636 | 0.155 | 0.070 | 2.33 | 95 | -1.34 | 103 | 9.8 | -0.2 | 146 | 653 | 84 | 76 |
| 72 | 10.786 | 0.150 | 0.070 | 2.32 | 95 | -3.08 | 100 | 9.6 | -0.2 | 145 | 640 | 85 | 75 |
| 73 | 10.938 | 0.152 | 0.070 | 2.31 | 95 | -0.25 | 101 | 9.3 | -0.3 | 144 | 629 | 87 | 75 |
| 74 | 11.093 | 0.155 | 0.070 | 2.30 | 96 | -0.34 | 103 | 9.2 | -0.1 | 144 | 618 | 86 | 75 |
| 75 | 11.244 | 0.151 | 0.070 | 2.34 | 96 | -0.55 | 100 | 9.0 | -0.2 | 143 | 612 | 86 | 76 |
| 76 | 11.397 | 0.153 | 0.070 | 2.32 | 96 | -1.5 | 101 | 8.8 | -0.2 | 141 | 603 | 85 | 75 |
| 77 | 11.547 | 0.150 | 0.070 | 2.32 | 96 | -2.74 | 99 | 8.6 | -0.2 | 141 | 596 | 84 | 76 |
| 78 | 11.703 | 0.156 | 0.070 | 2.31 | 96 | -2.02 | 103 | 8.6 | 0 | 139 | 587 | 84 | 75 |
| 79 | 11.854 | 0.151 | 0.070 | 2.30 | 96 | -0.29 | 100 | 8.3 | -0.3 | 139 | 586 | 85 | 76 |
| 80 | 12.007 | 0.153 | 0.070 | 2.33 | 96 | -2.68 | 101 | 8.1 | -0.2 | 139 | 587 | 86 | 75 |
| 81 | 12.158 | 0.151 | 0.070 | 2.31 | 97 | -1 | 99 | 8.0 | -0.1 | 138 | 582 | 86 | 76 |
| 82 | 12.311 | 0.153 | 0.070 | 2.31 | 97 | -0.7 | 101 | 7.8 | -0.2 | 137 | 576 | 86 | 76 |
| 83 | 12.466 | 0.155 | 0.070 | 2.31 | 97 | -2.93 | 102 | 7.7 | -0.1 | 136 | 569 | 86 | 75 |
| 84 | 12.615 | 0.149 | 0.070 | 2.34 | 97 | -2.97 | 98 | 7.5 | -0.2 | 135 | 564 | 85 | 76 |
| 85 | 12.770 | 0.155 | 0.070 | 2.31 | 97 | -2.76 | 102 | 7.5 | 0 | 135 | 558 | 84 | 76 |
| 86 | 12.920 | 0.150 | 0.070 | 2.31 | 97 | -1.3 | 98 | 7.3 | -0.2 | 134 | 555 | 84 | 75 |
| 87 | 13.076 | 0.156 | 0.070 | 2.31 | 97 | -0.7 | 102 | 7.1 | -0.2 | 133 | 552 | 85 | 75 |
| 88 | 13.226 | 0.150 | 0.070 | 2.29 | 97 | -2.8 | 98 | 7.0 | -0.1 | 133 | 544 | 86 | 75 |
| 89 | 13.379 | 0.153 | 0.070 | 2.31 | 98 | -2.82 | 100 | 6.9 | -0.1 | 132 | 534 | 86 | 75 |
| 90 | 13.533 | 0.154 | 0.070 | 2.30 | 98 | -1.63 | 100 | 6.8 | -0.1 | 130 | 524 | 86 | 75 |
| 91 | 13.684 | 0.151 | 0.070 | 2.30 | 98 | -2.98 | 99 | 6.8 | 0 | 130 | 519 | 85 | 76 |
| 92 | 13.839 | 0.155 | 0.070 | 2.31 | 98 | -2.48 | 101 | 6.6 | -0.2 | 128 | 513 | 84 | 75 |
| 93 | 13.988 | 0.149 | 0.070 | 2.30 | 98 | -0.25 | 97 | 6.5 | -0.1 | 128 | 505 | 84 | 75 |
| 94 | 14.144 | 0.156 | 0.070 | 2.31 | 98 | -0.31 | 102 | 6.4 | -0.1 | 127 | 499 | 85 | 75 |
| 95 | 14.294 | 0.150 | 0.070 | 2.29 | 98 | -2.84 | 98 | 6.3 | -0.1 | 126 | 491 | 86 | 75 |
| 96 | 14.449 | 0.155 | 0.070 | 2.30 | 98 | -0.46 | 101 | 6.2 | -0.1 | 126 | 488 | 86 | 75 |
| 97 | 14.600 | 0.151 | 0.070 | 2.31 | 99 | -2.82 | 98 | 6.1 | -0.1 | 125 | 482 | 86 | 75 |
| 98 | 14.753 | 0.153 | 0.070 | 2.31 | 99 | -3.03 | 99 | 6.2 | 0.1 | 124 | 480 | 85 | 75 |

BOX A TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 1

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 99 | 14.907 | 0.154 | 0.070 | 2.30 | 99 | -1.14 | 100 | 6.0 | -0.2 | 124 | 477 | 85 | 75 |
| 100 | 15.058 | 0.151 | 0.070 | 2.31 | 99 | -3.01 | 98 | 5.9 | -0.1 | 123 | 474 | 84 | 75 |
| 101 | 15.212 | 0.154 | 0.070 | 2.31 | 99 | -3.12 | 100 | 5.8 | -0.1 | 122 | 471 | 85 | 75 |
| 102 | 15.362 | 0.150 | 0.070 | 2.30 | 99 | -2 | 97 | 5.7 | -0.1 | 122 | 468 | 86 | 75 |
| 103 | 15.518 | 0.156 | 0.070 | 2.30 | 99 | -0.34 | 101 | 5.6 | -0.1 | 121 | 461 | 86 | 75 |
| 104 | 15.668 | 0.150 | 0.070 | 2.31 | 99 | -2.02 | 97 | 5.6 | 0 | 121 | 457 | 86 | 75 |
| 105 | 15.822 | 0.154 | 0.070 | 2.30 | 99 | -2.27 | 99 | 5.5 | -0.1 | 120 | 453 | 85 | 75 |
| 106 | 15.975 | 0.153 | 0.070 | 2.31 | 99 | -1.65 | 99 | 5.4 | -0.1 | 120 | 451 | 85 | 74 |
| 107 | 16.127 | 0.152 | 0.070 | 2.31 | 99 | -3.06 | 98 | 5.4 | 0 | 119 | 448 | 84 | 75 |
| 108 | 16.281 | 0.154 | 0.070 | 2.31 | 99 | -2.78 | 99 | 5.3 | -0.1 | 119 | 447 | 85 | 75 |
| 109 | 16.431 | 0.150 | 0.070 | 2.31 | 99 | -2.43 | 97 | 5.2 | -0.1 | 118 | 443 | 86 | 74 |
| 110 | 16.587 | 0.156 | 0.070 | 2.31 | 100 | -1.22 | 100 | 5.2 | 0 | 118 | 441 | 86 | 74 |
| 111 | 16.737 | 0.150 | 0.070 | 2.30 | 100 | -2.47 | 97 | 5.1 | -0.1 | 118 | 440 | 86 | 74 |
| 112 | 16.892 | 0.155 | 0.070 | 2.30 | 100 | -2.23 | 100 | 5.0 | -0.1 | 117 | 438 | 85 | 74 |
| 113 | 17.043 | 0.151 | 0.070 | 2.30 | 100 | -2.89 | 97 | 4.9 | -0.1 | 117 | 437 | 84 | 74 |
| 114 | 17.196 | 0.153 | 0.070 | 2.31 | 100 | -1.17 | 98 | 4.9 | 0 | 116 | 435 | 84 | 74 |
| 115 | 17.350 | 0.154 | 0.070 | 2.31 | 100 | -3.07 | 99 | 4.8 | -0.1 | 116 | 434 | 85 | 75 |
| 116 | 17.501 | 0.151 | 0.070 | 2.31 | 100 | -2.96 | 97 | 4.7 | -0.1 | 116 | 434 | 86 | 75 |
| 117 | 17.656 | 0.155 | 0.070 | 2.29 | 100 | -1.7 | 100 | 4.7 | 0 | 116 | 433 | 86 | 74 |
| 118 | 17.806 | 0.150 | 0.070 | 2.31 | 100 | -0.81 | 96 | 4.6 | -0.1 | 115 | 430 | 86 | 74 |
| 119 | 17.962 | 0.156 | 0.070 | 2.30 | 100 | -2.82 | 100 | 4.5 | -0.1 | 115 | 429 | 85 | 74 |
| 120 | 18.112 | 0.150 | 0.070 | 2.31 | 100 | -1.87 | 96 | 4.5 | 0 | 115 | 429 | 84 | 75 |
| 121 | 18.266 | 0.154 | 0.070 | 2.30 | 100 | -0.26 | 99 | 4.4 | -0.1 | 114 | 424 | 84 | 75 |
| 122 | 18.419 | 0.153 | 0.070 | 2.31 | 100 | -3.04 | 98 | 4.4 | 0 | 114 | 418 | 85 | 75 |
| 123 | 18.571 | 0.152 | 0.070 | 2.30 | 100 | -2.08 | 97 | 4.3 | -0.1 | 113 | 414 | 86 | 75 |
| 124 | 18.725 | 0.154 | 0.070 | 2.32 | 100 | -1.47 | 99 | 4.3 | 0 | 113 | 410 | 86 | 74 |
| Avg/Tot | 18.725 | 0.151 | 0.070 | 2.26 | 92 | -1.73 | 100 | | | 134 | 557 | 85 | 73.9 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 1

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 0 | 0.000 | | 0.00 | 79 | -1 | | 85 | 0.000 | 0.08 | 0.00 |
| 1 | 0.106 | 0.106 | 2.30 | 79 | -1.04 | 71 | 85 | -0.060 | 0.09 | 0.00 |
| 2 | 0.251 | 0.145 | 2.22 | 79 | -2.06 | 100 | 84 | -0.090 | 4.93 | 0.16 |
| 3 | 0.398 | 0.147 | 2.27 | 79 | -2.52 | 100 | 84 | -0.060 | 9.24 | 0.34 |
| 4 | 0.542 | 0.144 | 2.25 | 79 | -3.18 | 98 | 84 | -0.060 | 11.16 | 0.17 |
| 5 | 0.690 | 0.148 | 2.21 | 79 | -3.27 | 101 | 85 | -0.060 | 10.41 | 0.09 |
| 6 | 0.834 | 0.144 | 2.22 | 79 | -3.02 | 98 | 85 | -0.070 | 9.77 | 0.09 |
| 7 | 0.981 | 0.147 | 2.20 | 79 | -1.78 | 100 | 85 | -0.050 | 7.87 | 0.16 |
| 8 | 1.124 | 0.143 | 2.25 | 79 | -0.89 | 97 | 85 | -0.070 | 7.47 | 0.18 |
| 9 | 1.272 | 0.148 | 2.10 | 79 | -3.19 | 102 | 85 | -0.060 | 6.17 | 0.21 |
| 10 | 1.403 | 0.131 | 1.49 | 79 | -7.06 | 91 | 85 | -0.070 | 4.06 | 0.23 |
| 11 | 1.554 | 0.151 | 2.28 | 80 | -0.03 | 104 | 84 | -0.070 | 9.83 | 0.44 |
| 12 | 1.699 | 0.145 | 2.27 | 80 | -0.35 | 99 | 83 | -0.070 | 11.38 | 0.23 |
| 13 | 1.846 | 0.147 | 2.27 | 80 | -0.64 | 101 | 84 | -0.060 | 12.94 | 0.30 |
| 14 | 1.991 | 0.145 | 2.27 | 80 | -2.3 | 99 | 85 | -0.070 | 12.48 | 0.20 |
| 15 | 2.140 | 0.149 | 2.25 | 81 | -0.88 | 102 | 85 | -0.080 | 12.86 | 0.26 |
| 16 | 2.284 | 0.144 | 2.24 | 81 | -3.23 | 99 | 86 | -0.070 | 14.42 | 0.46 |
| 17 | 2.433 | 0.149 | 2.24 | 81 | -1.51 | 102 | 86 | -0.070 | 13.61 | 0.35 |
| 18 | 2.577 | 0.144 | 2.22 | 81 | -0.66 | 99 | 85 | -0.080 | 11.61 | 0.14 |
| 19 | 2.724 | 0.147 | 2.22 | 82 | -1.92 | 101 | 85 | -0.060 | 10.88 | 0.11 |
| 20 | 2.869 | 0.145 | 2.22 | 82 | -3.15 | 99 | 84 | -0.060 | 9.56 | 0.12 |
| 21 | 3.017 | 0.148 | 2.25 | 82 | -0.96 | 101 | 84 | -0.070 | 8.86 | 0.12 |
| 22 | 3.160 | 0.143 | 2.15 | 83 | -0.92 | 100 | 85 | -0.080 | 8.02 | 0.12 |
| 23 | 3.308 | 0.148 | 2.20 | 83 | -3.58 | 103 | 85 | -0.080 | 7.05 | 0.26 |
| 24 | 3.444 | 0.136 | 1.64 | 83 | -4.88 | 94 | 86 | -0.070 | 14.52 | 0.56 |
| 25 | 3.589 | 0.145 | 2.65 | 84 | -1.09 | 100 | 85 | -0.090 | 15.18 | 0.76 |
| 26 | 3.742 | 0.153 | 2.37 | 84 | -1.18 | 106 | 85 | -0.090 | 15.81 | 1.22 |
| 27 | 3.894 | 0.152 | 2.34 | 84 | -2.54 | 105 | 86 | -0.080 | 15.79 | 0.88 |
| 28 | 4.039 | 0.145 | 2.26 | 84 | -1.14 | 103 | 86 | -0.090 | 14.27 | 0.46 |
| 29 | 4.188 | 0.149 | 2.24 | 85 | -0.9 | 104 | 85 | -0.090 | 7.94 | 0.52 |
| 30 | 4.333 | 0.145 | 2.24 | 85 | -0.93 | 101 | 85 | -0.080 | 14.24 | 0.38 |
| 31 | 4.481 | 0.148 | 2.15 | 85 | -1.25 | 103 | 85 | -0.100 | 16.93 | 1.11 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 1

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 32 | 4.624 | 0.143 | 2.19 | 86 | -2.76 | 100 | 85 | -0.090 | 17.79 | 1.69 |
| 33 | 4.771 | 0.147 | 2.20 | 86 | -3.16 | 102 | 86 | -0.090 | 17.96 | 1.56 |
| 34 | 4.915 | 0.144 | 2.26 | 86 | -3.78 | 100 | 86 | -0.090 | 18.02 | 1.48 |
| 35 | 5.062 | 0.147 | 2.21 | 87 | -2 | 102 | 86 | -0.090 | 18.10 | 1.26 |
| 36 | 5.208 | 0.146 | 2.31 | 87 | -3.56 | 102 | 86 | -0.090 | 17.93 | 1.12 |
| 37 | 5.358 | 0.150 | 2.25 | 87 | -1.74 | 105 | 85 | -0.100 | 17.98 | 0.99 |
| 38 | 5.504 | 0.146 | 2.26 | 87 | -1.85 | 102 | 85 | -0.090 | 17.81 | 0.99 |
| 39 | 5.653 | 0.149 | 2.24 | 88 | -2.03 | 104 | 85 | -0.090 | 17.91 | 0.98 |
| 40 | 5.798 | 0.145 | 2.23 | 88 | -2.62 | 101 | 85 | -0.090 | 17.91 | 1.00 |
| 41 | 5.946 | 0.148 | 2.23 | 88 | -2.87 | 103 | 86 | -0.090 | 18.03 | 0.96 |
| 42 | 6.092 | 0.146 | 2.21 | 88 | -1.95 | 102 | 86 | -0.090 | 18.04 | 1.02 |
| 43 | 6.239 | 0.147 | 2.22 | 89 | -2.95 | 102 | 86 | -0.090 | 18.04 | 1.09 |
| 44 | 6.384 | 0.145 | 2.20 | 89 | -1.97 | 101 | 85 | -0.100 | 17.94 | 1.07 |
| 45 | 6.531 | 0.147 | 2.17 | 89 | -2.07 | 102 | 85 | -0.090 | 18.04 | 1.09 |
| 46 | 6.675 | 0.144 | 2.19 | 89 | -1.94 | 100 | 85 | -0.090 | 18.28 | 1.11 |
| 47 | 6.821 | 0.146 | 2.17 | 90 | -4.1 | 101 | 86 | -0.080 | 18.09 | 1.14 |
| 48 | 6.966 | 0.145 | 2.16 | 90 | -2.08 | 101 | 86 | -0.100 | 18.19 | 1.14 |
| 49 | 7.112 | 0.146 | 2.24 | 90 | -2.11 | 101 | 86 | -0.090 | 18.08 | 1.16 |
| 50 | 7.259 | 0.147 | 2.23 | 90 | -3.73 | 102 | 86 | -0.090 | 18.22 | 1.24 |
| 51 | 7.406 | 0.147 | 2.22 | 91 | -2.07 | 102 | 85 | -0.090 | 18.28 | 1.27 |
| 52 | 7.553 | 0.147 | 2.20 | 91 | -3.55 | 102 | 85 | -0.090 | 18.11 | 1.25 |
| 53 | 7.700 | 0.147 | 2.21 | 91 | -2.1 | 102 | 86 | -0.100 | 18.19 | 1.34 |
| 54 | 7.846 | 0.146 | 2.20 | 91 | -4.13 | 101 | 86 | -0.090 | 18.13 | 1.33 |
| 55 | 7.993 | 0.147 | 2.19 | 92 | -2.11 | 102 | 87 | -0.090 | 18.16 | 1.26 |
| 56 | 8.139 | 0.146 | 2.18 | 92 | -3.45 | 101 | 86 | -0.100 | 18.01 | 1.25 |
| 57 | 8.285 | 0.146 | 2.18 | 92 | -2.55 | 101 | 86 | -0.100 | 17.90 | 1.31 |
| 58 | 8.431 | 0.146 | 2.17 | 92 | -2.62 | 101 | 85 | -0.090 | 17.99 | 1.32 |
| 59 | 8.576 | 0.145 | 2.17 | 92 | -2.24 | 100 | 85 | -0.090 | 17.88 | 1.38 |
| 60 | 8.723 | 0.147 | 2.24 | 93 | -2.55 | 101 | 86 | -0.090 | 17.90 | 1.24 |
| 61 | 8.871 | 0.148 | 2.23 | 93 | -3.1 | 102 | 86 | -0.090 | 17.67 | 1.17 |
| 62 | 9.019 | 0.148 | 2.22 | 93 | -2.22 | 102 | 87 | -0.090 | 17.62 | 1.02 |
| 63 | 9.167 | 0.148 | 2.22 | 93 | -4.15 | 102 | 87 | -0.080 | 17.50 | 0.92 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 1

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 64 | 9.314 | 0.147 | 2.22 | 93 | -2.7 | 101 | 86 | -0.100 | 17.30 | 0.85 |
| 65 | 9.462 | 0.148 | 2.20 | 94 | -2.88 | 101 | 86 | -0.100 | 16.94 | 0.86 |
| 66 | 9.609 | 0.147 | 2.19 | 94 | -3.62 | 101 | 85 | -0.090 | 16.88 | 0.90 |
| 67 | 9.758 | 0.149 | 2.22 | 94 | -4.43 | 102 | 85 | -0.080 | 16.84 | 0.87 |
| 68 | 9.903 | 0.145 | 2.21 | 94 | -3.02 | 99 | 86 | -0.080 | 16.91 | 0.79 |
| 69 | 10.052 | 0.149 | 2.20 | 94 | -2.43 | 102 | 87 | -0.100 | 16.93 | 0.54 |
| 70 | 10.197 | 0.145 | 2.21 | 94 | -4.39 | 99 | 87 | -0.090 | 16.73 | 0.44 |
| 71 | 10.346 | 0.149 | 2.21 | 95 | -2.36 | 102 | 86 | -0.090 | 16.42 | 0.30 |
| 72 | 10.491 | 0.145 | 2.20 | 95 | -2.98 | 99 | 86 | -0.090 | 15.86 | 0.19 |
| 73 | 10.640 | 0.149 | 2.19 | 95 | -4.46 | 102 | 85 | -0.090 | 15.07 | 0.17 |
| 74 | 10.786 | 0.146 | 2.21 | 95 | -4.49 | 100 | 85 | -0.090 | 14.56 | 0.12 |
| 75 | 10.934 | 0.148 | 2.23 | 95 | -2.39 | 101 | 86 | -0.090 | 14.12 | 0.08 |
| 76 | 11.080 | 0.146 | 2.20 | 95 | -2.34 | 99 | 86 | -0.080 | 13.91 | 0.11 |
| 77 | 11.229 | 0.149 | 2.18 | 95 | -4.33 | 101 | 87 | -0.070 | 13.33 | 0.11 |
| 78 | 11.376 | 0.147 | 2.21 | 96 | -2.88 | 100 | 87 | -0.100 | 13.18 | 0.06 |
| 79 | 11.525 | 0.149 | 2.20 | 96 | -3.47 | 101 | 86 | -0.080 | 12.91 | 0.11 |
| 80 | 11.670 | 0.145 | 2.21 | 96 | -2.31 | 98 | 86 | -0.080 | 13.37 | 0.05 |
| 81 | 11.820 | 0.150 | 2.20 | 96 | -2.84 | 102 | 85 | -0.090 | 13.55 | 0.09 |
| 82 | 11.966 | 0.146 | 2.21 | 96 | -2.53 | 99 | 85 | -0.080 | 13.31 | 0.09 |
| 83 | 12.116 | 0.150 | 2.20 | 96 | -4.25 | 101 | 86 | -0.080 | 12.87 | 0.06 |
| 84 | 12.261 | 0.145 | 2.22 | 96 | -4.43 | 98 | 87 | -0.080 | 12.31 | 0.07 |
| 85 | 12.412 | 0.151 | 2.21 | 96 | -4.4 | 102 | 87 | -0.070 | 12.37 | 0.04 |
| 86 | 12.558 | 0.146 | 2.21 | 97 | -2.23 | 98 | 86 | -0.090 | 12.34 | 0.04 |
| 87 | 12.709 | 0.151 | 2.21 | 97 | -4.47 | 102 | 86 | -0.080 | 11.96 | 0.07 |
| 88 | 12.854 | 0.145 | 2.21 | 97 | -2.35 | 98 | 86 | -0.080 | 11.64 | 0.06 |
| 89 | 13.005 | 0.151 | 2.21 | 97 | -3.26 | 102 | 85 | -0.090 | 11.01 | 0.04 |
| 90 | 13.151 | 0.146 | 2.20 | 97 | -4.41 | 98 | 86 | -0.080 | 10.32 | 0.06 |
| 91 | 13.302 | 0.151 | 2.23 | 97 | -3.86 | 101 | 86 | -0.080 | 10.01 | 0.05 |
| 92 | 13.447 | 0.145 | 2.22 | 97 | -4.34 | 97 | 86 | -0.080 | 9.99 | 0.01 |
| 93 | 13.597 | 0.150 | 2.22 | 97 | -2.32 | 101 | 86 | -0.080 | 9.75 | 0.05 |
| 94 | 13.743 | 0.146 | 2.20 | 97 | -2.86 | 98 | 86 | -0.080 | 9.22 | 0.07 |
| 95 | 13.894 | 0.151 | 2.23 | 98 | -3.65 | 101 | 85 | -0.080 | 8.86 | 0.08 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 1

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 96 | 14.041 | 0.147 | 2.22 | 98 | -4.44 | 98 | 85 | -0.070 | 8.81 | 0.08 |
| 97 | 14.191 | 0.150 | 2.21 | 98 | -2.22 | 100 | 86 | -0.080 | 8.94 | 0.09 |
| 98 | 14.338 | 0.147 | 2.22 | 98 | -2.41 | 98 | 86 | -0.080 | 8.90 | 0.07 |
| 99 | 14.488 | 0.150 | 2.23 | 98 | -2.22 | 100 | 86 | -0.070 | 8.90 | 0.06 |
| 100 | 14.637 | 0.149 | 2.23 | 98 | -4.5 | 99 | 86 | -0.070 | 8.89 | 0.06 |
| 101 | 14.786 | 0.149 | 2.22 | 98 | -4.36 | 99 | 86 | -0.070 | 8.85 | 0.06 |
| 102 | 14.935 | 0.149 | 2.23 | 98 | -2.47 | 99 | 86 | -0.080 | 8.63 | 0.07 |
| 103 | 15.083 | 0.148 | 2.24 | 98 | -3.24 | 98 | 85 | -0.080 | 8.66 | 0.06 |
| 104 | 15.233 | 0.150 | 2.23 | 98 | -2.58 | 100 | 85 | -0.080 | 8.03 | 0.10 |
| 105 | 15.380 | 0.147 | 2.22 | 98 | -2.18 | 98 | 86 | -0.070 | 8.14 | 0.09 |
| 106 | 15.530 | 0.150 | 2.22 | 99 | -2.73 | 99 | 86 | -0.080 | 7.86 | 0.14 |
| 107 | 15.677 | 0.147 | 2.23 | 99 | -4.06 | 97 | 87 | -0.070 | 7.90 | 0.13 |
| 108 | 15.828 | 0.151 | 2.23 | 99 | -2.77 | 100 | 86 | -0.070 | 7.99 | 0.12 |
| 109 | 15.975 | 0.147 | 2.22 | 99 | -2.26 | 97 | 86 | -0.070 | 7.96 | 0.12 |
| 110 | 16.127 | 0.152 | 2.23 | 99 | -2.4 | 101 | 85 | -0.070 | 8.03 | 0.12 |
| 111 | 16.274 | 0.147 | 2.23 | 99 | -2.63 | 97 | 85 | -0.070 | 7.83 | 0.15 |
| 112 | 16.425 | 0.151 | 2.23 | 99 | -2.54 | 100 | 85 | -0.080 | 7.93 | 0.15 |
| 113 | 16.572 | 0.147 | 2.21 | 99 | -2.26 | 97 | 86 | -0.060 | 7.92 | 0.15 |
| 114 | 16.724 | 0.152 | 2.23 | 99 | -4.09 | 100 | 86 | -0.070 | 7.99 | 0.17 |
| 115 | 16.870 | 0.146 | 2.24 | 99 | -2.26 | 97 | 86 | -0.070 | 7.85 | 0.20 |
| 116 | 17.021 | 0.151 | 2.24 | 99 | -3.27 | 100 | 86 | -0.060 | 8.08 | 0.16 |
| 117 | 17.168 | 0.147 | 2.23 | 99 | -2.85 | 97 | 86 | -0.070 | 7.93 | 0.18 |
| 118 | 17.319 | 0.151 | 2.24 | 99 | -2.36 | 100 | 85 | -0.080 | 7.86 | 0.16 |
| 119 | 17.467 | 0.148 | 2.23 | 99 | -2.79 | 98 | 85 | -0.060 | 7.66 | 0.22 |
| 120 | 17.618 | 0.151 | 2.22 | 99 | -2.22 | 100 | 85 | -0.050 | 7.60 | 0.25 |
| 121 | 17.767 | 0.149 | 2.22 | 99 | -4.19 | 98 | 86 | -0.070 | 7.76 | 0.21 |
| 122 | 17.916 | 0.149 | 2.24 | 100 | -2.16 | 98 | 86 | -0.060 | 7.21 | 0.26 |
| 123 | 18.067 | 0.151 | 2.24 | 100 | -2.19 | 99 | 86 | -0.070 | 6.87 | 0.44 |
| 124 | 18.214 | 0.147 | 2.24 | 100 | -4.34 | 97 | 86 | -0.060 | 6.91 | 0.44 |
| Avg/Tot | 18.214 | 0.147 | 2.20 | 91 | -2.73 | 100 | | | 12.56 | 0.49 |

WOODSTOVE SURFACE TEMPERATURE DATA

Client: FPI
 Model: F2450
 Run #: 1

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Temperature Data (°F) | | | | | | Catalyst Exit |
|--------------------|-----------------------|----------|---------|--------|-----------|-----------------------|---------------|
| | FB Left | FB Right | FB Back | FB Top | FB Bottom | Stove Surface Average | |
| 0 | 74 | 74 | 72 | 75 | 74 | 73.8 | N/A |
| 1 | 74 | 74 | 74 | 88 | 74 | 76.8 | N/A |
| 2 | 78 | 78 | 87 | 137 | 74 | 90.8 | N/A |
| 3 | 87 | 88 | 98 | 189 | 74 | 107.2 | N/A |
| 4 | 98 | 100 | 106 | 234 | 74 | 122.4 | N/A |
| 5 | 111 | 113 | 115 | 267 | 74 | 136.0 | N/A |
| 6 | 125 | 126 | 122 | 292 | 75 | 148.0 | N/A |
| 7 | 139 | 136 | 132 | 310 | 76 | 158.6 | N/A |
| 8 | 152 | 145 | 141 | 319 | 78 | 167.0 | N/A |
| 9 | 164 | 153 | 149 | 324 | 80 | 174.0 | N/A |
| 10 | 174 | 160 | 160 | 346 | 82 | 184.4 | N/A |
| 11 | 185 | 168 | 172 | 374 | 85 | 196.8 | N/A |
| 12 | 196 | 178 | 185 | 407 | 88 | 210.8 | N/A |
| 13 | 208 | 190 | 198 | 439 | 91 | 225.2 | N/A |
| 14 | 220 | 203 | 213 | 466 | 95 | 239.4 | N/A |
| 15 | 233 | 217 | 227 | 497 | 99 | 254.6 | N/A |
| 16 | 247 | 232 | 243 | 529 | 103 | 270.8 | N/A |
| 17 | 261 | 247 | 259 | 550 | 107 | 284.8 | N/A |
| 18 | 275 | 261 | 274 | 562 | 111 | 296.6 | N/A |
| 19 | 289 | 275 | 286 | 568 | 116 | 306.8 | N/A |
| 20 | 301 | 287 | 297 | 569 | 120 | 314.8 | N/A |
| 21 | 313 | 299 | 307 | 567 | 125 | 322.2 | N/A |
| 22 | 324 | 308 | 318 | 567 | 130 | 329.4 | N/A |
| 23 | 334 | 317 | 327 | 585 | 134 | 339.4 | N/A |
| 24 | 342 | 326 | 337 | 618 | 139 | 352.4 | N/A |
| 25 | 352 | 336 | 347 | 653 | 144 | 366.4 | N/A |
| 26 | 362 | 345 | 357 | 687 | 149 | 380.0 | N/A |
| 27 | 373 | 355 | 366 | 712 | 153 | 391.8 | N/A |
| 28 | 390 | 364 | 376 | 739 | 159 | 405.6 | N/A |
| 29 | 402 | 372 | 384 | 738 | 164 | 412.0 | N/A |
| 30 | 411 | 381 | 389 | 762 | 169 | 422.4 | N/A |
| 31 | 418 | 387 | 394 | 791 | 174 | 432.8 | N/A |
| 32 | 424 | 393 | 398 | 817 | 178 | 442.0 | N/A |
| 33 | 429 | 397 | 403 | 841 | 183 | 450.6 | N/A |
| 34 | 435 | 401 | 409 | 858 | 187 | 458.0 | N/A |
| 35 | 439 | 406 | 414 | 877 | 191 | 465.4 | N/A |
| 36 | 444 | 410 | 419 | 888 | 196 | 471.4 | N/A |
| 37 | 449 | 414 | 425 | 897 | 200 | 477.0 | N/A |
| 38 | 454 | 417 | 430 | 908 | 204 | 482.6 | N/A |
| 39 | 459 | 422 | 435 | 916 | 209 | 488.2 | N/A |
| 40 | 463 | 426 | 439 | 922 | 212 | 492.4 | N/A |
| 41 | 467 | 430 | 444 | 929 | 216 | 497.2 | N/A |
| 42 | 471 | 434 | 448 | 935 | 219 | 501.4 | N/A |
| 43 | 476 | 439 | 452 | 941 | 223 | 506.2 | N/A |
| 44 | 481 | 443 | 456 | 948 | 226 | 510.8 | N/A |
| 45 | 485 | 448 | 460 | 953 | 229 | 515.0 | N/A |
| 46 | 489 | 453 | 464 | 956 | 231 | 518.6 | N/A |
| 47 | 494 | 458 | 467 | 962 | 234 | 523.0 | N/A |

WOODSTOVE SURFACE TEMPERATURE DATA

Client: FPI
 Model: F2450
 Run #: 1

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Temperature Data (*F) | | | | | | |
|--------------------|-----------------------|----------|---------|--------|-----------|-----------------------|---------------|
| | FB Left | FB Right | FB Back | FB Top | FB Bottom | Stove Surface Average | Catalyst Exit |
| 48 | 498 | 461 | 394 | 948 | 237 | 507.6 | N/A |
| 49 | 501 | 464 | 361 | 945 | 239 | 502.0 | N/A |
| 50 | 505 | 469 | 338 | 942 | 241 | 499.0 | N/A |
| 51 | 509 | 473 | 322 | 940 | 244 | 497.6 | N/A |
| 52 | 513 | 477 | 313 | 938 | 246 | 497.4 | N/A |
| 53 | 517 | 481 | 305 | 936 | 248 | 497.4 | N/A |
| 54 | 521 | 485 | 301 | 936 | 250 | 498.6 | N/A |
| 55 | 525 | 488 | 296 | 935 | 252 | 499.2 | N/A |
| 56 | 528 | 490 | 294 | 935 | 254 | 500.2 | N/A |
| 57 | 531 | 494 | 293 | 935 | 256 | 501.8 | N/A |
| 58 | 534 | 497 | 290 | 934 | 258 | 502.6 | N/A |
| 59 | 538 | 499 | 291 | 934 | 259 | 504.2 | N/A |
| 60 | 541 | 502 | 290 | 934 | 261 | 505.6 | N/A |
| 61 | 545 | 504 | 289 | 933 | 263 | 506.8 | N/A |
| 62 | 547 | 507 | 290 | 932 | 264 | 508.0 | N/A |
| 63 | 550 | 510 | 289 | 931 | 266 | 509.2 | N/A |
| 64 | 553 | 514 | 289 | 929 | 268 | 510.6 | N/A |
| 65 | 555 | 515 | 290 | 930 | 270 | 512.0 | N/A |
| 66 | 558 | 518 | 290 | 929 | 271 | 513.2 | N/A |
| 67 | 560 | 520 | 290 | 929 | 273 | 514.4 | N/A |
| 68 | 562 | 523 | 291 | 927 | 275 | 515.6 | N/A |
| 69 | 565 | 525 | 292 | 926 | 277 | 517.0 | N/A |
| 70 | 566 | 528 | 291 | 923 | 279 | 517.4 | N/A |
| 71 | 569 | 531 | 292 | 920 | 280 | 518.4 | N/A |
| 72 | 570 | 532 | 292 | 915 | 283 | 518.4 | N/A |
| 73 | 573 | 535 | 294 | 903 | 284 | 517.8 | N/A |
| 74 | 574 | 538 | 293 | 894 | 286 | 517.0 | N/A |
| 75 | 575 | 539 | 292 | 882 | 288 | 515.2 | N/A |
| 76 | 577 | 541 | 292 | 870 | 290 | 514.0 | N/A |
| 77 | 578 | 542 | 291 | 859 | 292 | 512.4 | N/A |
| 78 | 580 | 542 | 291 | 848 | 294 | 511.0 | N/A |
| 79 | 581 | 543 | 291 | 836 | 296 | 509.4 | N/A |
| 80 | 582 | 543 | 290 | 827 | 298 | 508.0 | N/A |
| 81 | 582 | 545 | 289 | 818 | 300 | 506.8 | N/A |
| 82 | 582 | 545 | 289 | 811 | 301 | 505.6 | N/A |
| 83 | 583 | 545 | 289 | 802 | 304 | 504.6 | N/A |
| 84 | 583 | 546 | 289 | 794 | 305 | 503.4 | N/A |
| 85 | 583 | 547 | 288 | 786 | 307 | 502.2 | N/A |
| 86 | 584 | 547 | 287 | 779 | 309 | 501.2 | N/A |
| 87 | 585 | 548 | 286 | 775 | 311 | 501.0 | N/A |
| 88 | 584 | 548 | 286 | 769 | 312 | 499.8 | N/A |
| 89 | 584 | 548 | 285 | 761 | 314 | 498.4 | N/A |
| 90 | 584 | 548 | 284 | 752 | 315 | 496.6 | N/A |
| 91 | 582 | 546 | 283 | 740 | 317 | 493.6 | N/A |
| 92 | 582 | 544 | 282 | 729 | 318 | 491.0 | N/A |
| 93 | 580 | 544 | 280 | 715 | 320 | 487.8 | N/A |
| 94 | 578 | 542 | 277 | 704 | 321 | 484.4 | N/A |
| 95 | 576 | 541 | 277 | 691 | 322 | 481.4 | N/A |

WOODSTOVE SURFACE TEMPERATURE DATA

Client: FPI
 Model: F2450
 Run #: 1

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Temperature Data (°F) | | | | | | |
|--------------------|-----------------------|----------|---------|--------|-----------|-----------------------|---------------|
| | FB Left | FB Right | FB Back | FB Top | FB Bottom | Stove Surface Average | Catalyst Exit |
| 96 | 574 | 539 | 275 | 679 | 323 | 478.0 | N/A |
| 97 | 572 | 536 | 274 | 671 | 325 | 475.6 | N/A |
| 98 | 569 | 535 | 272 | 659 | 326 | 472.2 | N/A |
| 99 | 567 | 533 | 270 | 652 | 327 | 469.8 | N/A |
| 100 | 563 | 531 | 269 | 642 | 327 | 466.4 | N/A |
| 101 | 562 | 530 | 268 | 636 | 328 | 464.8 | N/A |
| 102 | 560 | 528 | 266 | 626 | 329 | 461.8 | N/A |
| 103 | 558 | 526 | 265 | 620 | 330 | 459.8 | N/A |
| 104 | 556 | 525 | 263 | 612 | 330 | 457.2 | N/A |
| 105 | 554 | 522 | 261 | 603 | 331 | 454.2 | N/A |
| 106 | 552 | 520 | 259 | 596 | 331 | 451.6 | N/A |
| 107 | 550 | 518 | 258 | 591 | 332 | 449.8 | N/A |
| 108 | 547 | 515 | 257 | 585 | 332 | 447.2 | N/A |
| 109 | 545 | 512 | 255 | 578 | 332 | 444.4 | N/A |
| 110 | 543 | 510 | 252 | 573 | 332 | 442.0 | N/A |
| 111 | 541 | 508 | 251 | 566 | 333 | 439.8 | N/A |
| 112 | 539 | 506 | 250 | 562 | 333 | 438.0 | N/A |
| 113 | 537 | 504 | 249 | 559 | 333 | 436.4 | N/A |
| 114 | 534 | 502 | 248 | 555 | 333 | 434.4 | N/A |
| 115 | 533 | 500 | 247 | 553 | 333 | 433.2 | N/A |
| 116 | 531 | 498 | 247 | 549 | 334 | 431.8 | N/A |
| 117 | 529 | 497 | 245 | 546 | 334 | 430.2 | N/A |
| 118 | 528 | 495 | 246 | 542 | 334 | 429.0 | N/A |
| 119 | 527 | 493 | 245 | 541 | 334 | 428.0 | N/A |
| 120 | 525 | 492 | 244 | 539 | 334 | 426.8 | N/A |
| 121 | 524 | 492 | 243 | 536 | 335 | 426.0 | N/A |
| 122 | 523 | 490 | 242 | 530 | 335 | 424.0 | N/A |
| 123 | 521 | 488 | 239 | 522 | 336 | 421.2 | N/A |
| 124 | 520 | 487 | 239 | 517 | 336 | 419.8 | N/A |
| Average | 461 | 431 | 288 | 705 | 240 | 425 | N/A |

LAB SAMPLE DATA - ASTM E2515

Client: FPI
 Model: F2450
 Run #: 1

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

TRAIN A (1st Hour)

| Sample Component | Sample Type | Filter, Probe, or O-Ring # | Weights | | |
|-----------------------|-------------|----------------------------|-----------|----------|-----------------|
| | | | Final, mg | Tare, mg | Particulate, mg |
| A. Front filter catch | Filter | T103, T104, T110, T112 | 363.0 | 354.6 | 8.4 |
| B. Rear filter catch | Filter | | | | 0.0 |
| C. Probe catch* | Probe | | | | 0.0 |
| D. O-Ring catch* | O-Ring | | | | 0.0 |

Sub-Total Total Particulate, mg: 8.4

TRAIN A (Post 1st hour)

| Sample Component | Sample Type | Filter, Probe, or O-Ring # | Weights | | |
|-----------------------|-------------|----------------------------|-----------|----------|-----------------|
| | | | Final, mg | Tare, mg | Particulate, mg |
| A. Front filter catch | Filter | T113 | 178.9 | 88.8 | 1.8 |
| B. Rear filter catch | Filter | T105 | | 88.3 | |
| C. Probe catch* | Probe | 7A | 116740.1 | 116739.9 | 0.2 |
| D. O-Ring catch* | O-Ring | 7A | 3569.2 | 3569.1 | 0.1 |

Sub-Total Total Particulate, mg: 2.1

Train A Aggregate Total Particulate, mg: **10.5**

TRAIN B

| Sample Component | Reagent | Filter, Probe, or O-Ring # | Weights | | |
|-----------------------|---------|----------------------------|-----------|----------|-----------------|
| | | | Final, mg | Tare, mg | Particulate, mg |
| A. Front filter catch | Filter | T106, T109, T111 | 364.2 | 266.8 | 9.3 |
| B. Rear filter catch | Filter | T107 | | 88.1 | |
| C. Probe catch* | Probe | 7B | 117288.0 | 117287.7 | 0.3 |
| D. O-Ring catch* | O-Ring | 7B | 3517.9 | 3517.8 | 0.1 |

Total Particulate, mg: **9.7**

AMBIENT

| Sample Component | Reagent | Filter, Probe, or O-Ring # | Weights | | |
|------------------|---------|----------------------------|-----------|----------|-----------------|
| | | | Final, mg | Tare, mg | Particulate, mg |
| A. Filter catch* | Filter | T108 | 88.5 | 88.4 | 0.1 |

Total Particulate, mg: **0.1**

*Particulate catch that results in a negative number, is assumed to be zero for probes and O-rings, negative numbers for filters are assumed to be part of the O-Ring weight.

ASTM E3053 Wood Heater Run Sheets

Client: FPI Job Number: 19-460 Tracking #: 0022
 Model: F2450 Run Number: 1 Test Date: 2/27/2019

Wood Heater Run Notes

Pre-Test Notes

Pre-Test Start Time: N/A
 Air Control Setting: N/A

| Time | Notes |
|------|---------------------------------------|
| N/A | High Fire test begins from cold start |

Test Notes

Test Burn Start Time: 9:25
 Air Control Setting: Fully Open

| Time | Notes |
|---------|---|
| 0 min | 2.0 lbs of kindling and scrap paper loaded in stove, propane torch for 20 seconds; door cracked open ~3" |
| 1 min | Door closed down to 1" open |
| 2 min | Door closed engaged |
| 8 min | @0.7 lbs, added remaining kindling (1.0 lb) of kindling and 1.2 lbs of start-up fuel, door open 40 seconds, then closed but not engaged |
| 10 min | Door latch engaged, changed front filter on both sample trains due to plugging |
| 21 min | @0.7 lbs, added remaining start-up fuel (3.0 lbs), door open 120 seconds |
| 22 min | Changed front filter on both sample trains due to plugging |
| 27 min | @2.2 lbs, leveled coal bed and loaded high fire fuel load, door open 1 minute |
| 29 min | Changed front filter on both A & B trains due to plugging |
| 35 min | Changed Train A front filter due to plugging |
| 47 min | Fan turned on high (20 minutes after fuel loading) per manufacturer's instructions |
| 60 min | Changed 1-hour filter on train A |
| 124 min | End of Test |

Test Burn End Time: 11:29

Flue Gas Concentration Measurement

Calibration Gas Values: Span Gas CO₂ (%): 16.93 CO (%): 4.330
 Mid Gas CO₂ (%): 10.00 CO (%): 2.51

Calibration Results:

| | Pre Test | | | Post Test | | |
|-----------------|----------|-------|-------|-------------|-------------|-------------|
| | Zero | Mid | Span | Zero | Mid | Span |
| Time | 9:05 | 9:09 | 9:07 | 2/28 – 6:57 | 2/28 – 6:54 | 2/28 – 6:59 |
| CO ₂ | 0.00 | 10.06 | 16.93 | 0.02 | 10.15 | 17.13 |
| CO | 0.000 | 2.492 | 4.330 | 0.000 | 2.512 | 4.371 |

Flue Gas Probe Leak Check: Initial: No Leakage Final: No Leakage

Technician Signature: 

Date: 2/28/2019

ASTM E3053 Wood Heater Run Sheets

Client: FPI
Model: F2450

Job Number: 19-460
Run Number: 1

Tracking #: 0022
Test Date: 2/27/2019

Test Photos



Kindling Fuel Load



Start-up Fuel Load



High Fire Fuel Load



Residual Start-up Fuel Coal Bed

Technician Signature: 

Date: 2/28/2019

ASTM E3053 Wood Heater Run Sheets

Client: FPI
Model: F2450

Job Number: 19-460
Run Number: 1


Tracking #: 0022
Test Date: 2/27/2019



High Fire Fuel Loaded




Residual High Fire Load Coal Bed



N/A - High Fire Test Only

Low Fire Fuel Load



N/A - High Fire Test Only

Low Fire Fuel Loaded

Technician Signature: 

Date: 2/28/2019
Page 3 of 3

**WOOD STOVE TEST DATA PACKET
ASTM E3053/E2515**



Run 2 Data Summary

Client: FPI
Model: F2450
Job #: 19-460
Tracking #: 0022
Test Date: 2/27/2019

A handwritten signature in black ink, appearing to be "JL", is written above a horizontal line.

Techician Signature

3/4/2019

Date

TEST RESULTS - ASTM E3053 / ASTM E2515

Client: FPI

Model: F2450

Run #: 2

Job #: 19-460

Tracking #: 0022

Technician: SJB

Date: 2/27/2019

| | |
|---------------------------|-------------|
| Burn Rate (kg/hr): | 1.01 |
|---------------------------|-------------|

| | Ambient Sample | Sample Train A | Sample Train B | 1st Hour Filter |
|---|-------------------|-------------------|-------------------|-----------------|
| Total Sample Volume (ft ³) | 69.305 | 88.189 | 86.702 | 9.133 |
| Average Gas Velocity in Dilution Tunnel (ft/sec) | 16.24 | | | |
| Average Gas Flow Rate in Dilution Tunnel (dscf/hr) | 10596.8 | | | |
| Average Gas Meter Temperature (°F) | 74.9 | 103.1 | 102.3 | 99.6 |
| Total Sample Volume (dscf) | 67.977 | 83.051 | 81.434 | 8.652 |
| Average Tunnel Temperature (°F) | 97.3 | | | |
| Total Time of Test (min) | 573 | | | |
| Total Particulate Catch (mg) | 0.1 | 14.4 | 14.0 | 2.4 |
| Particulate Concentration, dry-standard (g/dscf) | 0.0000015 | 0.0001734 | 0.0001719 | 0.0002774 |
| Total PM Emissions (g) | 0.15 | 17.40 | 17.25 | 2.92 |
| Particulate Emission Rate (g/hr) | 0.02 | 1.82 | 1.81 | 2.92 |
| Emissions Factor (g/kg) | - | 1.80 | 1.78 | - |
| Difference from Average Total Particulate Emissions (g) | - | 0.07 | 0.07 | - |
| Difference from Average Emissions Factor (g/kg) | - | 0.01 | 0.01 | - |

| Final Average Results | |
|----------------------------------|-------|
| Total Particulate Emissions (g) | 17.32 |
| Particulate Emission Rate (g/hr) | 1.81 |
| Emissions Factor (g/kg) | 1.79 |
| HHV Efficiency (%) | 73.9% |
| LHV Efficiency (%) | 79.1% |
| CO Emissions (g/min) | 1.47 |

| Quality Checks | Requirement | Observed | Result |
|----------------------------------|---|-------------------|----------------------------------|
| Dual Train Precision | Each train within 7.5% of average emissions (in grams), or emission factors within 0.5 g/kg | See Above | OK |
| Filter Temps | >80 °F, <90 °F | Min: 80 / Max: 87 | OK |
| Face Velocity | < 30 ft/min | 9.5 | OK |
| Leakage Rate | Less than 4% of average sample rate | 0 cfm | OK |
| Ambient Temp | 55-90 °F | Min: 68 / Max: 77 | OK |
| Negative Probe Weight Evaluation | <5% of Total Catch | -0.7% | OK |
| Pro-Rate Variation | 90% of readings between 90-110%; none greater than 120% or less than 80% | See Data Tabs | CHECK 10 MIN. INTERVAL PRO-RATES |

B415.1 Efficiency Results

Manufacturer: FPI
Model: F2450
Date: 02/27/19
Run: 2
Control #: 19-460
Test Duration: 573
Output Category: Low

Test Results in Accordance with CSA B415.1-09

| | HHV Basis | LHV Basis |
|---------------------------------|-----------|-----------|
| Overall Efficiency | 73.9% | 79.1% |
| Combustion Efficiency | 94.1% | 94.1% |
| Heat Transfer Efficiency | 78.6% | 84.0% |

| | | | |
|---------------------------|--------|--------|----------------|
| Output Rate (kJ/h) | 14,947 | 14,179 | (Btu/h) |
| Burn Rate (kg/h) | 1.01 | 2.23 | (lb/h) |
| Input (kJ/h) | 20,217 | 19,178 | (Btu/h) |

| | | | |
|----------------------------------|-------|-------|---------------|
| Test Load Weight (dry kg) | 9.67 | 21.32 | dry lb |
| MC wet (%) | 18.00 | | |
| MC dry (%) | 21.96 | | |
| Particulate (g) | 17.32 | | |
| CO (g) | 843 | | |
| Test Duration (h) | 9.55 | | |

| Emissions | Particulate | CO |
|-------------------------|-------------|-------|
| g/MJ Output | 0.12 | 5.90 |
| g/kg Dry Fuel | 1.79 | 87.10 |
| g/h | 1.81 | 88.22 |
| g/min | 0.03 | 1.47 |
| lb/MM Btu Output | 0.28 | 13.72 |

| | |
|-----------------------------|-------|
| Air/Fuel Ratio (A/F) | 16.40 |
|-----------------------------|-------|

VERSION:

2.2

12/14/2009

HIGH FIRE FUEL LOAD DATA - ASTM E3053

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #0022
 Technician: SJB
 Date: 2/27/2019

Nominal Loading Density (lbs/ft³, wet basis): 10
 Usable Firebox Volume (ft³): 2.24
 Target Load Weight (lbs): 22.40
 Total Load Weight Range (lbs): 21.30 to 23.50
 Core Load Weight Range (lbs): 10.10 to 14.60
 Remainder Load Weight Range (lbs): 7.80 to 12.30
 Core Load Piece Range (lbs): 3.40 to 5.60
 Remainder Load Piece Range (lbs): 2.20 to 12.30
 Max Allowable Kindling Weight (lbs): 4.27
 Max Allowable Start-up Fuel Weight (lbs): 6.41

CORE LOAD DATA

| Piece # | Length (in) | Weight (lbs) | Within Spec? | Fuel Piece Moisture Readings (%DB) | | | | Within Spec? | Dry Weight | |
|---------------------|-------------|--------------|--------------|------------------------------------|------|------|------|--------------|------------|------|
| | | | | 1 | 2 | 3 | Ave. | | lbs | kg |
| 1 | 17.00 | 3.44 | In Range | 23.8 | 22.4 | 22.1 | 22.8 | In Range | 2.80 | 1.27 |
| 2 | 17.00 | 4.32 | In Range | 22.9 | 22.1 | 19.4 | 21.5 | In Range | 3.56 | 1.61 |
| 3 | 17.00 | 4.61 | In Range | 18.6 | 19.4 | 19.8 | 19.3 | In Range | 3.87 | 1.75 |
| Core Load Wt. (lbs) | | 12.37 | In Range | | | | | | | |

REMAINDER LOAD DATA (1 to 3 Pieces)

| Piece # | Length (in) | Weight (lbs) | Within Spec? | Fuel Piece Moisture Readings (%DB) | | | | Within Spec? | Dry Weight | |
|----------------------|-------------|--------------|--------------|------------------------------------|------|------|------|--------------|------------|------|
| | | | | 1 | 2 | 3 | Ave. | | lbs | kg |
| 1 | 17.00 | 3.22 | In Range | 19.3 | 19.5 | 18.7 | 19.2 | In Range | 2.70 | 1.23 |
| 2 | 17.00 | 2.25 | In Range | 25.2 | 23.4 | 24.6 | 24.4 | In Range | 1.81 | 0.82 |
| 3 | 17.00 | 3.53 | In Range | 19.4 | 18.3 | 19.1 | 18.9 | In Range | 2.97 | 1.35 |
| Remainder Load (lbs) | | 9.00 | In Range | | | | | | | |

Total Load Weight (lbs): 21.37 In Range
 Core Load % of Total Weight: 58% In Range 45-65%
 Remainder % of Total Weight: 42% In Range 35-55%
 Total Load % of Target Weight: 95% In Range 95-105%
 Actual Fuel Loading Density (lb/ft³): 9.5
 Total Load Average Moisture Content (%DB): 20.7 In Range 19-25%
 Total Load Average Moisture Content (%WB): 17.2
 Total Test Load Weight (dry basis): 17.70 lbs 8.03 kg

KINDLING AND START-UP FUEL

| Kindling Weight (lbs) | Within Spec? | Kindling Moisture Readings (%DB) | | | | Within Spec? | Dry Weight | |
|-----------------------|--------------|----------------------------------|----|----|------|--------------|------------|------|
| | | 1 | 2 | 3 | Avg. | | lbs | kg |
| 3.02 | In Range | 10 | 10 | 10 | 10.0 | In Range | 2.75 | 1.25 |

| Start-up Fuel Wt. (lb) | Within Spec? | Start-up Moisture Readings (%DB) | | | | Within Spec? | Dry Weight | |
|------------------------|--------------|----------------------------------|------|------|------|--------------|------------|------|
| | | 1 | 2 | 3 | Avg. | | lbs | kg |
| 4.19 | In Range | 19.3 | 22.4 | 18.7 | 20.1 | In Range | 3.49 | 1.58 |

TEST FUEL LOADING RANGE

Allowable Residual Start-up Fuel Range (lb): 2.1 to 4.3
 Actual Residual Start-up Fuel Weight (lb): 2.2 In Range

LOW & MEDIUM FIRE FUEL LOAD DATA - ASTM E3053

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

Nominal Loading Density (lbs/ft³, wet basis): 12
 Usable Firebox Volume (ft³): 2.24
 Target Load Weight (lbs): 26.88
 Total Load Weight Range (lbs): 25.54 to 28.22
 Core Load Weight Range (lbs): 12.10 to 17.47
 Remainder Load Weight Range (lbs): 9.41 to 14.78
 Core Load Piece Range (lbs): 4.03 to 6.72
 Remainder Load Piece Range (lbs): 2.69 to 8.06

CORE LOAD DATA

| Piece # | Length (in) | Weight (lbs) | Within Spec? | Fuel Piece Moisture Readings (%DB) | | | | Ave. | Within Spec? | Dry Weight | |
|---------------------|-------------|--------------|--------------|------------------------------------|------|------|------|----------|--------------|------------|----|
| | | | | 1 | 2 | 3 | | | | lbs | kg |
| 1 | 17.00 | 5.53 | In Range | 20.6 | 22.0 | 18.7 | 20.4 | In Range | 4.59 | 2.08 | |
| 2 | 17.00 | 5.18 | In Range | 24.2 | 21.7 | 22.6 | 22.8 | In Range | 4.22 | 1.91 | |
| 3 | 17.00 | 5.07 | In Range | 22.3 | 19.0 | 21.4 | 20.9 | In Range | 4.19 | 1.90 | |
| Core Load Wt. (lbs) | | 15.78 | In Range | | | | | | | | |

REMAINDER LOAD DATA (2 to 3 Pieces)

| Piece # | Length (in) | Weight (lbs) | Within Spec? | Fuel Piece Moisture Readings (%DB) | | | | Ave. | Within Spec? | Dry Weight | |
|----------------------|-------------|--------------|--------------|------------------------------------|------|------|------|----------|--------------|------------|----|
| | | | | 1 | 2 | 3 | | | | lbs | kg |
| 1 | 17.00 | 3.70 | In Range | 24.5 | 21.5 | 19.7 | 21.9 | In Range | 3.04 | 1.38 | |
| 2 | 17.00 | 6.48 | In Range | 22.8 | 24.7 | 22.9 | 23.5 | In Range | 5.25 | 2.38 | |
| 3 | | | NA | | | | NA | NA | NA | NA | |
| Remainder Load (lbs) | | 10.18 | In Range | | | | | | | | |

Remainder Load Small/Large Piece Weight Ratio: 57% In Range ≤ 67%
 Total Load Weight (lbs): 25.96 In Range
 Core Load % of Total Weight: 61% In Range 45-65%
 Remainder % of Total Weight: 39% In Range 35-55%
 Total Load % of Target Weight: 97% In Range 95-105%
 Actual Fuel Loading Density (lb/ft³): 11.6
 Total Load Average Moisture Content (%DB): 22.0 In Range 19-25%
 Total Load Average Moisture Content (%WB): 18.0
 Total Test Load Weight (dry basis): 21.29 lbs 9.66 kg

TEST FUEL LOADING RANGE

Allowable Charcoal Bed Weight Range (lb): 2.6 to 5.1
 Actual Charcoal Bed Wt. (lb): 3.9 In Range

TEST END POINT

Actual Fuel Load Ending Weight (lb): 0.0 Valid Test (≥90%)

Total Fuel Burned During Test Run:
 26.0 lbs, wet basis
 21.3 lbs, dry basis
 9.66 kg, dry basis

DILUTION TUNNEL & MISC. DATA - ASTM E3053 / E2515

Client: FPI
 Model: F2450
 Run #: 2
 Test Start Time: 11:38
 Test Type: Low Fire

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

Recording Interval (min): 1
 Total Sampling Time (min): 573

Meter Box γ Factor: 1.004 (A)
 Meter Box γ Factor: 1.000 (B)
 Meter Box γ Factor: 0.999 (Ambient)

Induced Draft Check (in. H₂O): 0
 Smoke Capture Check (%): 100%
 Date Flue Pipe Last Cleaned: 2/25/2019

| | Pre-Test | Post Test | Avg. |
|------------------------------|------------------------|-----------|-------|
| Barometric Pressure (in. Hg) | 29.82 | 29.72 | 29.77 |
| Relative Humidity (%) | 9.1 | 8.1 | |
| Room Air Velocity (ft/min) | 0 | 0 | |
| Scale Audit (lbs) | 10.0 | 10.0 | |
| Ambient Sample Volume: | 69.305 ft ³ | | |

Sample Train Post-Test Leak Checks

| | | | | |
|-----------|-------|-------|-----|--------|
| (A) | 0.000 | cfm @ | -16 | in. Hg |
| (B) | 0.000 | cfm @ | -13 | in. Hg |
| (Ambient) | 0.001 | cfm @ | -13 | in. Hg |

DILUTION TUNNEL FLOW**Traverse Data**

| Point | dP (in H ₂ O) | Temp (°F) |
|--------|--------------------------|-----------|
| 1 | 0.040 | 85 |
| 2 | 0.064 | 85 |
| 3 | 0.068 | 85 |
| 4 | 0.046 | 85 |
| 5 | 0.046 | 85 |
| 6 | 0.064 | 85 |
| 7 | 0.068 | 85 |
| 8 | 0.048 | 85 |
| Center | 0.070 | 85 |

Dilution Tunnel H₂O: 2.00 percent
 Tunnel Diameter: 6 inches
 Pitot Tube Cp: 0.99 [unitless]
 Dilution Tunnel MW(dry): 29.00 lb/lb-mole
 Dilution Tunnel MW(wet): 28.78 lb/lb-mole
 Tunnel Area: 0.1963 ft²

V_{strav}: 16.04 ft/sec
 V_{scnt}: 17.85 ft/sec
 F_p: 0.899 [ratio]

Initial Tunnel Flow: 176.1 scf/min

Static Pressure: -0.200 in. H₂O

TEST FUEL PROPERTIES**ASTM 3053-17 - Table A1.1 Fuel Properties by Fuel Species**

| Select Fuel Type | Species | %C | %H | %O | %Ash | MJ/kg | BTU/lb |
|------------------|---------------------------------------|-------|------|-------|------|-------|--------|
| | Ash, White | 49.70 | 6.90 | 43.00 | 0.30 | 20.75 | 8927 |
| | Beech | 48.70 | 5.80 | 44.70 | 0.60 | 18.80 | 8088 |
| | Birch, Sweet | 49.80 | 6.50 | 43.40 | 0.30 | 20.12 | 8656 |
| | Birch, Yellow | 49.80 | 6.50 | 43.40 | 0.30 | 20.12 | 8656 |
| | Doug Fir (Coast, Interior West/North) | 48.73 | 6.87 | 43.90 | 0.50 | 19.81 | 8522 |
| | Doug Fir (Interior South) | 48.73 | 6.87 | 43.90 | 0.50 | 19.81 | 8522 |
| | Elm, Rock | 50.40 | 6.60 | 42.30 | 0.70 | 20.49 | 8815 |
| | Elm, Soft | 50.40 | 6.60 | 42.30 | 0.70 | 20.49 | 8815 |
| | Gum, Red | 50.88 | 6.06 | 41.57 | 1.28 | 19.72 | 8478 |
| | Larch, Western | 50.54 | 6.36 | 42.40 | 0.70 | 17.58 | 7558 |
| X | Maple, Hard | 50.64 | 6.02 | 41.74 | 1.35 | 19.96 | 8587 |
| | Maple, Sugar | 50.64 | 6.02 | 41.74 | 1.35 | 19.96 | 8587 |
| | Oak, Red | 49.50 | 6.62 | 43.70 | 0.20 | 20.20 | 8690 |
| | Oak, White | 50.40 | 6.59 | 42.70 | 0.20 | 20.50 | 8819 |
| | Pine, Southern | 52.60 | 7.00 | 40.10 | 1.31 | 22.30 | 9587 |
| | Pine, Southern Long Leaf | 52.60 | 7.02 | 40.10 | 1.30 | 22.30 | 9594 |
| | Other | | | | | | |

WOODSTOVE PREBURN DATA

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

Recording Interval (min): 1
 Run Time (min): 124

| Elapsed Time (min) | Scale Reading (lbs) | Flue Draft (in H ₂ O) | Temperatures (°F) | | | | | | | Flue | Ambient |
|--------------------|---------------------|----------------------------------|-------------------|----------|---------|--------|-----------|-----------------------|-----|------|---------|
| | | | FB Left | FB Right | FB Back | FB Top | FB Bottom | Stove Surface Average | | | |
| 0 | 1.9 | 0.000 | 74 | 74 | 72 | 75 | 74 | 73.8 | 76 | 71 | |
| 1 | 1.7 | -0.060 | 74 | 74 | 74 | 88 | 74 | 76.8 | 230 | 71 | |
| 2 | 1.2 | -0.090 | 78 | 78 | 87 | 137 | 74 | 90.8 | 456 | 71 | |
| 3 | 1.1 | -0.060 | 87 | 88 | 98 | 189 | 74 | 107.2 | 419 | 71 | |
| 4 | 1.0 | -0.060 | 98 | 100 | 106 | 234 | 74 | 122.4 | 410 | 71 | |
| 5 | 0.8 | -0.060 | 111 | 113 | 115 | 267 | 74 | 136.0 | 401 | 71 | |
| 6 | 0.7 | -0.070 | 125 | 126 | 122 | 292 | 75 | 148.0 | 380 | 71 | |
| 7 | 0.6 | -0.050 | 139 | 136 | 132 | 310 | 76 | 158.6 | 364 | 71 | |
| 8 | 0.6 | -0.070 | 152 | 145 | 141 | 319 | 78 | 167.0 | 344 | 71 | |
| 9 | 2.7 | -0.060 | 164 | 153 | 149 | 324 | 80 | 174.0 | 357 | 71 | |
| 10 | 2.4 | -0.070 | 174 | 160 | 160 | 346 | 82 | 184.4 | 480 | 71 | |
| 11 | 2.2 | -0.070 | 185 | 168 | 172 | 374 | 85 | 196.8 | 451 | 71 | |
| 12 | 2.1 | -0.070 | 196 | 178 | 185 | 407 | 88 | 210.8 | 471 | 71 | |
| 13 | 1.8 | -0.060 | 208 | 190 | 198 | 439 | 91 | 225.2 | 479 | 71 | |
| 14 | 1.7 | -0.070 | 220 | 203 | 213 | 466 | 95 | 239.4 | 488 | 72 | |
| 15 | 1.6 | -0.080 | 233 | 217 | 227 | 497 | 99 | 254.6 | 516 | 72 | |
| 16 | 1.4 | -0.070 | 247 | 232 | 243 | 529 | 103 | 270.8 | 528 | 72 | |
| 17 | 1.2 | -0.070 | 261 | 247 | 259 | 550 | 107 | 284.8 | 509 | 72 | |
| 18 | 1.0 | -0.080 | 275 | 261 | 274 | 562 | 111 | 296.6 | 499 | 72 | |
| 19 | 0.9 | -0.060 | 289 | 275 | 286 | 568 | 116 | 306.8 | 484 | 72 | |
| 20 | 0.8 | -0.060 | 301 | 287 | 297 | 569 | 120 | 314.8 | 469 | 71 | |
| 21 | 0.7 | -0.070 | 313 | 299 | 307 | 567 | 125 | 322.2 | 461 | 72 | |
| 22 | 3.2 | -0.080 | 324 | 308 | 318 | 567 | 130 | 329.4 | 521 | 72 | |
| 23 | 3.2 | -0.080 | 334 | 317 | 327 | 585 | 134 | 339.4 | 586 | 72 | |
| 24 | 3.0 | -0.070 | 342 | 326 | 337 | 618 | 139 | 352.4 | 580 | 72 | |
| 25 | 2.6 | -0.090 | 352 | 336 | 347 | 653 | 144 | 366.4 | 593 | 72 | |
| 26 | 2.4 | -0.090 | 362 | 345 | 357 | 687 | 149 | 380.0 | 602 | 72 | |
| 27 | 2.2 | -0.080 | 373 | 355 | 366 | 712 | 153 | 391.8 | 602 | 73 | |
| 28 | 23.8 | -0.090 | 390 | 364 | 376 | 739 | 159 | 405.6 | 685 | 73 | |
| 29 | 22.9 | -0.090 | 402 | 372 | 384 | 738 | 164 | 412.0 | 618 | 73 | |
| 30 | 22.6 | -0.080 | 411 | 381 | 389 | 762 | 169 | 422.4 | 652 | 73 | |
| 31 | 22.2 | -0.100 | 418 | 387 | 394 | 791 | 174 | 432.8 | 670 | 73 | |
| 32 | 21.8 | -0.090 | 424 | 393 | 398 | 817 | 178 | 442.0 | 685 | 73 | |
| 33 | 21.6 | -0.090 | 429 | 397 | 403 | 841 | 183 | 450.6 | 691 | 73 | |
| 34 | 21.2 | -0.090 | 435 | 401 | 409 | 858 | 187 | 458.0 | 697 | 73 | |
| 35 | 20.8 | -0.090 | 439 | 406 | 414 | 877 | 191 | 465.4 | 702 | 73 | |
| 36 | 20.4 | -0.090 | 444 | 410 | 419 | 888 | 196 | 471.4 | 707 | 73 | |
| 37 | 20.1 | -0.100 | 449 | 414 | 425 | 897 | 200 | 477.0 | 705 | 73 | |
| 38 | 19.8 | -0.090 | 454 | 417 | 430 | 908 | 204 | 482.6 | 704 | 74 | |
| 39 | 19.6 | -0.090 | 459 | 422 | 435 | 916 | 209 | 488.2 | 710 | 74 | |
| 40 | 19.1 | -0.090 | 463 | 426 | 439 | 922 | 212 | 492.4 | 710 | 73 | |
| 41 | 18.8 | -0.090 | 467 | 430 | 444 | 929 | 216 | 497.2 | 713 | 73 | |
| 42 | 18.6 | -0.090 | 471 | 434 | 448 | 935 | 219 | 501.4 | 714 | 73 | |
| 43 | 18.1 | -0.090 | 476 | 439 | 452 | 941 | 223 | 506.2 | 719 | 73 | |

WOODSTOVE PREBURN DATA

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

Recording Interval (min): 1
 Run Time (min): 124

| Elapsed Time (min) | Scale Reading (lbs) | Flue Draft (in H ₂ O) | Temperatures (°F) | | | | | | | |
|--------------------|---------------------|----------------------------------|-------------------|----------|---------|--------|-----------|-----------------------|------|---------|
| | | | FB Left | FB Right | FB Back | FB Top | FB Bottom | Stove Surface Average | Flue | Ambient |
| 44 | 17.8 | -0.100 | 481 | 443 | 456 | 948 | 226 | 510.8 | 720 | 73 |
| 45 | 17.5 | -0.090 | 485 | 448 | 460 | 953 | 229 | 515.0 | 725 | 73 |
| 46 | 17.1 | -0.090 | 489 | 453 | 464 | 956 | 231 | 518.6 | 724 | 74 |
| 47 | 16.8 | -0.080 | 494 | 458 | 467 | 962 | 234 | 523.0 | 725 | 74 |
| 48 | 16.6 | -0.100 | 498 | 461 | 394 | 948 | 237 | 507.6 | 721 | 73 |
| 49 | 16.1 | -0.090 | 501 | 464 | 361 | 945 | 239 | 502.0 | 715 | 75 |
| 50 | 15.8 | -0.090 | 505 | 469 | 338 | 942 | 241 | 499.0 | 712 | 74 |
| 51 | 15.7 | -0.090 | 509 | 473 | 322 | 940 | 244 | 497.6 | 709 | 74 |
| 52 | 15.4 | -0.090 | 513 | 477 | 313 | 938 | 246 | 497.4 | 707 | 75 |
| 53 | 15.0 | -0.100 | 517 | 481 | 305 | 936 | 248 | 497.4 | 701 | 75 |
| 54 | 14.6 | -0.090 | 521 | 485 | 301 | 936 | 250 | 498.6 | 699 | 75 |
| 55 | 14.4 | -0.090 | 525 | 488 | 296 | 935 | 252 | 499.2 | 695 | 75 |
| 56 | 14.0 | -0.100 | 528 | 490 | 294 | 935 | 254 | 500.2 | 694 | 74 |
| 57 | 13.7 | -0.100 | 531 | 494 | 293 | 935 | 256 | 501.8 | 689 | 75 |
| 58 | 13.4 | -0.090 | 534 | 497 | 290 | 934 | 258 | 502.6 | 684 | 75 |
| 59 | 13.1 | -0.090 | 538 | 499 | 291 | 934 | 259 | 504.2 | 685 | 75 |
| 60 | 12.8 | -0.090 | 541 | 502 | 290 | 934 | 261 | 505.6 | 681 | 75 |
| 61 | 12.6 | -0.090 | 545 | 504 | 289 | 933 | 263 | 506.8 | 678 | 75 |
| 62 | 12.2 | -0.090 | 547 | 507 | 290 | 932 | 264 | 508.0 | 679 | 75 |
| 63 | 11.9 | -0.080 | 550 | 510 | 289 | 931 | 266 | 509.2 | 676 | 75 |
| 64 | 11.8 | -0.100 | 553 | 514 | 289 | 929 | 268 | 510.6 | 676 | 75 |
| 65 | 11.4 | -0.100 | 555 | 515 | 290 | 930 | 270 | 512.0 | 672 | 75 |
| 66 | 11.1 | -0.090 | 558 | 518 | 290 | 929 | 271 | 513.2 | 669 | 75 |
| 67 | 10.8 | -0.080 | 560 | 520 | 290 | 929 | 273 | 514.4 | 670 | 75 |
| 68 | 10.6 | -0.080 | 562 | 523 | 291 | 927 | 275 | 515.6 | 669 | 75 |
| 69 | 10.2 | -0.100 | 565 | 525 | 292 | 926 | 277 | 517.0 | 667 | 75 |
| 70 | 10.0 | -0.090 | 566 | 528 | 291 | 923 | 279 | 517.4 | 662 | 76 |
| 71 | 9.8 | -0.090 | 569 | 531 | 292 | 920 | 280 | 518.4 | 653 | 76 |
| 72 | 9.6 | -0.090 | 570 | 532 | 292 | 915 | 283 | 518.4 | 640 | 75 |
| 73 | 9.3 | -0.090 | 573 | 535 | 294 | 903 | 284 | 517.8 | 629 | 75 |
| 74 | 9.2 | -0.090 | 574 | 538 | 293 | 894 | 286 | 517.0 | 618 | 75 |
| 75 | 9.0 | -0.090 | 575 | 539 | 292 | 882 | 288 | 515.2 | 612 | 76 |
| 76 | 8.8 | -0.080 | 577 | 541 | 292 | 870 | 290 | 514.0 | 603 | 75 |
| 77 | 8.6 | -0.070 | 578 | 542 | 291 | 859 | 292 | 512.4 | 596 | 76 |
| 78 | 8.6 | -0.100 | 580 | 542 | 291 | 848 | 294 | 511.0 | 587 | 75 |
| 79 | 8.3 | -0.080 | 581 | 543 | 291 | 836 | 296 | 509.4 | 586 | 76 |
| 80 | 8.1 | -0.080 | 582 | 543 | 290 | 827 | 298 | 508.0 | 587 | 75 |
| 81 | 8.0 | -0.090 | 582 | 545 | 289 | 818 | 300 | 506.8 | 582 | 76 |
| 82 | 7.8 | -0.080 | 582 | 545 | 289 | 811 | 301 | 505.6 | 576 | 76 |
| 83 | 7.7 | -0.080 | 583 | 545 | 289 | 802 | 304 | 504.6 | 569 | 75 |
| 84 | 7.5 | -0.080 | 583 | 546 | 289 | 794 | 305 | 503.4 | 564 | 76 |
| 85 | 7.5 | -0.070 | 583 | 547 | 288 | 786 | 307 | 502.2 | 558 | 76 |
| 86 | 7.3 | -0.090 | 584 | 547 | 287 | 779 | 309 | 501.2 | 555 | 75 |
| 87 | 7.1 | -0.080 | 585 | 548 | 286 | 775 | 311 | 501.0 | 552 | 75 |

WOODSTOVE PREBURN DATA

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

Recording Interval (min): 1
 Run Time (min): 124

| Elapsed Time (min) | Scale Reading (lbs) | Flue Draft (in H ₂ O) | Temperatures (°F) | | | | | | | Flue | Ambient |
|--------------------|---------------------|----------------------------------|-------------------|----------|---------|--------|-----------|-----------------------|-----|------|---------|
| | | | FB Left | FB Right | FB Back | FB Top | FB Bottom | Stove Surface Average | | | |
| 88 | 7.0 | -0.080 | 584 | 548 | 286 | 769 | 312 | 499.8 | 544 | 75 | |
| 89 | 6.9 | -0.090 | 584 | 548 | 285 | 761 | 314 | 498.4 | 534 | 75 | |
| 90 | 6.8 | -0.080 | 584 | 548 | 284 | 752 | 315 | 496.6 | 524 | 75 | |
| 91 | 6.8 | -0.080 | 582 | 546 | 283 | 740 | 317 | 493.6 | 519 | 76 | |
| 92 | 6.6 | -0.080 | 582 | 544 | 282 | 729 | 318 | 491.0 | 513 | 75 | |
| 93 | 6.5 | -0.080 | 580 | 544 | 280 | 715 | 320 | 487.8 | 505 | 75 | |
| 94 | 6.4 | -0.080 | 578 | 542 | 277 | 704 | 321 | 484.4 | 499 | 75 | |
| 95 | 6.3 | -0.080 | 576 | 541 | 277 | 691 | 322 | 481.4 | 491 | 75 | |
| 96 | 6.2 | -0.070 | 574 | 539 | 275 | 679 | 323 | 478.0 | 488 | 75 | |
| 97 | 6.1 | -0.080 | 572 | 536 | 274 | 671 | 325 | 475.6 | 482 | 75 | |
| 98 | 6.2 | -0.080 | 569 | 535 | 272 | 659 | 326 | 472.2 | 480 | 75 | |
| 99 | 6.0 | -0.070 | 567 | 533 | 270 | 652 | 327 | 469.8 | 477 | 75 | |
| 100 | 5.9 | -0.070 | 563 | 531 | 269 | 642 | 327 | 466.4 | 474 | 75 | |
| 101 | 5.8 | -0.070 | 562 | 530 | 268 | 636 | 328 | 464.8 | 471 | 75 | |
| 102 | 5.7 | -0.080 | 560 | 528 | 266 | 626 | 329 | 461.8 | 468 | 75 | |
| 103 | 5.6 | -0.080 | 558 | 526 | 265 | 620 | 330 | 459.8 | 461 | 75 | |
| 104 | 5.6 | -0.080 | 556 | 525 | 263 | 612 | 330 | 457.2 | 457 | 75 | |
| 105 | 5.5 | -0.070 | 554 | 522 | 261 | 603 | 331 | 454.2 | 453 | 75 | |
| 106 | 5.4 | -0.080 | 552 | 520 | 259 | 596 | 331 | 451.6 | 451 | 74 | |
| 107 | 5.4 | -0.070 | 550 | 518 | 258 | 591 | 332 | 449.8 | 448 | 75 | |
| 108 | 5.3 | -0.070 | 547 | 515 | 257 | 585 | 332 | 447.2 | 447 | 75 | |
| 109 | 5.2 | -0.070 | 545 | 512 | 255 | 578 | 332 | 444.4 | 443 | 74 | |
| 110 | 5.2 | -0.070 | 543 | 510 | 252 | 573 | 332 | 442.0 | 441 | 74 | |
| 111 | 5.1 | -0.070 | 541 | 508 | 251 | 566 | 333 | 439.8 | 440 | 74 | |
| 112 | 5.0 | -0.080 | 539 | 506 | 250 | 562 | 333 | 438.0 | 438 | 74 | |
| 113 | 4.9 | -0.060 | 537 | 504 | 249 | 559 | 333 | 436.4 | 437 | 74 | |
| 114 | 4.9 | -0.070 | 534 | 502 | 248 | 555 | 333 | 434.4 | 435 | 74 | |
| 115 | 4.8 | -0.070 | 533 | 500 | 247 | 553 | 333 | 433.2 | 434 | 75 | |
| 116 | 4.7 | -0.060 | 531 | 498 | 247 | 549 | 334 | 431.8 | 434 | 75 | |
| 117 | 4.7 | -0.070 | 529 | 497 | 245 | 546 | 334 | 430.2 | 433 | 74 | |
| 118 | 4.6 | -0.080 | 528 | 495 | 246 | 542 | 334 | 429.0 | 430 | 74 | |
| 119 | 4.5 | -0.060 | 527 | 493 | 245 | 541 | 334 | 428.0 | 429 | 74 | |
| 120 | 4.5 | -0.050 | 525 | 492 | 244 | 539 | 334 | 426.8 | 429 | 75 | |
| 121 | 4.4 | -0.070 | 524 | 492 | 243 | 536 | 335 | 426.0 | 424 | 75 | |
| 122 | 4.4 | -0.060 | 523 | 490 | 242 | 530 | 335 | 424.0 | 418 | 75 | |
| 123 | 4.3 | -0.070 | 521 | 488 | 239 | 522 | 336 | 421.2 | 414 | 75 | |
| 124 | 4.3 | -0.060 | 520 | 487 | 239 | 517 | 336 | 419.8 | 410 | 74 | |

BOX A TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 0 | 0.000 | | 0.070 | 0.01 | 100 | -0.11 | | 26.0 | | 118 | 414 | 85 | 75 |
| 1 | 0.150 | 0.150 | 0.070 | 2.36 | 100 | -1.67 | 101 | 25.7 | -0.3 | 130 | 388 | 86 | 75 |
| 2 | 0.300 | 0.150 | 0.070 | 2.36 | 99 | -0.29 | 101 | 25.5 | -0.2 | 128 | 494 | 85 | 74 |
| 3 | 0.456 | 0.156 | 0.070 | 2.29 | 99 | -1.16 | 105 | 25.2 | -0.3 | 132 | 568 | 84 | 75 |
| 4 | 0.605 | 0.149 | 0.070 | 2.26 | 99 | -1.93 | 101 | 24.8 | -0.4 | 135 | 608 | 84 | 75 |
| 5 | 0.758 | 0.153 | 0.070 | 2.27 | 99 | -2.42 | 104 | 24.5 | -0.3 | 137 | 632 | 85 | 75 |
| 6 | 0.905 | 0.147 | 0.070 | 2.25 | 99 | -1.46 | 99 | 24.2 | -0.3 | 132 | 565 | 86 | 74 |
| 7 | 1.057 | 0.152 | 0.070 | 2.22 | 99 | -2.81 | 102 | 24.0 | -0.2 | 129 | 535 | 86 | 74 |
| 8 | 1.205 | 0.148 | 0.070 | 2.23 | 99 | -0.25 | 99 | 23.8 | -0.2 | 128 | 529 | 85 | 74 |
| 9 | 1.355 | 0.150 | 0.070 | 2.21 | 99 | -0.59 | 101 | 23.6 | -0.2 | 127 | 525 | 84 | 74 |
| 10 | 1.506 | 0.151 | 0.070 | 2.20 | 99 | -0.41 | 101 | 23.4 | -0.2 | 126 | 519 | 84 | 74 |
| 11 | 1.656 | 0.150 | 0.070 | 2.30 | 99 | -0.47 | 101 | 23.2 | -0.2 | 126 | 521 | 85 | 74 |
| 12 | 1.810 | 0.154 | 0.070 | 2.31 | 99 | -1.48 | 103 | 22.9 | -0.3 | 126 | 520 | 86 | 74 |
| 13 | 1.959 | 0.149 | 0.070 | 2.32 | 99 | -1.1 | 100 | 22.7 | -0.2 | 125 | 519 | 85 | 74 |
| 14 | 2.115 | 0.156 | 0.070 | 2.31 | 99 | -1.26 | 105 | 22.6 | -0.1 | 125 | 517 | 84 | 74 |
| 15 | 2.265 | 0.150 | 0.070 | 2.31 | 99 | -1.03 | 100 | 22.3 | -0.3 | 124 | 491 | 83 | 74 |
| 16 | 2.420 | 0.155 | 0.070 | 2.31 | 99 | -1.49 | 104 | 22.1 | -0.2 | 122 | 479 | 84 | 74 |
| 17 | 2.570 | 0.150 | 0.070 | 2.32 | 99 | -2.86 | 100 | 22.0 | -0.1 | 121 | 470 | 85 | 74 |
| 18 | 2.723 | 0.153 | 0.070 | 2.30 | 99 | -2.89 | 102 | 21.8 | -0.2 | 120 | 459 | 86 | 74 |
| 19 | 2.878 | 0.155 | 0.070 | 2.29 | 99 | -2.06 | 103 | 21.7 | -0.1 | 119 | 451 | 85 | 74 |
| 20 | 3.029 | 0.151 | 0.070 | 2.31 | 99 | -0.39 | 101 | 21.5 | -0.2 | 118 | 443 | 84 | 75 |
| 21 | 3.183 | 0.154 | 0.070 | 2.29 | 99 | -1.17 | 103 | 21.4 | -0.1 | 118 | 437 | 84 | 74 |
| 22 | 3.332 | 0.149 | 0.070 | 2.31 | 99 | -0.38 | 99 | 21.3 | -0.1 | 117 | 432 | 84 | 74 |
| 23 | 3.489 | 0.157 | 0.070 | 2.30 | 99 | -2.11 | 105 | 21.1 | -0.2 | 117 | 430 | 85 | 74 |
| 24 | 3.639 | 0.150 | 0.070 | 2.31 | 99 | -0.23 | 100 | 21.0 | -0.1 | 117 | 428 | 86 | 74 |
| 25 | 3.792 | 0.153 | 0.070 | 2.28 | 99 | -0.34 | 102 | 20.9 | -0.1 | 116 | 424 | 85 | 74 |
| 26 | 3.943 | 0.151 | 0.070 | 2.29 | 99 | -1.78 | 100 | 20.8 | -0.1 | 116 | 421 | 84 | 74 |
| 27 | 4.097 | 0.154 | 0.070 | 2.30 | 99 | -1.38 | 102 | 20.6 | -0.2 | 115 | 420 | 84 | 74 |
| 28 | 4.252 | 0.155 | 0.070 | 2.28 | 99 | -2.79 | 103 | 20.5 | -0.1 | 115 | 417 | 85 | 74 |
| 29 | 4.400 | 0.148 | 0.070 | 2.29 | 99 | -2.74 | 98 | 20.4 | -0.1 | 115 | 416 | 86 | 74 |
| 30 | 4.555 | 0.155 | 0.070 | 2.29 | 99 | -2.64 | 103 | 20.3 | -0.1 | 114 | 415 | 86 | 74 |
| 31 | 4.706 | 0.151 | 0.070 | 2.29 | 100 | -1.13 | 100 | 20.0 | -0.3 | 112 | 413 | 85 | 74 |
| 32 | 4.862 | 0.156 | 0.070 | 2.29 | 100 | -2.69 | 103 | 20.0 | 0 | 110 | 411 | 85 | 73 |

BOX A TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 33 | 5.011 | 0.149 | 0.070 | 2.30 | 100 | -2.34 | 98 | 19.9 | -0.1 | 108 | 409 | 84 | 74 |
| 34 | 5.164 | 0.153 | 0.070 | 2.31 | 100 | -2.4 | 101 | 19.7 | -0.2 | 107 | 405 | 85 | 75 |
| 35 | 5.318 | 0.154 | 0.070 | 2.30 | 100 | -2.08 | 101 | 19.7 | 0 | 107 | 401 | 86 | 75 |
| 36 | 5.470 | 0.152 | 0.070 | 2.29 | 100 | -2.88 | 100 | 19.5 | -0.2 | 107 | 399 | 86 | 74 |
| 37 | 5.624 | 0.154 | 0.070 | 2.32 | 100 | -2.84 | 101 | 19.4 | -0.1 | 106 | 396 | 85 | 74 |
| 38 | 5.773 | 0.149 | 0.070 | 2.29 | 100 | -0.23 | 98 | 19.3 | -0.1 | 106 | 395 | 84 | 74 |
| 39 | 5.930 | 0.157 | 0.070 | 2.29 | 100 | -2.94 | 103 | 19.1 | -0.2 | 106 | 394 | 84 | 74 |
| 40 | 6.080 | 0.150 | 0.070 | 2.30 | 100 | -2.94 | 99 | 18.9 | -0.2 | 106 | 392 | 84 | 74 |
| 41 | 6.234 | 0.154 | 0.070 | 2.32 | 100 | -0.23 | 101 | 19.0 | 0.1 | 106 | 393 | 86 | 74 |
| 42 | 6.385 | 0.151 | 0.070 | 2.29 | 100 | -1.41 | 99 | 18.8 | -0.2 | 106 | 394 | 86 | 74 |
| 43 | 6.538 | 0.153 | 0.070 | 2.30 | 100 | -2.65 | 101 | 18.6 | -0.2 | 106 | 395 | 85 | 73 |
| 44 | 6.692 | 0.154 | 0.070 | 2.29 | 100 | -0.65 | 101 | 18.5 | -0.1 | 106 | 395 | 84 | 74 |
| 45 | 6.842 | 0.150 | 0.070 | 2.29 | 100 | -0.22 | 99 | 18.4 | -0.1 | 105 | 393 | 84 | 73 |
| 46 | 6.997 | 0.155 | 0.070 | 2.31 | 100 | -0.28 | 102 | 18.3 | -0.1 | 105 | 393 | 85 | 73 |
| 47 | 7.147 | 0.150 | 0.070 | 2.29 | 100 | -2.94 | 99 | 18.1 | -0.2 | 105 | 392 | 86 | 73 |
| 48 | 7.303 | 0.156 | 0.070 | 2.30 | 100 | -2.07 | 103 | 18.0 | -0.1 | 105 | 392 | 86 | 74 |
| 49 | 7.453 | 0.150 | 0.070 | 2.29 | 100 | -0.29 | 99 | 17.8 | -0.2 | 104 | 391 | 85 | 73 |
| 50 | 7.606 | 0.153 | 0.070 | 2.29 | 100 | -2.41 | 101 | 17.8 | 0 | 104 | 391 | 84 | 74 |
| 51 | 7.760 | 0.154 | 0.070 | 2.31 | 100 | -2.49 | 101 | 17.7 | -0.1 | 104 | 392 | 84 | 73 |
| 52 | 7.912 | 0.152 | 0.070 | 2.30 | 100 | -2.52 | 100 | 17.5 | -0.2 | 104 | 394 | 85 | 74 |
| 53 | 8.066 | 0.154 | 0.070 | 2.30 | 100 | -0.24 | 101 | 17.4 | -0.1 | 104 | 394 | 86 | 74 |
| 54 | 8.215 | 0.149 | 0.070 | 2.29 | 100 | -0.48 | 98 | 17.3 | -0.1 | 104 | 395 | 86 | 74 |
| 55 | 8.371 | 0.156 | 0.070 | 2.28 | 101 | -2.77 | 102 | 17.1 | -0.2 | 105 | 395 | 85 | 73 |
| 56 | 8.521 | 0.150 | 0.070 | 2.28 | 101 | -0.69 | 98 | 17.0 | -0.1 | 105 | 394 | 84 | 74 |
| 57 | 8.675 | 0.154 | 0.070 | 2.28 | 101 | -1.34 | 101 | 16.9 | -0.1 | 105 | 393 | 84 | 74 |
| 58 | 8.826 | 0.151 | 0.070 | 2.29 | 101 | -0.17 | 99 | 16.8 | -0.1 | 105 | 393 | 85 | 74 |
| 59 | 8.979 | 0.153 | 0.070 | 2.28 | 101 | -2.48 | 100 | 16.7 | -0.1 | 104 | 392 | 86 | 74 |
| 60 | 9.133 | 0.154 | 0.070 | 2.29 | 101 | -0.87 | 101 | 16.4 | -0.3 | 104 | 390 | 86 | 74 |
| 61 | 9.294 | 0.161 | 0.070 | 2.52 | 101 | -1.52 | 106 | 16.4 | 0 | 104 | 390 | 85 | 73 |
| 62 | 9.453 | 0.159 | 0.070 | 2.25 | 101 | 0 | 104 | 16.3 | -0.1 | 104 | 389 | 84 | 74 |
| 63 | 9.602 | 0.149 | 0.070 | 2.26 | 101 | -1.33 | 98 | 16.3 | 0 | 103 | 387 | 85 | 74 |
| 64 | 9.754 | 0.152 | 0.070 | 2.26 | 101 | -2.26 | 100 | 16.1 | -0.2 | 103 | 386 | 86 | 73 |
| 65 | 9.904 | 0.150 | 0.070 | 2.24 | 101 | -1.68 | 98 | 16.0 | -0.1 | 103 | 384 | 85 | 73 |

BOX A TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 66 | 10.056 | 0.152 | 0.070 | 2.26 | 101 | -0.97 | 100 | 15.9 | -0.1 | 103 | 383 | 84 | 73 |
| 67 | 10.208 | 0.152 | 0.070 | 2.27 | 101 | -2.55 | 100 | 15.7 | -0.2 | 102 | 381 | 84 | 73 |
| 68 | 10.358 | 0.150 | 0.070 | 2.25 | 101 | -2.64 | 98 | 15.6 | -0.1 | 102 | 381 | 85 | 73 |
| 69 | 10.510 | 0.152 | 0.070 | 2.24 | 101 | -2.41 | 100 | 15.5 | -0.1 | 102 | 380 | 86 | 73 |
| 70 | 10.658 | 0.148 | 0.070 | 2.25 | 101 | 0 | 97 | 15.4 | -0.1 | 102 | 379 | 86 | 73 |
| 71 | 10.812 | 0.154 | 0.070 | 2.23 | 101 | -2.4 | 101 | 15.3 | -0.1 | 102 | 378 | 85 | 74 |
| 72 | 10.961 | 0.149 | 0.070 | 2.24 | 101 | -2.58 | 98 | 15.3 | 0 | 102 | 375 | 84 | 73 |
| 73 | 11.115 | 0.154 | 0.070 | 2.22 | 101 | -0.49 | 101 | 15.1 | -0.2 | 102 | 375 | 84 | 73 |
| 74 | 11.263 | 0.148 | 0.070 | 2.26 | 101 | -2.7 | 97 | 15.0 | -0.1 | 102 | 374 | 85 | 74 |
| 75 | 11.415 | 0.152 | 0.070 | 2.22 | 101 | -2.75 | 100 | 14.9 | -0.1 | 102 | 375 | 86 | 73 |
| 76 | 11.565 | 0.150 | 0.070 | 2.23 | 101 | -0.41 | 98 | 14.8 | -0.1 | 102 | 375 | 86 | 74 |
| 77 | 11.717 | 0.152 | 0.070 | 2.25 | 101 | -2.62 | 100 | 14.6 | -0.2 | 102 | 375 | 85 | 73 |
| 78 | 11.869 | 0.152 | 0.070 | 2.24 | 101 | -1.44 | 100 | 14.4 | -0.2 | 102 | 376 | 84 | 73 |
| 79 | 12.019 | 0.150 | 0.070 | 2.21 | 101 | 0 | 98 | 14.4 | 0 | 102 | 376 | 84 | 74 |
| 80 | 12.171 | 0.152 | 0.070 | 2.26 | 101 | 0 | 100 | 14.3 | -0.1 | 102 | 375 | 85 | 73 |
| 81 | 12.319 | 0.148 | 0.070 | 2.25 | 101 | -0.75 | 97 | 14.2 | -0.1 | 102 | 376 | 86 | 73 |
| 82 | 12.473 | 0.154 | 0.070 | 2.22 | 101 | -1.23 | 101 | 14.1 | -0.1 | 102 | 376 | 86 | 73 |
| 83 | 12.621 | 0.148 | 0.070 | 2.23 | 101 | 0 | 97 | 14.0 | -0.1 | 101 | 377 | 85 | 73 |
| 84 | 12.775 | 0.154 | 0.070 | 2.24 | 101 | 0 | 101 | 13.9 | -0.1 | 101 | 375 | 84 | 73 |
| 85 | 12.924 | 0.149 | 0.070 | 2.22 | 101 | -2.4 | 97 | 13.8 | -0.1 | 101 | 373 | 84 | 73 |
| 86 | 13.076 | 0.152 | 0.070 | 2.25 | 101 | -2.67 | 99 | 13.7 | -0.1 | 101 | 372 | 85 | 73 |
| 87 | 13.225 | 0.149 | 0.070 | 2.23 | 101 | 0 | 97 | 13.5 | -0.2 | 101 | 371 | 86 | 73 |
| 88 | 13.377 | 0.152 | 0.070 | 2.26 | 101 | -2.56 | 99 | 13.4 | -0.1 | 101 | 369 | 86 | 73 |
| 89 | 13.530 | 0.153 | 0.070 | 2.23 | 101 | 0 | 100 | 13.3 | -0.1 | 101 | 368 | 85 | 74 |
| 90 | 13.679 | 0.149 | 0.070 | 2.23 | 101 | -2.57 | 97 | 13.1 | -0.2 | 101 | 368 | 84 | 73 |
| 91 | 13.832 | 0.153 | 0.070 | 2.23 | 101 | -0.66 | 100 | 13.1 | 0 | 102 | 369 | 85 | 73 |
| 92 | 13.979 | 0.147 | 0.070 | 2.24 | 101 | -2.47 | 96 | 13.0 | -0.1 | 102 | 370 | 85 | 74 |
| 93 | 14.132 | 0.153 | 0.070 | 2.23 | 101 | 0 | 100 | 12.9 | -0.1 | 102 | 372 | 86 | 73 |
| 94 | 14.281 | 0.149 | 0.070 | 2.23 | 101 | 0 | 98 | 12.8 | -0.1 | 102 | 374 | 85 | 73 |
| 95 | 14.435 | 0.154 | 0.070 | 2.24 | 101 | -0.1 | 101 | 12.7 | -0.1 | 102 | 374 | 84 | 73 |
| 96 | 14.583 | 0.148 | 0.070 | 2.22 | 101 | -2.68 | 97 | 12.6 | -0.1 | 102 | 379 | 84 | 73 |
| 97 | 14.735 | 0.152 | 0.070 | 2.24 | 101 | 0 | 100 | 12.4 | -0.2 | 102 | 385 | 85 | 73 |
| 98 | 14.884 | 0.149 | 0.070 | 2.21 | 101 | -1.2 | 98 | 12.3 | -0.1 | 102 | 384 | 86 | 73 |

BOX A TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 99 | 15.035 | 0.151 | 0.070 | 2.22 | 101 | -1.24 | 99 | 12.2 | -0.1 | 102 | 383 | 86 | 73 |
| 100 | 15.185 | 0.150 | 0.070 | 2.22 | 101 | -1.73 | 98 | 12.1 | -0.1 | 101 | 380 | 85 | 74 |
| 101 | 15.336 | 0.151 | 0.070 | 2.21 | 101 | -1.43 | 99 | 12.0 | -0.1 | 101 | 377 | 84 | 74 |
| 102 | 15.487 | 0.151 | 0.070 | 2.20 | 101 | 0 | 99 | 11.9 | -0.1 | 101 | 374 | 84 | 73 |
| 103 | 15.636 | 0.149 | 0.070 | 2.20 | 101 | -2.63 | 98 | 11.8 | -0.1 | 102 | 368 | 85 | 73 |
| 104 | 15.787 | 0.151 | 0.070 | 2.22 | 101 | -1.94 | 99 | 11.7 | -0.1 | 102 | 363 | 86 | 74 |
| 105 | 15.935 | 0.148 | 0.070 | 2.20 | 101 | -2.55 | 97 | 11.6 | -0.1 | 102 | 359 | 85 | 73 |
| 106 | 16.087 | 0.152 | 0.070 | 2.20 | 101 | -2.65 | 100 | 11.5 | -0.1 | 102 | 355 | 84 | 73 |
| 107 | 16.235 | 0.148 | 0.070 | 2.22 | 101 | 0 | 97 | 11.4 | -0.1 | 103 | 352 | 84 | 73 |
| 108 | 16.389 | 0.154 | 0.070 | 2.21 | 101 | -2.74 | 101 | 11.3 | -0.1 | 103 | 349 | 84 | 73 |
| 109 | 16.536 | 0.147 | 0.070 | 2.22 | 101 | -2.09 | 96 | 11.3 | 0 | 103 | 345 | 86 | 74 |
| 110 | 16.689 | 0.153 | 0.070 | 2.27 | 101 | -0.14 | 100 | 11.2 | -0.1 | 104 | 343 | 86 | 74 |
| 111 | 16.839 | 0.150 | 0.070 | 2.29 | 101 | -0.07 | 98 | 11.1 | -0.1 | 104 | 340 | 86 | 74 |
| 112 | 16.991 | 0.152 | 0.070 | 2.26 | 101 | -0.57 | 100 | 11.1 | 0 | 104 | 337 | 84 | 74 |
| 113 | 17.145 | 0.154 | 0.070 | 2.27 | 101 | -2.67 | 101 | 10.9 | -0.2 | 104 | 335 | 84 | 73 |
| 114 | 17.296 | 0.151 | 0.070 | 2.26 | 101 | -0.47 | 99 | 10.9 | 0 | 104 | 333 | 85 | 74 |
| 115 | 17.449 | 0.153 | 0.070 | 2.27 | 101 | -2.28 | 100 | 10.8 | -0.1 | 104 | 330 | 86 | 74 |
| 116 | 17.597 | 0.148 | 0.070 | 2.27 | 101 | -0.57 | 97 | 10.8 | 0 | 104 | 328 | 86 | 74 |
| 117 | 17.753 | 0.156 | 0.070 | 2.27 | 101 | -2.71 | 102 | 10.7 | -0.1 | 104 | 327 | 85 | 73 |
| 118 | 17.902 | 0.149 | 0.070 | 2.26 | 101 | -1.09 | 98 | 10.6 | -0.1 | 104 | 325 | 84 | 74 |
| 119 | 18.056 | 0.154 | 0.070 | 2.25 | 101 | -2.33 | 101 | 10.5 | -0.1 | 104 | 324 | 84 | 74 |
| 120 | 18.205 | 0.149 | 0.070 | 2.25 | 101 | -0.72 | 98 | 10.5 | 0 | 104 | 321 | 85 | 74 |
| 121 | 18.358 | 0.153 | 0.070 | 2.26 | 101 | -2.19 | 100 | 10.4 | -0.1 | 104 | 320 | 86 | 74 |
| 122 | 18.511 | 0.153 | 0.070 | 2.25 | 101 | -1.62 | 100 | 10.3 | -0.1 | 104 | 320 | 86 | 74 |
| 123 | 18.662 | 0.151 | 0.070 | 2.27 | 101 | -2.2 | 99 | 10.2 | -0.1 | 104 | 319 | 85 | 74 |
| 124 | 18.815 | 0.153 | 0.070 | 2.25 | 101 | -2.65 | 100 | 10.2 | 0 | 104 | 318 | 84 | 74 |
| 125 | 18.964 | 0.149 | 0.070 | 2.26 | 101 | -1.27 | 98 | 10.1 | -0.1 | 105 | 316 | 84 | 74 |
| 126 | 19.118 | 0.154 | 0.070 | 2.26 | 102 | -0.43 | 101 | 10.0 | -0.1 | 105 | 315 | 85 | 74 |
| 127 | 19.267 | 0.149 | 0.070 | 2.22 | 102 | -2.23 | 98 | 10.0 | 0 | 104 | 314 | 86 | 74 |
| 128 | 19.422 | 0.155 | 0.070 | 2.25 | 102 | -1.47 | 102 | 9.9 | -0.1 | 105 | 313 | 85 | 74 |
| 129 | 19.571 | 0.149 | 0.070 | 2.26 | 102 | -0.22 | 98 | 9.8 | -0.1 | 105 | 312 | 84 | 74 |
| 130 | 19.723 | 0.152 | 0.070 | 2.27 | 102 | -0.01 | 100 | 9.7 | -0.1 | 105 | 311 | 84 | 74 |
| 131 | 19.873 | 0.150 | 0.070 | 2.24 | 102 | -2.47 | 98 | 9.7 | 0 | 105 | 310 | 85 | 73 |

BOX A TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 132 | 20.026 | 0.153 | 0.070 | 2.25 | 102 | -0.33 | 100 | 9.6 | -0.1 | 104 | 310 | 86 | 74 |
| 133 | 20.179 | 0.153 | 0.070 | 2.23 | 102 | -1.27 | 100 | 9.5 | -0.1 | 105 | 308 | 86 | 74 |
| 134 | 20.328 | 0.149 | 0.070 | 2.24 | 102 | -1.4 | 98 | 9.4 | -0.1 | 105 | 306 | 85 | 74 |
| 135 | 20.481 | 0.153 | 0.070 | 2.25 | 102 | 0 | 100 | 9.4 | 0 | 105 | 302 | 84 | 74 |
| 136 | 20.629 | 0.148 | 0.070 | 2.24 | 102 | -1.3 | 97 | 9.4 | 0 | 104 | 300 | 84 | 74 |
| 137 | 20.784 | 0.155 | 0.070 | 2.23 | 102 | -0.45 | 102 | 9.3 | -0.1 | 104 | 297 | 85 | 74 |
| 138 | 20.933 | 0.149 | 0.070 | 2.24 | 102 | -0.43 | 98 | 9.2 | -0.1 | 104 | 295 | 86 | 73 |
| 139 | 21.087 | 0.154 | 0.070 | 2.24 | 102 | -2.72 | 101 | 9.2 | 0 | 104 | 293 | 86 | 74 |
| 140 | 21.236 | 0.149 | 0.070 | 2.26 | 102 | -0.2 | 98 | 9.2 | 0 | 104 | 291 | 85 | 74 |
| 141 | 21.388 | 0.152 | 0.070 | 2.26 | 102 | -2.82 | 100 | 9.1 | -0.1 | 104 | 289 | 84 | 74 |
| 142 | 21.541 | 0.153 | 0.070 | 2.24 | 102 | -0.9 | 100 | 9.0 | -0.1 | 104 | 287 | 84 | 74 |
| 143 | 21.692 | 0.151 | 0.070 | 2.26 | 102 | -2.75 | 99 | 9.0 | 0 | 104 | 287 | 85 | 74 |
| 144 | 21.845 | 0.153 | 0.070 | 2.25 | 102 | -0.08 | 100 | 8.9 | -0.1 | 104 | 285 | 86 | 74 |
| 145 | 21.994 | 0.149 | 0.070 | 2.27 | 102 | -1.54 | 98 | 8.8 | -0.1 | 104 | 284 | 86 | 74 |
| 146 | 22.147 | 0.153 | 0.070 | 2.26 | 102 | -2.35 | 100 | 8.8 | 0 | 104 | 283 | 85 | 73 |
| 147 | 22.297 | 0.150 | 0.070 | 2.24 | 102 | -1.14 | 98 | 8.7 | -0.1 | 104 | 283 | 84 | 74 |
| 148 | 22.451 | 0.154 | 0.070 | 2.25 | 102 | -1.48 | 101 | 8.7 | 0 | 104 | 282 | 84 | 74 |
| 149 | 22.601 | 0.150 | 0.070 | 2.25 | 102 | -2.73 | 98 | 8.6 | -0.1 | 104 | 282 | 86 | 74 |
| 150 | 22.753 | 0.152 | 0.070 | 2.25 | 102 | -0.17 | 100 | 8.6 | 0 | 104 | 282 | 86 | 74 |
| 151 | 22.904 | 0.151 | 0.070 | 2.24 | 102 | -2.61 | 99 | 8.5 | -0.1 | 104 | 281 | 86 | 74 |
| 152 | 23.057 | 0.153 | 0.070 | 2.24 | 102 | -1.85 | 100 | 8.5 | 0 | 104 | 281 | 85 | 74 |
| 153 | 23.210 | 0.153 | 0.070 | 2.24 | 102 | -2.74 | 100 | 8.3 | -0.2 | 104 | 280 | 84 | 75 |
| 154 | 23.358 | 0.148 | 0.070 | 2.25 | 102 | -0.22 | 97 | 8.4 | 0.1 | 104 | 280 | 84 | 74 |
| 155 | 23.512 | 0.154 | 0.070 | 2.28 | 102 | -0.18 | 101 | 8.3 | -0.1 | 104 | 279 | 85 | 74 |
| 156 | 23.661 | 0.149 | 0.070 | 2.25 | 102 | -0.15 | 98 | 8.3 | 0 | 104 | 278 | 86 | 74 |
| 157 | 23.817 | 0.156 | 0.070 | 2.24 | 102 | -2.17 | 102 | 8.2 | -0.1 | 103 | 278 | 86 | 74 |
| 158 | 23.966 | 0.149 | 0.070 | 2.25 | 102 | -0.34 | 97 | 8.1 | -0.1 | 103 | 277 | 85 | 74 |
| 159 | 24.119 | 0.153 | 0.070 | 2.25 | 102 | -1.49 | 100 | 8.1 | 0 | 103 | 278 | 84 | 74 |
| 160 | 24.269 | 0.150 | 0.070 | 2.24 | 102 | -2.12 | 98 | 8.0 | -0.1 | 102 | 277 | 84 | 74 |
| 161 | 24.422 | 0.153 | 0.070 | 2.26 | 102 | -2.25 | 100 | 8.1 | 0.1 | 102 | 277 | 85 | 74 |
| 162 | 24.574 | 0.152 | 0.070 | 2.26 | 102 | -1.88 | 99 | 8.0 | -0.1 | 102 | 276 | 86 | 74 |
| 163 | 24.724 | 0.150 | 0.070 | 2.26 | 102 | -2.28 | 98 | 7.9 | -0.1 | 102 | 276 | 86 | 74 |
| 164 | 24.877 | 0.153 | 0.070 | 2.25 | 102 | -0.01 | 100 | 7.8 | -0.1 | 103 | 276 | 85 | 74 |

BOX A TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 165 | 25.026 | 0.149 | 0.070 | 2.26 | 102 | -0.8 | 97 | 7.8 | 0 | 103 | 275 | 84 | 74 |
| 166 | 25.181 | 0.155 | 0.070 | 2.25 | 102 | -2.39 | 101 | 7.7 | -0.1 | 103 | 274 | 84 | 74 |
| 167 | 25.330 | 0.149 | 0.070 | 2.24 | 102 | -2.46 | 97 | 7.7 | 0 | 103 | 273 | 85 | 74 |
| 168 | 25.484 | 0.154 | 0.070 | 2.24 | 102 | -1.91 | 101 | 7.6 | -0.1 | 102 | 271 | 86 | 74 |
| 169 | 25.633 | 0.149 | 0.070 | 2.25 | 102 | -2.74 | 97 | 7.6 | 0 | 102 | 270 | 86 | 74 |
| 170 | 25.785 | 0.152 | 0.070 | 2.24 | 102 | -2.59 | 99 | 7.5 | -0.1 | 101 | 268 | 85 | 74 |
| 171 | 25.938 | 0.153 | 0.070 | 2.25 | 102 | -1.61 | 100 | 7.6 | 0.1 | 101 | 267 | 84 | 74 |
| 172 | 26.089 | 0.151 | 0.070 | 2.25 | 102 | -1.6 | 99 | 7.5 | -0.1 | 101 | 262 | 84 | 74 |
| 173 | 26.242 | 0.153 | 0.070 | 2.24 | 102 | 0 | 100 | 7.4 | -0.1 | 101 | 256 | 85 | 74 |
| 174 | 26.390 | 0.148 | 0.070 | 2.22 | 102 | -2.62 | 97 | 7.4 | 0 | 101 | 252 | 86 | 74 |
| 175 | 26.543 | 0.153 | 0.070 | 2.20 | 102 | -0.01 | 100 | 7.3 | -0.1 | 101 | 250 | 86 | 74 |
| 176 | 26.690 | 0.147 | 0.070 | 2.20 | 102 | -2.16 | 96 | 7.3 | 0 | 102 | 249 | 86 | 74 |
| 177 | 26.844 | 0.154 | 0.070 | 2.18 | 102 | -0.24 | 101 | 7.2 | -0.1 | 102 | 246 | 85 | 74 |
| 178 | 26.990 | 0.146 | 0.070 | 2.14 | 102 | -2.84 | 95 | 7.2 | 0 | 102 | 244 | 84 | 74 |
| 179 | 27.140 | 0.150 | 0.070 | 2.11 | 102 | -1.94 | 98 | 7.2 | 0 | 101 | 241 | 85 | 74 |
| 180 | 27.285 | 0.145 | 0.070 | 2.08 | 102 | -0.25 | 95 | 7.1 | -0.1 | 101 | 240 | 86 | 74 |
| 181 | 27.433 | 0.148 | 0.070 | 2.04 | 103 | -1.71 | 96 | 7.0 | -0.1 | 100 | 238 | 86 | 74 |
| 182 | 27.575 | 0.142 | 0.070 | 1.99 | 103 | -2.98 | 92 | 7.0 | 0 | 100 | 235 | 86 | 74 |
| 183 | 27.720 | 0.145 | 0.070 | 1.97 | 103 | -1.61 | 94 | 6.9 | -0.1 | 100 | 233 | 85 | 74 |
| 184 | 27.859 | 0.139 | 0.070 | 1.98 | 103 | -1.99 | 91 | 7.0 | 0.1 | 100 | 232 | 84 | 74 |
| 185 | 28.003 | 0.144 | 0.070 | 1.94 | 103 | -0.51 | 94 | 6.8 | -0.2 | 100 | 230 | 84 | 74 |
| 186 | 28.143 | 0.140 | 0.070 | 1.91 | 103 | -0.66 | 91 | 6.8 | 0 | 100 | 227 | 85 | 74 |
| 187 | 28.284 | 0.141 | 0.070 | 1.90 | 103 | -3.19 | 92 | 6.8 | 0 | 100 | 226 | 86 | 74 |
| 188 | 28.423 | 0.139 | 0.070 | 1.88 | 103 | -3.07 | 91 | 6.8 | 0 | 100 | 224 | 86 | 74 |
| 189 | 28.562 | 0.139 | 0.070 | 1.88 | 103 | -0.95 | 91 | 6.7 | -0.1 | 100 | 223 | 85 | 74 |
| 190 | 28.703 | 0.141 | 0.070 | 1.87 | 103 | -0.63 | 92 | 6.6 | -0.1 | 100 | 224 | 84 | 74 |
| 191 | 28.838 | 0.135 | 0.070 | 1.86 | 103 | -0.71 | 88 | 6.7 | 0.1 | 100 | 225 | 85 | 74 |
| 192 | 28.980 | 0.142 | 0.070 | 1.84 | 103 | -2.83 | 92 | 6.6 | -0.1 | 99 | 225 | 86 | 74 |
| 193 | 29.116 | 0.136 | 0.070 | 1.84 | 103 | -0.7 | 89 | 6.6 | 0 | 99 | 228 | 86 | 74 |
| 194 | 29.253 | 0.137 | 0.070 | 1.83 | 103 | -0.77 | 89 | 6.4 | -0.2 | 99 | 229 | 86 | 74 |
| 195 | 29.394 | 0.141 | 0.070 | 1.85 | 103 | -1.77 | 92 | 6.4 | 0 | 99 | 230 | 85 | 74 |
| 196 | 29.529 | 0.135 | 0.070 | 1.83 | 103 | -3.34 | 88 | 6.4 | 0 | 99 | 231 | 84 | 74 |
| 197 | 29.669 | 0.140 | 0.070 | 1.84 | 103 | -0.88 | 91 | 6.3 | -0.1 | 99 | 231 | 84 | 74 |

BOX A TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 198 | 29.805 | 0.136 | 0.070 | 1.83 | 103 | -1.43 | 89 | 6.3 | 0 | 99 | 231 | 85 | 74 |
| 199 | 29.943 | 0.138 | 0.070 | 1.84 | 103 | -1.18 | 90 | 6.2 | -0.1 | 100 | 233 | 86 | 74 |
| 200 | 30.080 | 0.137 | 0.070 | 1.82 | 103 | -1.12 | 89 | 6.2 | 0 | 100 | 233 | 86 | 74 |
| 201 | 30.217 | 0.137 | 0.070 | 1.83 | 103 | -1.41 | 89 | 6.2 | 0 | 100 | 234 | 85 | 74 |
| 202 | 30.356 | 0.139 | 0.070 | 1.83 | 103 | -0.65 | 91 | 6.2 | 0 | 100 | 234 | 84 | 74 |
| 203 | 30.491 | 0.135 | 0.070 | 1.82 | 103 | -1.32 | 88 | 6.1 | -0.1 | 99 | 230 | 84 | 74 |
| 204 | 30.629 | 0.138 | 0.070 | 1.79 | 103 | -2.45 | 90 | 6.0 | -0.1 | 99 | 229 | 85 | 74 |
| 205 | 30.765 | 0.136 | 0.070 | 1.76 | 103 | -2.26 | 88 | 5.9 | -0.1 | 98 | 228 | 86 | 74 |
| 206 | 30.900 | 0.135 | 0.070 | 1.80 | 103 | -0.8 | 88 | 5.9 | 0 | 98 | 227 | 86 | 74 |
| 207 | 31.037 | 0.137 | 0.070 | 1.79 | 103 | -1.47 | 89 | 5.9 | 0 | 98 | 226 | 85 | 74 |
| 208 | 31.172 | 0.135 | 0.070 | 1.77 | 103 | -1.04 | 88 | 5.9 | 0 | 98 | 225 | 84 | 74 |
| 209 | 31.306 | 0.134 | 0.070 | 1.77 | 103 | -3.01 | 87 | 5.7 | -0.2 | 99 | 224 | 85 | 74 |
| 210 | 31.445 | 0.139 | 0.070 | 1.78 | 103 | -3.38 | 90 | 5.8 | 0.1 | 99 | 223 | 86 | 74 |
| 211 | 31.576 | 0.131 | 0.070 | 1.77 | 103 | -3.32 | 85 | 5.8 | 0 | 99 | 221 | 87 | 74 |
| 212 | 31.715 | 0.139 | 0.070 | 1.76 | 103 | -1.06 | 90 | 5.7 | -0.1 | 99 | 220 | 86 | 74 |
| 213 | 31.849 | 0.134 | 0.070 | 1.78 | 103 | -2.55 | 87 | 5.7 | 0 | 99 | 219 | 85 | 74 |
| 214 | 31.998 | 0.149 | 0.070 | 2.25 | 103 | -2.83 | 97 | 5.7 | 0 | 99 | 218 | 84 | 74 |
| 215 | 32.149 | 0.151 | 0.070 | 2.25 | 103 | -1.32 | 98 | 5.7 | 0 | 98 | 217 | 85 | 74 |
| 216 | 32.302 | 0.153 | 0.070 | 2.24 | 103 | -2.58 | 99 | 5.7 | 0 | 98 | 217 | 86 | 74 |
| 217 | 32.451 | 0.149 | 0.070 | 2.24 | 103 | -2.89 | 97 | 5.6 | -0.1 | 98 | 215 | 86 | 74 |
| 218 | 32.604 | 0.153 | 0.070 | 2.22 | 103 | -3.22 | 99 | 5.6 | 0 | 98 | 214 | 85 | 74 |
| 219 | 32.754 | 0.150 | 0.070 | 2.24 | 103 | -3.79 | 98 | 5.6 | 0 | 98 | 213 | 84 | 74 |
| 220 | 32.908 | 0.154 | 0.070 | 2.23 | 103 | -2.22 | 100 | 5.5 | -0.1 | 98 | 213 | 84 | 74 |
| 221 | 33.057 | 0.149 | 0.070 | 2.22 | 103 | -3.77 | 97 | 5.5 | 0 | 98 | 212 | 85 | 74 |
| 222 | 33.208 | 0.151 | 0.070 | 2.22 | 103 | -3.83 | 98 | 5.5 | 0 | 98 | 211 | 86 | 74 |
| 223 | 33.358 | 0.150 | 0.070 | 2.22 | 103 | -1.77 | 98 | 5.5 | 0 | 99 | 210 | 86 | 74 |
| 224 | 33.510 | 0.152 | 0.070 | 2.22 | 103 | -1.37 | 99 | 5.4 | -0.1 | 98 | 209 | 86 | 74 |
| 225 | 33.662 | 0.152 | 0.070 | 2.21 | 103 | -3.84 | 99 | 5.4 | 0 | 98 | 209 | 84 | 74 |
| 226 | 33.811 | 0.149 | 0.070 | 2.19 | 103 | -1.28 | 97 | 5.4 | 0 | 97 | 209 | 84 | 74 |
| 227 | 33.963 | 0.152 | 0.070 | 2.21 | 103 | -3.82 | 99 | 5.4 | 0 | 97 | 209 | 85 | 74 |
| 228 | 34.110 | 0.147 | 0.070 | 2.18 | 103 | -2.12 | 95 | 5.4 | 0 | 97 | 208 | 86 | 74 |
| 229 | 34.263 | 0.153 | 0.070 | 2.20 | 103 | -3.77 | 99 | 5.3 | -0.1 | 97 | 207 | 86 | 74 |
| 230 | 34.410 | 0.147 | 0.070 | 2.19 | 103 | -3.59 | 96 | 5.4 | 0.1 | 98 | 207 | 86 | 74 |

BOX A TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 231 | 34.564 | 0.154 | 0.070 | 2.17 | 103 | -2.81 | 100 | 5.3 | -0.1 | 98 | 207 | 85 | 74 |
| 232 | 34.711 | 0.147 | 0.070 | 2.18 | 103 | -1.61 | 96 | 5.2 | -0.1 | 98 | 206 | 84 | 74 |
| 233 | 34.863 | 0.152 | 0.070 | 2.17 | 103 | -3.99 | 99 | 5.2 | 0 | 98 | 206 | 84 | 74 |
| 234 | 35.010 | 0.147 | 0.070 | 2.17 | 103 | -2.31 | 96 | 5.3 | 0.1 | 98 | 205 | 85 | 74 |
| 235 | 35.160 | 0.150 | 0.070 | 2.15 | 103 | -2.41 | 98 | 5.2 | -0.1 | 98 | 204 | 86 | 74 |
| 236 | 35.307 | 0.147 | 0.070 | 2.15 | 103 | -1.93 | 96 | 5.1 | -0.1 | 98 | 204 | 86 | 74 |
| 237 | 35.457 | 0.150 | 0.070 | 2.16 | 103 | -3.88 | 98 | 5.1 | 0 | 99 | 203 | 84 | 74 |
| 238 | 35.604 | 0.147 | 0.070 | 2.15 | 103 | -2.17 | 96 | 5.1 | 0 | 99 | 203 | 84 | 74 |
| 239 | 35.753 | 0.149 | 0.070 | 2.14 | 103 | -3.96 | 97 | 5.1 | 0 | 99 | 203 | 84 | 75 |
| 240 | 35.901 | 0.148 | 0.070 | 2.11 | 103 | -4 | 96 | 5.1 | 0 | 99 | 202 | 85 | 74 |
| 241 | 36.051 | 0.150 | 0.070 | 2.28 | 103 | -1.71 | 98 | 5.0 | -0.1 | 99 | 202 | 86 | 74 |
| 242 | 36.205 | 0.154 | 0.070 | 2.24 | 103 | -1.87 | 100 | 5.0 | 0 | 98 | 203 | 86 | 74 |
| 243 | 36.355 | 0.150 | 0.070 | 2.25 | 103 | -1.79 | 97 | 5.0 | 0 | 97 | 202 | 85 | 74 |
| 244 | 36.508 | 0.153 | 0.070 | 2.26 | 103 | -3.96 | 99 | 5.0 | 0 | 97 | 202 | 84 | 74 |
| 245 | 36.657 | 0.149 | 0.070 | 2.24 | 103 | -3.06 | 97 | 4.9 | -0.1 | 97 | 201 | 84 | 74 |
| 246 | 36.813 | 0.156 | 0.070 | 2.25 | 103 | -1.67 | 101 | 4.9 | 0 | 97 | 201 | 85 | 74 |
| 247 | 36.961 | 0.148 | 0.070 | 2.25 | 103 | -4.1 | 96 | 4.9 | 0 | 97 | 202 | 86 | 74 |
| 248 | 37.115 | 0.154 | 0.070 | 2.24 | 103 | -1.77 | 100 | 4.9 | 0 | 98 | 202 | 86 | 74 |
| 249 | 37.264 | 0.149 | 0.070 | 2.25 | 103 | -1.63 | 97 | 4.8 | -0.1 | 98 | 203 | 85 | 74 |
| 250 | 37.415 | 0.151 | 0.070 | 2.23 | 103 | -4.05 | 98 | 4.8 | 0 | 98 | 203 | 84 | 74 |
| 251 | 37.568 | 0.153 | 0.070 | 2.23 | 103 | -4.2 | 99 | 4.8 | 0 | 98 | 205 | 84 | 74 |
| 252 | 37.718 | 0.150 | 0.070 | 2.24 | 103 | -1.8 | 98 | 4.7 | -0.1 | 98 | 205 | 85 | 74 |
| 253 | 37.871 | 0.153 | 0.070 | 2.22 | 103 | -2.49 | 99 | 4.7 | 0 | 98 | 205 | 86 | 74 |
| 254 | 38.019 | 0.148 | 0.070 | 2.21 | 103 | -2.9 | 96 | 4.7 | 0 | 97 | 205 | 86 | 74 |
| 255 | 38.173 | 0.154 | 0.070 | 2.21 | 103 | -3.79 | 100 | 4.7 | 0 | 97 | 206 | 86 | 74 |
| 256 | 38.321 | 0.148 | 0.070 | 2.23 | 103 | -1.69 | 96 | 4.7 | 0 | 97 | 207 | 85 | 74 |
| 257 | 38.476 | 0.155 | 0.070 | 2.22 | 103 | -4.23 | 101 | 4.7 | 0 | 97 | 207 | 84 | 74 |
| 258 | 38.625 | 0.149 | 0.070 | 2.21 | 103 | -3.1 | 97 | 4.6 | -0.1 | 97 | 208 | 85 | 74 |
| 259 | 38.777 | 0.152 | 0.070 | 2.23 | 103 | -3.54 | 99 | 4.6 | 0 | 97 | 208 | 86 | 74 |
| 260 | 38.926 | 0.149 | 0.070 | 2.23 | 103 | -3.81 | 97 | 4.6 | 0 | 97 | 208 | 86 | 74 |
| 261 | 39.078 | 0.152 | 0.070 | 2.24 | 103 | -3.93 | 99 | 4.6 | 0 | 98 | 209 | 85 | 75 |
| 262 | 39.231 | 0.153 | 0.070 | 2.23 | 103 | -4.17 | 99 | 4.6 | 0 | 98 | 210 | 84 | 74 |
| 263 | 39.381 | 0.150 | 0.070 | 2.22 | 103 | -3.92 | 98 | 4.6 | 0 | 98 | 211 | 84 | 74 |

BOX A TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 264 | 39.534 | 0.153 | 0.070 | 2.25 | 103 | -1.74 | 99 | 4.5 | -0.1 | 98 | 212 | 84 | 74 |
| 265 | 39.683 | 0.149 | 0.070 | 2.26 | 103 | -1.75 | 97 | 4.5 | 0 | 98 | 212 | 86 | 74 |
| 266 | 39.837 | 0.154 | 0.070 | 2.23 | 103 | -2.01 | 100 | 4.5 | 0 | 97 | 213 | 86 | 74 |
| 267 | 39.987 | 0.150 | 0.070 | 2.25 | 103 | -1.74 | 97 | 4.4 | -0.1 | 97 | 214 | 86 | 74 |
| 268 | 40.142 | 0.155 | 0.070 | 2.25 | 103 | -1.74 | 101 | 4.4 | 0 | 97 | 214 | 85 | 74 |
| 269 | 40.290 | 0.148 | 0.070 | 2.23 | 103 | -4.01 | 96 | 4.4 | 0 | 97 | 214 | 84 | 74 |
| 270 | 40.443 | 0.153 | 0.070 | 2.25 | 103 | -1.68 | 99 | 4.4 | 0 | 97 | 215 | 84 | 74 |
| 271 | 40.595 | 0.152 | 0.070 | 2.25 | 103 | -2.99 | 99 | 4.4 | 0 | 97 | 215 | 85 | 74 |
| 272 | 40.747 | 0.152 | 0.070 | 2.24 | 103 | -4.18 | 99 | 4.3 | -0.1 | 97 | 214 | 86 | 74 |
| 273 | 40.901 | 0.154 | 0.070 | 2.24 | 103 | -4.02 | 100 | 4.3 | 0 | 98 | 214 | 86 | 74 |
| 274 | 41.049 | 0.148 | 0.070 | 2.23 | 103 | -1.6 | 96 | 4.3 | 0 | 98 | 213 | 85 | 74 |
| 275 | 41.203 | 0.154 | 0.070 | 2.25 | 103 | -3.16 | 100 | 4.3 | 0 | 98 | 213 | 84 | 74 |
| 276 | 41.353 | 0.150 | 0.070 | 2.24 | 103 | -4.2 | 98 | 4.3 | 0 | 98 | 213 | 85 | 74 |
| 277 | 41.508 | 0.155 | 0.070 | 2.25 | 103 | -4.13 | 101 | 4.3 | 0 | 98 | 212 | 86 | 74 |
| 278 | 41.657 | 0.149 | 0.070 | 2.25 | 103 | -2.25 | 97 | 4.2 | -0.1 | 98 | 212 | 86 | 74 |
| 279 | 41.810 | 0.153 | 0.070 | 2.26 | 103 | -4.1 | 99 | 4.2 | 0 | 97 | 211 | 86 | 74 |
| 280 | 41.962 | 0.152 | 0.070 | 2.26 | 103 | -3.75 | 99 | 4.2 | 0 | 97 | 210 | 85 | 74 |
| 281 | 42.114 | 0.152 | 0.070 | 2.24 | 103 | -1.64 | 99 | 4.2 | 0 | 97 | 209 | 84 | 74 |
| 282 | 42.269 | 0.155 | 0.070 | 2.27 | 103 | -3.98 | 101 | 4.2 | 0 | 97 | 209 | 85 | 74 |
| 283 | 42.418 | 0.149 | 0.070 | 2.27 | 103 | -3.96 | 97 | 4.2 | 0 | 97 | 208 | 86 | 74 |
| 284 | 42.573 | 0.155 | 0.070 | 2.26 | 103 | -1.8 | 101 | 4.1 | -0.1 | 98 | 208 | 86 | 74 |
| 285 | 42.724 | 0.151 | 0.070 | 2.26 | 103 | -2.57 | 98 | 4.1 | 0 | 98 | 207 | 85 | 74 |
| 286 | 42.879 | 0.155 | 0.070 | 2.26 | 103 | -2.69 | 101 | 4.1 | 0 | 98 | 206 | 84 | 74 |
| 287 | 43.029 | 0.150 | 0.070 | 2.26 | 103 | -2.92 | 98 | 4.1 | 0 | 98 | 206 | 84 | 74 |
| 288 | 43.182 | 0.153 | 0.070 | 2.27 | 103 | -3.54 | 99 | 4.2 | 0.1 | 97 | 205 | 85 | 74 |
| 289 | 43.337 | 0.155 | 0.070 | 2.29 | 103 | -2.11 | 101 | 4.1 | -0.1 | 97 | 205 | 86 | 74 |
| 290 | 43.489 | 0.152 | 0.070 | 2.28 | 103 | -1.46 | 99 | 4.1 | 0 | 97 | 205 | 86 | 74 |
| 291 | 43.643 | 0.154 | 0.070 | 2.29 | 103 | -1.7 | 100 | 4.0 | -0.1 | 97 | 204 | 85 | 74 |
| 292 | 43.794 | 0.151 | 0.070 | 2.29 | 103 | -1.77 | 98 | 4.0 | 0 | 97 | 204 | 84 | 74 |
| 293 | 43.950 | 0.156 | 0.070 | 2.29 | 103 | -1.7 | 101 | 4.0 | 0 | 97 | 203 | 84 | 75 |
| 294 | 44.101 | 0.151 | 0.070 | 2.31 | 103 | -2.82 | 98 | 4.0 | 0 | 97 | 202 | 85 | 74 |
| 295 | 44.255 | 0.154 | 0.070 | 2.31 | 103 | -2.17 | 100 | 4.0 | 0 | 97 | 201 | 86 | 74 |
| 296 | 44.409 | 0.154 | 0.070 | 2.28 | 103 | -3.53 | 100 | 4.1 | 0.1 | 97 | 201 | 86 | 74 |

BOX A TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 297 | 44.563 | 0.154 | 0.070 | 2.31 | 103 | -2.91 | 100 | 4.0 | -0.1 | 97 | 200 | 85 | 74 |
| 298 | 44.718 | 0.155 | 0.070 | 2.32 | 103 | -2.19 | 101 | 3.9 | -0.1 | 97 | 200 | 84 | 74 |
| 299 | 44.869 | 0.151 | 0.070 | 2.32 | 104 | -4.03 | 98 | 3.9 | 0 | 96 | 199 | 85 | 74 |
| 300 | 45.026 | 0.157 | 0.070 | 2.30 | 104 | -1.51 | 102 | 3.9 | 0 | 96 | 199 | 86 | 74 |
| 301 | 45.177 | 0.151 | 0.070 | 2.33 | 104 | -1.45 | 98 | 3.9 | 0 | 96 | 199 | 86 | 74 |
| 302 | 45.332 | 0.155 | 0.070 | 2.32 | 104 | -3.13 | 100 | 3.9 | 0 | 96 | 199 | 86 | 72 |
| 303 | 45.488 | 0.156 | 0.070 | 2.30 | 104 | -4 | 101 | 4.0 | 0.1 | 96 | 199 | 85 | 70 |
| 304 | 45.640 | 0.152 | 0.070 | 2.33 | 104 | -3.93 | 99 | 3.8 | -0.2 | 97 | 198 | 84 | 69 |
| 305 | 45.796 | 0.156 | 0.070 | 2.33 | 104 | -2.54 | 101 | 3.8 | 0 | 97 | 198 | 84 | 68 |
| 306 | 45.949 | 0.153 | 0.070 | 2.33 | 104 | -1.45 | 99 | 3.8 | 0 | 97 | 197 | 85 | 69 |
| 307 | 46.106 | 0.157 | 0.070 | 2.34 | 104 | -1.82 | 102 | 3.8 | 0 | 97 | 196 | 86 | 69 |
| 308 | 46.258 | 0.152 | 0.070 | 2.36 | 104 | -3.62 | 99 | 3.8 | 0 | 98 | 196 | 86 | 68 |
| 309 | 46.414 | 0.156 | 0.070 | 2.34 | 104 | -1.72 | 101 | 3.8 | 0 | 97 | 195 | 85 | 69 |
| 310 | 46.570 | 0.156 | 0.070 | 2.36 | 104 | -1.36 | 101 | 3.7 | -0.1 | 97 | 195 | 84 | 70 |
| 311 | 46.722 | 0.152 | 0.070 | 2.34 | 103 | -1.33 | 99 | 3.7 | 0 | 97 | 194 | 84 | 71 |
| 312 | 46.881 | 0.159 | 0.070 | 2.37 | 103 | -1.24 | 103 | 3.7 | 0 | 97 | 193 | 85 | 72 |
| 313 | 47.033 | 0.152 | 0.070 | 2.37 | 103 | -2.55 | 99 | 3.7 | 0 | 97 | 193 | 86 | 72 |
| 314 | 47.189 | 0.156 | 0.070 | 2.36 | 103 | -3.91 | 101 | 3.8 | 0.1 | 96 | 193 | 86 | 73 |
| 315 | 47.346 | 0.157 | 0.070 | 2.37 | 103 | -1.32 | 102 | 3.7 | -0.1 | 96 | 193 | 85 | 73 |
| 316 | 47.499 | 0.153 | 0.070 | 2.35 | 103 | -1.86 | 99 | 3.7 | 0 | 96 | 193 | 84 | 73 |
| 317 | 47.658 | 0.159 | 0.070 | 2.37 | 103 | -1.26 | 103 | 3.8 | 0.1 | 96 | 193 | 83 | 73 |
| 318 | 47.812 | 0.154 | 0.070 | 2.38 | 103 | -1.9 | 100 | 3.8 | 0 | 96 | 193 | 84 | 74 |
| 319 | 47.968 | 0.156 | 0.070 | 2.36 | 103 | -1.47 | 101 | 3.6 | -0.2 | 96 | 193 | 85 | 74 |
| 320 | 48.124 | 0.156 | 0.070 | 2.39 | 103 | -1.35 | 101 | 3.7 | 0.1 | 96 | 193 | 86 | 74 |
| 321 | 48.278 | 0.154 | 0.070 | 2.39 | 103 | -1.76 | 100 | 3.6 | -0.1 | 96 | 193 | 85 | 74 |
| 322 | 48.436 | 0.158 | 0.070 | 2.38 | 103 | -1.29 | 103 | 3.6 | 0 | 96 | 193 | 84 | 75 |
| 323 | 48.591 | 0.155 | 0.070 | 2.39 | 103 | -2.88 | 101 | 3.6 | 0 | 96 | 193 | 84 | 75 |
| 324 | 48.748 | 0.157 | 0.070 | 2.42 | 103 | -1.38 | 102 | 3.6 | 0 | 95 | 192 | 85 | 75 |
| 325 | 48.905 | 0.157 | 0.070 | 2.39 | 103 | -1.46 | 102 | 3.6 | 0 | 95 | 192 | 85 | 75 |
| 326 | 49.060 | 0.155 | 0.070 | 2.40 | 103 | -3.15 | 101 | 3.6 | 0 | 95 | 192 | 86 | 75 |
| 327 | 49.218 | 0.158 | 0.070 | 2.39 | 103 | -2.07 | 102 | 3.6 | 0 | 95 | 192 | 85 | 75 |
| 328 | 49.373 | 0.155 | 0.070 | 2.39 | 103 | -3.06 | 100 | 3.5 | -0.1 | 94 | 192 | 84 | 75 |
| 329 | 49.531 | 0.158 | 0.070 | 2.41 | 103 | -3.1 | 102 | 3.5 | 0 | 93 | 192 | 84 | 76 |

BOX A TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 330 | 49.688 | 0.157 | 0.070 | 2.40 | 103 | -1.62 | 102 | 3.5 | 0 | 93 | 191 | 85 | 76 |
| 331 | 49.843 | 0.155 | 0.070 | 2.40 | 103 | -2.09 | 100 | 3.5 | 0 | 94 | 191 | 86 | 76 |
| 332 | 50.002 | 0.159 | 0.070 | 2.40 | 103 | -1.09 | 103 | 3.5 | 0 | 94 | 191 | 86 | 76 |
| 333 | 50.157 | 0.155 | 0.070 | 2.43 | 103 | -2.09 | 100 | 3.4 | -0.1 | 94 | 190 | 85 | 76 |
| 334 | 50.314 | 0.157 | 0.070 | 2.42 | 103 | -3.83 | 102 | 3.4 | 0 | 94 | 191 | 84 | 76 |
| 335 | 50.473 | 0.159 | 0.070 | 2.40 | 103 | -2.94 | 103 | 3.4 | 0 | 94 | 191 | 84 | 76 |
| 336 | 50.628 | 0.155 | 0.070 | 2.43 | 103 | -1.52 | 100 | 3.4 | 0 | 93 | 191 | 84 | 76 |
| 337 | 50.789 | 0.161 | 0.070 | 2.41 | 103 | -2.7 | 104 | 3.4 | 0 | 93 | 191 | 85 | 76 |
| 338 | 50.943 | 0.154 | 0.070 | 2.42 | 103 | -1.43 | 100 | 3.4 | 0 | 92 | 192 | 86 | 76 |
| 339 | 51.102 | 0.159 | 0.070 | 2.43 | 103 | -1.88 | 103 | 3.4 | 0 | 92 | 191 | 86 | 76 |
| 340 | 51.261 | 0.159 | 0.070 | 2.43 | 103 | -2.54 | 103 | 3.4 | 0 | 92 | 191 | 85 | 76 |
| 341 | 51.415 | 0.154 | 0.070 | 2.43 | 103 | -3.75 | 100 | 3.3 | -0.1 | 93 | 190 | 84 | 76 |
| 342 | 51.576 | 0.161 | 0.070 | 2.43 | 103 | -1.73 | 104 | 3.3 | 0 | 93 | 189 | 84 | 76 |
| 343 | 51.731 | 0.155 | 0.070 | 2.44 | 103 | -1.97 | 100 | 3.3 | 0 | 93 | 190 | 84 | 76 |
| 344 | 51.890 | 0.159 | 0.070 | 2.42 | 103 | -1.35 | 103 | 3.3 | 0 | 93 | 190 | 84 | 76 |
| 345 | 52.049 | 0.159 | 0.070 | 2.45 | 103 | -2.64 | 103 | 3.3 | 0 | 92 | 191 | 86 | 76 |
| 346 | 52.205 | 0.156 | 0.070 | 2.44 | 103 | -3.37 | 101 | 3.3 | 0 | 92 | 190 | 86 | 76 |
| 347 | 52.365 | 0.160 | 0.070 | 2.45 | 103 | -1.21 | 103 | 3.3 | 0 | 91 | 191 | 85 | 76 |
| 348 | 52.524 | 0.159 | 0.070 | 2.44 | 104 | -1.31 | 103 | 3.4 | 0.1 | 91 | 190 | 84 | 76 |
| 349 | 52.679 | 0.155 | 0.070 | 2.46 | 104 | -3.53 | 100 | 3.2 | -0.2 | 92 | 190 | 84 | 77 |
| 350 | 52.841 | 0.162 | 0.070 | 2.44 | 104 | -2.57 | 105 | 3.2 | 0 | 92 | 190 | 84 | 77 |
| 351 | 52.996 | 0.155 | 0.070 | 2.43 | 104 | -2.43 | 100 | 3.2 | 0 | 92 | 189 | 85 | 76 |
| 352 | 53.156 | 0.160 | 0.070 | 2.46 | 104 | -3.71 | 103 | 3.2 | 0 | 92 | 189 | 86 | 76 |
| 353 | 53.316 | 0.160 | 0.070 | 2.46 | 104 | -3.66 | 103 | 3.2 | 0 | 91 | 190 | 86 | 76 |
| 354 | 53.473 | 0.157 | 0.070 | 2.46 | 104 | -3.08 | 101 | 3.3 | 0.1 | 91 | 190 | 85 | 76 |
| 355 | 53.633 | 0.160 | 0.070 | 2.44 | 104 | -0.98 | 103 | 3.2 | -0.1 | 90 | 191 | 84 | 77 |
| 356 | 53.792 | 0.159 | 0.070 | 2.45 | 104 | -3.62 | 103 | 3.1 | -0.1 | 91 | 190 | 84 | 76 |
| 357 | 53.948 | 0.156 | 0.070 | 2.45 | 104 | -1.19 | 101 | 3.1 | 0 | 91 | 190 | 85 | 77 |
| 358 | 54.111 | 0.163 | 0.070 | 2.47 | 104 | -3.35 | 105 | 3.1 | 0 | 91 | 190 | 86 | 77 |
| 359 | 54.267 | 0.156 | 0.070 | 2.44 | 104 | -2.57 | 101 | 3.1 | 0 | 91 | 189 | 86 | 77 |
| 360 | 54.428 | 0.161 | 0.070 | 2.47 | 104 | -1.77 | 104 | 3.1 | 0 | 92 | 189 | 85 | 77 |
| 361 | 54.588 | 0.160 | 0.070 | 2.48 | 104 | -1.47 | 103 | 3.1 | 0 | 91 | 189 | 84 | 77 |
| 362 | 54.745 | 0.157 | 0.070 | 2.49 | 104 | -1.14 | 101 | 3.1 | 0 | 91 | 189 | 84 | 76 |

BOX A TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 363 | 54.906 | 0.161 | 0.070 | 2.48 | 104 | -3.57 | 104 | 3.0 | -0.1 | 90 | 189 | 83 | 76 |
| 364 | 55.066 | 0.160 | 0.070 | 2.47 | 104 | -3.1 | 103 | 3.0 | 0 | 90 | 189 | 85 | 77 |
| 365 | 55.222 | 0.156 | 0.070 | 2.47 | 104 | -1.67 | 101 | 3.0 | 0 | 91 | 189 | 86 | 77 |
| 366 | 55.386 | 0.164 | 0.070 | 2.48 | 104 | -3.51 | 106 | 3.0 | 0 | 91 | 189 | 86 | 76 |
| 367 | 55.542 | 0.156 | 0.070 | 2.49 | 104 | -1.2 | 101 | 3.0 | 0 | 91 | 189 | 85 | 77 |
| 368 | 55.703 | 0.161 | 0.070 | 2.46 | 104 | -3.42 | 104 | 3.0 | 0 | 91 | 188 | 84 | 76 |
| 369 | 55.863 | 0.160 | 0.070 | 2.49 | 104 | -3.21 | 103 | 2.9 | -0.1 | 91 | 188 | 84 | 77 |
| 370 | 56.022 | 0.159 | 0.070 | 2.48 | 104 | -2.08 | 102 | 2.9 | 0 | 90 | 189 | 83 | 76 |
| 371 | 56.182 | 0.160 | 0.070 | 2.49 | 104 | -1.22 | 103 | 2.9 | 0 | 90 | 189 | 84 | 76 |
| 372 | 56.343 | 0.161 | 0.070 | 2.50 | 104 | -3.66 | 104 | 3.0 | 0.1 | 90 | 189 | 85 | 77 |
| 373 | 56.500 | 0.157 | 0.070 | 2.48 | 104 | -0.93 | 101 | 2.9 | -0.1 | 90 | 188 | 86 | 77 |
| 374 | 56.662 | 0.162 | 0.070 | 2.48 | 104 | -2.34 | 104 | 3.0 | 0.1 | 90 | 188 | 86 | 77 |
| 375 | 56.823 | 0.161 | 0.070 | 2.49 | 104 | -2.01 | 104 | 2.9 | -0.1 | 91 | 187 | 85 | 77 |
| 376 | 56.980 | 0.157 | 0.070 | 2.51 | 104 | -1.32 | 101 | 2.9 | 0 | 91 | 188 | 84 | 76 |
| 377 | 57.144 | 0.164 | 0.070 | 2.50 | 104 | -2.23 | 106 | 3.0 | 0.1 | 91 | 188 | 84 | 77 |
| 378 | 57.301 | 0.157 | 0.070 | 2.51 | 104 | -2.84 | 101 | 2.8 | -0.2 | 90 | 188 | 84 | 76 |
| 379 | 57.463 | 0.162 | 0.070 | 2.51 | 104 | -0.99 | 104 | 2.9 | 0.1 | 90 | 189 | 85 | 76 |
| 380 | 57.624 | 0.161 | 0.070 | 2.50 | 104 | -3.49 | 104 | 2.8 | -0.1 | 89 | 189 | 86 | 77 |
| 381 | 57.782 | 0.158 | 0.070 | 2.52 | 104 | -2.21 | 102 | 2.8 | 0 | 90 | 189 | 86 | 77 |
| 382 | 57.943 | 0.161 | 0.070 | 2.51 | 104 | -0.97 | 104 | 2.7 | -0.1 | 90 | 189 | 85 | 77 |
| 383 | 58.104 | 0.161 | 0.070 | 2.50 | 104 | -1.6 | 104 | 2.8 | 0.1 | 90 | 189 | 84 | 76 |
| 384 | 58.263 | 0.159 | 0.070 | 2.50 | 104 | -2.18 | 102 | 2.7 | -0.1 | 90 | 189 | 84 | 77 |
| 385 | 58.424 | 0.161 | 0.070 | 2.51 | 104 | -1.33 | 104 | 2.7 | 0 | 91 | 188 | 84 | 76 |
| 386 | 58.586 | 0.162 | 0.070 | 2.52 | 104 | -1.94 | 104 | 2.7 | 0 | 90 | 189 | 85 | 77 |
| 387 | 58.743 | 0.157 | 0.070 | 2.51 | 104 | -1.94 | 101 | 2.7 | 0 | 90 | 189 | 86 | 76 |
| 388 | 58.907 | 0.164 | 0.070 | 2.52 | 105 | -1.42 | 105 | 2.7 | 0 | 89 | 189 | 86 | 77 |
| 389 | 59.066 | 0.159 | 0.070 | 2.51 | 105 | -3.43 | 102 | 2.7 | 0 | 89 | 189 | 85 | 77 |
| 390 | 59.225 | 0.159 | 0.070 | 2.52 | 105 | -1.08 | 102 | 2.7 | 0 | 90 | 189 | 84 | 77 |
| 391 | 59.389 | 0.164 | 0.070 | 2.50 | 105 | -3.62 | 105 | 2.6 | -0.1 | 90 | 188 | 84 | 77 |
| 392 | 59.546 | 0.157 | 0.070 | 2.50 | 105 | -2.04 | 101 | 2.6 | 0 | 90 | 189 | 83 | 77 |
| 393 | 59.708 | 0.162 | 0.070 | 2.51 | 105 | -0.97 | 104 | 2.6 | 0 | 90 | 188 | 84 | 77 |
| 394 | 59.869 | 0.161 | 0.070 | 2.52 | 105 | -3.01 | 104 | 2.6 | 0 | 90 | 188 | 86 | 77 |
| 395 | 60.028 | 0.159 | 0.070 | 2.51 | 105 | -3.6 | 102 | 2.6 | 0 | 90 | 188 | 86 | 77 |

BOX A TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 396 | 60.189 | 0.161 | 0.070 | 2.50 | 105 | -3.64 | 103 | 2.6 | 0 | 89 | 189 | 85 | 76 |
| 397 | 60.351 | 0.162 | 0.070 | 2.52 | 105 | -1.04 | 104 | 2.6 | 0 | 89 | 189 | 84 | 77 |
| 398 | 60.510 | 0.159 | 0.070 | 2.51 | 105 | -1.77 | 102 | 2.6 | 0 | 89 | 189 | 84 | 77 |
| 399 | 60.672 | 0.162 | 0.070 | 2.52 | 105 | -0.9 | 104 | 2.6 | 0 | 90 | 188 | 84 | 77 |
| 400 | 60.834 | 0.162 | 0.070 | 2.50 | 105 | -3.44 | 104 | 2.5 | -0.1 | 90 | 188 | 85 | 77 |
| 401 | 60.991 | 0.157 | 0.070 | 2.52 | 105 | -1.23 | 101 | 2.5 | 0 | 90 | 188 | 86 | 77 |
| 402 | 61.155 | 0.164 | 0.070 | 2.52 | 105 | -3.65 | 105 | 2.5 | 0 | 90 | 188 | 86 | 76 |
| 403 | 61.315 | 0.160 | 0.070 | 2.54 | 105 | -3.55 | 103 | 2.6 | 0.1 | 90 | 188 | 85 | 76 |
| 404 | 61.474 | 0.159 | 0.070 | 2.51 | 105 | -2.18 | 102 | 2.5 | -0.1 | 89 | 189 | 84 | 76 |
| 405 | 61.638 | 0.164 | 0.070 | 2.55 | 105 | -3.47 | 105 | 2.5 | 0 | 89 | 189 | 83 | 76 |
| 406 | 61.796 | 0.158 | 0.070 | 2.54 | 105 | -1.47 | 102 | 2.4 | -0.1 | 89 | 189 | 84 | 76 |
| 407 | 61.958 | 0.162 | 0.070 | 2.54 | 105 | -0.92 | 104 | 2.4 | 0 | 90 | 188 | 85 | 77 |
| 408 | 62.121 | 0.163 | 0.070 | 2.50 | 105 | -3.47 | 105 | 2.4 | 0 | 90 | 188 | 86 | 77 |
| 409 | 62.279 | 0.158 | 0.070 | 2.52 | 105 | -3.26 | 102 | 2.4 | 0 | 90 | 188 | 86 | 76 |
| 410 | 62.441 | 0.162 | 0.070 | 2.52 | 105 | -3.43 | 104 | 2.4 | 0 | 90 | 188 | 85 | 76 |
| 411 | 62.603 | 0.162 | 0.070 | 2.53 | 105 | -3.41 | 104 | 2.4 | 0 | 89 | 188 | 84 | 76 |
| 412 | 62.762 | 0.159 | 0.070 | 2.51 | 105 | -2.88 | 102 | 2.4 | 0 | 89 | 189 | 84 | 76 |
| 413 | 62.923 | 0.161 | 0.070 | 2.52 | 105 | -1.52 | 103 | 2.4 | 0 | 89 | 189 | 84 | 76 |
| 414 | 63.086 | 0.163 | 0.070 | 2.53 | 105 | -3.43 | 105 | 2.3 | -0.1 | 89 | 189 | 85 | 77 |
| 415 | 63.244 | 0.158 | 0.070 | 2.52 | 105 | -1.72 | 102 | 2.3 | 0 | 89 | 189 | 86 | 76 |
| 416 | 63.407 | 0.163 | 0.070 | 2.53 | 105 | -1.03 | 105 | 2.3 | 0 | 90 | 188 | 86 | 76 |
| 417 | 63.568 | 0.161 | 0.070 | 2.52 | 105 | -2.7 | 104 | 2.3 | 0 | 90 | 188 | 85 | 76 |
| 418 | 63.726 | 0.158 | 0.070 | 2.52 | 105 | -3.48 | 102 | 2.3 | 0 | 90 | 188 | 84 | 77 |
| 419 | 63.891 | 0.165 | 0.070 | 2.53 | 105 | -1.77 | 106 | 2.3 | 0 | 89 | 189 | 84 | 76 |
| 420 | 64.049 | 0.158 | 0.070 | 2.51 | 105 | -1.71 | 102 | 2.2 | -0.1 | 89 | 190 | 83 | 76 |
| 421 | 64.208 | 0.159 | 0.070 | 2.50 | 105 | -3.43 | 102 | 2.2 | 0 | 89 | 190 | 84 | 76 |
| 422 | 64.371 | 0.163 | 0.070 | 2.47 | 105 | -1.78 | 105 | 2.2 | 0 | 89 | 190 | 86 | 76 |
| 423 | 64.528 | 0.157 | 0.070 | 2.50 | 105 | -0.97 | 101 | 2.2 | 0 | 89 | 190 | 87 | 76 |
| 424 | 64.689 | 0.161 | 0.070 | 2.49 | 105 | -2.06 | 103 | 2.2 | 0 | 89 | 190 | 86 | 76 |
| 425 | 64.850 | 0.161 | 0.070 | 2.48 | 105 | -2.67 | 104 | 2.2 | 0 | 90 | 191 | 85 | 77 |
| 426 | 65.007 | 0.157 | 0.070 | 2.48 | 105 | -3.53 | 101 | 2.1 | -0.1 | 90 | 190 | 84 | 76 |
| 427 | 65.168 | 0.161 | 0.070 | 2.46 | 105 | -3.53 | 104 | 2.1 | 0 | 90 | 191 | 83 | 76 |
| 428 | 65.328 | 0.160 | 0.070 | 2.46 | 105 | -2.34 | 103 | 2.1 | 0 | 89 | 192 | 84 | 76 |

BOX A TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 429 | 65.484 | 0.156 | 0.070 | 2.47 | 105 | -1.08 | 100 | 2.1 | 0 | 89 | 193 | 85 | 76 |
| 430 | 65.647 | 0.163 | 0.070 | 2.45 | 105 | -2.68 | 105 | 2.1 | 0 | 89 | 193 | 86 | 76 |
| 431 | 65.803 | 0.156 | 0.070 | 2.47 | 105 | -3.2 | 100 | 2.2 | 0.1 | 89 | 192 | 86 | 77 |
| 432 | 65.962 | 0.159 | 0.070 | 2.46 | 105 | -1.07 | 102 | 2.1 | -0.1 | 89 | 193 | 85 | 77 |
| 433 | 66.122 | 0.160 | 0.070 | 2.45 | 105 | -2.03 | 103 | 2.0 | -0.1 | 90 | 193 | 84 | 77 |
| 434 | 66.279 | 0.157 | 0.070 | 2.45 | 105 | -1.37 | 101 | 2.1 | 0.1 | 90 | 193 | 84 | 77 |
| 435 | 66.438 | 0.159 | 0.070 | 2.45 | 105 | -2.93 | 102 | 2.0 | -0.1 | 90 | 194 | 84 | 76 |
| 436 | 66.598 | 0.160 | 0.070 | 2.45 | 105 | -2.19 | 103 | 2.0 | 0 | 90 | 195 | 85 | 76 |
| 437 | 66.753 | 0.155 | 0.070 | 2.45 | 105 | -1.68 | 100 | 2.0 | 0 | 89 | 196 | 86 | 76 |
| 438 | 66.915 | 0.162 | 0.070 | 2.45 | 105 | -3.32 | 104 | 2.0 | 0 | 89 | 196 | 86 | 76 |
| 439 | 67.071 | 0.156 | 0.070 | 2.43 | 105 | -1.99 | 100 | 1.9 | -0.1 | 89 | 196 | 85 | 76 |
| 440 | 67.230 | 0.159 | 0.070 | 2.43 | 105 | -3.37 | 102 | 1.9 | 0 | 90 | 196 | 84 | 76 |
| 441 | 67.389 | 0.159 | 0.070 | 2.42 | 105 | -2.29 | 102 | 1.9 | 0 | 90 | 196 | 84 | 76 |
| 442 | 67.544 | 0.155 | 0.070 | 2.41 | 105 | -3.14 | 100 | 1.9 | 0 | 90 | 196 | 84 | 76 |
| 443 | 67.704 | 0.160 | 0.070 | 2.42 | 105 | -1.29 | 103 | 1.9 | 0 | 90 | 196 | 85 | 76 |
| 444 | 67.862 | 0.158 | 0.070 | 2.43 | 105 | -1.76 | 102 | 1.9 | 0 | 90 | 196 | 86 | 76 |
| 445 | 68.019 | 0.157 | 0.070 | 2.44 | 105 | -3.68 | 101 | 2.0 | 0.1 | 90 | 197 | 86 | 76 |
| 446 | 68.179 | 0.160 | 0.070 | 2.42 | 105 | -1.69 | 103 | 1.8 | -0.2 | 89 | 197 | 85 | 77 |
| 447 | 68.335 | 0.156 | 0.070 | 2.43 | 105 | -1.21 | 100 | 1.8 | 0 | 89 | 197 | 84 | 77 |
| 448 | 68.493 | 0.158 | 0.070 | 2.43 | 105 | -1.26 | 102 | 1.8 | 0 | 90 | 196 | 84 | 77 |
| 449 | 68.653 | 0.160 | 0.070 | 2.42 | 105 | -3.31 | 103 | 1.8 | 0 | 90 | 196 | 85 | 77 |
| 450 | 68.807 | 0.154 | 0.070 | 2.45 | 105 | -3.64 | 99 | 1.8 | 0 | 90 | 197 | 86 | 77 |
| 451 | 68.969 | 0.162 | 0.070 | 2.42 | 105 | -1.26 | 104 | 1.8 | 0 | 90 | 196 | 86 | 77 |
| 452 | 69.124 | 0.155 | 0.070 | 2.42 | 105 | -1.09 | 100 | 1.7 | -0.1 | 90 | 196 | 85 | 77 |
| 453 | 69.283 | 0.159 | 0.070 | 2.42 | 105 | -1.18 | 102 | 1.7 | 0 | 90 | 197 | 84 | 76 |
| 454 | 69.443 | 0.160 | 0.070 | 2.45 | 105 | -1.57 | 103 | 1.7 | 0 | 90 | 197 | 84 | 76 |
| 455 | 69.599 | 0.156 | 0.070 | 2.43 | 105 | -1.11 | 100 | 1.7 | 0 | 89 | 197 | 84 | 77 |
| 456 | 69.758 | 0.159 | 0.070 | 2.42 | 105 | -1.15 | 102 | 1.8 | 0.1 | 89 | 196 | 85 | 77 |
| 457 | 69.917 | 0.159 | 0.070 | 2.43 | 105 | -1.13 | 102 | 1.7 | -0.1 | 90 | 196 | 86 | 77 |
| 458 | 70.073 | 0.156 | 0.070 | 2.45 | 105 | -3.64 | 100 | 1.7 | 0 | 90 | 196 | 86 | 77 |
| 459 | 70.234 | 0.161 | 0.070 | 2.41 | 105 | -3.77 | 104 | 1.6 | -0.1 | 90 | 196 | 86 | 77 |
| 460 | 70.389 | 0.155 | 0.070 | 2.44 | 105 | -3.61 | 100 | 1.6 | 0 | 90 | 196 | 85 | 77 |
| 461 | 70.549 | 0.160 | 0.070 | 2.44 | 105 | -3.52 | 103 | 1.6 | 0 | 90 | 196 | 84 | 77 |

BOX A TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 462 | 70.709 | 0.160 | 0.070 | 2.45 | 105 | -1.08 | 103 | 1.6 | 0 | 90 | 196 | 84 | 76 |
| 463 | 70.863 | 0.154 | 0.070 | 2.44 | 105 | -1.93 | 99 | 1.7 | 0.1 | 90 | 197 | 84 | 77 |
| 464 | 71.025 | 0.162 | 0.070 | 2.44 | 105 | -1.66 | 104 | 1.6 | -0.1 | 89 | 196 | 86 | 77 |
| 465 | 71.181 | 0.156 | 0.070 | 2.44 | 105 | -3.48 | 100 | 1.6 | 0 | 90 | 196 | 87 | 77 |
| 466 | 71.340 | 0.159 | 0.070 | 2.45 | 105 | -3.38 | 102 | 1.5 | -0.1 | 90 | 196 | 86 | 77 |
| 467 | 71.499 | 0.159 | 0.070 | 2.44 | 105 | -3.65 | 102 | 1.5 | 0 | 90 | 196 | 85 | 77 |
| 468 | 71.656 | 0.157 | 0.070 | 2.43 | 105 | -3.61 | 101 | 1.5 | 0 | 90 | 196 | 85 | 77 |
| 469 | 71.814 | 0.158 | 0.070 | 2.45 | 105 | -3.64 | 102 | 1.5 | 0 | 90 | 195 | 84 | 77 |
| 470 | 71.974 | 0.160 | 0.070 | 2.44 | 105 | -1.26 | 103 | 1.5 | 0 | 90 | 196 | 84 | 76 |
| 471 | 72.129 | 0.155 | 0.070 | 2.44 | 105 | -1.77 | 100 | 1.5 | 0 | 89 | 196 | 84 | 76 |
| 472 | 72.291 | 0.162 | 0.070 | 2.43 | 105 | -3.23 | 104 | 1.5 | 0 | 89 | 197 | 86 | 77 |
| 473 | 72.446 | 0.155 | 0.070 | 2.45 | 105 | -3.7 | 100 | 1.5 | 0 | 89 | 196 | 87 | 77 |
| 474 | 72.604 | 0.158 | 0.070 | 2.43 | 105 | -3.3 | 102 | 1.5 | 0 | 89 | 196 | 86 | 77 |
| 475 | 72.763 | 0.159 | 0.070 | 2.43 | 105 | -1.2 | 102 | 1.4 | -0.1 | 90 | 196 | 85 | 77 |
| 476 | 72.918 | 0.155 | 0.070 | 2.44 | 105 | -1.16 | 100 | 1.4 | 0 | 90 | 195 | 84 | 77 |
| 477 | 73.079 | 0.161 | 0.070 | 2.43 | 105 | -1.13 | 104 | 1.4 | 0 | 90 | 196 | 84 | 77 |
| 478 | 73.235 | 0.156 | 0.070 | 2.41 | 105 | -3.12 | 100 | 1.3 | -0.1 | 90 | 196 | 83 | 76 |
| 479 | 73.393 | 0.158 | 0.070 | 2.42 | 105 | -3.5 | 102 | 1.5 | 0.2 | 89 | 196 | 84 | 76 |
| 480 | 73.551 | 0.158 | 0.070 | 2.42 | 105 | -1.58 | 102 | 1.3 | -0.2 | 89 | 197 | 86 | 76 |
| 481 | 73.707 | 0.156 | 0.070 | 2.41 | 105 | -1.62 | 100 | 1.4 | 0.1 | 89 | 197 | 86 | 77 |
| 482 | 73.866 | 0.159 | 0.070 | 2.43 | 105 | -1.48 | 102 | 1.3 | -0.1 | 89 | 196 | 86 | 77 |
| 483 | 74.024 | 0.158 | 0.070 | 2.41 | 105 | -2.96 | 102 | 1.3 | 0 | 89 | 197 | 85 | 77 |
| 484 | 74.179 | 0.155 | 0.070 | 2.39 | 105 | -1.56 | 100 | 1.3 | 0 | 90 | 196 | 84 | 77 |
| 485 | 74.339 | 0.160 | 0.070 | 2.44 | 105 | -2.02 | 103 | 1.4 | 0.1 | 90 | 197 | 83 | 77 |
| 486 | 74.494 | 0.155 | 0.070 | 2.42 | 105 | -3.8 | 100 | 1.3 | -0.1 | 90 | 196 | 84 | 76 |
| 487 | 74.652 | 0.158 | 0.070 | 2.42 | 105 | -2.23 | 102 | 1.2 | -0.1 | 90 | 197 | 85 | 76 |
| 488 | 74.812 | 0.160 | 0.070 | 2.40 | 105 | -3.8 | 103 | 1.2 | 0 | 89 | 197 | 86 | 76 |
| 489 | 74.965 | 0.153 | 0.070 | 2.40 | 105 | -2.4 | 98 | 1.2 | 0 | 89 | 198 | 85 | 76 |
| 490 | 75.126 | 0.161 | 0.070 | 2.40 | 105 | -3.77 | 103 | 1.2 | 0 | 89 | 197 | 85 | 77 |
| 491 | 75.280 | 0.154 | 0.070 | 2.40 | 105 | -1.24 | 99 | 1.3 | 0.1 | 89 | 197 | 84 | 77 |
| 492 | 75.439 | 0.159 | 0.070 | 2.41 | 105 | -1.48 | 102 | 1.1 | -0.2 | 89 | 197 | 83 | 77 |
| 493 | 75.597 | 0.158 | 0.070 | 2.42 | 105 | -1.41 | 102 | 1.2 | 0.1 | 90 | 197 | 83 | 76 |
| 494 | 75.752 | 0.155 | 0.070 | 2.39 | 105 | -3.69 | 100 | 1.1 | -0.1 | 90 | 199 | 85 | 76 |

BOX A TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 495 | 75.912 | 0.160 | 0.070 | 2.39 | 105 | -1.1 | 103 | 1.1 | 0 | 90 | 197 | 86 | 77 |
| 496 | 76.067 | 0.155 | 0.070 | 2.40 | 105 | -3.66 | 100 | 1.1 | 0 | 90 | 198 | 85 | 76 |
| 497 | 76.225 | 0.158 | 0.070 | 2.39 | 105 | -1.99 | 102 | 1.1 | 0 | 90 | 198 | 84 | 76 |
| 498 | 76.383 | 0.158 | 0.070 | 2.40 | 105 | -1.23 | 102 | 1.1 | 0 | 89 | 198 | 84 | 76 |
| 499 | 76.539 | 0.156 | 0.070 | 2.41 | 105 | -3.41 | 100 | 1.1 | 0 | 89 | 198 | 83 | 76 |
| 500 | 76.697 | 0.158 | 0.070 | 2.39 | 105 | -2.64 | 102 | 1.0 | -0.1 | 90 | 198 | 84 | 77 |
| 501 | 76.855 | 0.158 | 0.070 | 2.42 | 105 | -1.98 | 102 | 1.0 | 0 | 90 | 198 | 85 | 76 |
| 502 | 77.011 | 0.156 | 0.070 | 2.41 | 105 | -1.63 | 100 | 1.0 | 0 | 90 | 199 | 85 | 76 |
| 503 | 77.171 | 0.160 | 0.070 | 2.41 | 105 | -3.18 | 103 | 1.0 | 0 | 90 | 198 | 85 | 77 |
| 504 | 77.326 | 0.155 | 0.070 | 2.40 | 105 | -1.84 | 100 | 1.0 | 0 | 90 | 198 | 84 | 77 |
| 505 | 77.484 | 0.158 | 0.070 | 2.41 | 105 | -1.39 | 102 | 1.1 | 0.1 | 90 | 198 | 83 | 77 |
| 506 | 77.644 | 0.160 | 0.070 | 2.41 | 105 | -3.51 | 103 | 1.0 | -0.1 | 91 | 199 | 83 | 76 |
| 507 | 77.797 | 0.153 | 0.070 | 2.42 | 105 | -1.43 | 98 | 1.0 | 0 | 90 | 199 | 84 | 77 |
| 508 | 77.959 | 0.162 | 0.070 | 2.44 | 105 | -1.87 | 104 | 0.9 | -0.1 | 90 | 198 | 85 | 77 |
| 509 | 78.113 | 0.154 | 0.070 | 2.43 | 105 | -1.05 | 99 | 0.9 | 0 | 90 | 199 | 86 | 77 |
| 510 | 78.272 | 0.159 | 0.070 | 2.41 | 105 | -3.84 | 102 | 0.9 | 0 | 90 | 199 | 85 | 76 |
| 511 | 78.431 | 0.159 | 0.070 | 2.42 | 105 | -3.05 | 102 | 0.9 | 0 | 90 | 198 | 84 | 76 |
| 512 | 78.586 | 0.155 | 0.070 | 2.42 | 105 | -3.68 | 100 | 0.9 | 0 | 90 | 198 | 83 | 76 |
| 513 | 78.746 | 0.160 | 0.070 | 2.42 | 105 | -2.3 | 103 | 0.8 | -0.1 | 90 | 198 | 84 | 76 |
| 514 | 78.901 | 0.155 | 0.070 | 2.41 | 105 | -1.45 | 100 | 0.9 | 0.1 | 91 | 198 | 85 | 76 |
| 515 | 79.059 | 0.158 | 0.070 | 2.39 | 105 | -3.57 | 102 | 0.8 | -0.1 | 91 | 198 | 86 | 76 |
| 516 | 79.218 | 0.159 | 0.070 | 2.41 | 105 | -1.91 | 102 | 0.8 | 0 | 90 | 198 | 85 | 76 |
| 517 | 79.374 | 0.156 | 0.070 | 2.40 | 105 | -1.26 | 100 | 0.8 | 0 | 90 | 199 | 84 | 76 |
| 518 | 79.532 | 0.158 | 0.070 | 2.43 | 105 | -3.38 | 102 | 0.8 | 0 | 90 | 198 | 84 | 77 |
| 519 | 79.690 | 0.158 | 0.070 | 2.39 | 105 | -1.37 | 102 | 0.8 | 0 | 90 | 198 | 84 | 76 |
| 520 | 79.845 | 0.155 | 0.070 | 2.43 | 105 | -1.89 | 100 | 0.7 | -0.1 | 90 | 198 | 85 | 76 |
| 521 | 80.006 | 0.161 | 0.070 | 2.41 | 105 | -3.33 | 104 | 0.8 | 0.1 | 90 | 198 | 86 | 76 |
| 522 | 80.161 | 0.155 | 0.070 | 2.43 | 105 | -1.22 | 100 | 0.7 | -0.1 | 90 | 198 | 85 | 76 |
| 523 | 80.319 | 0.158 | 0.070 | 2.41 | 105 | -3.43 | 102 | 0.8 | 0.1 | 90 | 197 | 84 | 76 |
| 524 | 80.479 | 0.160 | 0.070 | 2.41 | 105 | -3.72 | 103 | 0.7 | -0.1 | 90 | 198 | 83 | 76 |
| 525 | 80.632 | 0.153 | 0.070 | 2.42 | 105 | -1.35 | 98 | 0.7 | 0 | 90 | 198 | 84 | 76 |
| 526 | 80.794 | 0.162 | 0.070 | 2.40 | 105 | -1.61 | 104 | 0.7 | 0 | 90 | 199 | 85 | 77 |
| 527 | 80.949 | 0.155 | 0.070 | 2.41 | 105 | -1.57 | 100 | 0.6 | -0.1 | 89 | 198 | 86 | 76 |

BOX A TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 528 | 81.107 | 0.158 | 0.070 | 2.42 | 105 | -1.33 | 102 | 0.6 | 0 | 90 | 198 | 86 | 76 |
| 529 | 81.265 | 0.158 | 0.070 | 2.42 | 105 | -3.51 | 102 | 0.7 | 0.1 | 90 | 197 | 85 | 76 |
| 530 | 81.420 | 0.155 | 0.070 | 2.42 | 105 | -2.91 | 100 | 0.7 | 0 | 90 | 197 | 84 | 76 |
| 531 | 81.580 | 0.160 | 0.070 | 2.40 | 105 | -3.59 | 103 | 0.6 | -0.1 | 90 | 197 | 83 | 76 |
| 532 | 81.736 | 0.156 | 0.070 | 2.40 | 105 | -1.63 | 100 | 0.6 | 0 | 90 | 197 | 83 | 76 |
| 533 | 81.894 | 0.158 | 0.070 | 2.41 | 105 | -1.35 | 102 | 0.6 | 0 | 90 | 198 | 85 | 76 |
| 534 | 82.052 | 0.158 | 0.070 | 2.42 | 105 | -1.27 | 102 | 0.4 | -0.2 | 89 | 198 | 86 | 76 |
| 535 | 82.207 | 0.155 | 0.070 | 2.40 | 105 | -1.26 | 100 | 0.5 | 0.1 | 89 | 198 | 86 | 76 |
| 536 | 82.366 | 0.159 | 0.070 | 2.43 | 105 | -1.27 | 102 | 0.6 | 0.1 | 89 | 198 | 85 | 76 |
| 537 | 82.524 | 0.158 | 0.070 | 2.42 | 105 | -1.7 | 102 | 0.5 | -0.1 | 89 | 197 | 84 | 76 |
| 538 | 82.679 | 0.155 | 0.070 | 2.42 | 105 | -2.17 | 100 | 0.5 | 0 | 90 | 198 | 84 | 76 |
| 539 | 82.840 | 0.161 | 0.070 | 2.42 | 105 | -2.22 | 104 | 0.6 | 0.1 | 90 | 198 | 83 | 76 |
| 540 | 82.995 | 0.155 | 0.070 | 2.40 | 105 | -3.29 | 100 | 0.6 | 0 | 90 | 198 | 84 | 76 |
| 541 | 83.152 | 0.157 | 0.070 | 2.40 | 105 | -1.19 | 101 | 0.5 | -0.1 | 90 | 197 | 86 | 76 |
| 542 | 83.312 | 0.160 | 0.070 | 2.41 | 105 | -1.03 | 103 | 0.4 | -0.1 | 90 | 198 | 86 | 76 |
| 543 | 83.466 | 0.154 | 0.070 | 2.40 | 105 | -1.28 | 99 | 0.4 | 0 | 89 | 199 | 85 | 76 |
| 544 | 83.627 | 0.161 | 0.070 | 2.41 | 105 | -3.03 | 103 | 0.4 | 0 | 89 | 198 | 84 | 76 |
| 545 | 83.781 | 0.154 | 0.070 | 2.41 | 105 | -2.42 | 99 | 0.4 | 0 | 90 | 198 | 84 | 76 |
| 546 | 83.940 | 0.159 | 0.070 | 2.39 | 105 | -1.31 | 102 | 0.4 | 0 | 90 | 197 | 84 | 76 |
| 547 | 84.098 | 0.158 | 0.070 | 2.44 | 105 | -3.47 | 102 | 0.4 | 0 | 90 | 197 | 85 | 76 |
| 548 | 84.253 | 0.155 | 0.070 | 2.41 | 105 | -3.77 | 100 | 0.4 | 0 | 90 | 198 | 86 | 76 |
| 549 | 84.414 | 0.161 | 0.070 | 2.42 | 105 | -1.18 | 104 | 0.3 | -0.1 | 90 | 197 | 85 | 76 |
| 550 | 84.568 | 0.154 | 0.070 | 2.40 | 105 | -1.96 | 99 | 0.3 | 0 | 90 | 197 | 84 | 76 |
| 551 | 84.726 | 0.158 | 0.070 | 2.40 | 105 | -2.99 | 102 | 0.3 | 0 | 89 | 198 | 84 | 76 |
| 552 | 84.885 | 0.159 | 0.070 | 2.40 | 105 | -1.33 | 102 | 0.3 | 0 | 89 | 198 | 84 | 76 |
| 553 | 85.040 | 0.155 | 0.070 | 2.41 | 105 | -3.73 | 100 | 0.3 | 0 | 89 | 198 | 86 | 76 |
| 554 | 85.199 | 0.159 | 0.070 | 2.41 | 105 | -1.23 | 102 | 0.3 | 0 | 89 | 197 | 86 | 77 |
| 555 | 85.356 | 0.157 | 0.070 | 2.42 | 105 | -3.22 | 101 | 0.3 | 0 | 89 | 196 | 85 | 76 |
| 556 | 85.512 | 0.156 | 0.070 | 2.40 | 105 | -3.71 | 100 | 0.3 | 0 | 89 | 196 | 84 | 77 |
| 557 | 85.672 | 0.160 | 0.070 | 2.40 | 105 | -1.59 | 103 | 0.2 | -0.1 | 90 | 196 | 84 | 76 |
| 558 | 85.828 | 0.156 | 0.070 | 2.41 | 105 | -2.48 | 100 | 0.2 | 0 | 90 | 195 | 83 | 76 |
| 559 | 85.985 | 0.157 | 0.070 | 2.40 | 105 | -2.94 | 101 | 0.2 | 0 | 90 | 195 | 84 | 76 |
| 560 | 86.144 | 0.159 | 0.070 | 2.41 | 105 | -1.18 | 102 | 0.2 | 0 | 89 | 195 | 85 | 76 |

BOX A TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 561 | 86.298 | 0.154 | 0.070 | 2.41 | 105 | -1.22 | 99 | 0.3 | 0.1 | 89 | 196 | 86 | 76 |
| 562 | 86.459 | 0.161 | 0.070 | 2.42 | 105 | -3.76 | 103 | 0.3 | 0 | 89 | 196 | 85 | 76 |
| 563 | 86.613 | 0.154 | 0.070 | 2.42 | 105 | -1.96 | 99 | 0.2 | -0.1 | 89 | 195 | 84 | 76 |
| 564 | 86.772 | 0.159 | 0.070 | 2.43 | 105 | -2.12 | 102 | 0.1 | -0.1 | 89 | 195 | 84 | 76 |
| 565 | 86.931 | 0.159 | 0.070 | 2.42 | 105 | -3.73 | 102 | 0.1 | 0 | 89 | 194 | 84 | 76 |
| 566 | 87.085 | 0.154 | 0.070 | 2.41 | 105 | -3.6 | 99 | 0.2 | 0.1 | 89 | 194 | 85 | 76 |
| 567 | 87.246 | 0.161 | 0.070 | 2.39 | 105 | -1.35 | 104 | 0.1 | -0.1 | 90 | 194 | 85 | 76 |
| 568 | 87.400 | 0.154 | 0.070 | 2.41 | 105 | -3.41 | 99 | 0.1 | 0 | 89 | 194 | 86 | 76 |
| 569 | 87.559 | 0.159 | 0.070 | 2.42 | 105 | -1.24 | 102 | 0.3 | 0.2 | 89 | 195 | 85 | 76 |
| 570 | 87.718 | 0.159 | 0.070 | 2.45 | 105 | -1.33 | 102 | 0.1 | -0.2 | 89 | 194 | 84 | 76 |
| 571 | 87.873 | 0.155 | 0.070 | 2.41 | 105 | -2.84 | 100 | 0.1 | 0 | 89 | 193 | 84 | 76 |
| 572 | 88.032 | 0.159 | 0.070 | 2.43 | 105 | -1.78 | 102 | 0.1 | 0 | 89 | 192 | 85 | 76 |
| 573 | 88.189 | 0.157 | 0.070 | 2.41 | 105 | -2.93 | 101 | 0.0 | -0.1 | 89 | 192 | 86 | 76 |
| Avg/Tot | 88.189 | 0.154 | 0.070 | 2.31 | 103 | -2.08 | 100 | | | 97 | 251 | 85 | 74.9 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 0 | 0.000 | | 0.00 | 99 | -1 | | 85 | 0.000 | 6.67 | 0.44 |
| 1 | 0.143 | 0.143 | 2.31 | 99 | -0.69 | 98 | 85 | -0.080 | 5.19 | 0.40 |
| 2 | 0.295 | 0.152 | 2.28 | 99 | -2.51 | 104 | 86 | -0.080 | 4.23 | 0.51 |
| 3 | 0.442 | 0.147 | 2.24 | 99 | -2.58 | 101 | 85 | -0.090 | 13.26 | 0.47 |
| 4 | 0.592 | 0.150 | 2.24 | 98 | -1.19 | 103 | 85 | -0.080 | 15.75 | 1.27 |
| 5 | 0.739 | 0.147 | 2.22 | 98 | -3.16 | 101 | 85 | -0.090 | 16.19 | 1.52 |
| 6 | 0.889 | 0.150 | 2.20 | 98 | -1.11 | 103 | 85 | -0.080 | 16.43 | 1.53 |
| 7 | 1.035 | 0.146 | 2.22 | 98 | -2.25 | 100 | 85 | -0.090 | 15.71 | 1.18 |
| 8 | 1.186 | 0.151 | 2.21 | 98 | -2.73 | 103 | 85 | -0.080 | 14.40 | 0.33 |
| 9 | 1.332 | 0.146 | 2.20 | 98 | -3.03 | 100 | 86 | -0.080 | 15.12 | 0.62 |
| 10 | 1.482 | 0.150 | 2.21 | 98 | -0.87 | 102 | 86 | -0.090 | 14.95 | 0.48 |
| 11 | 1.627 | 0.145 | 2.17 | 98 | -3.27 | 99 | 86 | -0.080 | 14.44 | 0.24 |
| 12 | 1.780 | 0.153 | 2.26 | 98 | -1.29 | 104 | 85 | -0.080 | 15.01 | 0.62 |
| 13 | 1.927 | 0.147 | 2.27 | 98 | -1.13 | 100 | 85 | -0.080 | 14.77 | 0.50 |
| 14 | 2.078 | 0.151 | 2.26 | 98 | -0.86 | 103 | 85 | -0.090 | 14.42 | 0.42 |
| 15 | 2.226 | 0.148 | 2.27 | 98 | -3.02 | 101 | 85 | -0.080 | 14.30 | 0.36 |
| 16 | 2.377 | 0.151 | 2.26 | 98 | -2.59 | 103 | 85 | -0.080 | 14.36 | 0.52 |
| 17 | 2.527 | 0.150 | 2.27 | 98 | -3.29 | 102 | 86 | -0.080 | 13.89 | 0.42 |
| 18 | 2.677 | 0.150 | 2.27 | 98 | -0.83 | 102 | 86 | -0.080 | 13.16 | 0.36 |
| 19 | 2.828 | 0.151 | 2.26 | 98 | -1 | 102 | 86 | -0.080 | 12.27 | 0.25 |
| 20 | 2.977 | 0.149 | 2.26 | 98 | -0.83 | 101 | 86 | -0.070 | 11.58 | 0.28 |
| 21 | 3.127 | 0.150 | 2.27 | 98 | -3.26 | 102 | 86 | -0.080 | 11.25 | 0.26 |
| 22 | 3.276 | 0.149 | 2.28 | 98 | -2.42 | 101 | 85 | -0.070 | 10.86 | 0.32 |
| 23 | 3.427 | 0.151 | 2.26 | 98 | -3.21 | 102 | 85 | -0.070 | 10.64 | 0.29 |
| 24 | 3.575 | 0.148 | 2.24 | 99 | -1.9 | 100 | 85 | -0.070 | 10.34 | 0.28 |
| 25 | 3.728 | 0.153 | 2.25 | 99 | -2.32 | 103 | 85 | -0.080 | 10.33 | 0.29 |
| 26 | 3.875 | 0.147 | 2.25 | 99 | -3.03 | 99 | 86 | -0.070 | 10.12 | 0.29 |
| 27 | 4.028 | 0.153 | 2.24 | 99 | -1.26 | 103 | 86 | -0.070 | 9.99 | 0.30 |
| 28 | 4.175 | 0.147 | 2.26 | 99 | -2.81 | 99 | 86 | -0.070 | 9.96 | 0.30 |
| 29 | 4.327 | 0.152 | 2.24 | 99 | -2.93 | 103 | 86 | -0.070 | 9.93 | 0.30 |
| 30 | 4.475 | 0.148 | 2.26 | 99 | -0.86 | 100 | 85 | -0.060 | 10.03 | 0.31 |
| 31 | 4.626 | 0.151 | 2.26 | 99 | -2.28 | 102 | 85 | -0.080 | 10.17 | 0.25 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 32 | 4.776 | 0.150 | 2.26 | 99 | -1.54 | 101 | 85 | -0.070 | 10.07 | 0.31 |
| 33 | 4.927 | 0.151 | 2.25 | 99 | -0.95 | 101 | 85 | -0.070 | 10.00 | 0.32 |
| 34 | 5.077 | 0.150 | 2.26 | 99 | -3.05 | 101 | 86 | -0.070 | 10.02 | 0.29 |
| 35 | 5.226 | 0.149 | 2.26 | 99 | -3.27 | 100 | 86 | -0.060 | 9.86 | 0.33 |
| 36 | 5.377 | 0.151 | 2.26 | 99 | -2.86 | 101 | 86 | -0.060 | 9.93 | 0.32 |
| 37 | 5.525 | 0.148 | 2.27 | 99 | -3.33 | 99 | 86 | -0.070 | 9.77 | 0.35 |
| 38 | 5.677 | 0.152 | 2.26 | 99 | -1.01 | 102 | 86 | -0.070 | 9.86 | 0.32 |
| 39 | 5.825 | 0.148 | 2.26 | 99 | -3.16 | 99 | 85 | -0.060 | 9.99 | 0.30 |
| 40 | 5.977 | 0.152 | 2.27 | 99 | -3.26 | 102 | 84 | -0.070 | 9.96 | 0.35 |
| 41 | 6.125 | 0.148 | 2.25 | 99 | -1.07 | 99 | 84 | -0.080 | 10.23 | 0.32 |
| 42 | 6.278 | 0.153 | 2.26 | 99 | -0.89 | 102 | 85 | -0.070 | 10.23 | 0.28 |
| 43 | 6.425 | 0.147 | 2.25 | 99 | -3.17 | 98 | 85 | -0.050 | 10.24 | 0.29 |
| 44 | 6.576 | 0.151 | 2.26 | 100 | -3.27 | 101 | 86 | -0.070 | 10.38 | 0.25 |
| 45 | 6.724 | 0.148 | 2.26 | 100 | -3.19 | 99 | 86 | -0.080 | 10.38 | 0.24 |
| 46 | 6.876 | 0.152 | 2.25 | 100 | -2.9 | 102 | 86 | -0.060 | 10.36 | 0.25 |
| 47 | 7.026 | 0.150 | 2.26 | 100 | -1.02 | 100 | 86 | -0.070 | 10.37 | 0.25 |
| 48 | 7.176 | 0.150 | 2.25 | 100 | -3.05 | 100 | 85 | -0.070 | 10.37 | 0.26 |
| 49 | 7.327 | 0.151 | 2.26 | 100 | -1.41 | 101 | 84 | -0.070 | 10.34 | 0.27 |
| 50 | 7.475 | 0.148 | 2.26 | 100 | -3.15 | 99 | 84 | -0.080 | 10.46 | 0.25 |
| 51 | 7.626 | 0.151 | 2.24 | 100 | -2.78 | 101 | 85 | -0.060 | 10.52 | 0.23 |
| 52 | 7.774 | 0.148 | 2.25 | 100 | -1.31 | 99 | 85 | -0.070 | 10.56 | 0.26 |
| 53 | 7.926 | 0.152 | 2.24 | 100 | -2.04 | 101 | 86 | -0.070 | 10.84 | 0.25 |
| 54 | 8.075 | 0.149 | 2.24 | 100 | -2.84 | 99 | 86 | -0.070 | 10.63 | 0.29 |
| 55 | 8.227 | 0.152 | 2.23 | 100 | -2.56 | 102 | 86 | -0.070 | 10.79 | 0.25 |
| 56 | 8.375 | 0.148 | 2.24 | 100 | -1.25 | 99 | 85 | -0.070 | 10.79 | 0.29 |
| 57 | 8.527 | 0.152 | 2.26 | 100 | -0.82 | 102 | 85 | -0.070 | 10.64 | 0.32 |
| 58 | 8.674 | 0.147 | 2.23 | 100 | -3.18 | 98 | 84 | -0.070 | 10.65 | 0.31 |
| 59 | 8.826 | 0.152 | 2.25 | 100 | -0.86 | 101 | 85 | -0.070 | 10.65 | 0.34 |
| 60 | 8.974 | 0.148 | 2.24 | 100 | -2.12 | 99 | 85 | -0.080 | 10.39 | 0.37 |
| 61 | 9.125 | 0.151 | 2.26 | 100 | -3.19 | 101 | 86 | -0.070 | 10.47 | 0.36 |
| 62 | 9.275 | 0.150 | 2.25 | 100 | -1.33 | 100 | 86 | -0.060 | 10.46 | 0.34 |
| 63 | 9.425 | 0.150 | 2.24 | 100 | -0.95 | 100 | 86 | -0.070 | 10.48 | 0.37 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 64 | 9.576 | 0.151 | 2.25 | 100 | -0.93 | 101 | 86 | -0.060 | 10.39 | 0.37 |
| 65 | 9.724 | 0.148 | 2.25 | 100 | -2.56 | 99 | 85 | -0.070 | 10.47 | 0.33 |
| 66 | 9.874 | 0.150 | 2.24 | 100 | -2.04 | 100 | 85 | -0.080 | 10.21 | 0.30 |
| 67 | 10.022 | 0.148 | 2.25 | 100 | -3.31 | 99 | 84 | -0.070 | 10.20 | 0.28 |
| 68 | 10.173 | 0.151 | 2.25 | 100 | -1.2 | 101 | 85 | -0.060 | 10.17 | 0.27 |
| 69 | 10.321 | 0.148 | 2.25 | 100 | -1.17 | 99 | 85 | -0.070 | 10.12 | 0.25 |
| 70 | 10.474 | 0.153 | 2.25 | 100 | -2.63 | 102 | 86 | -0.070 | 10.13 | 0.26 |
| 71 | 10.621 | 0.147 | 2.24 | 100 | -2.53 | 98 | 86 | -0.060 | 10.09 | 0.22 |
| 72 | 10.773 | 0.152 | 2.24 | 100 | -2.48 | 101 | 86 | -0.070 | 10.04 | 0.27 |
| 73 | 10.920 | 0.147 | 2.24 | 100 | -3.28 | 98 | 86 | -0.070 | 10.03 | 0.26 |
| 74 | 11.071 | 0.151 | 2.23 | 100 | -2.36 | 101 | 85 | -0.070 | 10.27 | 0.22 |
| 75 | 11.219 | 0.148 | 2.24 | 100 | -1.75 | 99 | 85 | -0.060 | 10.19 | 0.26 |
| 76 | 11.369 | 0.150 | 2.24 | 101 | -0.88 | 100 | 85 | -0.060 | 10.18 | 0.23 |
| 77 | 11.518 | 0.149 | 2.24 | 100 | -2.01 | 99 | 85 | -0.060 | 10.23 | 0.25 |
| 78 | 11.669 | 0.151 | 2.23 | 100 | -0.91 | 101 | 85 | -0.060 | 10.39 | 0.21 |
| 79 | 11.818 | 0.149 | 2.25 | 100 | -1.41 | 99 | 86 | -0.080 | 10.43 | 0.20 |
| 80 | 11.967 | 0.149 | 2.24 | 101 | -3.23 | 99 | 86 | -0.070 | 10.27 | 0.25 |
| 81 | 12.118 | 0.151 | 2.24 | 101 | -2.17 | 100 | 86 | -0.060 | 10.39 | 0.25 |
| 82 | 12.266 | 0.148 | 2.24 | 101 | -2.65 | 98 | 85 | -0.060 | 10.63 | 0.21 |
| 83 | 12.417 | 0.151 | 2.23 | 101 | -1.08 | 100 | 85 | -0.070 | 10.52 | 0.21 |
| 84 | 12.564 | 0.147 | 2.24 | 101 | -2.67 | 98 | 85 | -0.060 | 10.58 | 0.20 |
| 85 | 12.715 | 0.151 | 2.23 | 101 | -2.25 | 100 | 85 | -0.070 | 10.33 | 0.22 |
| 86 | 12.863 | 0.148 | 2.25 | 101 | -2.87 | 98 | 85 | -0.060 | 10.19 | 0.23 |
| 87 | 13.015 | 0.152 | 2.22 | 101 | -3.21 | 101 | 85 | -0.050 | 10.19 | 0.22 |
| 88 | 13.162 | 0.147 | 2.20 | 101 | -2.7 | 98 | 86 | -0.070 | 9.94 | 0.25 |
| 89 | 13.313 | 0.151 | 2.22 | 101 | -1.08 | 100 | 86 | -0.060 | 10.13 | 0.22 |
| 90 | 13.460 | 0.147 | 2.23 | 101 | -0.9 | 98 | 86 | -0.080 | 10.19 | 0.24 |
| 91 | 13.611 | 0.151 | 2.23 | 101 | -0.94 | 100 | 85 | -0.060 | 10.21 | 0.20 |
| 92 | 13.758 | 0.147 | 2.23 | 101 | -2.16 | 98 | 85 | -0.070 | 10.35 | 0.25 |
| 93 | 13.909 | 0.151 | 2.23 | 101 | -3.3 | 100 | 84 | -0.060 | 10.36 | 0.25 |
| 94 | 14.056 | 0.147 | 2.23 | 101 | -2.13 | 98 | 84 | -0.070 | 10.64 | 0.24 |
| 95 | 14.207 | 0.151 | 2.23 | 101 | -0.9 | 100 | 85 | -0.060 | 10.67 | 0.21 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 96 | 14.356 | 0.149 | 2.22 | 101 | -0.92 | 99 | 85 | -0.070 | 11.05 | 0.29 |
| 97 | 14.505 | 0.149 | 2.23 | 101 | -2.85 | 99 | 86 | -0.060 | 11.57 | 0.44 |
| 98 | 14.654 | 0.149 | 2.22 | 101 | -1.98 | 99 | 86 | -0.070 | 12.18 | 0.54 |
| 99 | 14.803 | 0.149 | 2.20 | 101 | -0.95 | 99 | 85 | -0.050 | 11.54 | 0.34 |
| 100 | 14.952 | 0.149 | 2.22 | 101 | -2.06 | 99 | 85 | -0.060 | 11.17 | 0.23 |
| 101 | 15.100 | 0.148 | 2.22 | 101 | -1.42 | 98 | 84 | -0.070 | 10.84 | 0.23 |
| 102 | 15.249 | 0.149 | 2.22 | 101 | -1.63 | 99 | 84 | -0.070 | 10.50 | 0.24 |
| 103 | 15.396 | 0.147 | 2.21 | 101 | -0.93 | 98 | 84 | -0.060 | 10.22 | 0.18 |
| 104 | 15.547 | 0.151 | 2.21 | 101 | -2.31 | 100 | 85 | -0.060 | 9.68 | 0.18 |
| 105 | 15.693 | 0.146 | 2.22 | 101 | -3.43 | 97 | 85 | -0.060 | 9.32 | 0.19 |
| 106 | 15.844 | 0.151 | 2.20 | 101 | -2.52 | 100 | 86 | -0.060 | 8.96 | 0.27 |
| 107 | 15.991 | 0.147 | 2.23 | 101 | -2.8 | 98 | 85 | -0.060 | 8.92 | 0.23 |
| 108 | 16.143 | 0.152 | 2.21 | 101 | -2.03 | 101 | 85 | -0.060 | 8.75 | 0.26 |
| 109 | 16.289 | 0.146 | 2.21 | 101 | -1.5 | 97 | 85 | -0.060 | 8.60 | 0.27 |
| 110 | 16.440 | 0.151 | 2.23 | 101 | -3.31 | 101 | 84 | -0.040 | 8.47 | 0.30 |
| 111 | 16.587 | 0.147 | 2.26 | 101 | -1.06 | 98 | 84 | -0.070 | 8.33 | 0.33 |
| 112 | 16.739 | 0.152 | 2.23 | 101 | -1.07 | 101 | 84 | -0.060 | 8.09 | 0.31 |
| 113 | 16.885 | 0.146 | 2.22 | 101 | -1.17 | 97 | 85 | -0.060 | 8.12 | 0.33 |
| 114 | 17.037 | 0.152 | 2.24 | 101 | -0.94 | 101 | 86 | -0.050 | 8.09 | 0.38 |
| 115 | 17.184 | 0.147 | 2.24 | 101 | -2.41 | 98 | 86 | -0.060 | 8.03 | 0.32 |
| 116 | 17.335 | 0.151 | 2.23 | 101 | -2.87 | 101 | 86 | -0.060 | 7.92 | 0.33 |
| 117 | 17.484 | 0.149 | 2.23 | 101 | -1.11 | 99 | 86 | -0.060 | 7.75 | 0.36 |
| 118 | 17.634 | 0.150 | 2.24 | 101 | -3.27 | 100 | 85 | -0.060 | 7.97 | 0.35 |
| 119 | 17.783 | 0.149 | 2.22 | 101 | -2.97 | 99 | 85 | -0.060 | 7.92 | 0.34 |
| 120 | 17.932 | 0.149 | 2.24 | 101 | -3.35 | 99 | 84 | -0.070 | 7.86 | 0.35 |
| 121 | 18.082 | 0.150 | 2.23 | 101 | -1.72 | 100 | 84 | -0.050 | 7.72 | 0.36 |
| 122 | 18.229 | 0.147 | 2.23 | 101 | -2.08 | 98 | 85 | -0.050 | 7.76 | 0.35 |
| 123 | 18.380 | 0.151 | 2.21 | 101 | -3.04 | 101 | 86 | -0.060 | 7.68 | 0.37 |
| 124 | 18.527 | 0.147 | 2.22 | 101 | -1.27 | 98 | 86 | -0.050 | 7.93 | 0.32 |
| 125 | 18.678 | 0.151 | 2.21 | 101 | -3.35 | 101 | 86 | -0.060 | 7.99 | 0.33 |
| 126 | 18.825 | 0.147 | 2.23 | 101 | -0.97 | 98 | 86 | -0.060 | 7.97 | 0.34 |
| 127 | 18.977 | 0.152 | 2.21 | 101 | -1.35 | 101 | 86 | -0.060 | 7.92 | 0.37 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 128 | 19.124 | 0.147 | 2.21 | 101 | -1.22 | 98 | 85 | -0.050 | 7.90 | 0.37 |
| 129 | 19.275 | 0.151 | 2.21 | 101 | -2.23 | 101 | 85 | -0.060 | 7.98 | 0.38 |
| 130 | 19.422 | 0.147 | 2.22 | 101 | -3.27 | 98 | 85 | -0.050 | 7.96 | 0.34 |
| 131 | 19.573 | 0.151 | 2.22 | 101 | -3.19 | 101 | 85 | -0.070 | 7.78 | 0.40 |
| 132 | 19.719 | 0.146 | 2.22 | 101 | -1.75 | 97 | 85 | -0.060 | 8.02 | 0.37 |
| 133 | 19.869 | 0.150 | 2.20 | 101 | -1.42 | 100 | 86 | -0.050 | 7.82 | 0.41 |
| 134 | 20.016 | 0.147 | 2.21 | 101 | -1.03 | 98 | 86 | -0.060 | 7.63 | 0.47 |
| 135 | 20.166 | 0.150 | 2.22 | 101 | -1.53 | 100 | 86 | -0.050 | 7.62 | 0.43 |
| 136 | 20.314 | 0.148 | 2.20 | 101 | -1.62 | 99 | 85 | -0.050 | 7.25 | 0.42 |
| 137 | 20.464 | 0.150 | 2.20 | 101 | -2.68 | 100 | 85 | -0.040 | 7.11 | 0.42 |
| 138 | 20.611 | 0.147 | 2.20 | 101 | -3.2 | 98 | 84 | -0.060 | 6.88 | 0.48 |
| 139 | 20.761 | 0.150 | 2.19 | 101 | -0.98 | 100 | 85 | -0.050 | 6.97 | 0.48 |
| 140 | 20.908 | 0.147 | 2.17 | 101 | -1.51 | 98 | 85 | -0.050 | 6.97 | 0.49 |
| 141 | 21.055 | 0.147 | 2.17 | 101 | -1.22 | 98 | 86 | -0.050 | 6.77 | 0.54 |
| 142 | 21.203 | 0.148 | 2.14 | 101 | -1.1 | 99 | 86 | -0.050 | 7.02 | 0.48 |
| 143 | 21.349 | 0.146 | 2.12 | 101 | -3.33 | 97 | 86 | -0.050 | 7.00 | 0.53 |
| 144 | 21.494 | 0.145 | 2.09 | 101 | -3.28 | 97 | 86 | -0.060 | 6.90 | 0.55 |
| 145 | 21.638 | 0.144 | 2.05 | 101 | -1.39 | 96 | 85 | -0.050 | 6.87 | 0.55 |
| 146 | 21.779 | 0.141 | 2.01 | 101 | -3.08 | 94 | 85 | -0.060 | 7.00 | 0.52 |
| 147 | 21.922 | 0.143 | 1.94 | 101 | -3.92 | 95 | 84 | -0.060 | 6.87 | 0.55 |
| 148 | 22.059 | 0.137 | 1.88 | 101 | -2.32 | 91 | 85 | -0.040 | 7.18 | 0.50 |
| 149 | 22.196 | 0.137 | 1.82 | 101 | -1.91 | 91 | 85 | -0.050 | 7.08 | 0.50 |
| 150 | 22.330 | 0.134 | 1.74 | 101 | -3.92 | 89 | 86 | -0.050 | 7.27 | 0.46 |
| 151 | 22.459 | 0.129 | 1.67 | 101 | -3.53 | 86 | 86 | -0.040 | 7.20 | 0.48 |
| 152 | 22.588 | 0.129 | 1.57 | 101 | -4.61 | 86 | 86 | -0.050 | 7.25 | 0.45 |
| 153 | 22.712 | 0.124 | 1.49 | 101 | -4.52 | 83 | 86 | -0.050 | 7.23 | 0.45 |
| 154 | 22.830 | 0.118 | 1.39 | 101 | -3.1 | 79 | 85 | -0.040 | 7.18 | 0.50 |
| 155 | 22.946 | 0.116 | 1.28 | 101 | -3.21 | 77 | 85 | -0.050 | 7.21 | 0.46 |
| 156 | 23.060 | 0.114 | 1.20 | 101 | -5.51 | 76 | 85 | -0.050 | 7.24 | 0.46 |
| 157 | 23.214 | 0.154 | 3.28 | 101 | -0.38 | 103 | 80 | -0.060 | 7.20 | 0.47 |
| 158 | 23.391 | 0.177 | 3.09 | 101 | -0.82 | 118 | 84 | -0.040 | 7.19 | 0.43 |
| 159 | 23.545 | 0.154 | 2.39 | 101 | -2.79 | 103 | 85 | -0.030 | 7.15 | 0.45 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 160 | 23.699 | 0.154 | 2.28 | 102 | -1.26 | 102 | 86 | -0.050 | 7.19 | 0.43 |
| 161 | 23.850 | 0.151 | 2.26 | 102 | -2.88 | 100 | 86 | -0.050 | 7.14 | 0.45 |
| 162 | 23.999 | 0.149 | 2.27 | 102 | -0.57 | 99 | 86 | -0.050 | 7.14 | 0.48 |
| 163 | 24.152 | 0.153 | 2.27 | 102 | -1.26 | 102 | 85 | -0.060 | 7.18 | 0.46 |
| 164 | 24.300 | 0.148 | 2.26 | 102 | -2.88 | 98 | 85 | -0.050 | 7.23 | 0.42 |
| 165 | 24.454 | 0.154 | 2.26 | 102 | -2.15 | 102 | 84 | -0.050 | 7.22 | 0.44 |
| 166 | 24.602 | 0.148 | 2.28 | 102 | -1.18 | 98 | 84 | -0.050 | 7.27 | 0.43 |
| 167 | 24.754 | 0.152 | 2.26 | 102 | -2.69 | 101 | 84 | -0.050 | 7.11 | 0.44 |
| 168 | 24.903 | 0.149 | 2.27 | 102 | -1.84 | 99 | 85 | -0.050 | 6.89 | 0.47 |
| 169 | 25.055 | 0.152 | 2.27 | 102 | -2.14 | 101 | 86 | -0.040 | 6.82 | 0.49 |
| 170 | 25.206 | 0.151 | 2.27 | 102 | -2.22 | 100 | 86 | -0.040 | 6.89 | 0.51 |
| 171 | 25.357 | 0.151 | 2.27 | 102 | -2.92 | 100 | 86 | -0.030 | 6.23 | 0.58 |
| 172 | 25.508 | 0.151 | 2.28 | 102 | -2.98 | 100 | 86 | -0.050 | 6.31 | 0.56 |
| 173 | 25.657 | 0.149 | 2.27 | 102 | -2.78 | 99 | 85 | -0.040 | 5.65 | 1.13 |
| 174 | 25.809 | 0.152 | 2.28 | 102 | -2.89 | 101 | 85 | -0.050 | 5.46 | 1.30 |
| 175 | 25.957 | 0.148 | 2.25 | 102 | -1.49 | 98 | 84 | -0.050 | 5.52 | 1.28 |
| 176 | 26.111 | 0.154 | 2.26 | 102 | -1.43 | 102 | 84 | -0.040 | 5.64 | 1.31 |
| 177 | 26.258 | 0.147 | 2.26 | 102 | -1.13 | 98 | 85 | -0.040 | 6.10 | 1.11 |
| 178 | 26.411 | 0.153 | 2.23 | 102 | -1.75 | 102 | 85 | -0.040 | 5.63 | 1.30 |
| 179 | 26.559 | 0.148 | 2.24 | 102 | -0.52 | 98 | 86 | -0.040 | 5.67 | 1.31 |
| 180 | 26.710 | 0.151 | 2.25 | 102 | -0.68 | 100 | 86 | -0.050 | 5.50 | 1.27 |
| 181 | 26.858 | 0.148 | 2.23 | 102 | -2.2 | 98 | 86 | -0.040 | 5.62 | 1.26 |
| 182 | 27.009 | 0.151 | 2.21 | 102 | -2.79 | 100 | 85 | -0.040 | 5.56 | 1.29 |
| 183 | 27.157 | 0.148 | 2.21 | 102 | -2.76 | 98 | 85 | -0.040 | 5.48 | 1.30 |
| 184 | 27.307 | 0.150 | 2.20 | 102 | -1.03 | 99 | 84 | -0.040 | 5.46 | 1.27 |
| 185 | 27.455 | 0.148 | 2.19 | 102 | -1.57 | 98 | 84 | -0.040 | 5.69 | 1.28 |
| 186 | 27.604 | 0.149 | 2.17 | 102 | -3.13 | 99 | 85 | -0.030 | 5.65 | 1.36 |
| 187 | 27.751 | 0.147 | 2.16 | 102 | -2.5 | 97 | 85 | -0.040 | 5.40 | 1.45 |
| 188 | 27.898 | 0.147 | 2.16 | 102 | -0.96 | 97 | 86 | -0.040 | 5.49 | 1.46 |
| 189 | 28.046 | 0.148 | 2.15 | 102 | -0.83 | 98 | 86 | -0.040 | 5.73 | 1.45 |
| 190 | 28.192 | 0.146 | 2.14 | 102 | -2.37 | 97 | 86 | -0.050 | 5.66 | 1.45 |
| 191 | 28.339 | 0.147 | 2.15 | 102 | -2.06 | 97 | 85 | -0.040 | 6.20 | 1.27 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 192 | 28.485 | 0.146 | 2.14 | 102 | -3.12 | 97 | 85 | -0.040 | 6.19 | 1.19 |
| 193 | 28.632 | 0.147 | 2.13 | 102 | -2.88 | 97 | 85 | -0.030 | 6.16 | 1.22 |
| 194 | 28.778 | 0.146 | 2.14 | 102 | -2.15 | 97 | 84 | -0.050 | 6.63 | 0.87 |
| 195 | 28.925 | 0.147 | 2.13 | 102 | -0.81 | 97 | 85 | -0.040 | 6.55 | 0.79 |
| 196 | 29.071 | 0.146 | 2.13 | 102 | -0.89 | 97 | 85 | -0.040 | 6.90 | 0.73 |
| 197 | 29.217 | 0.146 | 2.14 | 102 | -0.97 | 97 | 86 | -0.050 | 6.92 | 0.70 |
| 198 | 29.363 | 0.146 | 2.13 | 102 | -1.18 | 97 | 86 | -0.030 | 6.99 | 0.65 |
| 199 | 29.510 | 0.147 | 2.13 | 102 | -3.35 | 97 | 86 | -0.050 | 6.91 | 0.62 |
| 200 | 29.656 | 0.146 | 2.13 | 102 | -1.84 | 97 | 85 | -0.050 | 6.82 | 0.64 |
| 201 | 29.802 | 0.146 | 2.13 | 102 | -1.73 | 97 | 85 | -0.040 | 6.87 | 0.63 |
| 202 | 29.948 | 0.146 | 2.12 | 102 | -1.29 | 97 | 85 | -0.030 | 6.96 | 0.57 |
| 203 | 30.094 | 0.146 | 2.11 | 102 | -3.28 | 97 | 85 | -0.040 | 6.65 | 0.79 |
| 204 | 30.240 | 0.146 | 2.11 | 102 | -1.13 | 97 | 85 | -0.050 | 6.00 | 1.49 |
| 205 | 30.385 | 0.145 | 2.10 | 102 | -1.04 | 96 | 85 | -0.040 | 5.93 | 1.45 |
| 206 | 30.530 | 0.145 | 2.10 | 102 | -1.29 | 96 | 86 | -0.040 | 5.90 | 1.46 |
| 207 | 30.674 | 0.144 | 2.09 | 102 | -1.93 | 95 | 86 | -0.050 | 5.84 | 1.36 |
| 208 | 30.821 | 0.147 | 2.10 | 102 | -1.83 | 97 | 86 | -0.040 | 5.78 | 1.31 |
| 209 | 30.965 | 0.144 | 2.09 | 102 | -0.89 | 95 | 85 | -0.040 | 5.81 | 1.28 |
| 210 | 31.112 | 0.147 | 2.10 | 102 | -1.44 | 97 | 85 | -0.040 | 5.70 | 1.28 |
| 211 | 31.255 | 0.143 | 2.08 | 102 | -3.02 | 95 | 84 | -0.040 | 5.81 | 1.26 |
| 212 | 31.402 | 0.147 | 2.09 | 102 | -3.31 | 97 | 85 | -0.030 | 5.70 | 1.28 |
| 213 | 31.545 | 0.143 | 2.09 | 102 | -3.38 | 95 | 85 | -0.030 | 5.76 | 1.27 |
| 214 | 31.693 | 0.148 | 2.22 | 102 | -0.95 | 98 | 86 | -0.030 | 5.77 | 1.23 |
| 215 | 31.840 | 0.147 | 2.22 | 103 | -1.65 | 97 | 86 | -0.040 | 5.65 | 1.22 |
| 216 | 31.991 | 0.151 | 2.22 | 103 | -1.45 | 100 | 86 | -0.020 | 5.62 | 1.23 |
| 217 | 32.138 | 0.147 | 2.21 | 103 | -0.97 | 97 | 86 | -0.030 | 5.98 | 1.17 |
| 218 | 32.289 | 0.151 | 2.21 | 103 | -1.75 | 100 | 85 | -0.030 | 5.79 | 1.13 |
| 219 | 32.438 | 0.149 | 2.22 | 103 | -1.48 | 98 | 85 | -0.050 | 5.64 | 1.15 |
| 220 | 32.587 | 0.149 | 2.21 | 103 | -3.31 | 98 | 85 | -0.040 | 5.89 | 1.09 |
| 221 | 32.736 | 0.149 | 2.20 | 103 | -2.12 | 98 | 85 | -0.040 | 5.91 | 1.09 |
| 222 | 32.885 | 0.149 | 2.19 | 103 | -2.96 | 98 | 85 | -0.030 | 5.88 | 1.12 |
| 223 | 33.035 | 0.150 | 2.22 | 103 | -2.38 | 99 | 86 | -0.030 | 5.91 | 1.16 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 224 | 33.182 | 0.147 | 2.21 | 103 | -0.92 | 97 | 86 | -0.030 | 5.78 | 1.19 |
| 225 | 33.332 | 0.150 | 2.20 | 103 | -3.01 | 99 | 86 | -0.030 | 6.03 | 1.17 |
| 226 | 33.479 | 0.147 | 2.20 | 103 | -2.32 | 97 | 85 | -0.050 | 5.77 | 1.31 |
| 227 | 33.630 | 0.151 | 2.21 | 103 | -1.02 | 100 | 85 | -0.020 | 5.87 | 1.22 |
| 228 | 33.776 | 0.146 | 2.21 | 103 | -2.31 | 96 | 84 | -0.040 | 5.84 | 1.24 |
| 229 | 33.927 | 0.151 | 2.19 | 103 | -1.7 | 100 | 85 | -0.020 | 5.99 | 1.22 |
| 230 | 34.074 | 0.147 | 2.20 | 103 | -1.41 | 97 | 85 | -0.050 | 5.94 | 1.20 |
| 231 | 34.225 | 0.151 | 2.20 | 103 | -1.38 | 100 | 85 | -0.030 | 6.05 | 1.23 |
| 232 | 34.371 | 0.146 | 2.19 | 103 | -1.09 | 96 | 86 | -0.030 | 6.17 | 1.19 |
| 233 | 34.522 | 0.151 | 2.19 | 103 | -3.35 | 100 | 86 | -0.020 | 6.09 | 1.22 |
| 234 | 34.667 | 0.145 | 2.19 | 103 | -1.63 | 96 | 85 | -0.040 | 5.82 | 1.33 |
| 235 | 34.818 | 0.151 | 2.17 | 103 | -1.84 | 100 | 85 | -0.030 | 5.71 | 1.26 |
| 236 | 34.964 | 0.146 | 2.19 | 103 | -2.84 | 96 | 84 | -0.030 | 5.85 | 1.21 |
| 237 | 35.114 | 0.150 | 2.18 | 103 | -1.48 | 99 | 84 | -0.030 | 5.74 | 1.22 |
| 238 | 35.260 | 0.146 | 2.18 | 103 | -1.4 | 97 | 85 | -0.030 | 5.76 | 1.20 |
| 239 | 35.409 | 0.149 | 2.18 | 103 | -3.42 | 98 | 85 | -0.030 | 5.93 | 1.15 |
| 240 | 35.555 | 0.146 | 2.17 | 103 | -2.35 | 97 | 86 | -0.030 | 5.86 | 1.12 |
| 241 | 35.706 | 0.151 | 2.29 | 103 | -3.48 | 100 | 86 | -0.040 | 5.88 | 1.14 |
| 242 | 35.856 | 0.150 | 2.28 | 103 | -2.77 | 99 | 86 | -0.040 | 5.77 | 1.17 |
| 243 | 36.008 | 0.152 | 2.27 | 103 | -3.56 | 100 | 86 | -0.030 | 6.03 | 1.18 |
| 244 | 36.160 | 0.152 | 2.28 | 103 | -1.49 | 100 | 85 | -0.030 | 5.76 | 1.18 |
| 245 | 36.310 | 0.150 | 2.28 | 103 | -1.34 | 99 | 85 | -0.030 | 6.05 | 1.20 |
| 246 | 36.462 | 0.152 | 2.28 | 103 | -1.34 | 100 | 84 | -0.030 | 5.93 | 1.24 |
| 247 | 36.611 | 0.149 | 2.27 | 103 | -2.81 | 98 | 84 | -0.030 | 5.82 | 1.31 |
| 248 | 36.765 | 0.154 | 2.27 | 103 | -1.26 | 102 | 85 | -0.040 | 5.91 | 1.36 |
| 249 | 36.914 | 0.149 | 2.27 | 103 | -3.05 | 98 | 85 | -0.040 | 6.00 | 1.39 |
| 250 | 37.068 | 0.154 | 2.27 | 103 | -1.33 | 102 | 86 | -0.040 | 5.97 | 1.35 |
| 251 | 37.215 | 0.147 | 2.27 | 103 | -1.07 | 97 | 86 | -0.030 | 6.28 | 1.17 |
| 252 | 37.368 | 0.153 | 2.28 | 103 | -1.92 | 101 | 86 | -0.030 | 6.24 | 1.22 |
| 253 | 37.517 | 0.149 | 2.26 | 103 | -2.48 | 98 | 85 | -0.030 | 6.35 | 0.99 |
| 254 | 37.670 | 0.153 | 2.27 | 103 | -1.2 | 101 | 85 | -0.040 | 6.31 | 0.96 |
| 255 | 37.821 | 0.151 | 2.28 | 103 | -3.1 | 100 | 85 | -0.030 | 6.41 | 0.91 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 256 | 37.971 | 0.150 | 2.28 | 103 | -1.31 | 99 | 84 | -0.030 | 6.50 | 0.84 |
| 257 | 38.122 | 0.151 | 2.26 | 103 | -2.22 | 100 | 85 | -0.040 | 6.30 | 0.85 |
| 258 | 38.272 | 0.150 | 2.27 | 103 | -1.26 | 99 | 85 | -0.040 | 6.37 | 0.84 |
| 259 | 38.426 | 0.154 | 2.28 | 103 | -1.15 | 102 | 86 | -0.030 | 6.60 | 0.80 |
| 260 | 38.574 | 0.148 | 2.28 | 103 | -1.85 | 98 | 86 | -0.030 | 6.53 | 0.75 |
| 261 | 38.728 | 0.154 | 2.26 | 103 | -1.19 | 102 | 85 | -0.040 | 6.45 | 0.76 |
| 262 | 38.876 | 0.148 | 2.27 | 103 | -1.53 | 98 | 85 | -0.040 | 6.62 | 0.73 |
| 263 | 39.029 | 0.153 | 2.30 | 103 | -2.11 | 101 | 84 | -0.040 | 6.56 | 0.71 |
| 264 | 39.178 | 0.149 | 2.28 | 103 | -1.36 | 98 | 85 | -0.030 | 6.58 | 0.72 |
| 265 | 39.331 | 0.153 | 2.27 | 103 | -1.1 | 101 | 85 | -0.040 | 6.73 | 0.70 |
| 266 | 39.482 | 0.151 | 2.28 | 103 | -3.24 | 100 | 86 | -0.040 | 6.59 | 0.73 |
| 267 | 39.633 | 0.151 | 2.27 | 103 | -2.35 | 100 | 86 | -0.050 | 6.42 | 0.71 |
| 268 | 39.784 | 0.151 | 2.27 | 103 | -1.56 | 100 | 86 | -0.040 | 6.48 | 0.74 |
| 269 | 39.933 | 0.149 | 2.29 | 103 | -3.47 | 98 | 85 | -0.040 | 6.30 | 0.77 |
| 270 | 40.088 | 0.155 | 2.29 | 103 | -1.28 | 102 | 85 | -0.040 | 6.46 | 0.71 |
| 271 | 40.236 | 0.148 | 2.27 | 103 | -2.29 | 98 | 85 | -0.050 | 6.42 | 0.70 |
| 272 | 40.391 | 0.155 | 2.28 | 103 | -1.55 | 102 | 85 | -0.040 | 6.17 | 0.76 |
| 273 | 40.538 | 0.147 | 2.28 | 103 | -3.52 | 97 | 85 | -0.030 | 5.58 | 0.70 |
| 274 | 40.692 | 0.154 | 2.29 | 103 | -2.43 | 102 | 85 | -0.030 | 5.51 | 0.74 |
| 275 | 40.841 | 0.149 | 2.28 | 103 | -1.11 | 98 | 86 | -0.040 | 5.24 | 0.89 |
| 276 | 40.994 | 0.153 | 2.28 | 103 | -1.09 | 101 | 86 | -0.030 | 5.42 | 1.05 |
| 277 | 41.146 | 0.152 | 2.27 | 103 | -1.04 | 100 | 86 | -0.040 | 5.34 | 1.04 |
| 278 | 41.296 | 0.150 | 2.28 | 103 | -3.22 | 99 | 85 | -0.030 | 5.18 | 1.06 |
| 279 | 41.449 | 0.153 | 2.29 | 103 | -1.25 | 101 | 85 | -0.040 | 5.23 | 0.99 |
| 280 | 41.597 | 0.148 | 2.28 | 103 | -1.13 | 98 | 84 | -0.040 | 5.20 | 0.95 |
| 281 | 41.752 | 0.155 | 2.28 | 103 | -1.31 | 102 | 85 | -0.040 | 5.28 | 0.93 |
| 282 | 41.901 | 0.149 | 2.28 | 103 | -3.47 | 98 | 85 | -0.030 | 5.18 | 0.94 |
| 283 | 42.055 | 0.154 | 2.29 | 103 | -3.41 | 102 | 86 | -0.050 | 5.19 | 0.91 |
| 284 | 42.204 | 0.149 | 2.29 | 103 | -2.02 | 98 | 86 | -0.030 | 5.35 | 0.89 |
| 285 | 42.356 | 0.152 | 2.28 | 103 | -1.64 | 100 | 86 | -0.030 | 5.36 | 0.91 |
| 286 | 42.507 | 0.151 | 2.28 | 103 | -1.13 | 100 | 86 | -0.030 | 5.29 | 0.90 |
| 287 | 42.659 | 0.152 | 2.28 | 103 | -1.91 | 100 | 85 | -0.040 | 5.36 | 0.89 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 288 | 42.812 | 0.153 | 2.29 | 103 | -1.19 | 101 | 85 | -0.030 | 5.37 | 0.91 |
| 289 | 42.961 | 0.149 | 2.29 | 103 | -3.38 | 98 | 84 | -0.040 | 5.38 | 0.89 |
| 290 | 43.114 | 0.153 | 2.29 | 103 | -1.41 | 101 | 85 | -0.040 | 5.25 | 0.91 |
| 291 | 43.264 | 0.150 | 2.29 | 103 | -2.52 | 99 | 85 | -0.020 | 5.35 | 0.88 |
| 292 | 43.418 | 0.154 | 2.29 | 103 | -2.46 | 102 | 86 | -0.030 | 5.25 | 0.90 |
| 293 | 43.567 | 0.149 | 2.30 | 103 | -1.53 | 98 | 86 | -0.030 | 5.31 | 0.92 |
| 294 | 43.721 | 0.154 | 2.31 | 103 | -1.84 | 102 | 86 | -0.050 | 5.20 | 0.92 |
| 295 | 43.870 | 0.149 | 2.29 | 103 | -1.15 | 98 | 85 | -0.030 | 5.39 | 0.90 |
| 296 | 44.024 | 0.154 | 2.29 | 103 | -1.02 | 102 | 85 | -0.030 | 5.12 | 0.91 |
| 297 | 44.176 | 0.152 | 2.29 | 103 | -2.84 | 100 | 85 | -0.030 | 5.29 | 0.85 |
| 298 | 44.326 | 0.150 | 2.30 | 103 | -1.18 | 99 | 84 | -0.040 | 5.24 | 0.88 |
| 299 | 44.479 | 0.153 | 2.29 | 103 | -2.4 | 101 | 85 | -0.030 | 5.20 | 0.91 |
| 300 | 44.629 | 0.150 | 2.30 | 103 | -3.15 | 99 | 85 | -0.050 | 5.21 | 0.91 |
| 301 | 44.784 | 0.155 | 2.30 | 103 | -1.59 | 102 | 86 | -0.040 | 5.09 | 0.87 |
| 302 | 44.934 | 0.150 | 2.32 | 103 | -2.76 | 99 | 86 | -0.030 | 5.30 | 0.87 |
| 303 | 45.087 | 0.153 | 2.30 | 103 | -1.84 | 101 | 86 | -0.040 | 5.10 | 0.85 |
| 304 | 45.237 | 0.150 | 2.31 | 104 | -1.03 | 99 | 85 | -0.010 | 5.32 | 0.85 |
| 305 | 45.391 | 0.154 | 2.32 | 104 | -3.23 | 101 | 85 | -0.040 | 5.12 | 0.87 |
| 306 | 45.543 | 0.152 | 2.31 | 104 | -0.99 | 100 | 84 | -0.030 | 5.20 | 0.85 |
| 307 | 45.694 | 0.151 | 2.31 | 104 | -3.36 | 99 | 85 | -0.030 | 5.17 | 0.89 |
| 308 | 45.848 | 0.154 | 2.31 | 104 | -1.1 | 102 | 85 | -0.030 | 5.20 | 0.87 |
| 309 | 45.998 | 0.150 | 2.31 | 104 | -2.04 | 99 | 85 | -0.020 | 5.25 | 0.85 |
| 310 | 46.153 | 0.155 | 2.32 | 103 | -1 | 102 | 86 | -0.030 | 5.12 | 0.89 |
| 311 | 46.303 | 0.150 | 2.31 | 103 | -2.71 | 99 | 86 | -0.030 | 5.23 | 0.88 |
| 312 | 46.457 | 0.154 | 2.32 | 103 | -3.28 | 102 | 86 | -0.030 | 5.23 | 0.89 |
| 313 | 46.607 | 0.150 | 2.32 | 103 | -2.88 | 99 | 85 | -0.030 | 5.39 | 0.88 |
| 314 | 46.761 | 0.154 | 2.32 | 103 | -2.38 | 102 | 84 | -0.040 | 5.32 | 0.86 |
| 315 | 46.915 | 0.154 | 2.32 | 103 | -1.34 | 102 | 85 | -0.030 | 5.43 | 0.86 |
| 316 | 47.065 | 0.150 | 2.32 | 103 | -2.46 | 99 | 85 | -0.030 | 5.41 | 0.86 |
| 317 | 47.219 | 0.154 | 2.32 | 102 | -1.44 | 102 | 85 | -0.040 | 5.29 | 0.85 |
| 318 | 47.370 | 0.151 | 2.32 | 102 | -1.99 | 100 | 86 | -0.030 | 5.26 | 0.89 |
| 319 | 47.525 | 0.155 | 2.30 | 102 | -1.78 | 102 | 86 | -0.030 | 5.30 | 0.90 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 320 | 47.674 | 0.149 | 2.32 | 102 | -1.94 | 98 | 86 | -0.030 | 5.30 | 0.90 |
| 321 | 47.828 | 0.154 | 2.33 | 102 | -1.61 | 102 | 85 | -0.030 | 5.31 | 0.90 |
| 322 | 47.981 | 0.153 | 2.33 | 102 | -2 | 101 | 85 | -0.040 | 5.29 | 0.90 |
| 323 | 48.134 | 0.153 | 2.31 | 102 | -2.87 | 101 | 84 | -0.030 | 5.46 | 0.86 |
| 324 | 48.287 | 0.153 | 2.34 | 102 | -0.94 | 101 | 85 | -0.030 | 5.34 | 0.91 |
| 325 | 48.437 | 0.150 | 2.33 | 102 | -1.88 | 99 | 85 | -0.040 | 5.30 | 0.88 |
| 326 | 48.593 | 0.156 | 2.33 | 102 | -0.97 | 103 | 86 | -0.040 | 5.32 | 0.86 |
| 327 | 48.743 | 0.150 | 2.33 | 102 | -2.84 | 99 | 86 | -0.040 | 5.31 | 0.90 |
| 328 | 48.898 | 0.155 | 2.33 | 102 | -3.09 | 102 | 86 | -0.040 | 5.28 | 0.87 |
| 329 | 49.048 | 0.150 | 2.33 | 102 | -3.42 | 99 | 86 | -0.030 | 5.26 | 0.86 |
| 330 | 49.203 | 0.155 | 2.33 | 102 | -3.33 | 102 | 85 | -0.030 | 5.41 | 0.87 |
| 331 | 49.356 | 0.153 | 2.34 | 102 | -2.89 | 101 | 85 | -0.030 | 5.32 | 0.84 |
| 332 | 49.507 | 0.151 | 2.33 | 102 | -3.43 | 100 | 85 | -0.030 | 5.26 | 0.86 |
| 333 | 49.661 | 0.154 | 2.33 | 102 | -3.22 | 102 | 85 | -0.040 | 5.30 | 0.87 |
| 334 | 49.813 | 0.152 | 2.33 | 102 | -1.55 | 100 | 86 | -0.030 | 5.40 | 0.84 |
| 335 | 49.968 | 0.155 | 2.32 | 102 | -3.43 | 102 | 86 | -0.040 | 5.35 | 0.87 |
| 336 | 50.118 | 0.150 | 2.34 | 102 | -2.27 | 99 | 86 | -0.030 | 5.39 | 0.86 |
| 337 | 50.272 | 0.154 | 2.34 | 103 | -2.59 | 101 | 86 | -0.040 | 5.28 | 0.89 |
| 338 | 50.425 | 0.153 | 2.33 | 103 | -1.04 | 101 | 85 | -0.040 | 5.33 | 0.87 |
| 339 | 50.579 | 0.154 | 2.34 | 103 | -2.42 | 101 | 85 | -0.010 | 5.20 | 0.85 |
| 340 | 50.732 | 0.153 | 2.33 | 103 | -1.01 | 101 | 85 | -0.040 | 5.40 | 0.86 |
| 341 | 50.883 | 0.151 | 2.34 | 103 | -1.75 | 99 | 85 | -0.030 | 5.32 | 0.86 |
| 342 | 51.039 | 0.156 | 2.34 | 103 | -2.9 | 103 | 86 | -0.030 | 5.31 | 0.85 |
| 343 | 51.190 | 0.151 | 2.36 | 103 | -1.5 | 99 | 86 | -0.040 | 5.30 | 0.84 |
| 344 | 51.345 | 0.155 | 2.34 | 103 | -3.4 | 102 | 86 | -0.030 | 5.33 | 0.87 |
| 345 | 51.496 | 0.151 | 2.34 | 103 | -1.02 | 99 | 86 | -0.030 | 5.20 | 0.85 |
| 346 | 51.650 | 0.154 | 2.33 | 103 | -1.41 | 101 | 86 | -0.030 | 5.25 | 0.85 |
| 347 | 51.805 | 0.155 | 2.34 | 103 | -1.03 | 102 | 85 | -0.040 | 5.20 | 0.83 |
| 348 | 51.955 | 0.150 | 2.34 | 103 | -2.26 | 98 | 85 | -0.030 | 5.16 | 0.85 |
| 349 | 52.111 | 0.156 | 2.35 | 103 | -1.26 | 102 | 85 | -0.030 | 5.29 | 0.83 |
| 350 | 52.262 | 0.151 | 2.34 | 103 | -2.69 | 99 | 85 | -0.030 | 5.34 | 0.84 |
| 351 | 52.417 | 0.155 | 2.34 | 103 | -1.28 | 102 | 86 | -0.030 | 5.30 | 0.87 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 352 | 52.568 | 0.151 | 2.37 | 103 | -3.38 | 99 | 86 | -0.040 | 5.24 | 0.87 |
| 353 | 52.724 | 0.156 | 2.35 | 103 | -3.14 | 102 | 86 | -0.030 | 5.30 | 0.85 |
| 354 | 52.878 | 0.154 | 2.35 | 103 | -3.33 | 101 | 86 | -0.040 | 5.27 | 0.85 |
| 355 | 53.029 | 0.151 | 2.35 | 103 | -1.84 | 99 | 85 | -0.030 | 5.30 | 0.85 |
| 356 | 53.184 | 0.155 | 2.35 | 103 | -1.25 | 102 | 85 | -0.020 | 5.22 | 0.83 |
| 357 | 53.336 | 0.152 | 2.35 | 103 | -1.35 | 100 | 85 | -0.040 | 5.20 | 0.89 |
| 358 | 53.491 | 0.155 | 2.36 | 103 | -3.29 | 102 | 85 | -0.030 | 5.17 | 0.91 |
| 359 | 53.643 | 0.152 | 2.35 | 103 | -1.9 | 100 | 85 | -0.030 | 5.24 | 0.88 |
| 360 | 53.798 | 0.155 | 2.35 | 103 | -1.48 | 102 | 86 | -0.030 | 5.38 | 0.86 |
| 361 | 53.952 | 0.154 | 2.37 | 103 | -2.62 | 101 | 86 | -0.040 | 5.19 | 0.88 |
| 362 | 54.104 | 0.152 | 2.36 | 103 | -2.88 | 100 | 86 | -0.040 | 5.28 | 0.87 |
| 363 | 54.259 | 0.155 | 2.35 | 103 | -2.06 | 102 | 86 | -0.040 | 5.26 | 0.84 |
| 364 | 54.411 | 0.152 | 2.34 | 103 | -1.12 | 100 | 85 | -0.030 | 5.17 | 0.85 |
| 365 | 54.567 | 0.156 | 2.37 | 103 | -1.04 | 102 | 84 | -0.040 | 5.06 | 0.89 |
| 366 | 54.718 | 0.151 | 2.36 | 103 | -1.09 | 99 | 85 | -0.040 | 5.30 | 0.83 |
| 367 | 54.873 | 0.155 | 2.35 | 103 | -3.29 | 102 | 85 | -0.030 | 5.10 | 0.86 |
| 368 | 55.028 | 0.155 | 2.36 | 103 | -1.31 | 102 | 85 | -0.030 | 5.31 | 0.83 |
| 369 | 55.179 | 0.151 | 2.37 | 103 | -1.02 | 99 | 86 | -0.040 | 5.28 | 0.85 |
| 370 | 55.335 | 0.156 | 2.35 | 103 | -2.65 | 102 | 86 | -0.040 | 5.25 | 0.86 |
| 371 | 55.487 | 0.152 | 2.34 | 103 | -3.34 | 100 | 86 | -0.020 | 5.31 | 0.83 |
| 372 | 55.643 | 0.156 | 2.37 | 103 | -1.81 | 102 | 86 | -0.030 | 5.12 | 0.89 |
| 373 | 55.794 | 0.151 | 2.36 | 103 | -1.29 | 99 | 85 | -0.030 | 5.14 | 0.87 |
| 374 | 55.950 | 0.156 | 2.36 | 103 | -1.64 | 102 | 85 | -0.040 | 5.23 | 0.87 |
| 375 | 56.105 | 0.155 | 2.35 | 103 | -1.13 | 102 | 85 | -0.040 | 5.18 | 0.87 |
| 376 | 56.256 | 0.151 | 2.37 | 103 | -3.33 | 99 | 85 | -0.040 | 5.16 | 0.89 |
| 377 | 56.413 | 0.157 | 2.36 | 103 | -1.47 | 103 | 86 | -0.030 | 5.38 | 0.90 |
| 378 | 56.565 | 0.152 | 2.35 | 103 | -2.74 | 100 | 86 | -0.020 | 5.28 | 0.87 |
| 379 | 56.720 | 0.155 | 2.37 | 104 | -1.05 | 101 | 86 | -0.040 | 5.12 | 0.93 |
| 380 | 56.872 | 0.152 | 2.36 | 104 | -3.31 | 99 | 86 | -0.040 | 5.23 | 0.92 |
| 381 | 57.027 | 0.155 | 2.36 | 104 | -1.02 | 101 | 85 | -0.030 | 5.34 | 0.89 |
| 382 | 57.182 | 0.155 | 2.36 | 104 | -2.93 | 101 | 84 | -0.040 | 5.26 | 0.91 |
| 383 | 57.333 | 0.151 | 2.37 | 104 | -1.73 | 99 | 85 | -0.040 | 5.11 | 0.86 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 384 | 57.491 | 0.158 | 2.37 | 104 | -2.61 | 103 | 85 | -0.030 | 5.16 | 0.90 |
| 385 | 57.642 | 0.151 | 2.37 | 104 | -3.19 | 99 | 85 | -0.040 | 5.39 | 0.87 |
| 386 | 57.798 | 0.156 | 2.37 | 104 | -3.35 | 102 | 86 | -0.030 | 5.17 | 0.92 |
| 387 | 57.951 | 0.153 | 2.35 | 104 | -3.22 | 100 | 86 | -0.050 | 5.23 | 0.89 |
| 388 | 58.106 | 0.155 | 2.39 | 104 | -1.1 | 101 | 86 | -0.030 | 5.24 | 0.85 |
| 389 | 58.261 | 0.155 | 2.39 | 104 | -3.27 | 101 | 86 | -0.030 | 5.19 | 0.86 |
| 390 | 58.413 | 0.152 | 2.38 | 104 | -0.92 | 99 | 85 | -0.020 | 5.31 | 0.90 |
| 391 | 58.570 | 0.157 | 2.37 | 104 | -2.25 | 103 | 85 | -0.030 | 5.22 | 0.86 |
| 392 | 58.721 | 0.151 | 2.35 | 104 | -0.87 | 99 | 85 | -0.030 | 5.16 | 0.87 |
| 393 | 58.876 | 0.155 | 2.38 | 104 | -2.53 | 101 | 85 | -0.030 | 5.28 | 0.84 |
| 394 | 59.031 | 0.155 | 2.37 | 104 | -1.31 | 101 | 86 | -0.030 | 4.82 | 0.85 |
| 395 | 59.184 | 0.153 | 2.38 | 104 | -1.34 | 100 | 86 | -0.030 | 5.06 | 0.84 |
| 396 | 59.340 | 0.156 | 2.39 | 104 | -2.56 | 102 | 86 | -0.040 | 4.92 | 0.82 |
| 397 | 59.493 | 0.153 | 2.37 | 104 | -1.24 | 100 | 86 | -0.030 | 4.90 | 0.83 |
| 398 | 59.649 | 0.156 | 2.38 | 104 | -2.89 | 102 | 85 | -0.020 | 5.00 | 0.80 |
| 399 | 59.801 | 0.152 | 2.37 | 104 | -1.5 | 99 | 84 | -0.030 | 4.95 | 0.84 |
| 400 | 59.957 | 0.156 | 2.37 | 104 | -1.35 | 102 | 85 | -0.030 | 5.02 | 0.79 |
| 401 | 60.112 | 0.155 | 2.37 | 104 | -3.17 | 101 | 85 | -0.030 | 5.11 | 0.80 |
| 402 | 60.264 | 0.152 | 2.38 | 104 | -0.91 | 99 | 86 | -0.030 | 4.87 | 0.85 |
| 403 | 60.421 | 0.157 | 2.37 | 104 | -1.03 | 103 | 86 | -0.030 | 5.06 | 0.80 |
| 404 | 60.573 | 0.152 | 2.40 | 104 | -1.41 | 99 | 86 | -0.030 | 5.01 | 0.80 |
| 405 | 60.729 | 0.156 | 2.39 | 104 | -0.92 | 102 | 86 | -0.030 | 5.14 | 0.80 |
| 406 | 60.882 | 0.153 | 2.39 | 104 | -2.54 | 100 | 85 | -0.030 | 5.20 | 0.85 |
| 407 | 61.037 | 0.155 | 2.37 | 104 | -3.13 | 101 | 85 | -0.040 | 5.16 | 0.85 |
| 408 | 61.192 | 0.155 | 2.38 | 104 | -0.92 | 101 | 85 | -0.040 | 5.15 | 0.86 |
| 409 | 61.345 | 0.153 | 2.38 | 104 | -0.95 | 100 | 85 | -0.030 | 5.13 | 0.88 |
| 410 | 61.502 | 0.157 | 2.38 | 104 | -0.91 | 103 | 85 | -0.010 | 5.14 | 0.89 |
| 411 | 61.653 | 0.151 | 2.38 | 104 | -0.95 | 99 | 86 | -0.030 | 5.15 | 0.89 |
| 412 | 61.809 | 0.156 | 2.38 | 104 | -0.91 | 102 | 86 | -0.010 | 5.18 | 0.87 |
| 413 | 61.964 | 0.155 | 2.38 | 104 | -3.22 | 101 | 86 | -0.040 | 5.19 | 0.85 |
| 414 | 62.117 | 0.153 | 2.41 | 104 | -1.88 | 100 | 85 | -0.030 | 5.13 | 0.89 |
| 415 | 62.273 | 0.156 | 2.38 | 104 | -3.38 | 102 | 85 | -0.040 | 5.20 | 0.86 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 416 | 62.426 | 0.153 | 2.38 | 104 | -1.95 | 100 | 84 | -0.020 | 5.03 | 0.86 |
| 417 | 62.582 | 0.156 | 2.40 | 104 | -0.9 | 102 | 85 | -0.030 | 5.19 | 0.88 |
| 418 | 62.734 | 0.152 | 2.38 | 104 | -1.04 | 99 | 85 | -0.030 | 5.39 | 0.87 |
| 419 | 62.891 | 0.157 | 2.38 | 104 | -0.87 | 103 | 86 | -0.040 | 5.27 | 0.87 |
| 420 | 63.046 | 0.155 | 2.39 | 104 | -0.93 | 101 | 86 | -0.030 | 5.34 | 0.89 |
| 421 | 63.198 | 0.152 | 2.38 | 104 | -3.2 | 99 | 86 | -0.040 | 5.34 | 0.86 |
| 422 | 63.356 | 0.158 | 2.38 | 104 | -0.86 | 103 | 85 | -0.030 | 5.37 | 0.83 |
| 423 | 63.507 | 0.151 | 2.40 | 104 | -3.44 | 99 | 85 | -0.020 | 5.38 | 0.87 |
| 424 | 63.663 | 0.156 | 2.39 | 104 | -3.21 | 102 | 84 | -0.040 | 5.35 | 0.86 |
| 425 | 63.818 | 0.155 | 2.38 | 104 | -1.78 | 101 | 85 | -0.040 | 5.39 | 0.86 |
| 426 | 63.972 | 0.154 | 2.37 | 104 | -2.25 | 101 | 85 | -0.030 | 5.31 | 0.90 |
| 427 | 64.127 | 0.155 | 2.38 | 104 | -0.98 | 101 | 85 | -0.030 | 5.37 | 0.88 |
| 428 | 64.280 | 0.153 | 2.37 | 104 | -3.3 | 100 | 86 | -0.030 | 5.41 | 0.90 |
| 429 | 64.437 | 0.157 | 2.38 | 104 | -0.92 | 103 | 86 | -0.040 | 5.39 | 0.90 |
| 430 | 64.589 | 0.152 | 2.39 | 104 | -1.07 | 99 | 86 | -0.040 | 5.40 | 0.88 |
| 431 | 64.744 | 0.155 | 2.38 | 104 | -1.47 | 101 | 85 | -0.030 | 5.44 | 0.89 |
| 432 | 64.900 | 0.156 | 2.40 | 104 | -1.9 | 102 | 84 | -0.040 | 5.29 | 0.88 |
| 433 | 65.052 | 0.152 | 2.39 | 104 | -1.27 | 99 | 84 | -0.030 | 5.52 | 0.89 |
| 434 | 65.209 | 0.157 | 2.39 | 104 | -3.32 | 103 | 85 | -0.040 | 5.52 | 0.88 |
| 435 | 65.361 | 0.152 | 2.36 | 104 | -2.94 | 99 | 85 | -0.020 | 5.44 | 0.91 |
| 436 | 65.517 | 0.156 | 2.40 | 104 | -1.5 | 102 | 86 | -0.030 | 5.59 | 0.89 |
| 437 | 65.671 | 0.154 | 2.38 | 104 | -2.78 | 101 | 86 | -0.020 | 5.54 | 0.91 |
| 438 | 65.826 | 0.155 | 2.40 | 104 | -1.48 | 101 | 86 | -0.040 | 5.51 | 0.91 |
| 439 | 65.980 | 0.154 | 2.37 | 104 | -0.85 | 101 | 85 | -0.030 | 5.38 | 0.90 |
| 440 | 66.133 | 0.153 | 2.38 | 104 | -1.16 | 100 | 85 | -0.040 | 5.61 | 0.88 |
| 441 | 66.290 | 0.157 | 2.38 | 104 | -2.59 | 103 | 85 | -0.040 | 5.42 | 0.87 |
| 442 | 66.442 | 0.152 | 2.39 | 104 | -2.35 | 99 | 85 | -0.040 | 5.59 | 0.85 |
| 443 | 66.598 | 0.156 | 2.37 | 104 | -2.43 | 102 | 85 | -0.040 | 5.45 | 0.89 |
| 444 | 66.753 | 0.155 | 2.38 | 104 | -0.86 | 101 | 86 | -0.020 | 5.29 | 0.97 |
| 445 | 66.906 | 0.153 | 2.38 | 104 | -0.94 | 100 | 86 | -0.030 | 5.37 | 0.95 |
| 446 | 67.061 | 0.155 | 2.39 | 104 | -1.2 | 101 | 86 | -0.020 | 5.36 | 0.94 |
| 447 | 67.215 | 0.154 | 2.37 | 104 | -3.02 | 101 | 86 | -0.040 | 5.34 | 0.92 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 448 | 67.371 | 0.156 | 2.38 | 104 | -0.93 | 102 | 85 | -0.030 | 5.48 | 0.91 |
| 449 | 67.523 | 0.152 | 2.39 | 104 | -0.93 | 99 | 85 | -0.040 | 5.37 | 0.87 |
| 450 | 67.679 | 0.156 | 2.38 | 104 | -1.06 | 102 | 85 | -0.030 | 5.47 | 0.86 |
| 451 | 67.834 | 0.155 | 2.39 | 104 | -0.95 | 101 | 85 | -0.040 | 5.28 | 0.89 |
| 452 | 67.986 | 0.152 | 2.39 | 104 | -3.32 | 99 | 85 | -0.040 | 5.43 | 0.86 |
| 453 | 68.144 | 0.158 | 2.38 | 104 | -1.52 | 103 | 86 | -0.040 | 5.37 | 0.86 |
| 454 | 68.296 | 0.152 | 2.38 | 104 | -1.19 | 99 | 86 | -0.040 | 5.27 | 0.88 |
| 455 | 68.452 | 0.156 | 2.38 | 104 | -1.9 | 102 | 86 | -0.030 | 5.42 | 0.86 |
| 456 | 68.605 | 0.153 | 2.38 | 104 | -1.36 | 100 | 86 | -0.030 | 5.42 | 0.82 |
| 457 | 68.761 | 0.156 | 2.41 | 104 | -2.28 | 102 | 85 | -0.030 | 5.21 | 0.85 |
| 458 | 68.916 | 0.155 | 2.39 | 104 | -3.39 | 101 | 85 | -0.030 | 5.25 | 0.81 |
| 459 | 69.068 | 0.152 | 2.38 | 104 | -0.9 | 99 | 85 | -0.020 | 5.32 | 0.80 |
| 460 | 69.226 | 0.158 | 2.37 | 103 | -3.13 | 104 | 85 | -0.030 | 5.44 | 0.80 |
| 461 | 69.377 | 0.151 | 2.40 | 103 | -0.95 | 99 | 86 | -0.030 | 5.36 | 0.82 |
| 462 | 69.533 | 0.156 | 2.39 | 103 | -0.88 | 102 | 86 | -0.030 | 5.32 | 0.80 |
| 463 | 69.688 | 0.155 | 2.38 | 103 | -1.66 | 102 | 86 | -0.040 | 5.23 | 0.85 |
| 464 | 69.841 | 0.153 | 2.37 | 103 | -1.36 | 100 | 86 | -0.040 | 5.31 | 0.83 |
| 465 | 69.997 | 0.156 | 2.39 | 103 | -0.97 | 102 | 85 | -0.030 | 5.26 | 0.83 |
| 466 | 70.150 | 0.153 | 2.37 | 103 | -2.88 | 100 | 85 | -0.030 | 5.32 | 0.83 |
| 467 | 70.306 | 0.156 | 2.39 | 103 | -1.07 | 102 | 85 | -0.030 | 5.35 | 0.79 |
| 468 | 70.459 | 0.153 | 2.39 | 103 | -3.28 | 100 | 85 | -0.040 | 5.34 | 0.79 |
| 469 | 70.614 | 0.155 | 2.39 | 103 | -1.02 | 102 | 85 | -0.030 | 5.37 | 0.78 |
| 470 | 70.769 | 0.155 | 2.40 | 103 | -1.01 | 102 | 86 | -0.030 | 5.33 | 0.83 |
| 471 | 70.922 | 0.153 | 2.38 | 103 | -3.09 | 100 | 86 | -0.030 | 5.23 | 0.81 |
| 472 | 71.079 | 0.157 | 2.38 | 103 | -1.95 | 103 | 86 | -0.030 | 5.42 | 0.80 |
| 473 | 71.231 | 0.152 | 2.40 | 103 | -1.67 | 100 | 86 | -0.030 | 5.40 | 0.83 |
| 474 | 71.387 | 0.156 | 2.39 | 103 | -3.26 | 102 | 85 | -0.020 | 5.31 | 0.83 |
| 475 | 71.542 | 0.155 | 2.38 | 103 | -1.75 | 102 | 85 | -0.050 | 5.27 | 0.79 |
| 476 | 71.695 | 0.153 | 2.40 | 103 | -2.19 | 100 | 85 | -0.050 | 5.37 | 0.82 |
| 477 | 71.851 | 0.156 | 2.40 | 103 | -1.34 | 102 | 85 | -0.030 | 5.34 | 0.82 |
| 478 | 72.004 | 0.153 | 2.39 | 103 | -1.08 | 100 | 86 | -0.030 | 5.50 | 0.82 |
| 479 | 72.161 | 0.157 | 2.39 | 103 | -2.45 | 103 | 86 | -0.030 | 5.38 | 0.77 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 480 | 72.313 | 0.152 | 2.39 | 103 | -1.2 | 100 | 86 | -0.020 | 5.47 | 0.81 |
| 481 | 72.469 | 0.156 | 2.38 | 103 | -1.86 | 102 | 86 | -0.030 | 5.56 | 0.76 |
| 482 | 72.624 | 0.155 | 2.39 | 103 | -1.17 | 102 | 86 | -0.030 | 5.39 | 0.76 |
| 483 | 72.776 | 0.152 | 2.39 | 103 | -0.9 | 100 | 85 | -0.030 | 5.53 | 0.78 |
| 484 | 72.934 | 0.158 | 2.38 | 103 | -3.23 | 104 | 85 | -0.040 | 5.40 | 0.78 |
| 485 | 73.086 | 0.152 | 2.40 | 103 | -2.37 | 100 | 85 | -0.040 | 5.42 | 0.83 |
| 486 | 73.241 | 0.155 | 2.39 | 103 | -2.11 | 102 | 85 | -0.030 | 5.34 | 0.79 |
| 487 | 73.396 | 0.155 | 2.39 | 103 | -1.52 | 102 | 86 | -0.040 | 5.48 | 0.76 |
| 488 | 73.550 | 0.154 | 2.39 | 103 | -2.2 | 101 | 86 | -0.030 | 5.44 | 0.79 |
| 489 | 73.706 | 0.156 | 2.39 | 103 | -1.31 | 102 | 86 | -0.030 | 5.46 | 0.75 |
| 490 | 73.858 | 0.152 | 2.39 | 103 | -0.93 | 100 | 86 | -0.030 | 5.58 | 0.76 |
| 491 | 74.016 | 0.158 | 2.40 | 103 | -3.24 | 104 | 85 | -0.040 | 5.30 | 0.78 |
| 492 | 74.167 | 0.151 | 2.40 | 103 | -0.92 | 99 | 85 | -0.040 | 5.47 | 0.77 |
| 493 | 74.323 | 0.156 | 2.40 | 103 | -1.51 | 102 | 85 | -0.030 | 5.51 | 0.75 |
| 494 | 74.479 | 0.156 | 2.38 | 103 | -1.44 | 102 | 84 | -0.030 | 5.56 | 0.76 |
| 495 | 74.631 | 0.152 | 2.39 | 103 | -1.34 | 100 | 85 | -0.050 | 5.45 | 0.78 |
| 496 | 74.788 | 0.157 | 2.39 | 103 | -1.01 | 103 | 86 | -0.040 | 5.45 | 0.75 |
| 497 | 74.940 | 0.152 | 2.38 | 103 | -2.59 | 100 | 86 | -0.040 | 5.43 | 0.79 |
| 498 | 75.096 | 0.156 | 2.39 | 103 | -2.17 | 102 | 86 | -0.040 | 5.38 | 0.75 |
| 499 | 75.250 | 0.154 | 2.37 | 103 | -1.86 | 101 | 86 | -0.040 | 5.49 | 0.76 |
| 500 | 75.405 | 0.155 | 2.39 | 103 | -2.06 | 102 | 85 | -0.030 | 5.38 | 0.79 |
| 501 | 75.560 | 0.155 | 2.38 | 103 | -3.28 | 102 | 85 | -0.020 | 5.43 | 0.79 |
| 502 | 75.712 | 0.152 | 2.39 | 103 | -2.86 | 100 | 84 | -0.030 | 5.32 | 0.81 |
| 503 | 75.870 | 0.158 | 2.39 | 103 | -3.37 | 104 | 85 | -0.030 | 5.34 | 0.76 |
| 504 | 76.021 | 0.151 | 2.41 | 103 | -2.27 | 99 | 85 | -0.030 | 5.39 | 0.81 |
| 505 | 76.178 | 0.157 | 2.39 | 103 | -3.25 | 103 | 86 | -0.030 | 5.51 | 0.80 |
| 506 | 76.333 | 0.155 | 2.39 | 103 | -2.15 | 102 | 86 | -0.030 | 5.54 | 0.79 |
| 507 | 76.486 | 0.153 | 2.41 | 103 | -1.39 | 100 | 86 | -0.030 | 5.53 | 0.80 |
| 508 | 76.642 | 0.156 | 2.38 | 103 | -1.21 | 102 | 86 | -0.040 | 5.43 | 0.79 |
| 509 | 76.795 | 0.153 | 2.40 | 103 | -2.63 | 100 | 85 | -0.030 | 5.47 | 0.79 |
| 510 | 76.951 | 0.156 | 2.40 | 103 | -3.23 | 102 | 84 | -0.030 | 5.49 | 0.82 |
| 511 | 77.104 | 0.153 | 2.39 | 103 | -3.02 | 100 | 85 | -0.040 | 5.43 | 0.81 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 512 | 77.260 | 0.156 | 2.38 | 103 | -0.92 | 102 | 85 | -0.040 | 5.25 | 0.82 |
| 513 | 77.415 | 0.155 | 2.39 | 103 | -1.14 | 102 | 85 | -0.030 | 5.32 | 0.83 |
| 514 | 77.567 | 0.152 | 2.39 | 103 | -0.9 | 100 | 86 | -0.030 | 5.40 | 0.86 |
| 515 | 77.725 | 0.158 | 2.40 | 103 | -0.94 | 104 | 86 | -0.030 | 5.47 | 0.83 |
| 516 | 77.877 | 0.152 | 2.40 | 103 | -0.95 | 100 | 86 | -0.050 | 5.27 | 0.88 |
| 517 | 78.033 | 0.156 | 2.39 | 103 | -0.99 | 102 | 86 | -0.030 | 5.28 | 0.85 |
| 518 | 78.188 | 0.155 | 2.39 | 103 | -1 | 102 | 85 | -0.030 | 5.43 | 0.82 |
| 519 | 78.342 | 0.154 | 2.39 | 103 | -2.95 | 101 | 85 | -0.030 | 5.28 | 0.89 |
| 520 | 78.498 | 0.156 | 2.39 | 103 | -0.84 | 102 | 85 | -0.030 | 5.44 | 0.83 |
| 521 | 78.651 | 0.153 | 2.40 | 103 | -2.6 | 100 | 85 | -0.030 | 5.30 | 0.83 |
| 522 | 78.808 | 0.157 | 2.39 | 103 | -2.13 | 103 | 85 | -0.040 | 5.21 | 0.85 |
| 523 | 78.960 | 0.152 | 2.41 | 103 | -0.81 | 100 | 86 | -0.040 | 5.30 | 0.83 |
| 524 | 79.116 | 0.156 | 2.39 | 103 | -3.26 | 102 | 86 | -0.020 | 5.14 | 0.83 |
| 525 | 79.272 | 0.156 | 2.40 | 103 | -1.02 | 102 | 86 | -0.030 | 5.23 | 0.76 |
| 526 | 79.424 | 0.152 | 2.40 | 103 | -3.08 | 100 | 85 | -0.030 | 5.24 | 0.73 |
| 527 | 79.582 | 0.158 | 2.40 | 103 | -3.24 | 104 | 85 | -0.040 | 5.05 | 0.75 |
| 528 | 79.734 | 0.152 | 2.39 | 103 | -0.96 | 100 | 84 | -0.040 | 5.18 | 0.73 |
| 529 | 79.889 | 0.155 | 2.39 | 103 | -3.1 | 102 | 85 | -0.030 | 5.19 | 0.74 |
| 530 | 80.045 | 0.156 | 2.39 | 103 | -2.51 | 102 | 85 | -0.040 | 5.21 | 0.70 |
| 531 | 80.199 | 0.154 | 2.40 | 103 | -1.51 | 101 | 85 | -0.030 | 5.05 | 0.71 |
| 532 | 80.354 | 0.155 | 2.41 | 103 | -0.86 | 102 | 86 | -0.030 | 5.40 | 0.68 |
| 533 | 80.508 | 0.154 | 2.39 | 103 | -1.58 | 101 | 86 | -0.030 | 5.12 | 0.69 |
| 534 | 80.664 | 0.156 | 2.40 | 103 | -3.13 | 102 | 86 | -0.040 | 5.13 | 0.69 |
| 535 | 80.816 | 0.152 | 2.40 | 103 | -3.14 | 100 | 86 | -0.030 | 5.21 | 0.66 |
| 536 | 80.973 | 0.157 | 2.41 | 103 | -0.96 | 103 | 85 | -0.040 | 5.28 | 0.69 |
| 537 | 81.128 | 0.155 | 2.40 | 103 | -1.76 | 102 | 85 | -0.030 | 5.17 | 0.69 |
| 538 | 81.280 | 0.152 | 2.40 | 103 | -0.91 | 100 | 85 | -0.030 | 4.97 | 0.70 |
| 539 | 81.439 | 0.159 | 2.39 | 103 | -1.03 | 104 | 85 | -0.030 | 5.26 | 0.70 |
| 540 | 81.591 | 0.152 | 2.39 | 103 | -1.21 | 100 | 86 | -0.030 | 5.16 | 0.68 |
| 541 | 81.746 | 0.155 | 2.40 | 104 | -2.14 | 101 | 86 | -0.030 | 5.08 | 0.72 |
| 542 | 81.902 | 0.156 | 2.39 | 104 | -0.89 | 102 | 86 | -0.040 | 5.13 | 0.74 |
| 543 | 82.056 | 0.154 | 2.40 | 104 | -1.39 | 101 | 86 | -0.030 | 5.13 | 0.70 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 544 | 82.212 | 0.156 | 2.41 | 104 | -0.92 | 102 | 85 | -0.040 | 5.07 | 0.69 |
| 545 | 82.365 | 0.153 | 2.40 | 104 | -3.13 | 100 | 85 | -0.040 | 5.08 | 0.71 |
| 546 | 82.522 | 0.157 | 2.39 | 104 | -1.65 | 103 | 84 | -0.040 | 5.06 | 0.71 |
| 547 | 82.674 | 0.152 | 2.40 | 104 | -1.29 | 99 | 85 | -0.040 | 5.14 | 0.69 |
| 548 | 82.831 | 0.157 | 2.39 | 104 | -1.97 | 103 | 85 | -0.030 | 5.20 | 0.69 |
| 549 | 82.986 | 0.155 | 2.40 | 104 | -0.84 | 101 | 86 | -0.030 | 5.17 | 0.69 |
| 550 | 83.138 | 0.152 | 2.40 | 104 | -3.14 | 99 | 86 | -0.030 | 5.01 | 0.72 |
| 551 | 83.296 | 0.158 | 2.40 | 104 | -1.21 | 103 | 86 | -0.050 | 5.12 | 0.71 |
| 552 | 83.448 | 0.152 | 2.40 | 104 | -2.39 | 99 | 86 | -0.020 | 5.07 | 0.81 |
| 553 | 83.604 | 0.156 | 2.39 | 104 | -2.62 | 102 | 85 | -0.040 | 5.12 | 0.78 |
| 554 | 83.759 | 0.155 | 2.40 | 104 | -1.58 | 101 | 84 | -0.030 | 5.09 | 0.77 |
| 555 | 83.913 | 0.154 | 2.38 | 104 | -0.84 | 101 | 84 | -0.030 | 4.94 | 0.81 |
| 556 | 84.069 | 0.156 | 2.40 | 104 | -1.16 | 102 | 85 | -0.030 | 4.87 | 0.75 |
| 557 | 84.223 | 0.154 | 2.40 | 104 | -2.18 | 101 | 85 | -0.020 | 4.76 | 0.76 |
| 558 | 84.379 | 0.156 | 2.41 | 104 | -3.23 | 102 | 86 | -0.020 | 4.75 | 0.76 |
| 559 | 84.532 | 0.153 | 2.41 | 104 | -0.97 | 100 | 86 | -0.030 | 4.80 | 0.77 |
| 560 | 84.688 | 0.156 | 2.40 | 104 | -0.9 | 102 | 86 | -0.010 | 4.81 | 0.77 |
| 561 | 84.844 | 0.156 | 2.41 | 104 | -1.49 | 102 | 86 | -0.040 | 4.86 | 0.76 |
| 562 | 84.996 | 0.152 | 2.39 | 104 | -1.09 | 99 | 85 | -0.030 | 4.84 | 0.75 |
| 563 | 85.154 | 0.158 | 2.38 | 104 | -2.71 | 103 | 85 | -0.040 | 4.72 | 0.79 |
| 564 | 85.306 | 0.152 | 2.42 | 104 | -3.24 | 99 | 84 | -0.030 | 4.91 | 0.75 |
| 565 | 85.462 | 0.156 | 2.40 | 104 | -1.05 | 102 | 85 | -0.030 | 4.83 | 0.76 |
| 566 | 85.618 | 0.156 | 2.39 | 104 | -3.41 | 102 | 85 | -0.030 | 4.89 | 0.75 |
| 567 | 85.771 | 0.153 | 2.41 | 104 | -2.47 | 100 | 86 | -0.040 | 4.73 | 0.79 |
| 568 | 85.928 | 0.157 | 2.40 | 104 | -2.15 | 103 | 86 | -0.040 | 4.91 | 0.76 |
| 569 | 86.081 | 0.153 | 2.40 | 104 | -3.31 | 100 | 86 | -0.030 | 4.81 | 0.76 |
| 570 | 86.238 | 0.157 | 2.40 | 104 | -1.29 | 103 | 86 | -0.030 | 4.83 | 0.74 |
| 571 | 86.391 | 0.153 | 2.40 | 104 | -2.99 | 100 | 85 | -0.040 | 4.83 | 0.76 |
| 572 | 86.547 | 0.156 | 2.40 | 104 | -3.38 | 102 | 85 | -0.040 | 4.79 | 0.72 |
| 573 | 86.702 | 0.155 | 2.40 | 104 | -2.67 | 101 | 84 | -0.040 | 4.70 | 0.73 |
| Avg/Tot | 86.702 | 0.151 | 2.29 | 102 | -2.01 | 100 | | | 6.70 | 0.74 |

WOODSTOVE SURFACE TEMPERATURE DATA

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Temperature Data (°F) | | | | | | Catalyst Exit |
|--------------------|-----------------------|----------|---------|--------|-----------|-----------------------|---------------|
| | FB Left | FB Right | FB Back | FB Top | FB Bottom | Stove Surface Average | |
| 0 | 515 | 472 | 255 | 521 | 341 | 420.8 | N/A |
| 1 | 514 | 470 | 275 | 513 | 343 | 423.0 | N/A |
| 2 | 512 | 467 | 288 | 546 | 343 | 431.2 | N/A |
| 3 | 508 | 465 | 298 | 605 | 344 | 444.0 | N/A |
| 4 | 503 | 460 | 308 | 666 | 345 | 456.4 | N/A |
| 5 | 499 | 456 | 317 | 719 | 345 | 467.2 | N/A |
| 6 | 494 | 455 | 327 | 754 | 347 | 475.4 | N/A |
| 7 | 492 | 453 | 338 | 768 | 347 | 479.6 | N/A |
| 8 | 489 | 452 | 346 | 781 | 348 | 483.2 | N/A |
| 9 | 487 | 451 | 355 | 794 | 348 | 487.0 | N/A |
| 10 | 484 | 449 | 363 | 798 | 348 | 488.4 | N/A |
| 11 | 483 | 449 | 370 | 805 | 349 | 491.2 | N/A |
| 12 | 481 | 449 | 379 | 813 | 349 | 494.2 | N/A |
| 13 | 479 | 449 | 386 | 815 | 349 | 495.6 | N/A |
| 14 | 478 | 448 | 392 | 817 | 349 | 496.8 | N/A |
| 15 | 478 | 448 | 399 | 814 | 349 | 497.6 | N/A |
| 16 | 477 | 448 | 404 | 814 | 349 | 498.4 | N/A |
| 17 | 476 | 448 | 409 | 810 | 348 | 498.2 | N/A |
| 18 | 476 | 447 | 412 | 806 | 348 | 497.8 | N/A |
| 19 | 475 | 446 | 415 | 796 | 347 | 495.8 | N/A |
| 20 | 474 | 443 | 417 | 787 | 347 | 493.6 | N/A |
| 21 | 473 | 441 | 417 | 777 | 346 | 490.8 | N/A |
| 22 | 472 | 439 | 418 | 767 | 345 | 488.2 | N/A |
| 23 | 471 | 436 | 417 | 761 | 344 | 485.8 | N/A |
| 24 | 469 | 433 | 415 | 752 | 343 | 482.4 | N/A |
| 25 | 467 | 430 | 413 | 744 | 342 | 479.2 | N/A |
| 26 | 465 | 426 | 410 | 739 | 341 | 476.2 | N/A |
| 27 | 463 | 423 | 408 | 733 | 340 | 473.4 | N/A |
| 28 | 460 | 419 | 405 | 727 | 339 | 470.0 | N/A |
| 29 | 457 | 416 | 402 | 723 | 337 | 467.0 | N/A |
| 30 | 454 | 413 | 400 | 718 | 335 | 464.0 | N/A |
| 31 | 451 | 409 | 356 | 714 | 334 | 452.8 | N/A |
| 32 | 447 | 407 | 337 | 710 | 333 | 446.8 | N/A |
| 33 | 444 | 405 | 322 | 705 | 331 | 441.4 | N/A |
| 34 | 441 | 403 | 306 | 701 | 330 | 436.2 | N/A |
| 35 | 438 | 401 | 296 | 695 | 328 | 431.6 | N/A |
| 36 | 435 | 400 | 287 | 690 | 327 | 427.8 | N/A |
| 37 | 432 | 399 | 281 | 685 | 325 | 424.4 | N/A |
| 38 | 429 | 397 | 276 | 684 | 323 | 421.8 | N/A |
| 39 | 426 | 395 | 270 | 680 | 322 | 418.6 | N/A |
| 40 | 423 | 395 | 266 | 677 | 320 | 416.2 | N/A |
| 41 | 421 | 394 | 263 | 678 | 319 | 415.0 | N/A |
| 42 | 418 | 392 | 260 | 678 | 317 | 413.0 | N/A |
| 43 | 415 | 391 | 257 | 676 | 315 | 410.8 | N/A |
| 44 | 413 | 391 | 255 | 676 | 314 | 409.8 | N/A |
| 45 | 411 | 390 | 254 | 676 | 312 | 408.6 | N/A |
| 46 | 409 | 389 | 253 | 674 | 310 | 407.0 | N/A |
| 47 | 408 | 388 | 251 | 676 | 309 | 406.4 | N/A |

WOODSTOVE SURFACE TEMPERATURE DATA

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Temperature Data (*F) | | | | | | |
|--------------------|-----------------------|----------|---------|--------|-----------|-----------------------|---------------|
| | FB Left | FB Right | FB Back | FB Top | FB Bottom | Stove Surface Average | Catalyst Exit |
| 48 | 406 | 387 | 251 | 675 | 307 | 405.2 | N/A |
| 49 | 405 | 386 | 249 | 673 | 306 | 403.8 | N/A |
| 50 | 404 | 385 | 248 | 673 | 304 | 402.8 | N/A |
| 51 | 403 | 384 | 247 | 673 | 303 | 402.0 | N/A |
| 52 | 402 | 383 | 246 | 675 | 301 | 401.4 | N/A |
| 53 | 401 | 383 | 245 | 677 | 300 | 401.2 | N/A |
| 54 | 401 | 382 | 247 | 681 | 299 | 402.0 | N/A |
| 55 | 400 | 382 | 246 | 679 | 297 | 400.8 | N/A |
| 56 | 400 | 381 | 247 | 680 | 296 | 400.8 | N/A |
| 57 | 400 | 380 | 247 | 679 | 295 | 400.2 | N/A |
| 58 | 400 | 380 | 247 | 680 | 294 | 400.2 | N/A |
| 59 | 401 | 379 | 245 | 677 | 292 | 398.8 | N/A |
| 60 | 402 | 378 | 247 | 677 | 291 | 399.0 | N/A |
| 61 | 403 | 378 | 245 | 675 | 290 | 398.2 | N/A |
| 62 | 404 | 377 | 246 | 675 | 289 | 398.2 | N/A |
| 63 | 404 | 376 | 247 | 673 | 288 | 397.6 | N/A |
| 64 | 405 | 376 | 248 | 672 | 286 | 397.4 | N/A |
| 65 | 405 | 376 | 247 | 670 | 286 | 396.8 | N/A |
| 66 | 406 | 375 | 248 | 668 | 284 | 396.2 | N/A |
| 67 | 406 | 375 | 248 | 668 | 283 | 396.0 | N/A |
| 68 | 406 | 375 | 247 | 664 | 282 | 394.8 | N/A |
| 69 | 407 | 375 | 248 | 661 | 281 | 394.4 | N/A |
| 70 | 407 | 375 | 247 | 659 | 281 | 393.8 | N/A |
| 71 | 407 | 375 | 248 | 655 | 280 | 393.0 | N/A |
| 72 | 406 | 376 | 248 | 653 | 279 | 392.4 | N/A |
| 73 | 406 | 375 | 248 | 651 | 278 | 391.6 | N/A |
| 74 | 406 | 375 | 248 | 650 | 277 | 391.2 | N/A |
| 75 | 406 | 377 | 247 | 646 | 276 | 390.4 | N/A |
| 76 | 405 | 377 | 247 | 645 | 276 | 390.0 | N/A |
| 77 | 405 | 377 | 247 | 644 | 275 | 389.6 | N/A |
| 78 | 405 | 377 | 249 | 643 | 274 | 389.6 | N/A |
| 79 | 405 | 378 | 249 | 641 | 274 | 389.4 | N/A |
| 80 | 405 | 379 | 249 | 642 | 273 | 389.6 | N/A |
| 81 | 405 | 379 | 249 | 639 | 273 | 389.0 | N/A |
| 82 | 405 | 380 | 249 | 636 | 272 | 388.4 | N/A |
| 83 | 405 | 381 | 251 | 636 | 272 | 389.0 | N/A |
| 84 | 405 | 382 | 250 | 635 | 271 | 388.6 | N/A |
| 85 | 406 | 382 | 253 | 634 | 271 | 389.2 | N/A |
| 86 | 406 | 383 | 254 | 631 | 270 | 388.8 | N/A |
| 87 | 406 | 384 | 253 | 631 | 270 | 388.8 | N/A |
| 88 | 406 | 385 | 251 | 628 | 270 | 388.0 | N/A |
| 89 | 406 | 387 | 250 | 627 | 269 | 387.8 | N/A |
| 90 | 406 | 387 | 251 | 625 | 269 | 387.6 | N/A |
| 91 | 406 | 387 | 251 | 624 | 269 | 387.4 | N/A |
| 92 | 406 | 388 | 249 | 626 | 268 | 387.4 | N/A |
| 93 | 406 | 389 | 253 | 626 | 268 | 388.4 | N/A |
| 94 | 406 | 389 | 255 | 626 | 268 | 388.8 | N/A |
| 95 | 406 | 390 | 254 | 628 | 268 | 389.2 | N/A |

WOODSTOVE SURFACE TEMPERATURE DATA

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Temperature Data (°F) | | | | | | Catalyst Exit |
|--------------------|-----------------------|----------|---------|--------|-----------|-----------------------|---------------|
| | FB Left | FB Right | FB Back | FB Top | FB Bottom | Stove Surface Average | |
| 96 | 407 | 391 | 255 | 629 | 267 | 389.8 | N/A |
| 97 | 407 | 393 | 258 | 636 | 267 | 392.2 | N/A |
| 98 | 408 | 393 | 260 | 643 | 267 | 394.2 | N/A |
| 99 | 409 | 395 | 262 | 643 | 267 | 395.2 | N/A |
| 100 | 409 | 397 | 266 | 642 | 266 | 396.0 | N/A |
| 101 | 410 | 399 | 265 | 642 | 266 | 396.4 | N/A |
| 102 | 410 | 400 | 267 | 636 | 266 | 395.8 | N/A |
| 103 | 411 | 403 | 268 | 636 | 266 | 396.8 | N/A |
| 104 | 410 | 403 | 268 | 628 | 265 | 394.8 | N/A |
| 105 | 410 | 405 | 269 | 621 | 265 | 394.0 | N/A |
| 106 | 410 | 405 | 270 | 618 | 265 | 393.6 | N/A |
| 107 | 410 | 406 | 268 | 611 | 265 | 392.0 | N/A |
| 108 | 409 | 406 | 267 | 605 | 264 | 390.2 | N/A |
| 109 | 409 | 405 | 270 | 598 | 264 | 389.2 | N/A |
| 110 | 408 | 405 | 267 | 592 | 264 | 387.2 | N/A |
| 111 | 408 | 405 | 266 | 586 | 264 | 385.8 | N/A |
| 112 | 407 | 402 | 266 | 578 | 263 | 383.2 | N/A |
| 113 | 406 | 402 | 266 | 574 | 263 | 382.2 | N/A |
| 114 | 405 | 402 | 263 | 567 | 263 | 380.0 | N/A |
| 115 | 404 | 399 | 262 | 562 | 263 | 378.0 | N/A |
| 116 | 404 | 398 | 260 | 556 | 262 | 376.0 | N/A |
| 117 | 402 | 397 | 262 | 551 | 262 | 374.8 | N/A |
| 118 | 401 | 395 | 261 | 547 | 262 | 373.2 | N/A |
| 119 | 401 | 395 | 258 | 541 | 262 | 371.4 | N/A |
| 120 | 399 | 393 | 260 | 537 | 262 | 370.2 | N/A |
| 121 | 398 | 391 | 259 | 534 | 261 | 368.6 | N/A |
| 122 | 397 | 390 | 258 | 528 | 261 | 366.8 | N/A |
| 123 | 396 | 388 | 260 | 528 | 261 | 366.6 | N/A |
| 124 | 395 | 387 | 259 | 523 | 261 | 365.0 | N/A |
| 125 | 394 | 387 | 259 | 519 | 261 | 364.0 | N/A |
| 126 | 393 | 385 | 259 | 516 | 261 | 362.8 | N/A |
| 127 | 392 | 385 | 258 | 515 | 261 | 362.2 | N/A |
| 128 | 392 | 384 | 259 | 512 | 260 | 361.4 | N/A |
| 129 | 391 | 384 | 258 | 511 | 260 | 360.8 | N/A |
| 130 | 391 | 383 | 259 | 508 | 260 | 360.2 | N/A |
| 131 | 390 | 381 | 260 | 507 | 260 | 359.6 | N/A |
| 132 | 390 | 381 | 259 | 504 | 260 | 358.8 | N/A |
| 133 | 390 | 380 | 259 | 503 | 260 | 358.4 | N/A |
| 134 | 389 | 378 | 259 | 502 | 260 | 357.6 | N/A |
| 135 | 389 | 377 | 260 | 499 | 260 | 357.0 | N/A |
| 136 | 389 | 376 | 259 | 496 | 260 | 356.0 | N/A |
| 137 | 388 | 376 | 259 | 491 | 260 | 354.8 | N/A |
| 138 | 387 | 373 | 255 | 487 | 260 | 352.4 | N/A |
| 139 | 386 | 372 | 256 | 483 | 260 | 351.4 | N/A |
| 140 | 385 | 370 | 254 | 480 | 260 | 349.8 | N/A |
| 141 | 384 | 368 | 255 | 477 | 259 | 348.6 | N/A |
| 142 | 383 | 367 | 251 | 473 | 259 | 346.6 | N/A |
| 143 | 381 | 365 | 252 | 469 | 259 | 345.2 | N/A |

WOODSTOVE SURFACE TEMPERATURE DATA

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Temperature Data (*F) | | | | | | |
|--------------------|-----------------------|----------|---------|--------|-----------|-----------------------|---------------|
| | FB Left | FB Right | FB Back | FB Top | FB Bottom | Stove Surface Average | Catalyst Exit |
| 144 | 380 | 364 | 250 | 467 | 259 | 344.0 | N/A |
| 145 | 378 | 362 | 248 | 463 | 259 | 342.0 | N/A |
| 146 | 377 | 360 | 245 | 460 | 259 | 340.2 | N/A |
| 147 | 376 | 359 | 245 | 458 | 259 | 339.4 | N/A |
| 148 | 375 | 358 | 244 | 455 | 259 | 338.2 | N/A |
| 149 | 374 | 357 | 243 | 452 | 259 | 337.0 | N/A |
| 150 | 373 | 355 | 243 | 452 | 259 | 336.4 | N/A |
| 151 | 372 | 355 | 242 | 451 | 259 | 335.8 | N/A |
| 152 | 372 | 354 | 243 | 447 | 259 | 335.0 | N/A |
| 153 | 371 | 353 | 241 | 447 | 259 | 334.2 | N/A |
| 154 | 370 | 352 | 241 | 445 | 259 | 333.4 | N/A |
| 155 | 370 | 352 | 240 | 443 | 259 | 332.8 | N/A |
| 156 | 369 | 351 | 241 | 442 | 259 | 332.4 | N/A |
| 157 | 369 | 351 | 240 | 441 | 259 | 332.0 | N/A |
| 158 | 368 | 350 | 240 | 442 | 259 | 331.8 | N/A |
| 159 | 368 | 349 | 239 | 440 | 259 | 331.0 | N/A |
| 160 | 367 | 348 | 239 | 438 | 259 | 330.2 | N/A |
| 161 | 367 | 348 | 238 | 436 | 260 | 329.8 | N/A |
| 162 | 366 | 348 | 240 | 439 | 260 | 330.6 | N/A |
| 163 | 366 | 346 | 238 | 435 | 260 | 329.0 | N/A |
| 164 | 365 | 346 | 239 | 435 | 260 | 329.0 | N/A |
| 165 | 365 | 346 | 239 | 434 | 261 | 329.0 | N/A |
| 166 | 364 | 345 | 239 | 435 | 261 | 328.8 | N/A |
| 167 | 364 | 345 | 237 | 433 | 261 | 328.0 | N/A |
| 168 | 364 | 345 | 237 | 430 | 261 | 327.4 | N/A |
| 169 | 363 | 344 | 235 | 430 | 262 | 326.8 | N/A |
| 170 | 363 | 343 | 234 | 428 | 262 | 326.0 | N/A |
| 171 | 362 | 343 | 233 | 424 | 262 | 324.8 | N/A |
| 172 | 360 | 342 | 230 | 421 | 262 | 323.0 | N/A |
| 173 | 359 | 341 | 227 | 414 | 263 | 320.8 | N/A |
| 174 | 357 | 340 | 223 | 410 | 263 | 318.6 | N/A |
| 175 | 356 | 338 | 220 | 405 | 263 | 316.4 | N/A |
| 176 | 354 | 337 | 216 | 398 | 263 | 313.6 | N/A |
| 177 | 351 | 335 | 215 | 395 | 263 | 311.8 | N/A |
| 178 | 349 | 333 | 211 | 389 | 263 | 309.0 | N/A |
| 179 | 347 | 332 | 209 | 385 | 264 | 307.4 | N/A |
| 180 | 346 | 330 | 206 | 380 | 264 | 305.2 | N/A |
| 181 | 344 | 328 | 204 | 376 | 264 | 303.2 | N/A |
| 182 | 342 | 327 | 202 | 372 | 264 | 301.4 | N/A |
| 183 | 340 | 325 | 200 | 367 | 264 | 299.2 | N/A |
| 184 | 339 | 324 | 198 | 362 | 265 | 297.6 | N/A |
| 185 | 337 | 322 | 196 | 360 | 265 | 296.0 | N/A |
| 186 | 336 | 320 | 195 | 356 | 265 | 294.4 | N/A |
| 187 | 335 | 318 | 194 | 352 | 265 | 292.8 | N/A |
| 188 | 333 | 317 | 191 | 348 | 265 | 290.8 | N/A |
| 189 | 332 | 315 | 191 | 345 | 265 | 289.6 | N/A |
| 190 | 330 | 314 | 189 | 343 | 266 | 288.4 | N/A |
| 191 | 329 | 313 | 189 | 341 | 266 | 287.6 | N/A |

WOODSTOVE SURFACE TEMPERATURE DATA

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Temperature Data (°F) | | | | | | Stove Surface Average | Catalyst Exit |
|--------------------|-----------------------|----------|---------|--------|-----------|-------|-----------------------|---------------|
| | FB Left | FB Right | FB Back | FB Top | FB Bottom | | | |
| 192 | 328 | 312 | 189 | 340 | 266 | 287.0 | N/A | |
| 193 | 327 | 311 | 189 | 339 | 266 | 286.4 | N/A | |
| 194 | 326 | 310 | 190 | 340 | 267 | 286.6 | N/A | |
| 195 | 326 | 310 | 192 | 340 | 267 | 287.0 | N/A | |
| 196 | 325 | 310 | 193 | 340 | 267 | 287.0 | N/A | |
| 197 | 325 | 311 | 195 | 342 | 268 | 288.2 | N/A | |
| 198 | 325 | 311 | 197 | 343 | 268 | 288.8 | N/A | |
| 199 | 325 | 311 | 199 | 344 | 268 | 289.4 | N/A | |
| 200 | 325 | 313 | 199 | 343 | 269 | 289.8 | N/A | |
| 201 | 325 | 313 | 201 | 346 | 269 | 290.8 | N/A | |
| 202 | 326 | 314 | 203 | 347 | 269 | 291.8 | N/A | |
| 203 | 326 | 315 | 203 | 348 | 270 | 292.4 | N/A | |
| 204 | 326 | 315 | 200 | 346 | 270 | 291.4 | N/A | |
| 205 | 325 | 315 | 199 | 347 | 270 | 291.2 | N/A | |
| 206 | 325 | 315 | 197 | 347 | 270 | 290.8 | N/A | |
| 207 | 324 | 315 | 197 | 345 | 271 | 290.4 | N/A | |
| 208 | 324 | 314 | 194 | 345 | 271 | 289.6 | N/A | |
| 209 | 323 | 314 | 193 | 343 | 271 | 288.8 | N/A | |
| 210 | 322 | 313 | 193 | 343 | 271 | 288.4 | N/A | |
| 211 | 322 | 313 | 190 | 340 | 271 | 287.2 | N/A | |
| 212 | 321 | 313 | 189 | 339 | 271 | 286.6 | N/A | |
| 213 | 320 | 312 | 187 | 337 | 271 | 285.4 | N/A | |
| 214 | 320 | 311 | 187 | 335 | 272 | 285.0 | N/A | |
| 215 | 320 | 310 | 186 | 335 | 272 | 284.6 | N/A | |
| 216 | 319 | 310 | 186 | 334 | 272 | 284.2 | N/A | |
| 217 | 319 | 309 | 185 | 332 | 272 | 283.4 | N/A | |
| 218 | 318 | 309 | 184 | 330 | 272 | 282.6 | N/A | |
| 219 | 318 | 308 | 183 | 328 | 272 | 281.8 | N/A | |
| 220 | 318 | 308 | 183 | 328 | 272 | 281.8 | N/A | |
| 221 | 318 | 307 | 182 | 326 | 272 | 281.0 | N/A | |
| 222 | 318 | 306 | 181 | 326 | 273 | 280.8 | N/A | |
| 223 | 317 | 306 | 180 | 323 | 273 | 279.8 | N/A | |
| 224 | 317 | 305 | 180 | 321 | 273 | 279.2 | N/A | |
| 225 | 317 | 304 | 180 | 321 | 273 | 279.0 | N/A | |
| 226 | 317 | 305 | 178 | 319 | 273 | 278.4 | N/A | |
| 227 | 317 | 304 | 178 | 319 | 274 | 278.4 | N/A | |
| 228 | 317 | 304 | 178 | 317 | 274 | 278.0 | N/A | |
| 229 | 316 | 303 | 178 | 317 | 274 | 277.6 | N/A | |
| 230 | 317 | 303 | 178 | 315 | 274 | 277.4 | N/A | |
| 231 | 317 | 303 | 177 | 315 | 275 | 277.4 | N/A | |
| 232 | 316 | 303 | 177 | 314 | 275 | 277.0 | N/A | |
| 233 | 317 | 302 | 177 | 313 | 275 | 276.8 | N/A | |
| 234 | 317 | 302 | 176 | 311 | 276 | 276.4 | N/A | |
| 235 | 316 | 303 | 177 | 311 | 276 | 276.6 | N/A | |
| 236 | 316 | 302 | 176 | 311 | 276 | 276.2 | N/A | |
| 237 | 316 | 302 | 176 | 311 | 277 | 276.4 | N/A | |
| 238 | 316 | 303 | 176 | 309 | 277 | 276.2 | N/A | |
| 239 | 316 | 302 | 176 | 309 | 278 | 276.2 | N/A | |

WOODSTOVE SURFACE TEMPERATURE DATA

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Temperature Data (°F) | | | | | | Catalyst Exit |
|--------------------|-----------------------|----------|---------|--------|-----------|-----------------------|---------------|
| | FB Left | FB Right | FB Back | FB Top | FB Bottom | Stove Surface Average | |
| 240 | 317 | 302 | 176 | 308 | 278 | 276.2 | N/A |
| 241 | 317 | 302 | 176 | 306 | 278 | 275.8 | N/A |
| 242 | 317 | 302 | 176 | 307 | 279 | 276.2 | N/A |
| 243 | 317 | 302 | 176 | 306 | 279 | 276.0 | N/A |
| 244 | 317 | 302 | 176 | 306 | 280 | 276.2 | N/A |
| 245 | 317 | 302 | 176 | 305 | 280 | 276.0 | N/A |
| 246 | 317 | 302 | 177 | 305 | 281 | 276.4 | N/A |
| 247 | 317 | 302 | 176 | 304 | 281 | 276.0 | N/A |
| 248 | 318 | 301 | 177 | 304 | 282 | 276.4 | N/A |
| 249 | 317 | 301 | 176 | 304 | 282 | 276.0 | N/A |
| 250 | 318 | 302 | 177 | 305 | 283 | 277.0 | N/A |
| 251 | 318 | 301 | 178 | 305 | 283 | 277.0 | N/A |
| 252 | 318 | 302 | 178 | 306 | 284 | 277.6 | N/A |
| 253 | 318 | 302 | 178 | 307 | 285 | 278.0 | N/A |
| 254 | 319 | 302 | 179 | 308 | 285 | 278.6 | N/A |
| 255 | 320 | 302 | 180 | 308 | 286 | 279.2 | N/A |
| 256 | 320 | 303 | 181 | 309 | 286 | 279.8 | N/A |
| 257 | 320 | 304 | 182 | 309 | 287 | 280.4 | N/A |
| 258 | 321 | 304 | 183 | 309 | 288 | 281.0 | N/A |
| 259 | 322 | 305 | 184 | 311 | 288 | 282.0 | N/A |
| 260 | 322 | 306 | 186 | 311 | 289 | 282.8 | N/A |
| 261 | 323 | 306 | 188 | 312 | 290 | 283.8 | N/A |
| 262 | 323 | 307 | 189 | 313 | 291 | 284.6 | N/A |
| 263 | 324 | 308 | 192 | 314 | 291 | 285.8 | N/A |
| 264 | 324 | 309 | 193 | 315 | 292 | 286.6 | N/A |
| 265 | 325 | 310 | 194 | 316 | 293 | 287.6 | N/A |
| 266 | 325 | 311 | 197 | 317 | 293 | 288.6 | N/A |
| 267 | 326 | 311 | 198 | 318 | 294 | 289.4 | N/A |
| 268 | 327 | 312 | 199 | 321 | 295 | 290.8 | N/A |
| 269 | 327 | 312 | 201 | 319 | 296 | 291.0 | N/A |
| 270 | 327 | 313 | 201 | 321 | 296 | 291.6 | N/A |
| 271 | 327 | 314 | 202 | 322 | 297 | 292.4 | N/A |
| 272 | 328 | 314 | 202 | 322 | 298 | 292.8 | N/A |
| 273 | 328 | 315 | 202 | 322 | 299 | 293.2 | N/A |
| 274 | 328 | 314 | 202 | 322 | 300 | 293.2 | N/A |
| 275 | 328 | 315 | 202 | 321 | 300 | 293.2 | N/A |
| 276 | 329 | 315 | 202 | 320 | 301 | 293.4 | N/A |
| 277 | 328 | 315 | 201 | 320 | 302 | 293.2 | N/A |
| 278 | 328 | 314 | 200 | 320 | 302 | 292.8 | N/A |
| 279 | 328 | 314 | 201 | 319 | 303 | 293.0 | N/A |
| 280 | 328 | 314 | 199 | 317 | 303 | 292.2 | N/A |
| 281 | 328 | 313 | 199 | 316 | 304 | 292.0 | N/A |
| 282 | 328 | 313 | 199 | 315 | 304 | 291.8 | N/A |
| 283 | 327 | 313 | 198 | 315 | 304 | 291.4 | N/A |
| 284 | 328 | 312 | 196 | 313 | 305 | 290.8 | N/A |
| 285 | 327 | 312 | 197 | 311 | 305 | 290.4 | N/A |
| 286 | 327 | 312 | 196 | 311 | 305 | 290.2 | N/A |
| 287 | 327 | 311 | 196 | 310 | 305 | 289.8 | N/A |

WOODSTOVE SURFACE TEMPERATURE DATA

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Temperature Data (*F) | | | | | | Stove Surface Average | Catalyst Exit |
|--------------------|-----------------------|----------|---------|--------|-----------|-------|-----------------------|---------------|
| | FB Left | FB Right | FB Back | FB Top | FB Bottom | | | |
| 288 | 327 | 310 | 195 | 309 | 305 | 289.2 | N/A | |
| 289 | 327 | 311 | 196 | 308 | 305 | 289.4 | N/A | |
| 290 | 327 | 310 | 193 | 308 | 305 | 288.6 | N/A | |
| 291 | 327 | 310 | 193 | 307 | 305 | 288.4 | N/A | |
| 292 | 326 | 309 | 193 | 306 | 305 | 287.8 | N/A | |
| 293 | 326 | 309 | 192 | 306 | 305 | 287.6 | N/A | |
| 294 | 327 | 309 | 193 | 304 | 305 | 287.6 | N/A | |
| 295 | 326 | 308 | 192 | 302 | 304 | 286.4 | N/A | |
| 296 | 326 | 308 | 192 | 302 | 304 | 286.4 | N/A | |
| 297 | 326 | 308 | 191 | 300 | 304 | 285.8 | N/A | |
| 298 | 325 | 307 | 191 | 301 | 304 | 285.6 | N/A | |
| 299 | 325 | 307 | 189 | 298 | 304 | 284.6 | N/A | |
| 300 | 325 | 307 | 189 | 299 | 303 | 284.6 | N/A | |
| 301 | 325 | 307 | 188 | 298 | 303 | 284.2 | N/A | |
| 302 | 325 | 306 | 187 | 298 | 303 | 283.8 | N/A | |
| 303 | 324 | 306 | 186 | 297 | 302 | 283.0 | N/A | |
| 304 | 324 | 305 | 185 | 297 | 302 | 282.6 | N/A | |
| 305 | 324 | 305 | 185 | 296 | 302 | 282.4 | N/A | |
| 306 | 323 | 305 | 184 | 295 | 302 | 281.8 | N/A | |
| 307 | 323 | 304 | 183 | 294 | 302 | 281.2 | N/A | |
| 308 | 322 | 303 | 183 | 293 | 301 | 280.4 | N/A | |
| 309 | 322 | 304 | 182 | 292 | 301 | 280.2 | N/A | |
| 310 | 322 | 303 | 183 | 290 | 301 | 279.8 | N/A | |
| 311 | 322 | 303 | 182 | 291 | 300 | 279.6 | N/A | |
| 312 | 322 | 303 | 182 | 290 | 300 | 279.4 | N/A | |
| 313 | 321 | 302 | 183 | 290 | 300 | 279.2 | N/A | |
| 314 | 321 | 303 | 184 | 290 | 299 | 279.4 | N/A | |
| 315 | 321 | 302 | 185 | 291 | 299 | 279.6 | N/A | |
| 316 | 321 | 302 | 183 | 289 | 299 | 278.8 | N/A | |
| 317 | 321 | 302 | 184 | 288 | 298 | 278.6 | N/A | |
| 318 | 320 | 302 | 184 | 289 | 298 | 278.6 | N/A | |
| 319 | 320 | 302 | 184 | 289 | 298 | 278.6 | N/A | |
| 320 | 320 | 302 | 185 | 289 | 298 | 278.8 | N/A | |
| 321 | 319 | 302 | 184 | 290 | 297 | 278.4 | N/A | |
| 322 | 320 | 301 | 184 | 288 | 297 | 278.0 | N/A | |
| 323 | 319 | 300 | 185 | 289 | 297 | 278.0 | N/A | |
| 324 | 319 | 301 | 185 | 288 | 297 | 278.0 | N/A | |
| 325 | 319 | 301 | 185 | 288 | 297 | 278.0 | N/A | |
| 326 | 319 | 301 | 186 | 288 | 297 | 278.2 | N/A | |
| 327 | 318 | 300 | 185 | 287 | 297 | 277.4 | N/A | |
| 328 | 318 | 301 | 185 | 287 | 297 | 277.6 | N/A | |
| 329 | 318 | 300 | 185 | 286 | 297 | 277.2 | N/A | |
| 330 | 318 | 300 | 185 | 287 | 297 | 277.4 | N/A | |
| 331 | 318 | 300 | 185 | 287 | 297 | 277.4 | N/A | |
| 332 | 318 | 300 | 185 | 288 | 296 | 277.4 | N/A | |
| 333 | 317 | 300 | 186 | 287 | 296 | 277.2 | N/A | |
| 334 | 317 | 299 | 186 | 286 | 296 | 276.8 | N/A | |
| 335 | 318 | 299 | 186 | 286 | 296 | 277.0 | N/A | |

WOODSTOVE SURFACE TEMPERATURE DATA

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Temperature Data (°F) | | | | | | Stove Surface Average | Catalyst Exit |
|--------------------|-----------------------|----------|---------|--------|-----------|-------|-----------------------|---------------|
| | FB Left | FB Right | FB Back | FB Top | FB Bottom | | | |
| 336 | 317 | 299 | 185 | 285 | 297 | 276.6 | N/A | |
| 337 | 318 | 298 | 185 | 285 | 297 | 276.6 | N/A | |
| 338 | 317 | 299 | 185 | 286 | 296 | 276.6 | N/A | |
| 339 | 317 | 298 | 186 | 285 | 297 | 276.6 | N/A | |
| 340 | 317 | 299 | 187 | 285 | 297 | 277.0 | N/A | |
| 341 | 317 | 298 | 186 | 285 | 297 | 276.6 | N/A | |
| 342 | 316 | 298 | 186 | 284 | 297 | 276.2 | N/A | |
| 343 | 316 | 298 | 186 | 284 | 297 | 276.2 | N/A | |
| 344 | 317 | 297 | 186 | 284 | 297 | 276.2 | N/A | |
| 345 | 316 | 298 | 186 | 283 | 297 | 276.0 | N/A | |
| 346 | 317 | 297 | 187 | 284 | 297 | 276.4 | N/A | |
| 347 | 316 | 297 | 187 | 284 | 297 | 276.2 | N/A | |
| 348 | 316 | 297 | 187 | 282 | 297 | 275.8 | N/A | |
| 349 | 316 | 297 | 187 | 283 | 297 | 276.0 | N/A | |
| 350 | 317 | 297 | 187 | 283 | 297 | 276.2 | N/A | |
| 351 | 316 | 296 | 187 | 282 | 298 | 275.8 | N/A | |
| 352 | 316 | 297 | 186 | 282 | 298 | 275.8 | N/A | |
| 353 | 316 | 297 | 187 | 282 | 298 | 276.0 | N/A | |
| 354 | 316 | 296 | 186 | 281 | 298 | 275.4 | N/A | |
| 355 | 316 | 296 | 187 | 283 | 298 | 276.0 | N/A | |
| 356 | 316 | 296 | 188 | 282 | 298 | 276.0 | N/A | |
| 357 | 316 | 295 | 187 | 282 | 298 | 275.6 | N/A | |
| 358 | 316 | 296 | 188 | 281 | 298 | 275.8 | N/A | |
| 359 | 316 | 296 | 188 | 281 | 298 | 275.8 | N/A | |
| 360 | 316 | 296 | 188 | 281 | 298 | 275.8 | N/A | |
| 361 | 316 | 296 | 188 | 281 | 298 | 275.8 | N/A | |
| 362 | 316 | 295 | 187 | 282 | 299 | 275.8 | N/A | |
| 363 | 316 | 295 | 188 | 280 | 299 | 275.6 | N/A | |
| 364 | 316 | 294 | 188 | 281 | 299 | 275.6 | N/A | |
| 365 | 317 | 296 | 188 | 280 | 299 | 276.0 | N/A | |
| 366 | 316 | 295 | 189 | 280 | 299 | 275.8 | N/A | |
| 367 | 317 | 295 | 188 | 280 | 299 | 275.8 | N/A | |
| 368 | 317 | 296 | 188 | 280 | 299 | 276.0 | N/A | |
| 369 | 316 | 295 | 188 | 280 | 299 | 275.6 | N/A | |
| 370 | 316 | 295 | 188 | 279 | 299 | 275.4 | N/A | |
| 371 | 316 | 295 | 188 | 279 | 299 | 275.4 | N/A | |
| 372 | 316 | 295 | 188 | 280 | 300 | 275.8 | N/A | |
| 373 | 316 | 295 | 188 | 278 | 300 | 275.4 | N/A | |
| 374 | 316 | 295 | 189 | 279 | 300 | 275.8 | N/A | |
| 375 | 316 | 295 | 189 | 278 | 300 | 275.6 | N/A | |
| 376 | 316 | 295 | 189 | 278 | 300 | 275.6 | N/A | |
| 377 | 316 | 296 | 189 | 277 | 300 | 275.6 | N/A | |
| 378 | 316 | 295 | 189 | 278 | 300 | 275.6 | N/A | |
| 379 | 316 | 295 | 189 | 278 | 301 | 275.8 | N/A | |
| 380 | 316 | 295 | 189 | 279 | 301 | 276.0 | N/A | |
| 381 | 316 | 295 | 190 | 278 | 301 | 276.0 | N/A | |
| 382 | 315 | 295 | 190 | 278 | 301 | 275.8 | N/A | |
| 383 | 315 | 295 | 191 | 278 | 301 | 276.0 | N/A | |

WOODSTOVE SURFACE TEMPERATURE DATA

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Temperature Data (°F) | | | | | | Catalyst Exit |
|--------------------|-----------------------|----------|---------|--------|-----------|-----------------------|---------------|
| | FB Left | FB Right | FB Back | FB Top | FB Bottom | Stove Surface Average | |
| 384 | 315 | 296 | 190 | 278 | 301 | 276.0 | N/A |
| 385 | 314 | 295 | 190 | 277 | 302 | 275.6 | N/A |
| 386 | 314 | 295 | 190 | 277 | 302 | 275.6 | N/A |
| 387 | 313 | 296 | 190 | 278 | 302 | 275.8 | N/A |
| 388 | 313 | 295 | 190 | 278 | 302 | 275.6 | N/A |
| 389 | 312 | 295 | 191 | 278 | 303 | 275.8 | N/A |
| 390 | 312 | 295 | 191 | 277 | 303 | 275.6 | N/A |
| 391 | 311 | 296 | 191 | 277 | 303 | 275.6 | N/A |
| 392 | 311 | 296 | 190 | 278 | 303 | 275.6 | N/A |
| 393 | 310 | 295 | 191 | 278 | 304 | 275.6 | N/A |
| 394 | 310 | 296 | 191 | 277 | 304 | 275.6 | N/A |
| 395 | 309 | 295 | 191 | 277 | 304 | 275.2 | N/A |
| 396 | 308 | 296 | 191 | 277 | 304 | 275.2 | N/A |
| 397 | 308 | 296 | 191 | 277 | 305 | 275.4 | N/A |
| 398 | 308 | 296 | 192 | 277 | 305 | 275.6 | N/A |
| 399 | 308 | 296 | 192 | 278 | 305 | 275.8 | N/A |
| 400 | 307 | 296 | 192 | 277 | 305 | 275.4 | N/A |
| 401 | 307 | 296 | 192 | 277 | 305 | 275.4 | N/A |
| 402 | 306 | 296 | 191 | 277 | 306 | 275.2 | N/A |
| 403 | 306 | 295 | 193 | 276 | 306 | 275.2 | N/A |
| 404 | 306 | 295 | 193 | 276 | 306 | 275.2 | N/A |
| 405 | 305 | 296 | 192 | 277 | 306 | 275.2 | N/A |
| 406 | 305 | 296 | 192 | 277 | 306 | 275.2 | N/A |
| 407 | 305 | 297 | 193 | 277 | 306 | 275.6 | N/A |
| 408 | 305 | 296 | 193 | 277 | 306 | 275.4 | N/A |
| 409 | 304 | 296 | 193 | 277 | 306 | 275.2 | N/A |
| 410 | 304 | 296 | 193 | 276 | 306 | 275.0 | N/A |
| 411 | 304 | 295 | 192 | 277 | 306 | 274.8 | N/A |
| 412 | 304 | 295 | 192 | 276 | 306 | 274.6 | N/A |
| 413 | 304 | 296 | 192 | 277 | 306 | 275.0 | N/A |
| 414 | 304 | 296 | 192 | 277 | 306 | 275.0 | N/A |
| 415 | 304 | 296 | 193 | 276 | 306 | 275.0 | N/A |
| 416 | 304 | 296 | 193 | 276 | 306 | 275.0 | N/A |
| 417 | 303 | 296 | 194 | 277 | 306 | 275.2 | N/A |
| 418 | 303 | 296 | 193 | 277 | 306 | 275.0 | N/A |
| 419 | 303 | 296 | 194 | 276 | 306 | 275.0 | N/A |
| 420 | 303 | 296 | 194 | 277 | 306 | 275.2 | N/A |
| 421 | 303 | 296 | 195 | 278 | 306 | 275.6 | N/A |
| 422 | 303 | 296 | 196 | 278 | 307 | 276.0 | N/A |
| 423 | 303 | 297 | 196 | 279 | 307 | 276.4 | N/A |
| 424 | 303 | 297 | 196 | 279 | 307 | 276.4 | N/A |
| 425 | 303 | 298 | 198 | 279 | 307 | 277.0 | N/A |
| 426 | 303 | 297 | 198 | 279 | 307 | 276.8 | N/A |
| 427 | 303 | 298 | 198 | 279 | 307 | 277.0 | N/A |
| 428 | 303 | 298 | 199 | 279 | 307 | 277.2 | N/A |
| 429 | 302 | 299 | 199 | 280 | 307 | 277.4 | N/A |
| 430 | 302 | 298 | 201 | 281 | 307 | 277.8 | N/A |
| 431 | 302 | 300 | 201 | 281 | 307 | 278.2 | N/A |

WOODSTOVE SURFACE TEMPERATURE DATA

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Temperature Data (*F) | | | | | | Catalyst Exit |
|--------------------|-----------------------|----------|---------|--------|-----------|-----------------------|---------------|
| | FB Left | FB Right | FB Back | FB Top | FB Bottom | Stove Surface Average | |
| 432 | 303 | 300 | 201 | 282 | 307 | 278.6 | N/A |
| 433 | 303 | 300 | 202 | 282 | 307 | 278.8 | N/A |
| 434 | 303 | 301 | 203 | 284 | 307 | 279.6 | N/A |
| 435 | 303 | 302 | 204 | 283 | 307 | 279.8 | N/A |
| 436 | 303 | 301 | 203 | 283 | 307 | 279.4 | N/A |
| 437 | 303 | 303 | 204 | 285 | 307 | 280.4 | N/A |
| 438 | 303 | 304 | 204 | 287 | 307 | 281.0 | N/A |
| 439 | 303 | 304 | 205 | 287 | 308 | 281.4 | N/A |
| 440 | 304 | 305 | 206 | 287 | 308 | 282.0 | N/A |
| 441 | 303 | 305 | 207 | 288 | 308 | 282.2 | N/A |
| 442 | 304 | 306 | 206 | 289 | 308 | 282.6 | N/A |
| 443 | 304 | 307 | 206 | 290 | 308 | 283.0 | N/A |
| 444 | 305 | 307 | 207 | 289 | 308 | 283.2 | N/A |
| 445 | 304 | 307 | 208 | 289 | 308 | 283.2 | N/A |
| 446 | 305 | 308 | 208 | 291 | 308 | 284.0 | N/A |
| 447 | 305 | 309 | 208 | 291 | 308 | 284.2 | N/A |
| 448 | 305 | 309 | 208 | 291 | 308 | 284.2 | N/A |
| 449 | 305 | 309 | 208 | 291 | 309 | 284.4 | N/A |
| 450 | 305 | 309 | 208 | 291 | 309 | 284.4 | N/A |
| 451 | 306 | 310 | 208 | 291 | 309 | 284.8 | N/A |
| 452 | 306 | 310 | 208 | 291 | 309 | 284.8 | N/A |
| 453 | 306 | 310 | 208 | 290 | 309 | 284.6 | N/A |
| 454 | 306 | 311 | 207 | 293 | 309 | 285.2 | N/A |
| 455 | 306 | 310 | 208 | 291 | 309 | 284.8 | N/A |
| 456 | 307 | 310 | 207 | 292 | 310 | 285.2 | N/A |
| 457 | 307 | 311 | 208 | 291 | 310 | 285.4 | N/A |
| 458 | 307 | 311 | 208 | 290 | 310 | 285.2 | N/A |
| 459 | 307 | 311 | 208 | 291 | 310 | 285.4 | N/A |
| 460 | 307 | 311 | 208 | 291 | 310 | 285.4 | N/A |
| 461 | 308 | 311 | 208 | 290 | 310 | 285.4 | N/A |
| 462 | 308 | 310 | 207 | 289 | 310 | 284.8 | N/A |
| 463 | 308 | 311 | 208 | 290 | 310 | 285.4 | N/A |
| 464 | 308 | 311 | 207 | 291 | 311 | 285.6 | N/A |
| 465 | 308 | 311 | 209 | 290 | 311 | 285.8 | N/A |
| 466 | 308 | 311 | 208 | 289 | 311 | 285.4 | N/A |
| 467 | 308 | 311 | 209 | 290 | 311 | 285.8 | N/A |
| 468 | 308 | 311 | 209 | 291 | 311 | 286.0 | N/A |
| 469 | 309 | 311 | 208 | 290 | 311 | 285.8 | N/A |
| 470 | 309 | 311 | 208 | 290 | 311 | 285.8 | N/A |
| 471 | 309 | 310 | 208 | 289 | 311 | 285.4 | N/A |
| 472 | 309 | 311 | 207 | 290 | 311 | 285.6 | N/A |
| 473 | 309 | 310 | 208 | 290 | 312 | 285.8 | N/A |
| 474 | 309 | 310 | 208 | 290 | 312 | 285.8 | N/A |
| 475 | 309 | 308 | 208 | 291 | 311 | 285.4 | N/A |
| 476 | 310 | 310 | 208 | 291 | 311 | 286.0 | N/A |
| 477 | 310 | 309 | 208 | 290 | 311 | 285.6 | N/A |
| 478 | 310 | 311 | 208 | 290 | 312 | 286.2 | N/A |
| 479 | 310 | 310 | 208 | 290 | 311 | 285.8 | N/A |

WOODSTOVE SURFACE TEMPERATURE DATA

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Temperature Data (*F) | | | | | | Catalyst Exit |
|--------------------|-----------------------|----------|---------|--------|-----------|-----------------------|---------------|
| | FB Left | FB Right | FB Back | FB Top | FB Bottom | Stove Surface Average | |
| 480 | 310 | 310 | 208 | 291 | 312 | 286.2 | N/A |
| 481 | 310 | 308 | 209 | 290 | 311 | 285.6 | N/A |
| 482 | 310 | 309 | 210 | 290 | 311 | 286.0 | N/A |
| 483 | 311 | 309 | 210 | 290 | 311 | 286.2 | N/A |
| 484 | 311 | 308 | 211 | 290 | 311 | 286.2 | N/A |
| 485 | 311 | 309 | 211 | 291 | 311 | 286.6 | N/A |
| 486 | 312 | 309 | 212 | 290 | 311 | 286.8 | N/A |
| 487 | 312 | 309 | 211 | 290 | 311 | 286.6 | N/A |
| 488 | 312 | 309 | 212 | 291 | 311 | 287.0 | N/A |
| 489 | 312 | 309 | 212 | 291 | 311 | 287.0 | N/A |
| 490 | 312 | 309 | 214 | 291 | 311 | 287.4 | N/A |
| 491 | 313 | 310 | 213 | 292 | 311 | 287.8 | N/A |
| 492 | 313 | 310 | 214 | 292 | 311 | 288.0 | N/A |
| 493 | 314 | 310 | 214 | 291 | 311 | 288.0 | N/A |
| 494 | 314 | 310 | 214 | 291 | 311 | 288.0 | N/A |
| 495 | 314 | 310 | 215 | 290 | 311 | 288.0 | N/A |
| 496 | 315 | 311 | 214 | 291 | 311 | 288.4 | N/A |
| 497 | 314 | 311 | 215 | 290 | 311 | 288.2 | N/A |
| 498 | 315 | 310 | 213 | 292 | 311 | 288.2 | N/A |
| 499 | 315 | 311 | 215 | 291 | 311 | 288.6 | N/A |
| 500 | 315 | 310 | 215 | 291 | 311 | 288.4 | N/A |
| 501 | 316 | 311 | 215 | 290 | 310 | 288.4 | N/A |
| 502 | 316 | 312 | 215 | 290 | 310 | 288.6 | N/A |
| 503 | 316 | 312 | 214 | 291 | 310 | 288.6 | N/A |
| 504 | 316 | 313 | 215 | 290 | 310 | 288.8 | N/A |
| 505 | 317 | 313 | 214 | 291 | 310 | 289.0 | N/A |
| 506 | 317 | 312 | 216 | 291 | 310 | 289.2 | N/A |
| 507 | 317 | 313 | 214 | 291 | 310 | 289.0 | N/A |
| 508 | 317 | 314 | 213 | 291 | 310 | 289.0 | N/A |
| 509 | 317 | 313 | 214 | 291 | 310 | 289.0 | N/A |
| 510 | 318 | 314 | 215 | 291 | 310 | 289.6 | N/A |
| 511 | 318 | 314 | 215 | 292 | 309 | 289.6 | N/A |
| 512 | 318 | 314 | 214 | 292 | 309 | 289.4 | N/A |
| 513 | 318 | 315 | 213 | 292 | 309 | 289.4 | N/A |
| 514 | 319 | 315 | 214 | 293 | 309 | 290.0 | N/A |
| 515 | 319 | 316 | 214 | 291 | 309 | 289.8 | N/A |
| 516 | 319 | 316 | 214 | 293 | 309 | 290.2 | N/A |
| 517 | 319 | 316 | 214 | 291 | 308 | 289.6 | N/A |
| 518 | 319 | 316 | 215 | 292 | 308 | 290.0 | N/A |
| 519 | 320 | 317 | 215 | 291 | 308 | 290.2 | N/A |
| 520 | 320 | 317 | 215 | 291 | 308 | 290.2 | N/A |
| 521 | 319 | 316 | 215 | 291 | 307 | 289.6 | N/A |
| 522 | 320 | 317 | 214 | 291 | 307 | 289.8 | N/A |
| 523 | 320 | 317 | 215 | 291 | 307 | 290.0 | N/A |
| 524 | 320 | 317 | 214 | 291 | 307 | 289.8 | N/A |
| 525 | 320 | 318 | 215 | 290 | 307 | 290.0 | N/A |
| 526 | 320 | 318 | 214 | 290 | 307 | 289.8 | N/A |
| 527 | 320 | 317 | 213 | 291 | 307 | 289.6 | N/A |

WOODSTOVE SURFACE TEMPERATURE DATA

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

| Elapsed Time (min) | Temperature Data (°F) | | | | | | |
|--------------------|-----------------------|----------|---------|--------|-----------|-----------------------|---------------|
| | FB Left | FB Right | FB Back | FB Top | FB Bottom | Stove Surface Average | Catalyst Exit |
| 528 | 320 | 316 | 214 | 290 | 306 | 289.2 | N/A |
| 529 | 320 | 316 | 214 | 289 | 306 | 289.0 | N/A |
| 530 | 320 | 318 | 215 | 290 | 306 | 289.8 | N/A |
| 531 | 320 | 317 | 214 | 291 | 306 | 289.6 | N/A |
| 532 | 320 | 317 | 216 | 290 | 305 | 289.6 | N/A |
| 533 | 319 | 318 | 215 | 289 | 305 | 289.2 | N/A |
| 534 | 320 | 318 | 215 | 289 | 306 | 289.6 | N/A |
| 535 | 320 | 317 | 215 | 290 | 305 | 289.4 | N/A |
| 536 | 320 | 317 | 216 | 289 | 305 | 289.4 | N/A |
| 537 | 319 | 317 | 217 | 289 | 305 | 289.4 | N/A |
| 538 | 320 | 315 | 216 | 290 | 305 | 289.2 | N/A |
| 539 | 319 | 317 | 216 | 290 | 305 | 289.4 | N/A |
| 540 | 319 | 317 | 217 | 289 | 304 | 289.2 | N/A |
| 541 | 319 | 317 | 216 | 289 | 304 | 289.0 | N/A |
| 542 | 319 | 317 | 217 | 288 | 304 | 289.0 | N/A |
| 543 | 319 | 317 | 216 | 289 | 304 | 289.0 | N/A |
| 544 | 318 | 316 | 217 | 290 | 304 | 289.0 | N/A |
| 545 | 318 | 315 | 218 | 289 | 304 | 288.8 | N/A |
| 546 | 318 | 316 | 218 | 288 | 304 | 288.8 | N/A |
| 547 | 317 | 315 | 217 | 289 | 303 | 288.2 | N/A |
| 548 | 317 | 315 | 216 | 289 | 303 | 288.0 | N/A |
| 549 | 317 | 316 | 218 | 289 | 303 | 288.6 | N/A |
| 550 | 317 | 314 | 216 | 289 | 303 | 287.8 | N/A |
| 551 | 317 | 316 | 217 | 288 | 303 | 288.2 | N/A |
| 552 | 317 | 315 | 215 | 288 | 303 | 287.6 | N/A |
| 553 | 317 | 315 | 216 | 288 | 303 | 287.8 | N/A |
| 554 | 317 | 315 | 215 | 287 | 303 | 287.4 | N/A |
| 555 | 317 | 314 | 215 | 288 | 303 | 287.4 | N/A |
| 556 | 317 | 314 | 215 | 287 | 302 | 287.0 | N/A |
| 557 | 316 | 314 | 213 | 288 | 302 | 286.6 | N/A |
| 558 | 316 | 314 | 213 | 288 | 302 | 286.6 | N/A |
| 559 | 316 | 314 | 211 | 287 | 302 | 286.0 | N/A |
| 560 | 316 | 315 | 210 | 285 | 302 | 285.6 | N/A |
| 561 | 316 | 313 | 209 | 285 | 302 | 285.0 | N/A |
| 562 | 316 | 313 | 209 | 285 | 302 | 285.0 | N/A |
| 563 | 316 | 310 | 209 | 285 | 302 | 284.4 | N/A |
| 564 | 315 | 311 | 208 | 284 | 302 | 284.0 | N/A |
| 565 | 315 | 312 | 207 | 285 | 301 | 284.0 | N/A |
| 566 | 316 | 311 | 206 | 284 | 301 | 283.6 | N/A |
| 567 | 315 | 311 | 206 | 284 | 301 | 283.4 | N/A |
| 568 | 315 | 311 | 206 | 282 | 301 | 283.0 | N/A |
| 569 | 315 | 311 | 206 | 283 | 301 | 283.2 | N/A |
| 570 | 315 | 311 | 204 | 283 | 301 | 282.8 | N/A |
| 571 | 315 | 308 | 205 | 283 | 301 | 282.4 | N/A |
| 572 | 314 | 309 | 204 | 282 | 301 | 282.0 | N/A |
| 573 | 314 | 309 | 205 | 282 | 300 | 282.0 | N/A |
| Average | 346 | 332 | 221 | 393 | 294 | 317 | N/A |

LAB SAMPLE DATA - ASTM E2515

Client: FPI
 Model: F2450
 Run #: 2

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/27/2019

TRAIN A (1st Hour)

| Sample Component | Sample Type | Filter, Probe, or O-Ring # | Weights | | |
|-----------------------|-------------|----------------------------|-----------|----------|-----------------|
| | | | Final, mg | Tare, mg | Particulate, mg |
| A. Front filter catch | Filter | T114 | 90.7 | 88.3 | 2.4 |
| B. Rear filter catch | Filter | | | | 0.0 |
| C. Probe catch* | Probe | | | | 0.0 |
| D. O-Ring catch* | O-Ring | | | | 0.0 |

Sub-Total Total Particulate, mg: 2.4

TRAIN A (Post 1st hour)

| Sample Component | Sample Type | Filter, Probe, or O-Ring # | Weights | | |
|-----------------------|-------------|----------------------------|-----------|----------|-----------------|
| | | | Final, mg | Tare, mg | Particulate, mg |
| A. Front filter catch | Filter | T115 | 190.3 | 89.3 | 11.7 |
| B. Rear filter catch | Filter | T116 | | 89.3 | |
| C. Probe catch* | Probe | 8A | 116824.2 | 116824.1 | 0.1 |
| D. O-Ring catch* | O-Ring | 8A | 3547.2 | 3547.0 | 0.2 |

Sub-Total Total Particulate, mg: 12.0

Train A Aggregate Total Particulate, mg: **14.4**

TRAIN B

| Sample Component | Reagent | Filter, Probe, or O-Ring # | Weights | | |
|-----------------------|---------|----------------------------|-----------|----------|-----------------|
| | | | Final, mg | Tare, mg | Particulate, mg |
| A. Front filter catch | Filter | T117, T120 | 275.5 | 180.1 | 13.2 |
| B. Rear filter catch | Filter | T118 | | 82.2 | |
| C. Probe catch* | Probe | 8B | 116826.0 | 116826.1 | 0.0 |
| D. O-Ring catch* | O-Ring | 8B | 3581.1 | 3580.3 | 0.8 |

Total Particulate, mg: **14.0**

AMBIENT

| Sample Component | Reagent | Filter, Probe, or O-Ring # | Weights | | |
|------------------|---------|----------------------------|-----------|----------|-----------------|
| | | | Final, mg | Tare, mg | Particulate, mg |
| A. Filter catch* | Filter | T119 | 92.0 | 91.9 | 0.1 |

Total Particulate, mg: **0.1**

*Particulate catch that results in a negative number, is assumed to be zero for probes and O-rings, negative numbers for filters are assumed to be part of the O-Ring weight.

ASTM E3053 Wood Heater Run Sheets

Client: FPI Job Number: 19-460 Tracking #: 0022
 Model: F2450 Run Number: 2 Test Date: 2/27/2019

Wood Heater Run Notes

Pre-Test Notes

Pre-Test Start Time: 9:25
 Air Control Setting: Fully Open

| Time | Notes |
|------|---|
| N/A | Low fire test done as a continuation of the Run 1 High Fire Test, See Run 1 notes for more detail |

Test Notes

Test Burn Start Time: 11:38
 Air Control Setting: Fully Closed

| Time | Notes |
|---------|--|
| 0 min | @3.9 lbs, leveled coal bed, turned off fan, zeroed scale and loaded low fire fuel load, door open 1 minute |
| 5 min | Set air to medium test setting |
| 14 min | Set air to low fire test setting |
| 30 min | Fan turned on low (30 minutes after fuel loading) per manufacturer's instructions |
| 60 min | Changed 1-hour filter on Train A |
| 157 min | Changed front filter on Train B due to plugging |
| 573 min | End of Test |

Test Burn End Time: 21:11

Flue Gas Concentration Measurement

Calibration Gas Values: Span Gas CO₂ (%): 16.93 CO (%): 4.330
 Mid Gas CO₂ (%): 10.00 CO (%): 2.51

Calibration Results:

| | Pre Test | | | Post Test | | |
|-----------------|----------|-------|-------|-------------|-------------|-------------|
| | Zero | Mid | Span | Zero | Mid | Span |
| Time | 9:05 | 9:09 | 9:07 | 2/28 – 6:57 | 2/28 – 6:54 | 2/28 – 6:59 |
| CO ₂ | 0.00 | 10.06 | 16.93 | 0.02 | 10.15 | 17.13 |
| CO | 0.000 | 2.492 | 4.330 | 0.000 | 2.512 | 4.371 |

Flue Gas Probe Leak Check: Initial: No Leakage Final: No Leakage

Technician Signature: 

Date: 2/28/2019
 Page 1 of 3

ASTM E3053 Wood Heater Run Sheets

Client: FPI
Model: F2450

Job Number: 19-460
Run Number: 2

Tracking #: 0022
Test Date: 2/27/2019

Test Photos



Kindling Fuel Load



Start-up Fuel Load



High Fire Fuel Load



Residual Start-up Fuel Coal Bed

Technician Signature: 

Date: 2/28/2019

ASTM E3053 Wood Heater Run Sheets

Client: FPI
Model: F2450

Job Number: 19-460
Run Number: 2

Tracking #: 0022
Test Date: 2/27/2019



High Fire Fuel Loaded



Residual High Fire Load Coal Bed



Low Fire Fuel Load



Low Fire Fuel Loaded

Technician Signature: 

Date: 2/28/2019
Page 3 of 3

**WOOD STOVE TEST DATA PACKET
ASTM E3053/E2515**



Run 3 Data Summary

Client: FPI
Model: F2450
Job #: 19-460
Tracking #: 0022
Test Date: 2/28/2019

A handwritten signature in black ink, appearing to be "AJL", is written over a horizontal line.

Techician Signature

3/5/2019

Date

TEST RESULTS - ASTM E3053 / ASTM E2515

Client: FPI

Model: F2450

Run #: 3

Job #: 19-460

Tracking #: 0022

Technician: SJB

Date: 2/28/2019

| | |
|---------------------------|-------------|
| Burn Rate (kg/hr): | 1.17 |
|---------------------------|-------------|

| | Ambient Sample | Sample Train A | Sample Train B | 1st Hour Filter |
|---|----------------|----------------|----------------|-----------------|
| Total Sample Volume (ft ³) | 59.776 | 73.736 | 72.329 | 8.861 |
| Average Gas Velocity in Dilution Tunnel (ft/sec) | 16.12 | | | |
| Average Gas Flow Rate in Dilution Tunnel (dscf/hr) | 10723.6 | | | |
| Average Gas Meter Temperature (°F) | 71.7 | 97.5 | 96.6 | 82.9 |
| Total Sample Volume (dscf) | 59.381 | 70.595 | 69.068 | 8.711 |
| Average Tunnel Temperature (°F) | 90.4 | | | |
| Total Time of Test (min) | 490 | | | |
| Total Particulate Catch (mg) | 0.1 | 6.4 | 6.3 | 4.6 |
| Particulate Concentration, dry-standard (g/dscf) | 0.0000017 | 0.0000907 | 0.0000912 | 0.0005281 |
| Total PM Emissions (g) | 0.15 | 7.79 | 7.84 | 5.65 |
| Particulate Emission Rate (g/hr) | 0.02 | 0.95 | 0.96 | 5.65 |
| Emissions Factor (g/kg) | - | 0.81 | 0.82 | - |
| Difference from Average Total Particulate Emissions (g) | - | 0.02 | 0.02 | - |
| Difference from Average Emissions Factor (g/kg) | - | 0.00 | 0.00 | - |

| Final Average Results | |
|----------------------------------|-------|
| Total Particulate Emissions (g) | 7.82 |
| Particulate Emission Rate (g/hr) | 0.96 |
| Emissions Factor (g/kg) | 0.81 |
| HHV Efficiency (%) | 73.7% |
| LHV Efficiency (%) | 78.9% |
| CO Emissions (g/min) | 1.37 |

| Quality Checks | Requirement | Observed | Result |
|----------------------------------|---|-------------------|--------|
| Dual Train Precision | Each train within 7.5% of average emissions (in grams), or emission factors within 0.5 g/kg | See Above | OK |
| Filter Temps | >80 °F, <90 °F | Min: 81 / Max: 87 | OK |
| Face Velocity | < 30 ft/min | 8.6 | OK |
| Leakage Rate | Less than 4% of average sample rate | 0 cfm | OK |
| Ambient Temp | 55-90 °F | Min: 69 / Max: 74 | OK |
| Negative Probe Weight Evaluation | <5% of Total Catch | -3.2% | OK |
| Pro-Rate Variation | 90% of readings between 90-110%; none greater than 120% or less than 80% | See Data Tabs | OK |

B415.1 Efficiency Results

Manufacturer: FPI
Model: F2450
Date: 02/28/19
Run: 3
Control #: 19-460
Test Duration: 490
Output Category: Medium

Test Results in Accordance with CSA B415.1-09

| | HHV Basis | LHV Basis |
|---------------------------------|-----------|-----------|
| Overall Efficiency | 73.7% | 78.9% |
| Combustion Efficiency | 95.3% | 95.3% |
| Heat Transfer Efficiency | 77.4% | 82.7% |

| | | | |
|---------------------------|--------|--------|----------------|
| Output Rate (kJ/h) | 17,294 | 16,405 | (Btu/h) |
| Burn Rate (kg/h) | 1.17 | 2.59 | (lb/h) |
| Input (kJ/h) | 23,450 | 22,244 | (Btu/h) |

| | | | |
|----------------------------------|-------|-------|---------------|
| Test Load Weight (dry kg) | 9.59 | 21.15 | dry lb |
| MC wet (%) | 18.35 | | |
| MC dry (%) | 22.48 | | |
| Particulate (g) | 7.82 | | |
| CO (g) | 669 | | |
| Test Duration (h) | 8.17 | | |

| Emissions | Particulate | CO |
|-------------------------|-------------|-------|
| g/MJ Output | 0.06 | 4.74 |
| g/kg Dry Fuel | 0.81 | 69.72 |
| g/h | 0.96 | 81.91 |
| g/min | 0.02 | 1.37 |
| lb/MM Btu Output | 0.13 | 11.01 |

| | |
|-----------------------------|-------|
| Air/Fuel Ratio (A/F) | 17.02 |
|-----------------------------|-------|

VERSION:

2.2

12/14/2009

HIGH FIRE FUEL LOAD DATA - ASTM E3053

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #0022
 Technician: SJB
 Date: 2/28/2019

Nominal Loading Density (lbs/ft³, wet basis): 10
 Usable Firebox Volume (ft³): 2.24
 Target Load Weight (lbs): 22.40
 Total Load Weight Range (lbs): 21.30 to 23.50
 Core Load Weight Range (lbs): 10.10 to 14.60
 Remainder Load Weight Range (lbs): 7.80 to 12.30
 Core Load Piece Range (lbs): 3.40 to 5.60
 Remainder Load Piece Range (lbs): 2.20 to 12.30
 Max Allowable Kindling Weight (lbs): 4.33
 Max Allowable Start-up Fuel Weight (lbs): 6.49

CORE LOAD DATA

| Piece # | Length (in) | Weight (lbs) | Within Spec? | Fuel Piece Moisture Readings (%DB) | | | | Within Spec? | Dry Weight | |
|---------------------|-------------|--------------|--------------|------------------------------------|------|------|------|--------------|------------|------|
| | | | | 1 | 2 | 3 | Ave. | | lbs | kg |
| 1 | 17.00 | 4.56 | In Range | 25.9 | 27.8 | 27.8 | 27.2 | In Range | 3.59 | 1.63 |
| 2 | 17.00 | 4.08 | In Range | 23.6 | 26.1 | 20.8 | 23.5 | In Range | 3.30 | 1.50 |
| 3 | 17.00 | 4.54 | In Range | 26.1 | 25.0 | 24.1 | 25.1 | In Range | 3.63 | 1.65 |
| Core Load Wt. (lbs) | | 13.18 | In Range | | | | | | | |

REMAINDER LOAD DATA (1 to 3 Pieces)

| Piece # | Length (in) | Weight (lbs) | Within Spec? | Fuel Piece Moisture Readings (%DB) | | | | Within Spec? | Dry Weight | |
|----------------------|-------------|--------------|--------------|------------------------------------|------|------|------|--------------|------------|------|
| | | | | 1 | 2 | 3 | Ave. | | lbs | kg |
| 1 | 17.00 | 3.40 | In Range | 25.0 | 27.4 | 25.0 | 25.8 | In Range | 2.70 | 1.23 |
| 2 | 17.00 | 2.71 | In Range | 21.0 | 21.3 | 20.8 | 21.0 | In Range | 2.24 | 1.02 |
| 3 | 17.00 | 2.34 | In Range | 24.2 | 22.4 | 20.9 | 22.5 | In Range | 1.91 | 0.87 |
| Remainder Load (lbs) | | 8.45 | In Range | | | | | | | |

Total Load Weight (lbs): 21.63 In Range
 Core Load % of Total Weight: 61% In Range 45-65%
 Remainder % of Total Weight: 39% In Range 35-55%
 Total Load % of Target Weight: 97% In Range 95-105%
 Actual Fuel Loading Density (lb/ft³): 9.7
 Total Load Average Moisture Content (%DB): 24.5 In Range 19-25%
 Total Load Average Moisture Content (%WB): 19.7
 Total Test Load Weight (dry basis): 17.37 lbs 7.88 kg

KINDLING AND START-UP FUEL

| Kindling Weight (lbs) | Within Spec? | Kindling Moisture Readings (%DB) | | | | Within Spec? | Dry Weight | |
|-----------------------|--------------|----------------------------------|----|----|------|--------------|------------|------|
| | | 1 | 2 | 3 | Avg. | | lbs | kg |
| 3.04 | In Range | 10 | 10 | 10 | 10.0 | In Range | 2.76 | 1.25 |

| Start-up Fuel Wt. (lb) | Within Spec? | Start-up Moisture Readings (%DB) | | | | Within Spec? | Dry Weight | |
|------------------------|--------------|----------------------------------|------|------|------|--------------|------------|------|
| | | 1 | 2 | 3 | Avg. | | lbs | kg |
| 4.28 | In Range | 18.7 | 19.4 | 20.6 | 19.6 | In Range | 3.58 | 1.62 |

TEST FUEL LOADING RANGE

Allowable Residual Start-up Fuel Range (lb): 2.2 to 4.3
 Actual Residual Start-up Fuel Weight (lb): 2.3 In Range

LOW & MEDIUM FIRE FUEL LOAD DATA - ASTM E3053

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

Nominal Loading Density (lbs/ft³, wet basis): 12
 Usable Firebox Volume (ft³): 2.24
 Target Load Weight (lbs): 26.88
 Total Load Weight Range (lbs): 25.54 to 28.22
 Core Load Weight Range (lbs): 12.10 to 17.47
 Remainder Load Weight Range (lbs): 9.41 to 14.78
 Core Load Piece Range (lbs): 4.03 to 6.72
 Remainder Load Piece Range (lbs): 2.69 to 8.06

CORE LOAD DATA

| Piece # | Length (in) | Weight (lbs) | Within Spec? | Fuel Piece Moisture Readings (%DB) | | | | Within Spec? | Dry Weight | |
|---------------------|-------------|--------------|--------------|------------------------------------|------|------|------|--------------|------------|------|
| | | | | 1 | 2 | 3 | Ave. | | lbs | kg |
| 1 | 17.00 | 5.16 | In Range | 22.8 | 18.3 | 23.1 | 21.4 | In Range | 4.25 | 1.93 |
| 2 | 17.00 | 4.61 | In Range | 23.5 | 24.7 | 24.9 | 24.4 | In Range | 3.71 | 1.68 |
| 3 | 17.00 | 6.06 | In Range | 22.3 | 22.7 | 22.3 | 22.4 | In Range | 4.95 | 2.25 |
| Core Load Wt. (lbs) | | 15.83 | In Range | | | | | | | |

REMAINDER LOAD DATA (2 to 3 Pieces)

| Piece # | Length (in) | Weight (lbs) | Within Spec? | Fuel Piece Moisture Readings (%DB) | | | | Within Spec? | Dry Weight | |
|----------------------|-------------|--------------|--------------|------------------------------------|------|------|------|--------------|------------|------|
| | | | | 1 | 2 | 3 | Ave. | | lbs | kg |
| 1 | 17.00 | 6.46 | In Range | 24.2 | 23.4 | 23.1 | 23.6 | In Range | 5.23 | 2.37 |
| 2 | 17.00 | 3.59 | In Range | 22.3 | 18.7 | 18.6 | 19.9 | In Range | 2.99 | 1.36 |
| 3 | | | NA | | | | NA | NA | NA | NA |
| Remainder Load (lbs) | | 10.05 | In Range | | | | | | | |

Remainder Load Small/Large Piece Weight Ratio: 56% In Range ≤ 67%
 Total Load Weight (lbs): 25.88 In Range
 Core Load % of Total Weight: 61% In Range 45-65%
 Remainder % of Total Weight: 39% In Range 35-55%
 Total Load % of Target Weight: 96% In Range 95-105%
 Actual Fuel Loading Density (lb/ft³): 11.6
 Total Load Average Moisture Content (%DB): 22.5 In Range 19-25%
 Total Load Average Moisture Content (%WB): 18.4
 Total Test Load Weight (dry basis): 21.13 lbs 9.58 kg

TEST FUEL LOADING RANGE

Allowable Charcoal Bed Weight Range (lb): 2.6 to 5.1
 Actual Charcoal Bed Wt. (lb): 4.1 In Range

TEST END POINT

Actual Fuel Load Ending Weight (lb): 0.0 Valid Test (≥90%)

Total Fuel Burned During Test Run:
 25.9 lbs, wet basis
 21.1 lbs, dry basis
 9.58 kg, dry basis

DILUTION TUNNEL & MISC. DATA - ASTM E3053 / E2515

Client: FPI
 Model: F2450
 Run #: 3
 Test Start Time: 9:32
 Test Type: Medium Fire

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

Recording Interval (min): 1
 Total Sampling Time (min): 490

Meter Box γ Factor: 1.004 (A)
 Meter Box γ Factor: 1.000 (B)
 Meter Box γ Factor: 0.999 (Ambient)

Induced Draft Check (in. H₂O): 0
 Smoke Capture Check (%): 100%
 Date Flue Pipe Last Cleaned: 2/25/2019

| | Pre-Test | Post Test | Avg. |
|------------------------------|------------------------|-----------|-------|
| Barometric Pressure (in. Hg) | 29.96 | 29.98 | 29.97 |
| Relative Humidity (%) | 10.1 | 9.3 | |
| Room Air Velocity (ft/min) | 0 | 0 | |
| Scale Audit (lbs) | 10.0 | 10.0 | |
| Ambient Sample Volume: | 59.776 ft ³ | | |

Sample Train Post-Test Leak Checks

| | | | | |
|-----------|-------|-------|-----|--------|
| (A) | 0.000 | cfm @ | -13 | in. Hg |
| (B) | 0.000 | cfm @ | -12 | in. Hg |
| (Ambient) | 0.001 | cfm @ | -14 | in. Hg |

DILUTION TUNNEL FLOW

Traverse Data

| Point | dP (in H ₂ O) | Temp (°F) |
|--------|--------------------------|-----------|
| 1 | 0.042 | 77 |
| 2 | 0.066 | 77 |
| 3 | 0.066 | 77 |
| 4 | 0.048 | 77 |
| 5 | 0.046 | 77 |
| 6 | 0.064 | 77 |
| 7 | 0.068 | 77 |
| 8 | 0.046 | 77 |
| Center | 0.070 | 77 |

Dilution Tunnel H₂O: 2.00 percent
 Tunnel Diameter: 6 inches
 Pitot Tube Cp: 0.99 [unitless]
 Dilution Tunnel MW(dry): 29.00 lb/lb-mole
 Dilution Tunnel MW(wet): 28.78 lb/lb-mole
 Tunnel Area: 0.1963 ft²

V_{strav}: 15.92 ft/sec
 V_{scnt}: 17.68 ft/sec
 F_p: 0.901 [ratio]

Initial Tunnel Flow: 178.5 scf/min

Static Pressure: -0.200 in. H₂O

TEST FUEL PROPERTIES

ASTM 3053-17 - Table A1.1 Fuel Properties by Fuel Species

| Select Fuel Type | Species | %C | %H | %O | %Ash | MJ/kg | BTU/lb |
|------------------|---------------------------------------|-------|------|-------|------|-------|--------|
| | Ash, White | 49.70 | 6.90 | 43.00 | 0.30 | 20.75 | 8927 |
| | Beech | 48.70 | 5.80 | 44.70 | 0.60 | 18.80 | 8088 |
| | Birch, Sweet | 49.80 | 6.50 | 43.40 | 0.30 | 20.12 | 8656 |
| | Birch, Yellow | 49.80 | 6.50 | 43.40 | 0.30 | 20.12 | 8656 |
| | Doug Fir (Coast, Interior West/North) | 48.73 | 6.87 | 43.90 | 0.50 | 19.81 | 8522 |
| | Doug Fir (Interior South) | 48.73 | 6.87 | 43.90 | 0.50 | 19.81 | 8522 |
| | Elm, Rock | 50.40 | 6.60 | 42.30 | 0.70 | 20.49 | 8815 |
| | Elm, Soft | 50.40 | 6.60 | 42.30 | 0.70 | 20.49 | 8815 |
| | Gum, Red | 50.88 | 6.06 | 41.57 | 1.28 | 19.72 | 8478 |
| | Larch, Western | 50.54 | 6.36 | 42.40 | 0.70 | 17.58 | 7558 |
| X | Maple, Hard | 50.64 | 6.02 | 41.74 | 1.35 | 19.96 | 8587 |
| | Maple, Sugar | 50.64 | 6.02 | 41.74 | 1.35 | 19.96 | 8587 |
| | Oak, Red | 49.50 | 6.62 | 43.70 | 0.20 | 20.20 | 8690 |
| | Oak, White | 50.40 | 6.59 | 42.70 | 0.20 | 20.50 | 8819 |
| | Pine, Southern | 52.60 | 7.00 | 40.10 | 1.31 | 22.30 | 9587 |
| | Pine, Southern Long Leaf | 52.60 | 7.02 | 40.10 | 1.30 | 22.30 | 9594 |
| | Other | | | | | | |

WOODSTOVE PREBURN DATA

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

Recording Interval (min): 1
 Run Time (min): 98

| Elapsed Time (min) | Scale Reading (lbs) | Flue Draft (in H ₂ O) | Temperatures (°F) | | | | | | | |
|--------------------|---------------------|----------------------------------|-------------------|----------|---------|--------|-----------|-----------------------|------|---------|
| | | | FB Left | FB Right | FB Back | FB Top | FB Bottom | Stove Surface Average | Flue | Ambient |
| 0 | 1.9 | -0.007 | 78 | 77 | 78 | 76 | 81 | 78.0 | 74 | 66 |
| 1 | 1.5 | -0.082 | 78 | 77 | 82 | 100 | 81 | 83.6 | 288 | 66 |
| 2 | 0.5 | -0.098 | 83 | 83 | 101 | 153 | 80 | 100.0 | 490 | 66 |
| 3 | 0.7 | -0.079 | 93 | 95 | 117 | 230 | 80 | 123.0 | 501 | 66 |
| 4 | 0.6 | -0.073 | 105 | 109 | 129 | 296 | 80 | 143.8 | 473 | 65 |
| 5 | 0.4 | -0.069 | 118 | 124 | 146 | 330 | 80 | 159.6 | 432 | 65 |
| 6 | 2.7 | -0.062 | 133 | 138 | 157 | 350 | 80 | 171.6 | 428 | 65 |
| 7 | 2.5 | -0.084 | 147 | 150 | 168 | 366 | 81 | 182.4 | 441 | 65 |
| 8 | 2.2 | -0.091 | 161 | 162 | 179 | 409 | 83 | 198.8 | 500 | 65 |
| 9 | 1.8 | -0.095 | 174 | 176 | 192 | 466 | 85 | 218.6 | 547 | 65 |
| 10 | 1.8 | -0.080 | 189 | 191 | 206 | 520 | 87 | 238.6 | 562 | 65 |
| 11 | 1.5 | -0.092 | 206 | 207 | 223 | 562 | 90 | 257.6 | 574 | 65 |
| 12 | 1.2 | -0.085 | 224 | 222 | 239 | 597 | 93 | 275.0 | 568 | 65 |
| 13 | 1.1 | -0.091 | 242 | 237 | 256 | 623 | 97 | 291.0 | 560 | 65 |
| 14 | 0.9 | -0.079 | 259 | 253 | 271 | 644 | 101 | 305.6 | 557 | 65 |
| 15 | 0.8 | -0.079 | 276 | 269 | 286 | 661 | 105 | 319.4 | 554 | 64 |
| 16 | 3.5 | -0.093 | 292 | 283 | 302 | 669 | 109 | 331.0 | 599 | 64 |
| 17 | 3.2 | -0.089 | 307 | 296 | 315 | 688 | 114 | 344.0 | 617 | 64 |
| 18 | 2.9 | -0.093 | 321 | 311 | 329 | 723 | 118 | 360.4 | 631 | 64 |
| 19 | 2.6 | -0.092 | 333 | 325 | 342 | 755 | 123 | 375.6 | 635 | 64 |
| 20 | 2.2 | -0.085 | 346 | 340 | 357 | 779 | 128 | 390.0 | 640 | 64 |
| 21 | 16.6 | -0.101 | 359 | 354 | 372 | 815 | 133 | 406.6 | 768 | 64 |
| 22 | 23.0 | -0.086 | 372 | 369 | 381 | 808 | 138 | 413.6 | 666 | 64 |
| 23 | 22.8 | -0.096 | 384 | 380 | 387 | 836 | 144 | 426.2 | 686 | 64 |
| 24 | 22.3 | -0.089 | 394 | 388 | 391 | 861 | 149 | 436.6 | 685 | 64 |
| 25 | 22.0 | -0.077 | 402 | 395 | 396 | 883 | 154 | 446.0 | 691 | 64 |
| 26 | 21.8 | -0.087 | 410 | 400 | 401 | 900 | 159 | 454.0 | 696 | 64 |
| 27 | 22.1 | -0.109 | 417 | 406 | 405 | 917 | 163 | 461.6 | 702 | 64 |
| 28 | 22.0 | -0.102 | 423 | 410 | 409 | 928 | 168 | 467.6 | 709 | 64 |
| 29 | 21.6 | -0.091 | 429 | 414 | 413 | 935 | 173 | 472.8 | 712 | 64 |
| 30 | 21.4 | -0.102 | 435 | 418 | 417 | 946 | 177 | 478.6 | 712 | 64 |
| 31 | 20.8 | -0.089 | 440 | 421 | 420 | 954 | 181 | 483.2 | 719 | 64 |
| 32 | 20.5 | -0.096 | 446 | 425 | 423 | 963 | 185 | 488.4 | 727 | 64 |
| 33 | 19.9 | -0.092 | 451 | 428 | 425 | 972 | 190 | 493.2 | 728 | 64 |
| 34 | 19.2 | -0.097 | 456 | 431 | 427 | 976 | 194 | 496.8 | 726 | 64 |
| 35 | 18.1 | -0.099 | 460 | 435 | 430 | 981 | 197 | 500.6 | 728 | 64 |
| 36 | 17.7 | -0.101 | 466 | 438 | 432 | 982 | 201 | 503.8 | 721 | 64 |
| 37 | 17.3 | -0.091 | 470 | 441 | 434 | 985 | 205 | 507.0 | 721 | 64 |
| 38 | 17.0 | -0.098 | 474 | 444 | 437 | 985 | 208 | 509.6 | 734 | 64 |
| 39 | 16.6 | -0.095 | 478 | 447 | 439 | 987 | 212 | 512.6 | 735 | 64 |
| 40 | 16.3 | -0.102 | 481 | 449 | 441 | 987 | 215 | 514.6 | 723 | 64 |
| 41 | 15.9 | -0.097 | 485 | 452 | 366 | 968 | 218 | 497.8 | 718 | 64 |
| 42 | 15.6 | -0.104 | 489 | 454 | 335 | 957 | 221 | 491.2 | 713 | 64 |
| 43 | 15.2 | -0.104 | 492 | 457 | 313 | 952 | 224 | 487.6 | 713 | 64 |

WOODSTOVE PREBURN DATA

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

Recording Interval (min): 1
 Run Time (min): 98

| Elapsed Time (min) | Scale Reading (lbs) | Flue Draft (in H ₂ O) | Temperatures (°F) | | | | | | | |
|--------------------|---------------------|----------------------------------|-------------------|----------|---------|--------|-----------|-----------------------|------|---------|
| | | | FB Left | FB Right | FB Back | FB Top | FB Bottom | Stove Surface Average | Flue | Ambient |
| 44 | 14.9 | -0.103 | 496 | 459 | 297 | 951 | 227 | 486.0 | 703 | 64 |
| 45 | 14.6 | -0.089 | 499 | 462 | 287 | 947 | 230 | 485.0 | 704 | 64 |
| 46 | 14.2 | -0.089 | 502 | 465 | 280 | 946 | 233 | 485.2 | 707 | 64 |
| 47 | 13.9 | -0.100 | 506 | 467 | 275 | 943 | 236 | 485.4 | 706 | 64 |
| 48 | 13.6 | -0.099 | 510 | 470 | 271 | 937 | 238 | 485.2 | 704 | 64 |
| 49 | 13.4 | -0.100 | 513 | 472 | 267 | 936 | 241 | 485.8 | 704 | 64 |
| 50 | 13.0 | -0.089 | 516 | 475 | 265 | 934 | 244 | 486.8 | 698 | 64 |
| 51 | 12.7 | -0.087 | 520 | 476 | 264 | 931 | 246 | 487.4 | 699 | 65 |
| 52 | 12.3 | -0.104 | 522 | 479 | 265 | 935 | 249 | 490.0 | 697 | 65 |
| 53 | 12.1 | -0.102 | 526 | 481 | 264 | 938 | 251 | 492.0 | 696 | 65 |
| 54 | 11.8 | -0.096 | 529 | 483 | 264 | 941 | 254 | 494.2 | 691 | 65 |
| 55 | 11.5 | -0.086 | 532 | 485 | 264 | 934 | 257 | 494.4 | 688 | 65 |
| 56 | 11.2 | -0.087 | 536 | 488 | 264 | 931 | 260 | 495.8 | 673 | 65 |
| 57 | 11.0 | -0.098 | 539 | 489 | 265 | 927 | 263 | 496.6 | 663 | 65 |
| 58 | 10.7 | -0.101 | 542 | 492 | 265 | 921 | 265 | 497.0 | 657 | 65 |
| 59 | 10.5 | -0.092 | 544 | 494 | 266 | 915 | 268 | 497.4 | 655 | 65 |
| 60 | 10.2 | -0.087 | 547 | 496 | 267 | 911 | 271 | 498.4 | 649 | 65 |
| 61 | 10.0 | -0.092 | 549 | 498 | 267 | 907 | 273 | 498.8 | 646 | 65 |
| 62 | 9.7 | -0.099 | 551 | 500 | 268 | 905 | 276 | 500.0 | 646 | 65 |
| 63 | 9.5 | -0.099 | 552 | 502 | 270 | 900 | 278 | 500.4 | 643 | 65 |
| 64 | 9.2 | -0.094 | 553 | 503 | 271 | 898 | 281 | 501.2 | 641 | 65 |
| 65 | 9.0 | -0.096 | 554 | 507 | 272 | 895 | 284 | 502.4 | 639 | 65 |
| 66 | 8.8 | -0.086 | 556 | 508 | 273 | 892 | 287 | 503.2 | 637 | 65 |
| 67 | 8.5 | -0.086 | 556 | 510 | 275 | 884 | 289 | 502.8 | 633 | 65 |
| 68 | 8.3 | -0.087 | 557 | 512 | 276 | 878 | 292 | 503.0 | 630 | 65 |
| 69 | 8.1 | -0.094 | 560 | 515 | 277 | 873 | 295 | 504.0 | 625 | 65 |
| 70 | 7.9 | -0.096 | 562 | 517 | 277 | 869 | 297 | 504.4 | 620 | 65 |
| 71 | 7.7 | -0.083 | 563 | 519 | 279 | 859 | 300 | 504.0 | 615 | 66 |
| 72 | 7.5 | -0.090 | 564 | 521 | 281 | 855 | 303 | 504.8 | 613 | 65 |
| 73 | 7.3 | -0.098 | 566 | 523 | 282 | 849 | 305 | 505.0 | 611 | 66 |
| 74 | 7.1 | -0.084 | 568 | 526 | 283 | 850 | 308 | 507.0 | 609 | 66 |
| 75 | 6.9 | -0.091 | 569 | 528 | 283 | 844 | 311 | 507.0 | 605 | 66 |
| 76 | 6.7 | -0.078 | 571 | 530 | 284 | 842 | 314 | 508.2 | 602 | 66 |
| 77 | 6.5 | -0.088 | 573 | 531 | 285 | 839 | 316 | 508.8 | 600 | 66 |
| 78 | 6.3 | -0.088 | 573 | 534 | 286 | 839 | 319 | 510.2 | 600 | 66 |
| 79 | 6.1 | -0.088 | 575 | 535 | 286 | 837 | 321 | 510.8 | 597 | 66 |
| 80 | 6.0 | -0.080 | 577 | 537 | 288 | 837 | 324 | 512.6 | 599 | 66 |
| 81 | 5.7 | -0.085 | 582 | 538 | 293 | 842 | 328 | 516.6 | 651 | 66 |
| 82 | 5.5 | -0.098 | 585 | 540 | 296 | 858 | 332 | 522.2 | 631 | 66 |
| 83 | 5.3 | -0.096 | 587 | 543 | 300 | 864 | 336 | 526.0 | 618 | 66 |
| 84 | 5.2 | -0.083 | 591 | 544 | 299 | 862 | 339 | 527.0 | 602 | 66 |
| 85 | 5.0 | -0.082 | 593 | 546 | 300 | 857 | 341 | 527.4 | 586 | 66 |
| 86 | 4.9 | -0.096 | 596 | 547 | 300 | 843 | 344 | 526.0 | 574 | 66 |
| 87 | 4.8 | -0.078 | 597 | 549 | 302 | 824 | 346 | 523.6 | 557 | 66 |

WOODSTOVE PREBURN DATA

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

Recording Interval (min): 1
 Run Time (min): 98

| Elapsed Time (min) | Scale Reading (lbs) | Flue Draft (in H ₂ O) | Temperatures (°F) | | | | | | | Flue | Ambient |
|--------------------|---------------------|----------------------------------|-------------------|----------|---------|--------|-----------|-----------------------|-----|------|---------|
| | | | FB Left | FB Right | FB Back | FB Top | FB Bottom | Stove Surface Average | | | |
| 88 | 4.6 | -0.077 | 599 | 549 | 302 | 806 | 348 | 520.8 | 541 | 66 | |
| 89 | 4.6 | -0.074 | 599 | 549 | 301 | 787 | 350 | 517.2 | 527 | 66 | |
| 90 | 4.5 | -0.074 | 600 | 550 | 301 | 765 | 352 | 513.6 | 513 | 66 | |
| 91 | 4.4 | -0.073 | 598 | 549 | 299 | 743 | 353 | 508.4 | 497 | 66 | |
| 92 | 4.2 | -0.081 | 596 | 547 | 297 | 721 | 354 | 503.0 | 488 | 66 | |
| 93 | 4.3 | -0.086 | 594 | 545 | 294 | 699 | 355 | 497.4 | 479 | 66 | |
| 94 | 4.3 | -0.075 | 590 | 543 | 292 | 680 | 355 | 492.0 | 470 | 66 | |
| 95 | 4.3 | -0.071 | 586 | 541 | 288 | 663 | 356 | 486.8 | 462 | 66 | |
| 96 | 4.2 | -0.078 | 583 | 539 | 283 | 647 | 356 | 481.6 | 455 | 66 | |
| 97 | 4.2 | -0.073 | 579 | 536 | 278 | 632 | 357 | 476.4 | 449 | 66 | |
| 98 | 4.1 | -0.074 | 575 | 533 | 275 | 617 | 357 | 471.4 | 445 | 66 | |

BOX A TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 0 | 0.000 | | 0.070 | 0.01 | 75 | -0.13 | | 25.9 | | 124 | 444 | 85 | 74 |
| 1 | 0.134 | 0.134 | 0.070 | 2.27 | 75 | -0.63 | 97 | 25.6 | -0.3 | 140 | 430 | 86 | 74 |
| 2 | 0.277 | 0.143 | 0.070 | 2.25 | 75 | -2.39 | 103 | 25.3 | -0.3 | 134 | 508 | 86 | 73 |
| 3 | 0.424 | 0.147 | 0.070 | 2.13 | 75 | -1.19 | 106 | 24.9 | -0.4 | 136 | 559 | 85 | 73 |
| 4 | 0.562 | 0.138 | 0.070 | 2.12 | 75 | -2.44 | 99 | 24.5 | -0.4 | 131 | 524 | 83 | 73 |
| 5 | 0.709 | 0.147 | 0.070 | 2.27 | 75 | 0 | 105 | 24.3 | -0.2 | 128 | 516 | 83 | 73 |
| 6 | 0.851 | 0.142 | 0.070 | 2.20 | 75 | -2.5 | 101 | 24.1 | -0.2 | 126 | 517 | 83 | 73 |
| 7 | 1.002 | 0.151 | 0.070 | 2.34 | 75 | -2.66 | 108 | 23.8 | -0.3 | 125 | 519 | 85 | 73 |
| 8 | 1.148 | 0.146 | 0.070 | 2.28 | 76 | -2.11 | 104 | 23.5 | -0.3 | 124 | 521 | 87 | 72 |
| 9 | 1.299 | 0.151 | 0.070 | 2.30 | 76 | 0 | 107 | 23.3 | -0.2 | 123 | 523 | 86 | 73 |
| 10 | 1.443 | 0.144 | 0.070 | 2.27 | 76 | 0 | 103 | 23.1 | -0.2 | 124 | 524 | 84 | 73 |
| 11 | 1.593 | 0.150 | 0.070 | 2.26 | 76 | -0.46 | 107 | 22.8 | -0.3 | 123 | 521 | 83 | 72 |
| 12 | 1.737 | 0.144 | 0.070 | 2.23 | 77 | -2.43 | 102 | 22.4 | -0.4 | 123 | 520 | 84 | 73 |
| 13 | 1.886 | 0.149 | 0.070 | 2.23 | 77 | 0 | 106 | 22.3 | -0.1 | 123 | 520 | 85 | 73 |
| 14 | 2.029 | 0.143 | 0.070 | 2.22 | 77 | -0.94 | 102 | 22.1 | -0.2 | 123 | 521 | 86 | 73 |
| 15 | 2.179 | 0.150 | 0.070 | 2.22 | 78 | -1.15 | 106 | 21.8 | -0.3 | 122 | 518 | 85 | 73 |
| 16 | 2.322 | 0.143 | 0.070 | 2.22 | 78 | -1.08 | 101 | 21.7 | -0.1 | 122 | 514 | 84 | 73 |
| 17 | 2.471 | 0.149 | 0.070 | 2.22 | 78 | -0.65 | 106 | 21.3 | -0.4 | 122 | 513 | 84 | 73 |
| 18 | 2.614 | 0.143 | 0.070 | 2.21 | 79 | -1.24 | 101 | 21.1 | -0.2 | 122 | 508 | 85 | 73 |
| 19 | 2.763 | 0.149 | 0.070 | 2.18 | 79 | 0 | 105 | 21.0 | -0.1 | 122 | 507 | 85 | 73 |
| 20 | 2.906 | 0.143 | 0.070 | 2.19 | 79 | 0 | 101 | 20.7 | -0.3 | 122 | 505 | 84 | 73 |
| 21 | 3.055 | 0.149 | 0.070 | 2.21 | 80 | -2.8 | 105 | 20.5 | -0.2 | 120 | 504 | 83 | 73 |
| 22 | 3.198 | 0.143 | 0.070 | 2.21 | 80 | -2.56 | 101 | 20.3 | -0.2 | 118 | 500 | 84 | 73 |
| 23 | 3.347 | 0.149 | 0.070 | 2.20 | 80 | -2.27 | 105 | 20.2 | -0.1 | 117 | 497 | 85 | 73 |
| 24 | 3.490 | 0.143 | 0.070 | 2.19 | 81 | -2.13 | 100 | 19.9 | -0.3 | 116 | 490 | 86 | 73 |
| 25 | 3.639 | 0.149 | 0.070 | 2.20 | 81 | 0 | 104 | 19.7 | -0.2 | 116 | 485 | 85 | 73 |
| 26 | 3.782 | 0.143 | 0.070 | 2.19 | 81 | -2.2 | 100 | 19.5 | -0.2 | 115 | 481 | 84 | 73 |
| 27 | 3.931 | 0.149 | 0.070 | 2.18 | 82 | -0.41 | 104 | 19.3 | -0.2 | 115 | 477 | 84 | 73 |
| 28 | 4.076 | 0.145 | 0.070 | 2.27 | 82 | -1.16 | 101 | 19.2 | -0.1 | 114 | 473 | 85 | 73 |
| 29 | 4.228 | 0.152 | 0.070 | 2.27 | 83 | -0.16 | 106 | 19.0 | -0.2 | 114 | 469 | 86 | 73 |
| 30 | 4.374 | 0.146 | 0.070 | 2.28 | 83 | 0 | 102 | 18.8 | -0.2 | 113 | 464 | 85 | 73 |
| 31 | 4.525 | 0.151 | 0.070 | 2.27 | 83 | -0.74 | 105 | 18.8 | 0 | 113 | 458 | 84 | 74 |
| 32 | 4.671 | 0.146 | 0.070 | 2.27 | 84 | -2.36 | 101 | 18.5 | -0.3 | 112 | 455 | 84 | 73 |

BOX A TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 33 | 4.824 | 0.153 | 0.070 | 2.28 | 84 | -1.8 | 106 | 18.3 | -0.2 | 112 | 451 | 85 | 73 |
| 34 | 4.970 | 0.146 | 0.070 | 2.27 | 84 | -0.37 | 101 | 18.2 | -0.1 | 111 | 448 | 85 | 73 |
| 35 | 5.122 | 0.152 | 0.070 | 2.27 | 85 | -2.7 | 105 | 18.1 | -0.1 | 111 | 444 | 86 | 73 |
| 36 | 5.269 | 0.147 | 0.070 | 2.27 | 85 | -1.61 | 102 | 17.8 | -0.3 | 111 | 441 | 85 | 73 |
| 37 | 5.421 | 0.152 | 0.070 | 2.28 | 85 | -0.05 | 105 | 17.7 | -0.1 | 110 | 440 | 84 | 73 |
| 38 | 5.567 | 0.146 | 0.070 | 2.28 | 86 | -0.61 | 101 | 17.5 | -0.2 | 110 | 437 | 84 | 73 |
| 39 | 5.717 | 0.150 | 0.070 | 2.27 | 86 | 0 | 104 | 17.5 | 0 | 110 | 436 | 85 | 73 |
| 40 | 5.866 | 0.149 | 0.070 | 2.26 | 86 | -0.08 | 103 | 17.2 | -0.3 | 109 | 432 | 86 | 73 |
| 41 | 6.015 | 0.149 | 0.070 | 2.28 | 87 | -1.13 | 103 | 17.1 | -0.1 | 109 | 432 | 85 | 73 |
| 42 | 6.165 | 0.150 | 0.070 | 2.26 | 87 | -0.04 | 103 | 16.9 | -0.2 | 109 | 430 | 84 | 73 |
| 43 | 6.315 | 0.150 | 0.070 | 2.26 | 87 | -0.28 | 103 | 16.8 | -0.1 | 108 | 428 | 83 | 73 |
| 44 | 6.466 | 0.151 | 0.070 | 2.26 | 88 | -2.22 | 104 | 16.6 | -0.2 | 108 | 427 | 84 | 73 |
| 45 | 6.614 | 0.148 | 0.070 | 2.27 | 88 | -1.52 | 102 | 16.4 | -0.2 | 108 | 426 | 85 | 73 |
| 46 | 6.766 | 0.152 | 0.070 | 2.27 | 88 | -2.79 | 104 | 16.3 | -0.1 | 108 | 423 | 86 | 73 |
| 47 | 6.912 | 0.146 | 0.070 | 2.26 | 89 | -0.65 | 100 | 16.2 | -0.1 | 107 | 422 | 86 | 73 |
| 48 | 7.064 | 0.152 | 0.070 | 2.28 | 89 | -0.98 | 104 | 16.1 | -0.1 | 107 | 418 | 85 | 73 |
| 49 | 7.210 | 0.146 | 0.070 | 2.28 | 89 | -2.84 | 100 | 15.9 | -0.2 | 107 | 417 | 84 | 73 |
| 50 | 7.363 | 0.153 | 0.070 | 2.27 | 89 | -0.75 | 105 | 15.8 | -0.1 | 107 | 414 | 83 | 74 |
| 51 | 7.511 | 0.148 | 0.070 | 2.25 | 90 | -0.3 | 101 | 15.6 | -0.2 | 106 | 413 | 84 | 73 |
| 52 | 7.663 | 0.152 | 0.070 | 2.27 | 90 | -0.16 | 104 | 15.5 | -0.1 | 106 | 414 | 85 | 73 |
| 53 | 7.811 | 0.148 | 0.070 | 2.25 | 90 | -0.28 | 101 | 15.4 | -0.1 | 106 | 415 | 86 | 73 |
| 54 | 7.963 | 0.152 | 0.070 | 2.26 | 90 | -1.23 | 104 | 15.2 | -0.2 | 106 | 414 | 84 | 74 |
| 55 | 8.110 | 0.147 | 0.070 | 2.28 | 91 | -0.25 | 100 | 15.1 | -0.1 | 106 | 413 | 83 | 72 |
| 56 | 8.261 | 0.151 | 0.070 | 2.26 | 91 | -2.68 | 103 | 14.9 | -0.2 | 106 | 414 | 84 | 73 |
| 57 | 8.410 | 0.149 | 0.070 | 2.28 | 91 | -0.67 | 102 | 14.8 | -0.1 | 106 | 414 | 85 | 73 |
| 58 | 8.561 | 0.151 | 0.070 | 2.27 | 91 | -1.34 | 103 | 14.7 | -0.1 | 105 | 411 | 86 | 73 |
| 59 | 8.712 | 0.151 | 0.070 | 2.27 | 92 | -2.64 | 103 | 14.5 | -0.2 | 105 | 411 | 85 | 73 |
| 60 | 8.861 | 0.149 | 0.070 | 2.28 | 92 | -1.2 | 101 | 14.4 | -0.1 | 105 | 411 | 84 | 73 |
| 61 | 9.021 | 0.160 | 0.070 | 2.39 | 92 | -1.18 | 109 | 14.3 | -0.1 | 105 | 410 | 83 | 73 |
| 62 | 9.168 | 0.147 | 0.070 | 2.24 | 92 | -0.56 | 100 | 14.1 | -0.2 | 105 | 413 | 84 | 73 |
| 63 | 9.321 | 0.153 | 0.070 | 2.25 | 92 | -2.01 | 104 | 14.0 | -0.1 | 105 | 413 | 86 | 73 |
| 64 | 9.468 | 0.147 | 0.070 | 2.25 | 93 | -2.59 | 100 | 13.9 | -0.1 | 105 | 412 | 86 | 73 |
| 65 | 9.620 | 0.152 | 0.070 | 2.24 | 93 | -1.92 | 103 | 13.8 | -0.1 | 105 | 414 | 85 | 73 |

BOX A TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 66 | 9.768 | 0.148 | 0.070 | 2.26 | 93 | -2.61 | 100 | 13.6 | -0.2 | 105 | 413 | 84 | 73 |
| 67 | 9.918 | 0.150 | 0.070 | 2.26 | 93 | -1.89 | 102 | 13.5 | -0.1 | 105 | 413 | 84 | 73 |
| 68 | 10.065 | 0.147 | 0.070 | 2.22 | 93 | 0 | 100 | 13.4 | -0.1 | 105 | 411 | 85 | 73 |
| 69 | 10.216 | 0.151 | 0.070 | 2.26 | 94 | 0 | 102 | 13.2 | -0.2 | 105 | 413 | 86 | 73 |
| 70 | 10.364 | 0.148 | 0.070 | 2.24 | 94 | -2.59 | 100 | 13.1 | -0.1 | 105 | 415 | 86 | 73 |
| 71 | 10.514 | 0.150 | 0.070 | 2.24 | 94 | -2.6 | 102 | 12.9 | -0.2 | 105 | 413 | 84 | 73 |
| 72 | 10.664 | 0.150 | 0.070 | 2.23 | 94 | 0 | 102 | 12.8 | -0.1 | 105 | 413 | 83 | 73 |
| 73 | 10.813 | 0.149 | 0.070 | 2.23 | 94 | 0 | 101 | 12.7 | -0.1 | 105 | 410 | 84 | 73 |
| 74 | 10.964 | 0.151 | 0.070 | 2.25 | 95 | 0 | 102 | 12.6 | -0.1 | 105 | 411 | 85 | 74 |
| 75 | 11.111 | 0.147 | 0.070 | 2.25 | 95 | -1.1 | 99 | 12.5 | -0.1 | 104 | 408 | 86 | 73 |
| 76 | 11.262 | 0.151 | 0.070 | 2.25 | 95 | -0.68 | 102 | 12.3 | -0.2 | 104 | 407 | 85 | 73 |
| 77 | 11.408 | 0.146 | 0.070 | 2.22 | 95 | -2.15 | 99 | 12.2 | -0.1 | 104 | 407 | 84 | 74 |
| 78 | 11.561 | 0.153 | 0.070 | 2.24 | 95 | 0 | 103 | 12.1 | -0.1 | 104 | 407 | 83 | 73 |
| 79 | 11.706 | 0.145 | 0.070 | 2.23 | 95 | -0.07 | 98 | 12.0 | -0.1 | 104 | 406 | 84 | 73 |
| 80 | 11.858 | 0.152 | 0.070 | 2.21 | 95 | 0 | 103 | 11.8 | -0.2 | 104 | 407 | 85 | 74 |
| 81 | 12.005 | 0.147 | 0.070 | 2.22 | 96 | -0.5 | 99 | 11.7 | -0.1 | 104 | 406 | 86 | 74 |
| 82 | 12.157 | 0.152 | 0.070 | 2.22 | 96 | 0 | 103 | 11.6 | -0.1 | 104 | 408 | 85 | 74 |
| 83 | 12.303 | 0.146 | 0.070 | 2.22 | 96 | 0 | 98 | 11.5 | -0.1 | 104 | 412 | 84 | 74 |
| 84 | 12.455 | 0.152 | 0.070 | 2.21 | 96 | 0 | 103 | 11.2 | -0.3 | 104 | 416 | 83 | 74 |
| 85 | 12.601 | 0.146 | 0.070 | 2.21 | 96 | 0 | 98 | 11.2 | 0 | 104 | 419 | 84 | 73 |
| 86 | 12.752 | 0.151 | 0.070 | 2.22 | 96 | -2.25 | 102 | 11.0 | -0.2 | 105 | 421 | 86 | 73 |
| 87 | 12.898 | 0.146 | 0.070 | 2.36 | 96 | -2.66 | 99 | 10.9 | -0.1 | 105 | 426 | 86 | 74 |
| 88 | 13.051 | 0.153 | 0.070 | 2.34 | 96 | 0 | 103 | 10.8 | -0.1 | 105 | 430 | 85 | 74 |
| 89 | 13.205 | 0.154 | 0.070 | 2.33 | 97 | 0 | 104 | 10.6 | -0.2 | 105 | 428 | 84 | 74 |
| 90 | 13.357 | 0.152 | 0.070 | 2.32 | 97 | -1.79 | 102 | 10.5 | -0.1 | 105 | 421 | 84 | 73 |
| 91 | 13.511 | 0.154 | 0.070 | 2.34 | 97 | -1.09 | 104 | 10.4 | -0.1 | 104 | 414 | 85 | 73 |
| 92 | 13.660 | 0.149 | 0.070 | 2.32 | 97 | -0.35 | 100 | 10.3 | -0.1 | 104 | 410 | 86 | 73 |
| 93 | 13.817 | 0.157 | 0.070 | 2.33 | 97 | 0 | 106 | 10.2 | -0.1 | 104 | 407 | 86 | 74 |
| 94 | 13.967 | 0.150 | 0.070 | 2.32 | 97 | -1.76 | 101 | 10.1 | -0.1 | 104 | 403 | 84 | 74 |
| 95 | 14.121 | 0.154 | 0.070 | 2.34 | 97 | 0 | 104 | 10.1 | 0 | 104 | 403 | 83 | 73 |
| 96 | 14.272 | 0.151 | 0.070 | 2.32 | 97 | -2.66 | 102 | 9.9 | -0.2 | 104 | 403 | 84 | 74 |
| 97 | 14.425 | 0.153 | 0.070 | 2.31 | 97 | -1.08 | 103 | 9.7 | -0.2 | 104 | 402 | 85 | 74 |
| 98 | 14.579 | 0.154 | 0.070 | 2.32 | 98 | 0 | 103 | 9.7 | 0 | 103 | 402 | 85 | 73 |

BOX A TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 99 | 14.729 | 0.150 | 0.070 | 2.32 | 98 | 0 | 101 | 9.6 | -0.1 | 103 | 400 | 85 | 74 |
| 100 | 14.884 | 0.155 | 0.070 | 2.32 | 98 | 0 | 104 | 9.4 | -0.2 | 103 | 400 | 84 | 74 |
| 101 | 15.033 | 0.149 | 0.070 | 2.32 | 98 | -1.82 | 100 | 9.4 | 0 | 103 | 398 | 83 | 73 |
| 102 | 15.189 | 0.156 | 0.070 | 2.30 | 98 | -0.07 | 105 | 9.2 | -0.2 | 103 | 396 | 84 | 73 |
| 103 | 15.339 | 0.150 | 0.070 | 2.31 | 98 | -2 | 101 | 9.2 | 0 | 103 | 393 | 85 | 74 |
| 104 | 15.492 | 0.153 | 0.070 | 2.33 | 98 | -2.37 | 103 | 9.1 | -0.1 | 103 | 389 | 86 | 73 |
| 105 | 15.644 | 0.152 | 0.070 | 2.31 | 98 | -2.36 | 102 | 9.0 | -0.1 | 102 | 386 | 85 | 73 |
| 106 | 15.797 | 0.153 | 0.070 | 2.32 | 98 | -2.5 | 103 | 8.9 | -0.1 | 102 | 384 | 83 | 73 |
| 107 | 15.951 | 0.154 | 0.070 | 2.32 | 98 | 0 | 103 | 8.8 | -0.1 | 102 | 382 | 84 | 73 |
| 108 | 16.100 | 0.149 | 0.070 | 2.30 | 98 | 0 | 100 | 8.7 | -0.1 | 102 | 379 | 85 | 74 |
| 109 | 16.254 | 0.154 | 0.070 | 2.30 | 98 | -2.65 | 103 | 8.6 | -0.1 | 101 | 378 | 86 | 74 |
| 110 | 16.405 | 0.151 | 0.070 | 2.30 | 99 | 0 | 101 | 8.6 | 0 | 101 | 375 | 85 | 74 |
| 111 | 16.560 | 0.155 | 0.070 | 2.29 | 99 | 0 | 104 | 8.6 | 0 | 101 | 373 | 84 | 74 |
| 112 | 16.710 | 0.150 | 0.070 | 2.29 | 99 | -0.07 | 100 | 8.4 | -0.2 | 101 | 371 | 83 | 74 |
| 113 | 16.863 | 0.153 | 0.070 | 2.28 | 99 | -0.43 | 102 | 8.3 | -0.1 | 101 | 370 | 84 | 74 |
| 114 | 17.016 | 0.153 | 0.070 | 2.30 | 99 | -2.07 | 102 | 8.2 | -0.1 | 100 | 368 | 85 | 74 |
| 115 | 17.168 | 0.152 | 0.070 | 2.30 | 99 | -0.46 | 102 | 8.1 | -0.1 | 100 | 366 | 86 | 73 |
| 116 | 17.322 | 0.154 | 0.070 | 2.32 | 99 | -0.53 | 103 | 8.1 | 0 | 100 | 364 | 85 | 74 |
| 117 | 17.471 | 0.149 | 0.070 | 2.30 | 99 | -0.11 | 100 | 8.0 | -0.1 | 100 | 364 | 84 | 74 |
| 118 | 17.626 | 0.155 | 0.070 | 2.29 | 99 | -2.51 | 104 | 7.9 | -0.1 | 100 | 362 | 83 | 73 |
| 119 | 17.776 | 0.150 | 0.070 | 2.31 | 99 | -0.02 | 100 | 7.8 | -0.1 | 99 | 361 | 84 | 74 |
| 120 | 17.931 | 0.155 | 0.070 | 2.28 | 99 | -2.43 | 104 | 7.7 | -0.1 | 99 | 360 | 85 | 74 |
| 121 | 18.081 | 0.150 | 0.070 | 2.33 | 99 | -1.74 | 100 | 7.7 | 0 | 99 | 359 | 86 | 74 |
| 122 | 18.233 | 0.152 | 0.070 | 2.30 | 99 | 0 | 102 | 7.6 | -0.1 | 99 | 357 | 85 | 73 |
| 123 | 18.387 | 0.154 | 0.070 | 2.29 | 99 | -0.16 | 103 | 7.5 | -0.1 | 98 | 356 | 84 | 74 |
| 124 | 18.538 | 0.151 | 0.070 | 2.28 | 99 | -1.56 | 101 | 7.5 | 0 | 98 | 352 | 83 | 73 |
| 125 | 18.691 | 0.153 | 0.070 | 2.31 | 99 | -1.59 | 102 | 7.5 | 0 | 98 | 349 | 84 | 73 |
| 126 | 18.840 | 0.149 | 0.070 | 2.31 | 100 | -0.57 | 99 | 7.3 | -0.2 | 98 | 345 | 85 | 73 |
| 127 | 18.996 | 0.156 | 0.070 | 2.28 | 100 | -1.05 | 104 | 7.2 | -0.1 | 98 | 343 | 85 | 73 |
| 128 | 19.145 | 0.149 | 0.070 | 2.31 | 100 | -0.96 | 99 | 7.2 | 0 | 98 | 342 | 84 | 73 |
| 129 | 19.300 | 0.155 | 0.070 | 2.30 | 100 | -2.73 | 103 | 7.1 | -0.1 | 98 | 340 | 83 | 74 |
| 130 | 19.449 | 0.149 | 0.070 | 2.29 | 100 | -1.91 | 99 | 7.0 | -0.1 | 97 | 340 | 84 | 73 |
| 131 | 19.602 | 0.153 | 0.070 | 2.29 | 100 | 0 | 102 | 7.0 | 0 | 97 | 339 | 85 | 73 |

BOX A TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 132 | 19.756 | 0.154 | 0.070 | 2.29 | 100 | -2.66 | 102 | 6.9 | -0.1 | 97 | 336 | 85 | 73 |
| 133 | 19.907 | 0.151 | 0.070 | 2.30 | 100 | -0.65 | 100 | 6.9 | 0 | 97 | 333 | 84 | 73 |
| 134 | 20.060 | 0.153 | 0.070 | 2.30 | 100 | -0.45 | 102 | 6.8 | -0.1 | 97 | 331 | 83 | 73 |
| 135 | 20.209 | 0.149 | 0.070 | 2.29 | 100 | -1.2 | 99 | 6.8 | 0 | 96 | 328 | 83 | 73 |
| 136 | 20.364 | 0.155 | 0.070 | 2.31 | 100 | -1.37 | 103 | 6.7 | -0.1 | 96 | 326 | 85 | 73 |
| 137 | 20.514 | 0.150 | 0.070 | 2.28 | 100 | -0.2 | 100 | 6.6 | -0.1 | 96 | 325 | 85 | 73 |
| 138 | 20.668 | 0.154 | 0.070 | 2.30 | 100 | -2.64 | 102 | 6.6 | 0 | 96 | 323 | 85 | 73 |
| 139 | 20.818 | 0.150 | 0.070 | 2.31 | 100 | -1.76 | 100 | 6.5 | -0.1 | 96 | 322 | 83 | 74 |
| 140 | 20.971 | 0.153 | 0.070 | 2.30 | 100 | -0.78 | 102 | 6.5 | 0 | 96 | 321 | 83 | 73 |
| 141 | 21.125 | 0.154 | 0.070 | 2.29 | 100 | -1.46 | 102 | 6.4 | -0.1 | 96 | 321 | 84 | 73 |
| 142 | 21.276 | 0.151 | 0.070 | 2.30 | 100 | -0.62 | 100 | 6.4 | 0 | 95 | 319 | 85 | 73 |
| 143 | 21.429 | 0.153 | 0.070 | 2.27 | 100 | -0.97 | 102 | 6.3 | -0.1 | 95 | 317 | 85 | 73 |
| 144 | 21.578 | 0.149 | 0.070 | 2.30 | 100 | -0.05 | 99 | 6.3 | 0 | 95 | 315 | 84 | 73 |
| 145 | 21.734 | 0.156 | 0.070 | 2.30 | 100 | -2.83 | 104 | 6.2 | -0.1 | 95 | 313 | 83 | 73 |
| 146 | 21.884 | 0.150 | 0.070 | 2.30 | 100 | -2.64 | 100 | 6.2 | 0 | 94 | 312 | 84 | 73 |
| 147 | 22.037 | 0.153 | 0.070 | 2.30 | 100 | -0.73 | 102 | 6.1 | -0.1 | 94 | 312 | 85 | 73 |
| 148 | 22.188 | 0.151 | 0.070 | 2.30 | 100 | -2.42 | 100 | 6.1 | 0 | 94 | 311 | 85 | 73 |
| 149 | 22.341 | 0.153 | 0.070 | 2.29 | 100 | -0.66 | 102 | 6.0 | -0.1 | 94 | 310 | 84 | 73 |
| 150 | 22.494 | 0.153 | 0.070 | 2.30 | 100 | -0.84 | 102 | 6.1 | 0.1 | 94 | 311 | 83 | 73 |
| 151 | 22.645 | 0.151 | 0.070 | 2.30 | 100 | -2.77 | 100 | 5.9 | -0.2 | 94 | 312 | 84 | 73 |
| 152 | 22.798 | 0.153 | 0.070 | 2.29 | 100 | -0.03 | 102 | 5.9 | 0 | 94 | 310 | 85 | 73 |
| 153 | 22.947 | 0.149 | 0.070 | 2.29 | 100 | -0.38 | 99 | 6.0 | 0.1 | 94 | 308 | 85 | 73 |
| 154 | 23.103 | 0.156 | 0.070 | 2.30 | 100 | -2.39 | 103 | 5.8 | -0.2 | 93 | 306 | 85 | 73 |
| 155 | 23.253 | 0.150 | 0.070 | 2.30 | 101 | -0.72 | 99 | 5.8 | 0 | 93 | 303 | 83 | 73 |
| 156 | 23.406 | 0.153 | 0.070 | 2.31 | 101 | -0.05 | 101 | 5.8 | 0 | 93 | 301 | 83 | 73 |
| 157 | 23.557 | 0.151 | 0.070 | 2.30 | 101 | -2.77 | 100 | 5.7 | -0.1 | 93 | 300 | 84 | 73 |
| 158 | 23.710 | 0.153 | 0.070 | 2.29 | 101 | -0.44 | 101 | 5.6 | -0.1 | 93 | 297 | 85 | 73 |
| 159 | 23.864 | 0.154 | 0.070 | 2.29 | 101 | -0.07 | 102 | 5.6 | 0 | 93 | 296 | 85 | 73 |
| 160 | 24.013 | 0.149 | 0.070 | 2.30 | 101 | -2.7 | 99 | 5.7 | 0.1 | 93 | 295 | 84 | 73 |
| 161 | 24.168 | 0.155 | 0.070 | 2.29 | 101 | -2.1 | 103 | 5.5 | -0.2 | 93 | 296 | 83 | 73 |
| 162 | 24.316 | 0.148 | 0.070 | 2.29 | 101 | -2.69 | 98 | 5.5 | 0 | 92 | 294 | 84 | 73 |
| 163 | 24.472 | 0.156 | 0.070 | 2.29 | 101 | -2.67 | 103 | 5.4 | -0.1 | 92 | 293 | 85 | 73 |
| 164 | 24.622 | 0.150 | 0.070 | 2.29 | 101 | -1.35 | 99 | 5.4 | 0 | 92 | 292 | 85 | 73 |

BOX A TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 165 | 24.775 | 0.153 | 0.070 | 2.29 | 101 | -2.71 | 101 | 5.3 | -0.1 | 92 | 292 | 85 | 73 |
| 166 | 24.926 | 0.151 | 0.070 | 2.31 | 101 | -1.76 | 100 | 5.3 | 0 | 92 | 290 | 83 | 73 |
| 167 | 25.079 | 0.153 | 0.070 | 2.30 | 101 | -1.24 | 101 | 5.3 | 0 | 92 | 290 | 83 | 73 |
| 168 | 25.233 | 0.154 | 0.070 | 2.30 | 101 | -0.96 | 102 | 5.2 | -0.1 | 92 | 290 | 84 | 73 |
| 169 | 25.382 | 0.149 | 0.070 | 2.30 | 101 | -0.12 | 99 | 5.2 | 0 | 92 | 289 | 85 | 73 |
| 170 | 25.536 | 0.154 | 0.070 | 2.30 | 101 | -1.46 | 102 | 5.1 | -0.1 | 91 | 289 | 85 | 73 |
| 171 | 25.686 | 0.150 | 0.070 | 2.28 | 101 | -0.02 | 99 | 5.0 | -0.1 | 91 | 288 | 84 | 73 |
| 172 | 25.841 | 0.155 | 0.070 | 2.29 | 101 | -0.5 | 102 | 5.0 | 0 | 91 | 287 | 83 | 73 |
| 173 | 25.991 | 0.150 | 0.070 | 2.28 | 101 | -1.06 | 99 | 5.0 | 0 | 91 | 286 | 84 | 73 |
| 174 | 26.143 | 0.152 | 0.070 | 2.25 | 101 | -2.77 | 100 | 5.0 | 0 | 91 | 285 | 85 | 73 |
| 175 | 26.294 | 0.151 | 0.070 | 2.29 | 101 | -1.57 | 100 | 5.0 | 0 | 91 | 282 | 85 | 73 |
| 176 | 26.447 | 0.153 | 0.070 | 2.27 | 101 | -0.18 | 101 | 4.9 | -0.1 | 91 | 280 | 84 | 73 |
| 177 | 26.601 | 0.154 | 0.070 | 2.29 | 101 | 0 | 102 | 4.9 | 0 | 90 | 274 | 83 | 73 |
| 178 | 26.750 | 0.149 | 0.070 | 2.29 | 101 | -2.18 | 98 | 4.9 | 0 | 90 | 271 | 83 | 73 |
| 179 | 26.904 | 0.154 | 0.070 | 2.29 | 101 | -0.69 | 102 | 4.8 | -0.1 | 90 | 268 | 84 | 73 |
| 180 | 27.053 | 0.149 | 0.070 | 2.26 | 101 | -2.49 | 98 | 4.9 | 0.1 | 90 | 266 | 85 | 73 |
| 181 | 27.208 | 0.155 | 0.070 | 2.27 | 101 | 0 | 102 | 4.8 | -0.1 | 90 | 264 | 85 | 73 |
| 182 | 27.358 | 0.150 | 0.070 | 2.30 | 101 | -0.29 | 99 | 4.8 | 0 | 90 | 263 | 84 | 73 |
| 183 | 27.510 | 0.152 | 0.070 | 2.29 | 101 | -2.53 | 100 | 4.7 | -0.1 | 89 | 260 | 83 | 73 |
| 184 | 27.661 | 0.151 | 0.070 | 2.27 | 101 | 0 | 100 | 4.7 | 0 | 89 | 260 | 84 | 73 |
| 185 | 27.813 | 0.152 | 0.070 | 2.29 | 101 | -2.17 | 100 | 4.7 | 0 | 89 | 259 | 85 | 73 |
| 186 | 27.966 | 0.153 | 0.070 | 2.28 | 101 | -2.52 | 101 | 4.7 | 0 | 89 | 257 | 85 | 73 |
| 187 | 28.116 | 0.150 | 0.070 | 2.29 | 101 | 0 | 99 | 4.7 | 0 | 89 | 256 | 85 | 73 |
| 188 | 28.269 | 0.153 | 0.070 | 2.27 | 101 | -2.55 | 101 | 4.5 | -0.2 | 89 | 255 | 83 | 73 |
| 189 | 28.417 | 0.148 | 0.070 | 2.28 | 101 | -1.08 | 98 | 4.6 | 0.1 | 89 | 254 | 83 | 73 |
| 190 | 28.573 | 0.156 | 0.070 | 2.26 | 101 | -2.55 | 103 | 4.6 | 0 | 89 | 253 | 84 | 73 |
| 191 | 28.722 | 0.149 | 0.070 | 2.27 | 101 | -2.71 | 98 | 4.5 | -0.1 | 88 | 251 | 85 | 73 |
| 192 | 28.876 | 0.154 | 0.070 | 2.26 | 101 | -2.75 | 101 | 4.5 | 0 | 88 | 250 | 85 | 73 |
| 193 | 29.025 | 0.149 | 0.070 | 2.27 | 101 | -1.05 | 98 | 4.4 | -0.1 | 88 | 249 | 84 | 73 |
| 194 | 29.177 | 0.152 | 0.070 | 2.27 | 101 | -2.25 | 100 | 4.5 | 0.1 | 88 | 248 | 83 | 73 |
| 195 | 29.330 | 0.153 | 0.070 | 2.28 | 101 | -2.61 | 101 | 4.5 | 0 | 88 | 247 | 83 | 73 |
| 196 | 29.481 | 0.151 | 0.070 | 2.27 | 101 | -0.84 | 99 | 4.3 | -0.2 | 88 | 246 | 84 | 73 |
| 197 | 29.634 | 0.153 | 0.070 | 2.25 | 101 | 0 | 101 | 4.4 | 0.1 | 88 | 245 | 85 | 73 |

BOX A TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 198 | 29.782 | 0.148 | 0.070 | 2.25 | 101 | -2.17 | 97 | 4.4 | 0 | 87 | 244 | 85 | 73 |
| 199 | 29.936 | 0.154 | 0.070 | 2.28 | 101 | -2.83 | 101 | 4.4 | 0 | 87 | 243 | 84 | 73 |
| 200 | 30.086 | 0.150 | 0.070 | 2.27 | 101 | -2.82 | 99 | 4.3 | -0.1 | 87 | 243 | 83 | 73 |
| 201 | 30.240 | 0.154 | 0.070 | 2.27 | 101 | -2.87 | 101 | 4.2 | -0.1 | 87 | 242 | 84 | 73 |
| 202 | 30.390 | 0.150 | 0.070 | 2.27 | 101 | -0.07 | 99 | 4.4 | 0.2 | 87 | 241 | 85 | 73 |
| 203 | 30.542 | 0.152 | 0.070 | 2.28 | 101 | -0.84 | 100 | 4.3 | -0.1 | 87 | 240 | 85 | 73 |
| 204 | 30.692 | 0.150 | 0.070 | 2.27 | 101 | -2.7 | 99 | 4.2 | -0.1 | 87 | 239 | 84 | 73 |
| 205 | 30.845 | 0.153 | 0.070 | 2.26 | 101 | -1.81 | 101 | 4.3 | 0.1 | 87 | 239 | 83 | 73 |
| 206 | 30.998 | 0.153 | 0.070 | 2.26 | 101 | -0.13 | 101 | 4.2 | -0.1 | 87 | 238 | 83 | 72 |
| 207 | 31.147 | 0.149 | 0.070 | 2.28 | 101 | -2.45 | 98 | 4.2 | 0 | 87 | 238 | 84 | 72 |
| 208 | 31.300 | 0.153 | 0.070 | 2.28 | 101 | -2.34 | 101 | 4.3 | 0.1 | 87 | 238 | 85 | 72 |
| 209 | 31.448 | 0.148 | 0.070 | 2.28 | 101 | -0.04 | 97 | 4.2 | -0.1 | 87 | 237 | 85 | 72 |
| 210 | 31.603 | 0.155 | 0.070 | 2.26 | 101 | -0.09 | 102 | 4.1 | -0.1 | 86 | 237 | 84 | 72 |
| 211 | 31.752 | 0.149 | 0.070 | 2.27 | 101 | -2.68 | 98 | 4.2 | 0.1 | 86 | 236 | 83 | 72 |
| 212 | 31.906 | 0.154 | 0.070 | 2.25 | 101 | -2.59 | 101 | 4.1 | -0.1 | 86 | 235 | 84 | 72 |
| 213 | 32.054 | 0.148 | 0.070 | 2.25 | 101 | -2.12 | 97 | 4.1 | 0 | 86 | 235 | 85 | 72 |
| 214 | 32.206 | 0.152 | 0.070 | 2.27 | 101 | -1.49 | 100 | 4.0 | -0.1 | 86 | 235 | 86 | 72 |
| 215 | 32.358 | 0.152 | 0.070 | 2.27 | 101 | -1.29 | 100 | 4.0 | 0 | 86 | 234 | 85 | 72 |
| 216 | 32.509 | 0.151 | 0.070 | 2.28 | 101 | -2.57 | 99 | 4.0 | 0 | 86 | 234 | 84 | 72 |
| 217 | 32.662 | 0.153 | 0.070 | 2.27 | 101 | -0.64 | 101 | 4.0 | 0 | 86 | 234 | 83 | 72 |
| 218 | 32.810 | 0.148 | 0.070 | 2.28 | 101 | -0.02 | 97 | 4.0 | 0 | 86 | 234 | 84 | 72 |
| 219 | 32.964 | 0.154 | 0.070 | 2.28 | 101 | -0.62 | 101 | 4.1 | 0.1 | 86 | 233 | 85 | 72 |
| 220 | 33.112 | 0.148 | 0.070 | 2.25 | 101 | -1.1 | 97 | 3.9 | -0.2 | 86 | 233 | 86 | 72 |
| 221 | 33.267 | 0.155 | 0.070 | 2.28 | 101 | -2.21 | 102 | 3.9 | 0 | 86 | 232 | 85 | 72 |
| 222 | 33.415 | 0.148 | 0.070 | 2.26 | 101 | -1.04 | 97 | 3.9 | 0 | 86 | 231 | 84 | 72 |
| 223 | 33.568 | 0.153 | 0.070 | 2.27 | 101 | -2.37 | 101 | 3.9 | 0 | 86 | 232 | 84 | 72 |
| 224 | 33.718 | 0.150 | 0.070 | 2.27 | 101 | -0.21 | 99 | 3.9 | 0 | 86 | 231 | 84 | 72 |
| 225 | 33.869 | 0.151 | 0.070 | 2.25 | 101 | -2.51 | 99 | 3.8 | -0.1 | 85 | 231 | 85 | 72 |
| 226 | 34.021 | 0.152 | 0.070 | 2.26 | 101 | -1.95 | 100 | 3.8 | 0 | 85 | 230 | 86 | 72 |
| 227 | 34.171 | 0.150 | 0.070 | 2.24 | 101 | -0.2 | 99 | 3.8 | 0 | 85 | 230 | 85 | 72 |
| 228 | 34.325 | 0.154 | 0.070 | 2.25 | 101 | -2.1 | 101 | 3.8 | 0 | 85 | 230 | 83 | 72 |
| 229 | 34.472 | 0.147 | 0.070 | 2.25 | 101 | 0 | 97 | 3.8 | 0 | 85 | 229 | 84 | 72 |
| 230 | 34.626 | 0.154 | 0.070 | 2.26 | 101 | -0.03 | 101 | 3.8 | 0 | 85 | 230 | 85 | 72 |

BOX A TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 231 | 34.775 | 0.149 | 0.070 | 2.25 | 101 | 0 | 98 | 3.8 | 0 | 85 | 229 | 86 | 72 |
| 232 | 34.929 | 0.154 | 0.070 | 2.25 | 101 | 0 | 101 | 3.7 | -0.1 | 85 | 229 | 86 | 72 |
| 233 | 35.077 | 0.148 | 0.070 | 2.25 | 101 | -0.27 | 97 | 3.7 | 0 | 85 | 228 | 84 | 72 |
| 234 | 35.230 | 0.153 | 0.070 | 2.27 | 101 | -0.6 | 101 | 3.7 | 0 | 85 | 228 | 83 | 72 |
| 235 | 35.379 | 0.149 | 0.070 | 2.27 | 101 | -0.04 | 98 | 3.7 | 0 | 85 | 228 | 84 | 72 |
| 236 | 35.530 | 0.151 | 0.070 | 2.25 | 101 | -2.28 | 99 | 3.7 | 0 | 85 | 227 | 85 | 72 |
| 237 | 35.683 | 0.153 | 0.070 | 2.23 | 101 | -1.26 | 101 | 3.6 | -0.1 | 85 | 228 | 86 | 72 |
| 238 | 35.833 | 0.150 | 0.070 | 2.25 | 101 | -2.55 | 99 | 3.6 | 0 | 85 | 227 | 86 | 72 |
| 239 | 35.986 | 0.153 | 0.070 | 2.25 | 101 | -0.99 | 101 | 3.6 | 0 | 85 | 227 | 84 | 72 |
| 240 | 36.134 | 0.148 | 0.070 | 2.24 | 101 | -1.95 | 97 | 3.6 | 0 | 85 | 226 | 84 | 72 |
| 241 | 36.287 | 0.153 | 0.070 | 2.26 | 101 | -0.06 | 101 | 3.5 | -0.1 | 85 | 226 | 84 | 72 |
| 242 | 36.436 | 0.149 | 0.070 | 2.25 | 101 | -1.1 | 98 | 3.5 | 0 | 85 | 226 | 85 | 72 |
| 243 | 36.590 | 0.154 | 0.070 | 2.25 | 101 | -2.68 | 101 | 3.5 | 0 | 85 | 225 | 86 | 72 |
| 244 | 36.739 | 0.149 | 0.070 | 2.24 | 101 | -0.02 | 98 | 3.5 | 0 | 85 | 224 | 86 | 72 |
| 245 | 36.891 | 0.152 | 0.070 | 2.27 | 101 | -0.66 | 100 | 3.5 | 0 | 85 | 225 | 84 | 72 |
| 246 | 37.040 | 0.149 | 0.070 | 2.28 | 101 | -0.9 | 98 | 3.5 | 0 | 85 | 225 | 84 | 72 |
| 247 | 37.191 | 0.151 | 0.070 | 2.27 | 101 | -0.2 | 99 | 3.5 | 0 | 85 | 224 | 84 | 72 |
| 248 | 37.344 | 0.153 | 0.070 | 2.26 | 101 | -0.19 | 101 | 3.4 | -0.1 | 85 | 224 | 85 | 72 |
| 249 | 37.494 | 0.150 | 0.070 | 2.24 | 101 | -1.47 | 98 | 3.5 | 0.1 | 84 | 224 | 86 | 72 |
| 250 | 37.647 | 0.153 | 0.070 | 2.27 | 101 | -0.6 | 100 | 3.4 | -0.1 | 84 | 223 | 85 | 72 |
| 251 | 37.794 | 0.147 | 0.070 | 2.25 | 101 | -2.38 | 97 | 3.5 | 0.1 | 84 | 223 | 84 | 72 |
| 252 | 37.948 | 0.154 | 0.070 | 2.25 | 101 | -2.88 | 101 | 3.4 | -0.1 | 84 | 223 | 84 | 72 |
| 253 | 38.095 | 0.147 | 0.070 | 2.25 | 101 | -0.5 | 97 | 3.3 | -0.1 | 84 | 222 | 84 | 72 |
| 254 | 38.250 | 0.155 | 0.070 | 2.25 | 101 | -1.81 | 102 | 3.3 | 0 | 84 | 222 | 85 | 72 |
| 255 | 38.398 | 0.148 | 0.070 | 2.26 | 101 | -0.41 | 97 | 3.3 | 0 | 84 | 222 | 86 | 72 |
| 256 | 38.552 | 0.154 | 0.070 | 2.25 | 101 | -1.27 | 101 | 3.3 | 0 | 84 | 222 | 85 | 72 |
| 257 | 38.700 | 0.148 | 0.070 | 2.23 | 101 | -1.15 | 97 | 3.3 | 0 | 84 | 222 | 84 | 72 |
| 258 | 38.851 | 0.151 | 0.070 | 2.27 | 101 | -0.65 | 99 | 3.3 | 0 | 84 | 221 | 84 | 72 |
| 259 | 39.003 | 0.152 | 0.070 | 2.24 | 101 | -2.5 | 100 | 3.2 | -0.1 | 84 | 221 | 84 | 72 |
| 260 | 39.153 | 0.150 | 0.070 | 2.23 | 101 | -2.22 | 98 | 3.2 | 0 | 84 | 221 | 86 | 72 |
| 261 | 39.306 | 0.153 | 0.070 | 2.24 | 101 | -2.51 | 100 | 3.2 | 0 | 84 | 220 | 86 | 72 |
| 262 | 39.454 | 0.148 | 0.070 | 2.26 | 101 | -2.78 | 97 | 3.2 | 0 | 84 | 221 | 85 | 72 |
| 263 | 39.607 | 0.153 | 0.070 | 2.26 | 101 | -1.17 | 100 | 3.2 | 0 | 84 | 220 | 84 | 72 |

BOX A TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 264 | 39.754 | 0.147 | 0.070 | 2.26 | 101 | -2.82 | 97 | 3.2 | 0 | 84 | 220 | 84 | 72 |
| 265 | 39.909 | 0.155 | 0.070 | 2.25 | 101 | -0.01 | 102 | 3.1 | -0.1 | 84 | 219 | 84 | 72 |
| 266 | 40.057 | 0.148 | 0.070 | 2.26 | 101 | -0.24 | 97 | 3.1 | 0 | 84 | 219 | 86 | 72 |
| 267 | 40.211 | 0.154 | 0.070 | 2.24 | 101 | -1.86 | 101 | 3.1 | 0 | 84 | 219 | 86 | 72 |
| 268 | 40.358 | 0.147 | 0.070 | 2.26 | 101 | -0.12 | 97 | 3.0 | -0.1 | 84 | 218 | 85 | 72 |
| 269 | 40.511 | 0.153 | 0.070 | 2.25 | 101 | -0.24 | 100 | 3.1 | 0.1 | 84 | 218 | 84 | 72 |
| 270 | 40.660 | 0.149 | 0.070 | 2.25 | 101 | -2.36 | 98 | 3.0 | -0.1 | 84 | 218 | 84 | 72 |
| 271 | 40.812 | 0.152 | 0.070 | 2.25 | 101 | -0.6 | 100 | 3.0 | 0 | 84 | 218 | 84 | 72 |
| 272 | 40.964 | 0.152 | 0.070 | 2.25 | 101 | -0.15 | 100 | 3.0 | 0 | 84 | 218 | 86 | 72 |
| 273 | 41.114 | 0.150 | 0.070 | 2.25 | 101 | -1.71 | 98 | 3.0 | 0 | 84 | 219 | 86 | 72 |
| 274 | 41.266 | 0.152 | 0.070 | 2.25 | 101 | -1.36 | 100 | 3.0 | 0 | 84 | 219 | 85 | 72 |
| 275 | 41.414 | 0.148 | 0.070 | 2.26 | 101 | -0.35 | 97 | 3.0 | 0 | 84 | 220 | 83 | 72 |
| 276 | 41.567 | 0.153 | 0.070 | 2.23 | 101 | -0.57 | 100 | 2.9 | -0.1 | 84 | 219 | 84 | 72 |
| 277 | 41.715 | 0.148 | 0.070 | 2.26 | 101 | -2.7 | 97 | 2.9 | 0 | 84 | 219 | 85 | 72 |
| 278 | 41.869 | 0.154 | 0.070 | 2.23 | 101 | 0 | 101 | 2.9 | 0 | 84 | 219 | 86 | 71 |
| 279 | 42.018 | 0.149 | 0.070 | 2.24 | 101 | -2.78 | 98 | 2.9 | 0 | 83 | 219 | 86 | 72 |
| 280 | 42.169 | 0.151 | 0.070 | 2.25 | 101 | -0.65 | 99 | 2.9 | 0 | 83 | 219 | 85 | 71 |
| 281 | 42.318 | 0.149 | 0.070 | 2.24 | 101 | -2.65 | 98 | 2.9 | 0 | 83 | 219 | 84 | 71 |
| 282 | 42.469 | 0.151 | 0.070 | 2.26 | 101 | -2.34 | 99 | 2.9 | 0 | 83 | 218 | 84 | 71 |
| 283 | 42.621 | 0.152 | 0.070 | 2.25 | 101 | -0.03 | 100 | 2.8 | -0.1 | 83 | 218 | 85 | 72 |
| 284 | 42.771 | 0.150 | 0.070 | 2.24 | 101 | -0.16 | 98 | 2.8 | 0 | 83 | 218 | 86 | 72 |
| 285 | 42.924 | 0.153 | 0.070 | 2.24 | 101 | -2.81 | 100 | 2.8 | 0 | 83 | 218 | 85 | 72 |
| 286 | 43.071 | 0.147 | 0.070 | 2.24 | 101 | -0.17 | 96 | 2.8 | 0 | 83 | 218 | 84 | 71 |
| 287 | 43.225 | 0.154 | 0.070 | 2.25 | 101 | -2.55 | 101 | 2.8 | 0 | 83 | 216 | 84 | 71 |
| 288 | 43.372 | 0.147 | 0.070 | 2.23 | 101 | -1.28 | 96 | 2.8 | 0 | 83 | 216 | 84 | 71 |
| 289 | 43.526 | 0.154 | 0.070 | 2.23 | 101 | -1.7 | 101 | 2.7 | -0.1 | 83 | 216 | 85 | 72 |
| 290 | 43.674 | 0.148 | 0.070 | 2.24 | 101 | -0.94 | 97 | 2.7 | 0 | 83 | 216 | 86 | 72 |
| 291 | 43.828 | 0.154 | 0.070 | 2.24 | 101 | -1.94 | 101 | 2.7 | 0 | 83 | 216 | 85 | 71 |
| 292 | 43.975 | 0.147 | 0.070 | 2.26 | 101 | -0.25 | 96 | 2.6 | -0.1 | 83 | 216 | 84 | 71 |
| 293 | 44.127 | 0.152 | 0.070 | 2.24 | 100 | -0.19 | 100 | 2.7 | 0.1 | 83 | 215 | 84 | 72 |
| 294 | 44.278 | 0.151 | 0.070 | 2.24 | 100 | -2.83 | 99 | 2.7 | 0 | 83 | 215 | 84 | 72 |
| 295 | 44.429 | 0.151 | 0.070 | 2.23 | 100 | -2.39 | 99 | 2.7 | 0 | 83 | 215 | 86 | 71 |
| 296 | 44.581 | 0.152 | 0.070 | 2.24 | 100 | -0.72 | 100 | 2.6 | -0.1 | 83 | 214 | 86 | 71 |

BOX A TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 297 | 44.730 | 0.149 | 0.070 | 2.24 | 100 | -0.58 | 98 | 2.6 | 0 | 83 | 213 | 85 | 71 |
| 298 | 44.882 | 0.152 | 0.070 | 2.25 | 100 | -0.62 | 100 | 2.6 | 0 | 83 | 212 | 83 | 71 |
| 299 | 45.030 | 0.148 | 0.070 | 2.25 | 100 | -2.34 | 97 | 2.6 | 0 | 83 | 213 | 84 | 72 |
| 300 | 45.183 | 0.153 | 0.070 | 2.24 | 100 | -1.99 | 101 | 2.6 | 0 | 83 | 213 | 85 | 71 |
| 301 | 45.332 | 0.149 | 0.070 | 2.24 | 100 | -0.03 | 98 | 2.6 | 0 | 83 | 212 | 86 | 72 |
| 302 | 45.485 | 0.153 | 0.070 | 2.25 | 100 | -0.95 | 101 | 2.6 | 0 | 83 | 211 | 85 | 72 |
| 303 | 45.634 | 0.149 | 0.070 | 2.24 | 100 | -0.07 | 98 | 2.5 | -0.1 | 83 | 211 | 84 | 71 |
| 304 | 45.785 | 0.151 | 0.070 | 2.25 | 100 | -0.27 | 99 | 2.5 | 0 | 83 | 210 | 84 | 71 |
| 305 | 45.935 | 0.150 | 0.070 | 2.25 | 100 | -0.06 | 99 | 2.5 | 0 | 83 | 210 | 84 | 71 |
| 306 | 46.086 | 0.151 | 0.070 | 2.25 | 100 | -0.9 | 99 | 2.5 | 0 | 83 | 209 | 85 | 71 |
| 307 | 46.238 | 0.152 | 0.070 | 2.24 | 100 | -1.71 | 100 | 2.6 | 0.1 | 83 | 209 | 86 | 71 |
| 308 | 46.388 | 0.150 | 0.070 | 2.22 | 100 | -0.05 | 98 | 2.5 | -0.1 | 82 | 208 | 85 | 71 |
| 309 | 46.540 | 0.152 | 0.070 | 2.26 | 100 | -2.84 | 100 | 2.5 | 0 | 82 | 209 | 84 | 71 |
| 310 | 46.687 | 0.147 | 0.070 | 2.25 | 100 | -1.36 | 96 | 2.4 | -0.1 | 82 | 209 | 84 | 71 |
| 311 | 46.841 | 0.154 | 0.070 | 2.25 | 100 | -2.69 | 101 | 2.4 | 0 | 82 | 208 | 84 | 71 |
| 312 | 46.988 | 0.147 | 0.070 | 2.24 | 100 | -0.71 | 96 | 2.4 | 0 | 82 | 208 | 86 | 71 |
| 313 | 47.143 | 0.155 | 0.070 | 2.23 | 100 | -1.74 | 102 | 2.4 | 0 | 82 | 208 | 86 | 71 |
| 314 | 47.291 | 0.148 | 0.070 | 2.24 | 100 | -0.04 | 97 | 2.4 | 0 | 82 | 207 | 85 | 72 |
| 315 | 47.444 | 0.153 | 0.070 | 2.25 | 100 | -0.28 | 100 | 2.4 | 0 | 82 | 207 | 83 | 72 |
| 316 | 47.592 | 0.148 | 0.070 | 2.25 | 100 | -0.24 | 97 | 2.4 | 0 | 82 | 207 | 84 | 71 |
| 317 | 47.744 | 0.152 | 0.070 | 2.24 | 100 | -0.78 | 100 | 2.5 | 0.1 | 82 | 206 | 85 | 71 |
| 318 | 47.894 | 0.150 | 0.070 | 2.24 | 100 | -0.83 | 98 | 2.3 | -0.2 | 82 | 206 | 86 | 71 |
| 319 | 48.045 | 0.151 | 0.070 | 2.24 | 100 | -0.4 | 99 | 2.3 | 0 | 82 | 206 | 85 | 71 |
| 320 | 48.197 | 0.152 | 0.070 | 2.23 | 100 | -0.03 | 100 | 2.3 | 0 | 82 | 205 | 84 | 71 |
| 321 | 48.346 | 0.149 | 0.070 | 2.24 | 100 | -0.23 | 98 | 2.3 | 0 | 82 | 205 | 84 | 71 |
| 322 | 48.498 | 0.152 | 0.070 | 2.25 | 100 | -1.28 | 100 | 2.3 | 0 | 82 | 205 | 84 | 71 |
| 323 | 48.646 | 0.148 | 0.070 | 2.26 | 100 | -0.08 | 97 | 2.3 | 0 | 82 | 204 | 85 | 71 |
| 324 | 48.800 | 0.154 | 0.070 | 2.24 | 100 | -0.09 | 101 | 2.3 | 0 | 82 | 204 | 86 | 71 |
| 325 | 48.948 | 0.148 | 0.070 | 2.23 | 100 | -2.04 | 97 | 2.2 | -0.1 | 82 | 204 | 85 | 71 |
| 326 | 49.101 | 0.153 | 0.070 | 2.24 | 100 | -1.41 | 100 | 2.2 | 0 | 82 | 204 | 84 | 71 |
| 327 | 49.250 | 0.149 | 0.070 | 2.26 | 100 | -2.73 | 98 | 2.2 | 0 | 82 | 204 | 84 | 71 |
| 328 | 49.401 | 0.151 | 0.070 | 2.26 | 100 | -0.11 | 99 | 2.2 | 0 | 82 | 203 | 85 | 71 |
| 329 | 49.550 | 0.149 | 0.070 | 2.25 | 100 | -2.83 | 98 | 2.2 | 0 | 82 | 204 | 86 | 71 |

BOX A TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 330 | 49.702 | 0.152 | 0.070 | 2.23 | 100 | -2.72 | 100 | 2.3 | 0.1 | 82 | 204 | 86 | 71 |
| 331 | 49.853 | 0.151 | 0.070 | 2.22 | 100 | -0.1 | 99 | 2.2 | -0.1 | 82 | 203 | 85 | 71 |
| 332 | 50.003 | 0.150 | 0.070 | 2.24 | 100 | -1.27 | 98 | 2.1 | -0.1 | 82 | 203 | 83 | 71 |
| 333 | 50.156 | 0.153 | 0.070 | 2.27 | 100 | -2.81 | 100 | 2.1 | 0 | 82 | 203 | 84 | 71 |
| 334 | 50.303 | 0.147 | 0.070 | 2.27 | 100 | -0.31 | 96 | 2.1 | 0 | 81 | 203 | 85 | 71 |
| 335 | 50.456 | 0.153 | 0.070 | 2.26 | 100 | -0.07 | 100 | 2.1 | 0 | 82 | 203 | 86 | 71 |
| 336 | 50.603 | 0.147 | 0.070 | 2.25 | 100 | -2.4 | 96 | 2.2 | 0.1 | 81 | 203 | 85 | 71 |
| 337 | 50.758 | 0.155 | 0.070 | 2.24 | 100 | -1.72 | 102 | 2.1 | -0.1 | 81 | 203 | 84 | 71 |
| 338 | 50.906 | 0.148 | 0.070 | 2.23 | 100 | -2.02 | 97 | 2.1 | 0 | 81 | 203 | 84 | 71 |
| 339 | 51.059 | 0.153 | 0.070 | 2.25 | 100 | -0.07 | 100 | 2.1 | 0 | 82 | 203 | 84 | 71 |
| 340 | 51.207 | 0.148 | 0.070 | 2.24 | 100 | -0.89 | 97 | 2.0 | -0.1 | 82 | 203 | 85 | 71 |
| 341 | 51.359 | 0.152 | 0.070 | 2.25 | 100 | -0.01 | 100 | 2.0 | 0 | 82 | 203 | 86 | 71 |
| 342 | 51.508 | 0.149 | 0.070 | 2.27 | 100 | -2.24 | 98 | 2.0 | 0 | 81 | 203 | 85 | 71 |
| 343 | 51.660 | 0.152 | 0.070 | 2.25 | 100 | -1.58 | 100 | 2.0 | 0 | 82 | 203 | 83 | 71 |
| 344 | 51.811 | 0.151 | 0.070 | 2.24 | 100 | -0.14 | 99 | 2.0 | 0 | 81 | 203 | 84 | 71 |
| 345 | 51.961 | 0.150 | 0.070 | 2.25 | 100 | -0.13 | 98 | 2.1 | 0.1 | 81 | 203 | 84 | 71 |
| 346 | 52.113 | 0.152 | 0.070 | 2.24 | 100 | -2.49 | 100 | 1.9 | -0.2 | 81 | 203 | 86 | 71 |
| 347 | 52.260 | 0.147 | 0.070 | 2.27 | 100 | -2.81 | 96 | 1.9 | 0 | 81 | 202 | 86 | 70 |
| 348 | 52.413 | 0.153 | 0.070 | 2.26 | 100 | -2.02 | 100 | 2.0 | 0.1 | 81 | 202 | 85 | 71 |
| 349 | 52.561 | 0.148 | 0.070 | 2.24 | 100 | 0 | 97 | 1.9 | -0.1 | 81 | 202 | 84 | 71 |
| 350 | 52.715 | 0.154 | 0.070 | 2.24 | 100 | -0.47 | 101 | 1.9 | 0 | 81 | 201 | 84 | 71 |
| 351 | 52.863 | 0.148 | 0.070 | 2.24 | 100 | 0 | 97 | 1.9 | 0 | 81 | 201 | 85 | 71 |
| 352 | 53.015 | 0.152 | 0.070 | 2.25 | 100 | -1.82 | 100 | 1.9 | 0 | 81 | 201 | 86 | 70 |
| 353 | 53.164 | 0.149 | 0.070 | 2.22 | 100 | -0.72 | 98 | 1.9 | 0 | 81 | 201 | 85 | 70 |
| 354 | 53.315 | 0.151 | 0.070 | 2.25 | 100 | -2.86 | 99 | 1.9 | 0 | 81 | 201 | 84 | 71 |
| 355 | 53.466 | 0.151 | 0.070 | 2.24 | 100 | -2.51 | 99 | 1.9 | 0 | 81 | 201 | 84 | 70 |
| 356 | 53.616 | 0.150 | 0.070 | 2.24 | 100 | -1.05 | 98 | 1.8 | -0.1 | 81 | 200 | 84 | 70 |
| 357 | 53.768 | 0.152 | 0.070 | 2.25 | 100 | -0.06 | 100 | 1.9 | 0.1 | 81 | 200 | 86 | 70 |
| 358 | 53.917 | 0.149 | 0.070 | 2.23 | 100 | -1.27 | 98 | 1.8 | -0.1 | 81 | 200 | 86 | 70 |
| 359 | 54.069 | 0.152 | 0.070 | 2.26 | 100 | -2.71 | 100 | 1.8 | 0 | 81 | 200 | 85 | 70 |
| 360 | 54.217 | 0.148 | 0.070 | 2.25 | 100 | 0 | 97 | 1.9 | 0.1 | 81 | 200 | 83 | 70 |
| 361 | 54.370 | 0.153 | 0.070 | 2.24 | 100 | -1.49 | 100 | 1.8 | -0.1 | 81 | 200 | 83 | 70 |
| 362 | 54.518 | 0.148 | 0.070 | 2.24 | 100 | -2.68 | 97 | 1.7 | -0.1 | 81 | 200 | 84 | 70 |

BOX A TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 363 | 54.672 | 0.154 | 0.070 | 2.24 | 100 | -0.69 | 101 | 1.8 | 0.1 | 81 | 200 | 86 | 70 |
| 364 | 54.820 | 0.148 | 0.070 | 2.26 | 100 | -1.3 | 97 | 1.7 | -0.1 | 81 | 199 | 86 | 70 |
| 365 | 54.972 | 0.152 | 0.070 | 2.25 | 100 | -0.12 | 100 | 1.7 | 0 | 81 | 199 | 84 | 70 |
| 366 | 55.121 | 0.149 | 0.070 | 2.27 | 100 | -0.14 | 98 | 1.7 | 0 | 81 | 199 | 83 | 70 |
| 367 | 55.271 | 0.150 | 0.070 | 2.27 | 100 | -0.65 | 98 | 1.7 | 0 | 81 | 199 | 84 | 70 |
| 368 | 55.423 | 0.152 | 0.070 | 2.25 | 100 | -2.85 | 100 | 1.7 | 0 | 81 | 199 | 85 | 70 |
| 369 | 55.573 | 0.150 | 0.070 | 2.24 | 100 | -2.52 | 98 | 1.7 | 0 | 81 | 199 | 86 | 70 |
| 370 | 55.726 | 0.153 | 0.070 | 2.26 | 100 | -2.81 | 100 | 1.6 | -0.1 | 81 | 198 | 86 | 70 |
| 371 | 55.873 | 0.147 | 0.070 | 2.26 | 100 | -0.07 | 96 | 1.6 | 0 | 81 | 199 | 84 | 70 |
| 372 | 56.026 | 0.153 | 0.070 | 2.25 | 100 | -0.64 | 100 | 1.6 | 0 | 81 | 199 | 83 | 70 |
| 373 | 56.173 | 0.147 | 0.070 | 2.24 | 100 | -0.1 | 96 | 1.6 | 0 | 81 | 198 | 84 | 70 |
| 374 | 56.327 | 0.154 | 0.070 | 2.25 | 100 | -2.5 | 101 | 1.6 | 0 | 81 | 198 | 85 | 70 |
| 375 | 56.475 | 0.148 | 0.070 | 2.25 | 100 | -2.46 | 97 | 1.6 | 0 | 80 | 198 | 86 | 70 |
| 376 | 56.628 | 0.153 | 0.070 | 2.24 | 100 | -2.61 | 100 | 1.5 | -0.1 | 80 | 198 | 85 | 70 |
| 377 | 56.776 | 0.148 | 0.070 | 2.25 | 100 | -1.05 | 97 | 1.5 | 0 | 80 | 198 | 84 | 70 |
| 378 | 56.927 | 0.151 | 0.070 | 2.23 | 100 | -0.02 | 99 | 1.6 | 0.1 | 80 | 198 | 84 | 70 |
| 379 | 57.076 | 0.149 | 0.070 | 2.25 | 100 | -2.38 | 98 | 1.5 | -0.1 | 80 | 198 | 84 | 70 |
| 380 | 57.227 | 0.151 | 0.070 | 2.25 | 100 | -0.1 | 99 | 1.5 | 0 | 80 | 198 | 86 | 70 |
| 381 | 57.379 | 0.152 | 0.070 | 2.24 | 100 | -1.15 | 100 | 1.6 | 0.1 | 80 | 198 | 86 | 70 |
| 382 | 57.528 | 0.149 | 0.070 | 2.23 | 100 | -2.82 | 98 | 1.4 | -0.2 | 80 | 198 | 85 | 70 |
| 383 | 57.681 | 0.153 | 0.070 | 2.24 | 100 | -1.1 | 100 | 1.5 | 0.1 | 80 | 198 | 83 | 70 |
| 384 | 57.828 | 0.147 | 0.070 | 2.24 | 100 | -2.86 | 96 | 1.5 | 0 | 80 | 198 | 84 | 70 |
| 385 | 57.981 | 0.153 | 0.070 | 2.25 | 100 | -0.5 | 100 | 1.4 | -0.1 | 80 | 198 | 85 | 70 |
| 386 | 58.128 | 0.147 | 0.070 | 2.26 | 100 | -2.88 | 96 | 1.4 | 0 | 80 | 198 | 86 | 70 |
| 387 | 58.282 | 0.154 | 0.070 | 2.23 | 100 | -0.74 | 101 | 1.4 | 0 | 80 | 198 | 85 | 70 |
| 388 | 58.430 | 0.148 | 0.070 | 2.25 | 99 | -0.2 | 97 | 1.4 | 0 | 80 | 198 | 84 | 70 |
| 389 | 58.583 | 0.153 | 0.070 | 2.23 | 100 | -1.51 | 100 | 1.4 | 0 | 80 | 198 | 83 | 70 |
| 390 | 58.731 | 0.148 | 0.070 | 2.25 | 99 | -2.86 | 97 | 1.4 | 0 | 80 | 198 | 84 | 70 |
| 391 | 58.882 | 0.151 | 0.070 | 2.24 | 99 | -0.05 | 99 | 1.4 | 0 | 80 | 198 | 85 | 70 |
| 392 | 59.031 | 0.149 | 0.070 | 2.24 | 99 | -2.74 | 98 | 1.3 | -0.1 | 80 | 197 | 86 | 70 |
| 393 | 59.182 | 0.151 | 0.070 | 2.23 | 99 | -1.51 | 99 | 1.3 | 0 | 80 | 197 | 85 | 70 |
| 394 | 59.334 | 0.152 | 0.070 | 2.23 | 99 | -2.74 | 100 | 1.3 | 0 | 80 | 197 | 83 | 70 |
| 395 | 59.483 | 0.149 | 0.070 | 2.23 | 99 | -2.83 | 98 | 1.5 | 0.2 | 80 | 198 | 83 | 70 |

BOX A TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 396 | 59.635 | 0.152 | 0.070 | 2.24 | 99 | -2.54 | 100 | 1.3 | -0.2 | 80 | 197 | 84 | 70 |
| 397 | 59.782 | 0.147 | 0.070 | 2.25 | 99 | -2.9 | 96 | 1.3 | 0 | 80 | 197 | 86 | 70 |
| 398 | 59.935 | 0.153 | 0.070 | 2.25 | 99 | -2.61 | 100 | 1.2 | -0.1 | 80 | 197 | 86 | 70 |
| 399 | 60.082 | 0.147 | 0.070 | 2.23 | 99 | -2.89 | 96 | 1.2 | 0 | 80 | 198 | 84 | 70 |
| 400 | 60.236 | 0.154 | 0.070 | 2.23 | 99 | -2.87 | 101 | 1.2 | 0 | 80 | 198 | 83 | 70 |
| 401 | 60.384 | 0.148 | 0.070 | 2.23 | 99 | -2.83 | 97 | 1.2 | 0 | 80 | 197 | 84 | 69 |
| 402 | 60.537 | 0.153 | 0.070 | 2.23 | 99 | -0.25 | 100 | 1.2 | 0 | 80 | 197 | 85 | 70 |
| 403 | 60.685 | 0.148 | 0.070 | 2.23 | 99 | -0.23 | 97 | 1.2 | 0 | 80 | 198 | 86 | 70 |
| 404 | 60.836 | 0.151 | 0.070 | 2.24 | 99 | -0.32 | 99 | 1.2 | 0 | 80 | 198 | 85 | 70 |
| 405 | 60.985 | 0.149 | 0.070 | 2.23 | 99 | -0.43 | 98 | 1.1 | -0.1 | 80 | 198 | 84 | 70 |
| 406 | 61.135 | 0.150 | 0.070 | 2.23 | 99 | -2.88 | 98 | 1.1 | 0 | 80 | 199 | 83 | 70 |
| 407 | 61.287 | 0.152 | 0.070 | 2.23 | 99 | -0.31 | 100 | 1.1 | 0 | 80 | 199 | 84 | 70 |
| 408 | 61.436 | 0.149 | 0.070 | 2.23 | 99 | -1.15 | 98 | 1.1 | 0 | 80 | 199 | 85 | 70 |
| 409 | 61.589 | 0.153 | 0.070 | 2.22 | 99 | -1.25 | 100 | 1.1 | 0 | 80 | 199 | 86 | 70 |
| 410 | 61.736 | 0.147 | 0.070 | 2.25 | 99 | -0.3 | 96 | 1.1 | 0 | 80 | 199 | 85 | 70 |
| 411 | 61.888 | 0.152 | 0.070 | 2.22 | 99 | -2.8 | 100 | 1.0 | -0.1 | 80 | 199 | 83 | 69 |
| 412 | 62.035 | 0.147 | 0.070 | 2.23 | 99 | -2.44 | 96 | 1.0 | 0 | 80 | 199 | 84 | 70 |
| 413 | 62.188 | 0.153 | 0.070 | 2.23 | 99 | 0 | 100 | 1.0 | 0 | 80 | 199 | 85 | 70 |
| 414 | 62.336 | 0.148 | 0.070 | 2.21 | 99 | -0.15 | 97 | 1.1 | 0.1 | 80 | 200 | 86 | 70 |
| 415 | 62.489 | 0.153 | 0.070 | 2.23 | 99 | -1.83 | 100 | 0.9 | -0.2 | 80 | 200 | 86 | 69 |
| 416 | 62.637 | 0.148 | 0.070 | 2.23 | 99 | -1.37 | 97 | 1.1 | 0.2 | 80 | 201 | 84 | 69 |
| 417 | 62.789 | 0.152 | 0.070 | 2.24 | 99 | -2.91 | 100 | 1.1 | 0 | 80 | 201 | 84 | 69 |
| 418 | 62.937 | 0.148 | 0.070 | 2.25 | 99 | -0.15 | 97 | 0.9 | -0.2 | 80 | 201 | 84 | 69 |
| 419 | 63.088 | 0.151 | 0.070 | 2.24 | 99 | -2.75 | 99 | 0.9 | 0 | 80 | 201 | 85 | 69 |
| 420 | 63.238 | 0.150 | 0.070 | 2.23 | 99 | -0.21 | 98 | 0.9 | 0 | 80 | 201 | 86 | 69 |
| 421 | 63.388 | 0.150 | 0.070 | 2.22 | 99 | -2.17 | 98 | 1.0 | 0.1 | 80 | 202 | 85 | 70 |
| 422 | 63.540 | 0.152 | 0.070 | 2.22 | 99 | -2.41 | 100 | 0.9 | -0.1 | 80 | 202 | 84 | 70 |
| 423 | 63.689 | 0.149 | 0.070 | 2.25 | 99 | -2.83 | 98 | 0.9 | 0 | 80 | 202 | 84 | 69 |
| 424 | 63.840 | 0.151 | 0.070 | 2.25 | 99 | -0.36 | 99 | 0.9 | 0 | 80 | 202 | 84 | 70 |
| 425 | 63.987 | 0.147 | 0.070 | 2.24 | 99 | -0.41 | 96 | 0.9 | 0 | 80 | 202 | 85 | 69 |
| 426 | 64.140 | 0.153 | 0.070 | 2.24 | 99 | -0.03 | 100 | 0.8 | -0.1 | 80 | 201 | 86 | 69 |
| 427 | 64.287 | 0.147 | 0.070 | 2.21 | 99 | -2.66 | 96 | 0.8 | 0 | 80 | 201 | 85 | 70 |
| 428 | 64.441 | 0.154 | 0.070 | 2.22 | 99 | -0.75 | 101 | 0.8 | 0 | 80 | 202 | 83 | 70 |

BOX A TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 429 | 64.588 | 0.147 | 0.070 | 2.25 | 99 | -0.13 | 96 | 0.8 | 0 | 80 | 202 | 84 | 70 |
| 430 | 64.741 | 0.153 | 0.070 | 2.22 | 99 | -0.24 | 100 | 0.8 | 0 | 80 | 202 | 85 | 69 |
| 431 | 64.888 | 0.147 | 0.070 | 2.25 | 99 | -2.32 | 96 | 0.8 | 0 | 80 | 202 | 86 | 70 |
| 432 | 65.039 | 0.151 | 0.070 | 2.22 | 99 | -2.7 | 99 | 0.7 | -0.1 | 80 | 202 | 86 | 70 |
| 433 | 65.188 | 0.149 | 0.070 | 2.25 | 99 | -1.2 | 98 | 0.8 | 0.1 | 80 | 201 | 84 | 70 |
| 434 | 65.339 | 0.151 | 0.070 | 2.21 | 99 | -0.4 | 99 | 0.7 | -0.1 | 80 | 201 | 83 | 69 |
| 435 | 65.490 | 0.151 | 0.070 | 2.21 | 99 | -2.92 | 99 | 0.7 | 0 | 80 | 201 | 84 | 69 |
| 436 | 65.639 | 0.149 | 0.070 | 2.24 | 99 | -0.2 | 98 | 0.8 | 0.1 | 80 | 200 | 85 | 69 |
| 437 | 65.791 | 0.152 | 0.070 | 2.23 | 99 | -0.06 | 100 | 0.7 | -0.1 | 80 | 200 | 86 | 69 |
| 438 | 65.938 | 0.147 | 0.070 | 2.23 | 99 | -1.49 | 96 | 0.7 | 0 | 80 | 200 | 85 | 69 |
| 439 | 66.090 | 0.152 | 0.070 | 2.22 | 99 | -0.26 | 100 | 0.7 | 0 | 80 | 199 | 84 | 69 |
| 440 | 66.237 | 0.147 | 0.070 | 2.23 | 99 | -0.09 | 96 | 0.7 | 0 | 80 | 199 | 84 | 69 |
| 441 | 66.390 | 0.153 | 0.070 | 2.22 | 99 | -0.79 | 100 | 0.8 | 0.1 | 80 | 199 | 84 | 69 |
| 442 | 66.537 | 0.147 | 0.070 | 2.23 | 99 | -1.03 | 96 | 0.6 | -0.2 | 80 | 199 | 86 | 69 |
| 443 | 66.690 | 0.153 | 0.070 | 2.22 | 99 | -2.84 | 100 | 0.7 | 0.1 | 80 | 199 | 86 | 69 |
| 444 | 66.838 | 0.148 | 0.070 | 2.23 | 99 | -0.51 | 97 | 0.7 | 0 | 80 | 198 | 84 | 69 |
| 445 | 66.990 | 0.152 | 0.070 | 2.22 | 99 | -0.45 | 100 | 0.6 | -0.1 | 79 | 198 | 83 | 69 |
| 446 | 67.137 | 0.147 | 0.070 | 2.23 | 99 | -0.04 | 96 | 0.6 | 0 | 79 | 198 | 84 | 69 |
| 447 | 67.289 | 0.152 | 0.070 | 2.25 | 99 | -2.83 | 100 | 0.6 | 0 | 79 | 197 | 85 | 69 |
| 448 | 67.438 | 0.149 | 0.070 | 2.23 | 99 | -2.74 | 98 | 0.6 | 0 | 79 | 197 | 86 | 69 |
| 449 | 67.589 | 0.151 | 0.070 | 2.23 | 99 | -1.19 | 99 | 0.5 | -0.1 | 79 | 197 | 85 | 69 |
| 450 | 67.740 | 0.151 | 0.070 | 2.24 | 99 | -0.13 | 99 | 0.5 | 0 | 79 | 197 | 84 | 69 |
| 451 | 67.888 | 0.148 | 0.070 | 2.23 | 99 | -1.7 | 97 | 0.5 | 0 | 79 | 197 | 83 | 69 |
| 452 | 68.040 | 0.152 | 0.070 | 2.23 | 99 | -0.21 | 100 | 0.5 | 0 | 79 | 197 | 84 | 69 |
| 453 | 68.187 | 0.147 | 0.070 | 2.24 | 99 | -2.46 | 96 | 0.5 | 0 | 79 | 196 | 85 | 69 |
| 454 | 68.340 | 0.153 | 0.070 | 2.23 | 99 | -2.78 | 100 | 0.5 | 0 | 79 | 196 | 86 | 69 |
| 455 | 68.486 | 0.146 | 0.070 | 2.22 | 99 | -0.66 | 96 | 0.5 | 0 | 79 | 197 | 85 | 69 |
| 456 | 68.640 | 0.154 | 0.070 | 2.22 | 99 | -1.03 | 101 | 0.4 | -0.1 | 79 | 196 | 83 | 69 |
| 457 | 68.787 | 0.147 | 0.070 | 2.23 | 99 | -2.41 | 96 | 0.5 | 0.1 | 79 | 195 | 84 | 69 |
| 458 | 68.940 | 0.153 | 0.070 | 2.21 | 99 | -2.88 | 100 | 0.4 | -0.1 | 79 | 195 | 84 | 69 |
| 459 | 69.088 | 0.148 | 0.070 | 2.22 | 99 | -0.91 | 97 | 0.5 | 0.1 | 79 | 195 | 86 | 69 |
| 460 | 69.239 | 0.151 | 0.070 | 2.22 | 99 | -0.98 | 99 | 0.5 | 0 | 79 | 195 | 86 | 69 |
| 461 | 69.387 | 0.148 | 0.070 | 2.22 | 99 | -1.09 | 97 | 0.5 | 0 | 79 | 195 | 84 | 69 |

BOX A TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 462 | 69.538 | 0.151 | 0.070 | 2.23 | 99 | -2.81 | 99 | 0.5 | 0 | 79 | 195 | 84 | 69 |
| 463 | 69.687 | 0.149 | 0.070 | 2.24 | 99 | -2.86 | 98 | 0.4 | -0.1 | 79 | 195 | 84 | 69 |
| 464 | 69.838 | 0.151 | 0.070 | 2.22 | 99 | -1.9 | 99 | 0.5 | 0.1 | 79 | 195 | 85 | 69 |
| 465 | 69.989 | 0.151 | 0.070 | 2.23 | 99 | -1.71 | 99 | 0.3 | -0.2 | 79 | 194 | 86 | 69 |
| 466 | 70.138 | 0.149 | 0.070 | 2.19 | 99 | -0.24 | 98 | 0.4 | 0.1 | 79 | 194 | 85 | 69 |
| 467 | 70.289 | 0.151 | 0.070 | 2.23 | 99 | -0.16 | 99 | 0.3 | -0.1 | 79 | 193 | 84 | 69 |
| 468 | 70.436 | 0.147 | 0.070 | 2.22 | 99 | -0.06 | 96 | 0.3 | 0 | 79 | 193 | 83 | 69 |
| 469 | 70.588 | 0.152 | 0.070 | 2.22 | 99 | -0.09 | 100 | 0.3 | 0 | 79 | 194 | 84 | 69 |
| 470 | 70.735 | 0.147 | 0.070 | 2.22 | 99 | -2.8 | 96 | 0.3 | 0 | 79 | 193 | 85 | 69 |
| 471 | 70.889 | 0.154 | 0.070 | 2.23 | 99 | -2.19 | 101 | 0.4 | 0.1 | 79 | 193 | 86 | 69 |
| 472 | 71.036 | 0.147 | 0.070 | 2.23 | 99 | -2.2 | 96 | 0.3 | -0.1 | 79 | 193 | 85 | 69 |
| 473 | 71.189 | 0.153 | 0.070 | 2.21 | 99 | -2.71 | 100 | 0.2 | -0.1 | 79 | 193 | 83 | 69 |
| 474 | 71.336 | 0.147 | 0.070 | 2.22 | 99 | -2.12 | 96 | 0.2 | 0 | 79 | 193 | 84 | 69 |
| 475 | 71.487 | 0.151 | 0.070 | 2.23 | 99 | -0.5 | 99 | 0.2 | 0 | 79 | 193 | 85 | 69 |
| 476 | 71.636 | 0.149 | 0.070 | 2.25 | 98 | -0.06 | 98 | 0.2 | 0 | 79 | 193 | 86 | 69 |
| 477 | 71.786 | 0.150 | 0.070 | 2.23 | 98 | -0.11 | 99 | 0.2 | 0 | 79 | 192 | 86 | 69 |
| 478 | 71.936 | 0.150 | 0.070 | 2.22 | 98 | -0.53 | 99 | 0.2 | 0 | 79 | 192 | 84 | 69 |
| 479 | 72.086 | 0.150 | 0.070 | 2.24 | 98 | -1.77 | 99 | 0.2 | 0 | 79 | 192 | 83 | 69 |
| 480 | 72.238 | 0.152 | 0.070 | 2.23 | 98 | -0.1 | 100 | 0.2 | 0 | 79 | 192 | 84 | 69 |
| 481 | 72.386 | 0.148 | 0.070 | 2.24 | 98 | -1.03 | 97 | 0.2 | 0 | 79 | 191 | 85 | 69 |
| 482 | 72.538 | 0.152 | 0.070 | 2.23 | 98 | -2.56 | 100 | 0.1 | -0.1 | 79 | 191 | 86 | 69 |
| 483 | 72.684 | 0.146 | 0.070 | 2.21 | 98 | -2.56 | 96 | 0.1 | 0 | 79 | 191 | 85 | 69 |
| 484 | 72.837 | 0.153 | 0.070 | 2.22 | 98 | -1.25 | 100 | 0.2 | 0.1 | 78 | 191 | 84 | 69 |
| 485 | 72.984 | 0.147 | 0.070 | 2.22 | 98 | -0.18 | 97 | 0.1 | -0.1 | 79 | 191 | 83 | 69 |
| 486 | 73.137 | 0.153 | 0.070 | 2.23 | 98 | -0.16 | 101 | 0.1 | 0 | 79 | 191 | 84 | 69 |
| 487 | 73.285 | 0.148 | 0.070 | 2.23 | 98 | -2.6 | 97 | 0.1 | 0 | 78 | 190 | 85 | 69 |
| 488 | 73.437 | 0.152 | 0.070 | 2.21 | 98 | -0.01 | 100 | 0.1 | 0 | 78 | 189 | 86 | 69 |
| 489 | 73.585 | 0.148 | 0.070 | 2.22 | 98 | -0.48 | 97 | 0.1 | 0 | 78 | 190 | 85 | 69 |
| 490 | 73.736 | 0.151 | 0.070 | 2.23 | 98 | -1.16 | 99 | 0.0 | -0.1 | 78 | 189 | 83 | 69 |
| Avg/Tot | 73.736 | 0.150 | 0.070 | 2.25 | 97 | -1.26 | 100 | | | 90 | 278 | 85 | 71.7 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 0 | 0.000 | | 0.00 | 74 | -1 | | 85 | 0.000 | 7.11 | 0.29 |
| 1 | 0.109 | 0.109 | 2.22 | 74 | -2.31 | 80 | 86 | -0.070 | 5.20 | 0.25 |
| 2 | 0.255 | 0.146 | 2.19 | 74 | -3.15 | 107 | 86 | -0.090 | 5.79 | 0.79 |
| 3 | 0.397 | 0.142 | 2.19 | 74 | -2.36 | 104 | 86 | -0.080 | 14.36 | 1.87 |
| 4 | 0.538 | 0.141 | 2.17 | 74 | -3.45 | 103 | 85 | -0.090 | 15.26 | 3.79 |
| 5 | 0.680 | 0.142 | 2.49 | 74 | -1.92 | 104 | 84 | -0.080 | 15.34 | 2.13 |
| 6 | 0.835 | 0.155 | 2.48 | 75 | -1.3 | 113 | 84 | -0.070 | 15.26 | 1.37 |
| 7 | 0.983 | 0.148 | 2.33 | 75 | -2.75 | 108 | 81 | -0.090 | 15.43 | 1.05 |
| 8 | 1.133 | 0.150 | 2.29 | 75 | -0.74 | 109 | 85 | -0.080 | 15.50 | 0.98 |
| 9 | 1.276 | 0.143 | 2.28 | 75 | -0.87 | 104 | 86 | -0.080 | 15.60 | 1.14 |
| 10 | 1.424 | 0.148 | 2.24 | 75 | -2.74 | 107 | 86 | -0.080 | 15.72 | 1.46 |
| 11 | 1.566 | 0.142 | 2.24 | 76 | -2.92 | 103 | 86 | -0.080 | 15.68 | 1.57 |
| 12 | 1.713 | 0.147 | 2.21 | 76 | -1.37 | 106 | 86 | -0.090 | 15.52 | 1.60 |
| 13 | 1.854 | 0.141 | 2.21 | 76 | -2.12 | 102 | 85 | -0.080 | 15.55 | 1.41 |
| 14 | 2.001 | 0.147 | 2.21 | 76 | -0.89 | 106 | 85 | -0.080 | 15.51 | 1.24 |
| 15 | 2.141 | 0.140 | 2.21 | 77 | -0.94 | 101 | 85 | -0.090 | 15.24 | 1.14 |
| 16 | 2.288 | 0.147 | 2.20 | 77 | -0.72 | 106 | 85 | -0.080 | 15.01 | 1.06 |
| 17 | 2.430 | 0.142 | 2.17 | 77 | -3.13 | 103 | 85 | -0.070 | 14.74 | 0.89 |
| 18 | 2.576 | 0.146 | 2.20 | 78 | -2.53 | 105 | 86 | -0.080 | 14.52 | 0.81 |
| 19 | 2.719 | 0.143 | 2.20 | 78 | -1.41 | 103 | 86 | -0.090 | 14.36 | 0.72 |
| 20 | 2.863 | 0.144 | 2.19 | 79 | -3.06 | 104 | 86 | -0.080 | 14.36 | 0.60 |
| 21 | 3.006 | 0.143 | 2.19 | 79 | -1.78 | 103 | 86 | -0.080 | 14.21 | 0.54 |
| 22 | 3.149 | 0.143 | 2.19 | 79 | -3.19 | 103 | 85 | -0.080 | 14.11 | 0.51 |
| 23 | 3.292 | 0.143 | 2.16 | 80 | -3.22 | 102 | 85 | -0.070 | 14.11 | 0.47 |
| 24 | 3.435 | 0.143 | 2.17 | 80 | -2.18 | 102 | 85 | -0.080 | 13.91 | 0.41 |
| 25 | 3.581 | 0.146 | 2.17 | 80 | -0.85 | 104 | 85 | -0.070 | 13.54 | 0.40 |
| 26 | 3.723 | 0.142 | 2.17 | 81 | -2.01 | 101 | 86 | -0.080 | 13.43 | 0.28 |
| 27 | 3.869 | 0.146 | 2.18 | 81 | -2.56 | 104 | 86 | -0.070 | 13.20 | 0.20 |
| 28 | 4.012 | 0.143 | 2.25 | 81 | -0.81 | 102 | 86 | -0.080 | 12.85 | 0.19 |
| 29 | 4.161 | 0.149 | 2.25 | 82 | -3.3 | 106 | 86 | -0.080 | 12.62 | 0.18 |
| 30 | 4.305 | 0.144 | 2.26 | 82 | -2.32 | 102 | 85 | -0.080 | 12.50 | 0.11 |
| 31 | 4.454 | 0.149 | 2.24 | 82 | -2.5 | 106 | 85 | -0.070 | 12.15 | 0.17 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 32 | 4.598 | 0.144 | 2.25 | 83 | -3.2 | 102 | 85 | -0.070 | 12.20 | 0.10 |
| 33 | 4.747 | 0.149 | 2.26 | 83 | -0.78 | 105 | 85 | -0.070 | 11.92 | 0.15 |
| 34 | 4.892 | 0.145 | 2.27 | 84 | -2.55 | 102 | 86 | -0.080 | 11.89 | 0.14 |
| 35 | 5.041 | 0.149 | 2.26 | 84 | -1.87 | 105 | 86 | -0.070 | 11.66 | 0.13 |
| 36 | 5.186 | 0.145 | 2.27 | 84 | -2.73 | 102 | 86 | -0.070 | 11.71 | 0.14 |
| 37 | 5.335 | 0.149 | 2.27 | 85 | -1.02 | 105 | 85 | -0.080 | 11.39 | 0.16 |
| 38 | 5.480 | 0.145 | 2.26 | 85 | -1.33 | 102 | 85 | -0.080 | 11.61 | 0.15 |
| 39 | 5.629 | 0.149 | 2.25 | 85 | -1.02 | 105 | 85 | -0.070 | 11.46 | 0.12 |
| 40 | 5.774 | 0.145 | 2.25 | 86 | -2.74 | 102 | 85 | -0.080 | 11.46 | 0.13 |
| 41 | 5.923 | 0.149 | 2.26 | 86 | -3.26 | 105 | 85 | -0.070 | 11.28 | 0.11 |
| 42 | 6.067 | 0.144 | 2.26 | 86 | -0.84 | 101 | 86 | -0.080 | 11.27 | 0.14 |
| 43 | 6.217 | 0.150 | 2.26 | 86 | -3.27 | 105 | 86 | -0.070 | 11.12 | 0.15 |
| 44 | 6.361 | 0.144 | 2.25 | 87 | -3.22 | 101 | 86 | -0.080 | 11.10 | 0.10 |
| 45 | 6.511 | 0.150 | 2.25 | 87 | -1.23 | 105 | 86 | -0.080 | 11.05 | 0.15 |
| 46 | 6.656 | 0.145 | 2.26 | 87 | -0.77 | 102 | 85 | -0.080 | 11.08 | 0.14 |
| 47 | 6.805 | 0.149 | 2.26 | 88 | -1 | 104 | 85 | -0.070 | 11.08 | 0.14 |
| 48 | 6.951 | 0.146 | 2.23 | 88 | -1.27 | 102 | 85 | -0.080 | 10.81 | 0.14 |
| 49 | 7.100 | 0.149 | 2.26 | 88 | -2.45 | 104 | 85 | -0.080 | 10.75 | 0.19 |
| 50 | 7.246 | 0.146 | 2.25 | 88 | -3.2 | 102 | 86 | -0.060 | 10.84 | 0.12 |
| 51 | 7.395 | 0.149 | 2.25 | 89 | -3.21 | 104 | 86 | -0.070 | 10.79 | 0.12 |
| 52 | 7.541 | 0.146 | 2.25 | 89 | -3.27 | 102 | 86 | -0.080 | 10.69 | 0.17 |
| 53 | 7.689 | 0.148 | 2.25 | 89 | -1.47 | 103 | 86 | -0.070 | 11.01 | 0.15 |
| 54 | 7.835 | 0.146 | 2.25 | 89 | -3.25 | 102 | 85 | -0.080 | 10.86 | 0.16 |
| 55 | 7.984 | 0.149 | 2.23 | 90 | -2.52 | 104 | 85 | -0.070 | 10.91 | 0.14 |
| 56 | 8.131 | 0.147 | 2.24 | 90 | -2.38 | 102 | 85 | -0.070 | 10.98 | 0.13 |
| 57 | 8.280 | 0.149 | 2.24 | 90 | -0.93 | 104 | 85 | -0.070 | 10.94 | 0.13 |
| 58 | 8.427 | 0.147 | 2.25 | 90 | -1.23 | 102 | 86 | -0.080 | 10.88 | 0.13 |
| 59 | 8.575 | 0.148 | 2.24 | 91 | -1.88 | 103 | 86 | -0.070 | 10.84 | 0.13 |
| 60 | 8.723 | 0.148 | 2.25 | 91 | -3.18 | 103 | 86 | -0.080 | 10.93 | 0.13 |
| 61 | 8.871 | 0.148 | 2.24 | 91 | -3.06 | 103 | 86 | -0.070 | 11.00 | 0.11 |
| 62 | 9.019 | 0.148 | 2.25 | 91 | -1.43 | 103 | 85 | -0.070 | 10.90 | 0.11 |
| 63 | 9.166 | 0.147 | 2.25 | 92 | -3.25 | 102 | 85 | -0.070 | 11.23 | 0.09 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 64 | 9.315 | 0.149 | 2.25 | 92 | -0.85 | 103 | 85 | -0.070 | 10.95 | 0.14 |
| 65 | 9.462 | 0.147 | 2.23 | 92 | -0.91 | 102 | 85 | -0.070 | 11.15 | 0.13 |
| 66 | 9.611 | 0.149 | 2.26 | 92 | -2.31 | 103 | 86 | -0.080 | 11.15 | 0.12 |
| 67 | 9.758 | 0.147 | 2.24 | 92 | -3.05 | 102 | 86 | -0.060 | 11.23 | 0.12 |
| 68 | 9.907 | 0.149 | 2.25 | 92 | -2.98 | 103 | 86 | -0.080 | 11.21 | 0.11 |
| 69 | 10.052 | 0.145 | 2.24 | 93 | -3.18 | 100 | 85 | -0.070 | 11.15 | 0.13 |
| 70 | 10.202 | 0.150 | 2.24 | 93 | -2.46 | 104 | 85 | -0.070 | 11.31 | 0.10 |
| 71 | 10.348 | 0.146 | 2.24 | 93 | -3.1 | 101 | 85 | -0.070 | 11.32 | 0.07 |
| 72 | 10.498 | 0.150 | 2.24 | 93 | -3.09 | 104 | 85 | -0.060 | 11.09 | 0.11 |
| 73 | 10.644 | 0.146 | 2.24 | 93 | -1.56 | 101 | 85 | -0.050 | 10.94 | 0.11 |
| 74 | 10.794 | 0.150 | 2.25 | 94 | -0.8 | 103 | 86 | -0.070 | 10.74 | 0.09 |
| 75 | 10.939 | 0.145 | 2.24 | 94 | -2.3 | 100 | 86 | -0.070 | 10.79 | 0.14 |
| 76 | 11.090 | 0.151 | 2.23 | 94 | -3.27 | 104 | 86 | -0.070 | 10.76 | 0.12 |
| 77 | 11.236 | 0.146 | 2.24 | 94 | -1.53 | 101 | 86 | -0.070 | 10.81 | 0.10 |
| 78 | 11.387 | 0.151 | 2.24 | 94 | -3.05 | 104 | 85 | -0.070 | 10.95 | 0.11 |
| 79 | 11.532 | 0.145 | 2.24 | 94 | -0.82 | 100 | 85 | -0.070 | 10.80 | 0.13 |
| 80 | 11.683 | 0.151 | 2.24 | 94 | -3.17 | 104 | 85 | -0.080 | 10.90 | 0.13 |
| 81 | 11.828 | 0.145 | 2.24 | 95 | -1.7 | 100 | 85 | -0.070 | 10.96 | 0.12 |
| 82 | 11.979 | 0.151 | 2.23 | 95 | -0.97 | 104 | 86 | -0.070 | 11.00 | 0.10 |
| 83 | 12.125 | 0.146 | 2.22 | 95 | -3.1 | 100 | 86 | -0.070 | 11.21 | 0.12 |
| 84 | 12.275 | 0.150 | 2.24 | 95 | -3.04 | 103 | 86 | -0.070 | 11.41 | 0.15 |
| 85 | 12.421 | 0.146 | 2.23 | 95 | -0.85 | 100 | 86 | -0.070 | 11.68 | 0.14 |
| 86 | 12.570 | 0.149 | 2.23 | 95 | -0.85 | 103 | 85 | -0.070 | 11.89 | 0.18 |
| 87 | 12.716 | 0.146 | 2.24 | 95 | -0.85 | 101 | 85 | -0.080 | 12.31 | 0.20 |
| 88 | 12.866 | 0.150 | 2.22 | 96 | -1.63 | 103 | 85 | -0.080 | 12.44 | 0.23 |
| 89 | 13.012 | 0.146 | 2.23 | 96 | -2.01 | 100 | 85 | -0.080 | 12.44 | 0.22 |
| 90 | 13.162 | 0.150 | 2.24 | 96 | -0.84 | 103 | 86 | -0.080 | 12.00 | 0.17 |
| 91 | 13.308 | 0.146 | 2.22 | 96 | -1.02 | 100 | 86 | -0.070 | 10.87 | 0.16 |
| 92 | 13.457 | 0.149 | 2.22 | 96 | -1.19 | 102 | 86 | -0.060 | 10.24 | 0.12 |
| 93 | 13.603 | 0.146 | 2.22 | 96 | -1.73 | 100 | 86 | -0.070 | 10.16 | 0.11 |
| 94 | 13.752 | 0.149 | 2.22 | 96 | -3.13 | 102 | 85 | -0.070 | 10.08 | 0.15 |
| 95 | 13.900 | 0.148 | 2.22 | 96 | -0.9 | 102 | 85 | -0.070 | 10.13 | 0.15 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 96 | 14.049 | 0.149 | 2.22 | 96 | -2.08 | 102 | 85 | -0.070 | 10.32 | 0.11 |
| 97 | 14.196 | 0.147 | 2.22 | 97 | -3.34 | 101 | 85 | -0.060 | 10.25 | 0.13 |
| 98 | 14.345 | 0.149 | 2.22 | 97 | -3.23 | 102 | 85 | -0.070 | 10.31 | 0.13 |
| 99 | 14.493 | 0.148 | 2.21 | 97 | -2.28 | 101 | 86 | -0.070 | 10.39 | 0.12 |
| 100 | 14.641 | 0.148 | 2.22 | 97 | -0.87 | 101 | 86 | -0.070 | 10.23 | 0.16 |
| 101 | 14.789 | 0.148 | 2.22 | 97 | -3.21 | 101 | 86 | -0.060 | 10.09 | 0.16 |
| 102 | 14.936 | 0.147 | 2.23 | 97 | -2.41 | 101 | 85 | -0.060 | 10.01 | 0.16 |
| 103 | 15.086 | 0.150 | 2.22 | 97 | -1.75 | 103 | 85 | -0.070 | 9.82 | 0.18 |
| 104 | 15.232 | 0.146 | 2.22 | 97 | -1.04 | 100 | 85 | -0.070 | 9.57 | 0.17 |
| 105 | 15.381 | 0.149 | 2.23 | 97 | -2.64 | 102 | 85 | -0.060 | 9.61 | 0.15 |
| 106 | 15.527 | 0.146 | 2.23 | 97 | -1.42 | 100 | 85 | -0.070 | 9.38 | 0.17 |
| 107 | 15.677 | 0.150 | 2.22 | 97 | -3.25 | 103 | 86 | -0.060 | 9.23 | 0.16 |
| 108 | 15.823 | 0.146 | 2.23 | 97 | -1.48 | 100 | 86 | -0.070 | 9.05 | 0.19 |
| 109 | 15.973 | 0.150 | 2.21 | 98 | -3.24 | 102 | 86 | -0.070 | 9.16 | 0.14 |
| 110 | 16.119 | 0.146 | 2.22 | 98 | -2.33 | 100 | 85 | -0.060 | 9.08 | 0.14 |
| 111 | 16.269 | 0.150 | 2.22 | 98 | -3.17 | 102 | 85 | -0.060 | 8.95 | 0.17 |
| 112 | 16.415 | 0.146 | 2.22 | 98 | -1.27 | 100 | 85 | -0.060 | 8.95 | 0.16 |
| 113 | 16.566 | 0.151 | 2.23 | 98 | -3.24 | 103 | 85 | -0.070 | 8.70 | 0.21 |
| 114 | 16.711 | 0.145 | 2.22 | 98 | -2.48 | 99 | 85 | -0.070 | 8.71 | 0.22 |
| 115 | 16.862 | 0.151 | 2.22 | 98 | -1.51 | 103 | 86 | -0.070 | 8.77 | 0.24 |
| 116 | 17.008 | 0.146 | 2.22 | 98 | -1.05 | 100 | 86 | -0.070 | 8.67 | 0.26 |
| 117 | 17.158 | 0.150 | 2.22 | 98 | -3.24 | 102 | 86 | -0.080 | 8.77 | 0.23 |
| 118 | 17.304 | 0.146 | 2.22 | 98 | -2.46 | 100 | 86 | -0.060 | 8.93 | 0.20 |
| 119 | 17.455 | 0.151 | 2.20 | 98 | -3.08 | 103 | 85 | -0.060 | 8.60 | 0.24 |
| 120 | 17.600 | 0.145 | 2.22 | 98 | -3.31 | 99 | 85 | -0.050 | 8.77 | 0.22 |
| 121 | 17.750 | 0.150 | 2.20 | 98 | -1 | 102 | 85 | -0.070 | 8.74 | 0.27 |
| 122 | 17.896 | 0.146 | 2.21 | 98 | -3.21 | 99 | 85 | -0.070 | 8.63 | 0.29 |
| 123 | 18.045 | 0.149 | 2.22 | 98 | -0.89 | 101 | 86 | -0.060 | 8.64 | 0.26 |
| 124 | 18.192 | 0.147 | 2.21 | 99 | -0.81 | 100 | 86 | -0.070 | 8.35 | 0.24 |
| 125 | 18.342 | 0.150 | 2.22 | 99 | -3.28 | 102 | 86 | -0.060 | 8.19 | 0.21 |
| 126 | 18.488 | 0.146 | 2.23 | 99 | -0.8 | 99 | 85 | -0.060 | 8.02 | 0.22 |
| 127 | 18.637 | 0.149 | 2.22 | 99 | -1.53 | 101 | 85 | -0.060 | 7.95 | 0.25 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 128 | 18.784 | 0.147 | 2.23 | 99 | -1.76 | 100 | 84 | -0.060 | 7.95 | 0.26 |
| 129 | 18.933 | 0.149 | 2.21 | 99 | -1.54 | 101 | 85 | -0.060 | 7.95 | 0.24 |
| 130 | 19.081 | 0.148 | 2.20 | 99 | -0.88 | 100 | 85 | -0.070 | 8.05 | 0.25 |
| 131 | 19.229 | 0.148 | 2.21 | 99 | -1.63 | 100 | 86 | -0.060 | 7.97 | 0.26 |
| 132 | 19.378 | 0.149 | 2.22 | 99 | -0.94 | 101 | 86 | -0.060 | 8.17 | 0.21 |
| 133 | 19.526 | 0.148 | 2.23 | 99 | -0.9 | 100 | 86 | -0.060 | 7.84 | 0.29 |
| 134 | 19.674 | 0.148 | 2.21 | 99 | -0.87 | 100 | 86 | -0.060 | 7.69 | 0.31 |
| 135 | 19.822 | 0.148 | 2.21 | 99 | -2.78 | 100 | 85 | -0.050 | 7.52 | 0.32 |
| 136 | 19.971 | 0.149 | 2.22 | 99 | -2 | 101 | 85 | -0.060 | 7.35 | 0.38 |
| 137 | 20.118 | 0.147 | 2.21 | 99 | -2.21 | 100 | 85 | -0.050 | 7.40 | 0.34 |
| 138 | 20.267 | 0.149 | 2.23 | 99 | -0.92 | 101 | 85 | -0.070 | 7.35 | 0.37 |
| 139 | 20.414 | 0.147 | 2.22 | 99 | -1.66 | 100 | 85 | -0.060 | 7.32 | 0.29 |
| 140 | 20.563 | 0.149 | 2.22 | 99 | -1.88 | 101 | 86 | -0.060 | 7.46 | 0.31 |
| 141 | 20.709 | 0.146 | 2.21 | 99 | -0.97 | 99 | 86 | -0.060 | 7.46 | 0.30 |
| 142 | 20.860 | 0.151 | 2.21 | 99 | -3.22 | 102 | 85 | -0.050 | 7.41 | 0.24 |
| 143 | 21.005 | 0.145 | 2.21 | 99 | -3.25 | 98 | 85 | -0.060 | 7.33 | 0.28 |
| 144 | 21.156 | 0.151 | 2.21 | 99 | -0.95 | 102 | 84 | -0.050 | 6.94 | 0.32 |
| 145 | 21.302 | 0.146 | 2.20 | 99 | -1.01 | 99 | 85 | -0.060 | 7.00 | 0.37 |
| 146 | 21.453 | 0.151 | 2.22 | 99 | -2.63 | 102 | 85 | -0.050 | 6.76 | 0.39 |
| 147 | 21.598 | 0.145 | 2.22 | 99 | -0.93 | 98 | 86 | -0.060 | 6.79 | 0.36 |
| 148 | 21.750 | 0.152 | 2.22 | 99 | -2.69 | 103 | 86 | -0.050 | 6.85 | 0.37 |
| 149 | 21.895 | 0.145 | 2.21 | 100 | -1.09 | 98 | 86 | -0.050 | 6.99 | 0.33 |
| 150 | 22.046 | 0.151 | 2.21 | 100 | -2.2 | 102 | 85 | -0.050 | 7.00 | 0.34 |
| 151 | 22.191 | 0.145 | 2.21 | 100 | -2.67 | 98 | 85 | -0.060 | 7.15 | 0.33 |
| 152 | 22.343 | 0.152 | 2.23 | 100 | -2.97 | 103 | 84 | -0.060 | 7.00 | 0.37 |
| 153 | 22.488 | 0.145 | 2.21 | 100 | -3.31 | 98 | 84 | -0.060 | 6.94 | 0.43 |
| 154 | 22.638 | 0.150 | 2.21 | 100 | -3.03 | 101 | 85 | -0.060 | 6.83 | 0.45 |
| 155 | 22.784 | 0.146 | 2.23 | 100 | -1.3 | 99 | 85 | -0.070 | 6.81 | 0.44 |
| 156 | 22.934 | 0.150 | 2.21 | 100 | -1.4 | 101 | 86 | -0.070 | 6.62 | 0.54 |
| 157 | 23.081 | 0.147 | 2.23 | 100 | -3.04 | 99 | 86 | -0.060 | 6.50 | 0.57 |
| 158 | 23.230 | 0.149 | 2.21 | 100 | -3.05 | 101 | 86 | -0.050 | 6.63 | 0.55 |
| 159 | 23.377 | 0.147 | 2.21 | 100 | -1 | 99 | 85 | -0.040 | 6.63 | 0.54 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 160 | 23.526 | 0.149 | 2.21 | 100 | -1.7 | 101 | 85 | -0.060 | 6.53 | 0.56 |
| 161 | 23.674 | 0.148 | 2.20 | 100 | -2.34 | 100 | 84 | -0.050 | 6.58 | 0.55 |
| 162 | 23.823 | 0.149 | 2.22 | 100 | -3.04 | 100 | 85 | -0.050 | 6.73 | 0.51 |
| 163 | 23.971 | 0.148 | 2.22 | 100 | -1.08 | 100 | 85 | -0.060 | 6.64 | 0.49 |
| 164 | 24.120 | 0.149 | 2.21 | 100 | -3.23 | 100 | 86 | -0.060 | 6.83 | 0.48 |
| 165 | 24.268 | 0.148 | 2.22 | 100 | -1.47 | 100 | 86 | -0.050 | 6.58 | 0.49 |
| 166 | 24.416 | 0.148 | 2.21 | 100 | -0.84 | 100 | 86 | -0.060 | 6.54 | 0.48 |
| 167 | 24.566 | 0.150 | 2.22 | 100 | -1.24 | 101 | 85 | -0.050 | 6.61 | 0.50 |
| 168 | 24.712 | 0.146 | 2.22 | 100 | -2.12 | 98 | 85 | -0.050 | 6.67 | 0.45 |
| 169 | 24.862 | 0.150 | 2.21 | 100 | -1.43 | 101 | 85 | -0.050 | 6.62 | 0.44 |
| 170 | 25.008 | 0.146 | 2.23 | 100 | -2.39 | 98 | 85 | -0.070 | 6.45 | 0.48 |
| 171 | 25.158 | 0.150 | 2.20 | 100 | -1.62 | 101 | 85 | -0.050 | 6.57 | 0.44 |
| 172 | 25.305 | 0.147 | 2.21 | 100 | -2.65 | 99 | 86 | -0.040 | 6.46 | 0.47 |
| 173 | 25.455 | 0.150 | 2.21 | 100 | -3.18 | 101 | 86 | -0.050 | 6.62 | 0.44 |
| 174 | 25.600 | 0.145 | 2.21 | 100 | -3.32 | 98 | 86 | -0.060 | 6.65 | 0.43 |
| 175 | 25.751 | 0.151 | 2.21 | 100 | -1.14 | 102 | 85 | -0.050 | 6.36 | 0.49 |
| 176 | 25.897 | 0.146 | 2.20 | 100 | -3.31 | 98 | 85 | -0.050 | 6.09 | 0.54 |
| 177 | 26.048 | 0.151 | 2.20 | 100 | -2.19 | 102 | 84 | -0.050 | 5.80 | 0.66 |
| 178 | 26.194 | 0.146 | 2.21 | 100 | -2.59 | 98 | 85 | -0.050 | 5.65 | 0.91 |
| 179 | 26.345 | 0.151 | 2.21 | 100 | -0.84 | 102 | 85 | -0.050 | 5.51 | 1.02 |
| 180 | 26.490 | 0.145 | 2.21 | 100 | -1.11 | 98 | 86 | -0.050 | 5.53 | 1.05 |
| 181 | 26.641 | 0.151 | 2.20 | 100 | -0.91 | 102 | 86 | -0.040 | 5.66 | 1.02 |
| 182 | 26.787 | 0.146 | 2.19 | 100 | -3 | 98 | 86 | -0.040 | 5.79 | 1.00 |
| 183 | 26.938 | 0.151 | 2.20 | 100 | -0.93 | 102 | 85 | -0.040 | 5.73 | 0.99 |
| 184 | 27.083 | 0.145 | 2.21 | 100 | -2.84 | 98 | 85 | -0.050 | 5.54 | 1.02 |
| 185 | 27.233 | 0.150 | 2.21 | 100 | -2.29 | 101 | 84 | -0.050 | 5.72 | 1.00 |
| 186 | 27.378 | 0.145 | 2.21 | 100 | -3.23 | 98 | 85 | -0.050 | 5.68 | 0.99 |
| 187 | 27.529 | 0.151 | 2.21 | 100 | -3.24 | 102 | 85 | -0.050 | 5.70 | 1.02 |
| 188 | 27.675 | 0.146 | 2.20 | 100 | -0.92 | 98 | 86 | -0.040 | 5.66 | 0.99 |
| 189 | 27.824 | 0.149 | 2.20 | 100 | -2.21 | 100 | 86 | -0.050 | 5.74 | 0.97 |
| 190 | 27.970 | 0.146 | 2.20 | 100 | -1.59 | 98 | 86 | -0.030 | 5.72 | 1.00 |
| 191 | 28.120 | 0.150 | 2.20 | 100 | -0.89 | 101 | 85 | -0.040 | 5.54 | 1.02 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 192 | 28.267 | 0.147 | 2.20 | 100 | -0.91 | 99 | 85 | -0.040 | 5.64 | 1.06 |
| 193 | 28.417 | 0.150 | 2.20 | 100 | -3.27 | 101 | 84 | -0.040 | 5.70 | 1.04 |
| 194 | 28.564 | 0.147 | 2.19 | 100 | -2.46 | 99 | 85 | -0.040 | 5.48 | 1.06 |
| 195 | 28.713 | 0.149 | 2.20 | 100 | -1.56 | 100 | 85 | -0.050 | 5.52 | 1.04 |
| 196 | 28.861 | 0.148 | 2.20 | 100 | -2.13 | 99 | 86 | -0.040 | 5.47 | 1.14 |
| 197 | 29.009 | 0.148 | 2.19 | 100 | -2.36 | 99 | 86 | -0.050 | 5.35 | 1.16 |
| 198 | 29.157 | 0.148 | 2.21 | 100 | -3.26 | 99 | 86 | -0.050 | 5.35 | 1.14 |
| 199 | 29.305 | 0.148 | 2.21 | 100 | -2.28 | 99 | 85 | -0.040 | 5.39 | 1.10 |
| 200 | 29.454 | 0.149 | 2.21 | 100 | -0.93 | 100 | 85 | -0.050 | 5.45 | 1.09 |
| 201 | 29.601 | 0.147 | 2.20 | 100 | -1.14 | 99 | 84 | -0.040 | 5.58 | 1.07 |
| 202 | 29.749 | 0.148 | 2.21 | 100 | -1.6 | 99 | 85 | -0.050 | 5.52 | 1.07 |
| 203 | 29.896 | 0.147 | 2.22 | 100 | -2.6 | 99 | 85 | -0.040 | 5.59 | 1.06 |
| 204 | 30.046 | 0.150 | 2.20 | 100 | -0.86 | 101 | 86 | -0.050 | 5.54 | 1.05 |
| 205 | 30.192 | 0.146 | 2.20 | 100 | -3.08 | 98 | 86 | -0.040 | 5.54 | 1.06 |
| 206 | 30.342 | 0.150 | 2.20 | 100 | -1.2 | 101 | 86 | -0.040 | 5.50 | 1.10 |
| 207 | 30.487 | 0.145 | 2.20 | 100 | -3.28 | 97 | 85 | -0.040 | 5.48 | 1.08 |
| 208 | 30.638 | 0.151 | 2.20 | 100 | -1.81 | 101 | 85 | -0.040 | 5.42 | 1.12 |
| 209 | 30.783 | 0.145 | 2.18 | 100 | -2.11 | 97 | 84 | -0.030 | 5.42 | 1.11 |
| 210 | 30.935 | 0.152 | 2.21 | 100 | -1.64 | 102 | 85 | -0.050 | 5.46 | 1.02 |
| 211 | 31.080 | 0.145 | 2.20 | 100 | -3.17 | 97 | 85 | -0.040 | 5.33 | 0.99 |
| 212 | 31.231 | 0.151 | 2.20 | 100 | -1.25 | 101 | 86 | -0.050 | 5.43 | 0.97 |
| 213 | 31.376 | 0.145 | 2.20 | 100 | -0.97 | 97 | 86 | -0.040 | 5.36 | 0.95 |
| 214 | 31.526 | 0.150 | 2.19 | 100 | -0.98 | 101 | 86 | -0.040 | 5.38 | 0.92 |
| 215 | 31.672 | 0.146 | 2.20 | 100 | -2.89 | 98 | 85 | -0.040 | 5.40 | 0.94 |
| 216 | 31.823 | 0.151 | 2.18 | 100 | -3.33 | 101 | 85 | -0.040 | 5.27 | 0.93 |
| 217 | 31.969 | 0.146 | 2.21 | 100 | -0.95 | 98 | 84 | -0.050 | 5.28 | 0.91 |
| 218 | 32.119 | 0.150 | 2.21 | 100 | -3.35 | 101 | 85 | -0.040 | 5.28 | 0.88 |
| 219 | 32.264 | 0.145 | 2.21 | 100 | -0.98 | 97 | 85 | -0.040 | 5.40 | 0.88 |
| 220 | 32.414 | 0.150 | 2.21 | 100 | -1.68 | 101 | 85 | -0.050 | 5.25 | 0.89 |
| 221 | 32.560 | 0.146 | 2.19 | 100 | -0.82 | 98 | 86 | -0.040 | 5.31 | 0.86 |
| 222 | 32.710 | 0.150 | 2.20 | 100 | -2.75 | 101 | 86 | -0.040 | 5.55 | 0.82 |
| 223 | 32.856 | 0.146 | 2.20 | 100 | -3.37 | 98 | 85 | -0.040 | 5.52 | 0.78 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 224 | 33.005 | 0.149 | 2.20 | 100 | -1.38 | 100 | 85 | -0.040 | 5.38 | 0.83 |
| 225 | 33.152 | 0.147 | 2.21 | 100 | -2.09 | 99 | 84 | -0.040 | 5.48 | 0.81 |
| 226 | 33.301 | 0.149 | 2.19 | 100 | -2.91 | 100 | 85 | -0.040 | 5.36 | 0.80 |
| 227 | 33.449 | 0.148 | 2.21 | 100 | -2.71 | 99 | 85 | -0.050 | 5.57 | 0.79 |
| 228 | 33.598 | 0.149 | 2.20 | 100 | -0.88 | 100 | 86 | -0.040 | 5.31 | 0.81 |
| 229 | 33.746 | 0.148 | 2.20 | 100 | -0.9 | 99 | 86 | -0.040 | 5.30 | 0.78 |
| 230 | 33.894 | 0.148 | 2.20 | 100 | -3.29 | 99 | 86 | -0.040 | 5.46 | 0.76 |
| 231 | 34.042 | 0.148 | 2.19 | 100 | -1.39 | 99 | 85 | -0.050 | 5.51 | 0.76 |
| 232 | 34.190 | 0.148 | 2.21 | 100 | -0.87 | 99 | 85 | -0.050 | 5.44 | 0.74 |
| 233 | 34.339 | 0.149 | 2.20 | 100 | -3.28 | 100 | 84 | -0.050 | 5.47 | 0.76 |
| 234 | 34.486 | 0.147 | 2.21 | 100 | -3.27 | 99 | 85 | -0.050 | 5.37 | 0.76 |
| 235 | 34.635 | 0.149 | 2.20 | 100 | -0.96 | 100 | 85 | -0.050 | 5.63 | 0.74 |
| 236 | 34.781 | 0.146 | 2.21 | 100 | -1.38 | 98 | 85 | -0.040 | 5.49 | 0.79 |
| 237 | 34.930 | 0.149 | 2.20 | 100 | -2.24 | 100 | 86 | -0.040 | 5.38 | 0.76 |
| 238 | 35.076 | 0.146 | 2.20 | 100 | -2.71 | 98 | 86 | -0.040 | 5.27 | 0.79 |
| 239 | 35.226 | 0.150 | 2.20 | 100 | -1.86 | 101 | 85 | -0.040 | 5.26 | 0.79 |
| 240 | 35.373 | 0.147 | 2.20 | 100 | -1.57 | 99 | 85 | -0.040 | 5.21 | 0.79 |
| 241 | 35.522 | 0.149 | 2.21 | 100 | -2.66 | 100 | 84 | -0.040 | 5.27 | 0.75 |
| 242 | 35.668 | 0.146 | 2.21 | 100 | -2.74 | 98 | 84 | -0.050 | 5.31 | 0.70 |
| 243 | 35.818 | 0.150 | 2.19 | 100 | -1.7 | 101 | 85 | -0.030 | 5.20 | 0.73 |
| 244 | 35.964 | 0.146 | 2.19 | 100 | -0.87 | 98 | 85 | -0.040 | 5.29 | 0.72 |
| 245 | 36.115 | 0.151 | 2.20 | 100 | -3.11 | 101 | 86 | -0.040 | 5.18 | 0.73 |
| 246 | 36.260 | 0.145 | 2.20 | 100 | -2.33 | 97 | 86 | -0.040 | 5.42 | 0.71 |
| 247 | 36.411 | 0.151 | 2.19 | 100 | -1.26 | 101 | 85 | -0.050 | 5.28 | 0.70 |
| 248 | 36.556 | 0.145 | 2.20 | 100 | -0.8 | 97 | 85 | -0.040 | 5.24 | 0.71 |
| 249 | 36.707 | 0.151 | 2.21 | 100 | -0.89 | 101 | 84 | -0.040 | 5.19 | 0.74 |
| 250 | 36.852 | 0.145 | 2.21 | 100 | -2.33 | 97 | 84 | -0.040 | 5.26 | 0.73 |
| 251 | 37.003 | 0.151 | 2.19 | 100 | -0.93 | 101 | 84 | -0.040 | 5.14 | 0.76 |
| 252 | 37.149 | 0.146 | 2.22 | 100 | -3.43 | 98 | 85 | -0.030 | 5.28 | 0.72 |
| 253 | 37.299 | 0.150 | 2.20 | 100 | -3.28 | 100 | 85 | -0.050 | 5.23 | 0.71 |
| 254 | 37.444 | 0.145 | 2.21 | 100 | -1.88 | 97 | 85 | -0.050 | 5.17 | 0.74 |
| 255 | 37.594 | 0.150 | 2.21 | 100 | -3.34 | 100 | 85 | -0.030 | 5.29 | 0.73 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 256 | 37.739 | 0.145 | 2.21 | 100 | -3.21 | 97 | 85 | -0.030 | 5.02 | 0.81 |
| 257 | 37.889 | 0.150 | 2.19 | 100 | -3.28 | 100 | 84 | -0.040 | 5.02 | 0.77 |
| 258 | 38.036 | 0.147 | 2.21 | 100 | -0.91 | 98 | 84 | -0.040 | 5.08 | 0.74 |
| 259 | 38.185 | 0.149 | 2.22 | 100 | -3.37 | 100 | 85 | -0.050 | 5.04 | 0.74 |
| 260 | 38.331 | 0.146 | 2.21 | 100 | -2.72 | 98 | 85 | -0.040 | 4.99 | 0.74 |
| 261 | 38.480 | 0.149 | 2.20 | 100 | -3.31 | 100 | 85 | -0.050 | 5.14 | 0.71 |
| 262 | 38.627 | 0.147 | 2.19 | 100 | -1.72 | 98 | 85 | -0.020 | 5.07 | 0.69 |
| 263 | 38.776 | 0.149 | 2.20 | 100 | -1.83 | 100 | 85 | -0.040 | 5.12 | 0.69 |
| 264 | 38.924 | 0.148 | 2.20 | 100 | -0.97 | 99 | 85 | -0.050 | 5.08 | 0.67 |
| 265 | 39.072 | 0.148 | 2.20 | 100 | -1.3 | 99 | 84 | -0.040 | 5.14 | 0.68 |
| 266 | 39.221 | 0.149 | 2.20 | 100 | -2.06 | 100 | 84 | -0.040 | 5.04 | 0.72 |
| 267 | 39.368 | 0.147 | 2.20 | 100 | -1.04 | 98 | 85 | -0.040 | 4.92 | 0.71 |
| 268 | 39.517 | 0.149 | 2.21 | 100 | -1.63 | 100 | 85 | -0.040 | 4.92 | 0.70 |
| 269 | 39.664 | 0.147 | 2.19 | 100 | -0.91 | 98 | 85 | -0.040 | 5.04 | 0.66 |
| 270 | 39.813 | 0.149 | 2.19 | 100 | -1.19 | 100 | 86 | -0.040 | 5.05 | 0.68 |
| 271 | 39.960 | 0.147 | 2.20 | 100 | -2.78 | 98 | 85 | -0.050 | 5.04 | 0.69 |
| 272 | 40.109 | 0.149 | 2.20 | 100 | -1.17 | 100 | 85 | -0.040 | 5.09 | 0.66 |
| 273 | 40.255 | 0.146 | 2.20 | 100 | -1.98 | 98 | 84 | -0.040 | 5.20 | 0.69 |
| 274 | 40.405 | 0.150 | 2.20 | 100 | -3.35 | 100 | 84 | -0.040 | 5.17 | 0.70 |
| 275 | 40.551 | 0.146 | 2.19 | 100 | -2.81 | 98 | 84 | -0.040 | 5.09 | 0.69 |
| 276 | 40.701 | 0.150 | 2.23 | 100 | -3.35 | 100 | 85 | -0.050 | 5.23 | 0.69 |
| 277 | 40.847 | 0.146 | 2.19 | 100 | -2.49 | 98 | 85 | -0.030 | 5.22 | 0.69 |
| 278 | 40.996 | 0.149 | 2.20 | 100 | -0.97 | 100 | 85 | -0.040 | 4.85 | 0.82 |
| 279 | 41.142 | 0.146 | 2.20 | 100 | -1.37 | 98 | 85 | -0.040 | 4.72 | 0.79 |
| 280 | 41.292 | 0.150 | 2.20 | 100 | -2.9 | 100 | 85 | -0.040 | 4.79 | 0.76 |
| 281 | 41.438 | 0.146 | 2.20 | 100 | -1.77 | 98 | 84 | -0.050 | 4.77 | 0.74 |
| 282 | 41.589 | 0.151 | 2.21 | 100 | -3.24 | 101 | 84 | -0.040 | 4.83 | 0.71 |
| 283 | 41.734 | 0.145 | 2.21 | 100 | -2.68 | 97 | 85 | -0.040 | 4.83 | 0.69 |
| 284 | 41.885 | 0.151 | 2.18 | 100 | -1.77 | 101 | 85 | -0.040 | 4.86 | 0.68 |
| 285 | 42.030 | 0.145 | 2.19 | 100 | -3.37 | 97 | 85 | -0.040 | 4.69 | 0.71 |
| 286 | 42.180 | 0.150 | 2.19 | 100 | -3.2 | 100 | 85 | -0.040 | 4.77 | 0.66 |
| 287 | 42.326 | 0.146 | 2.21 | 100 | -1.56 | 98 | 85 | -0.060 | 4.68 | 0.70 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 288 | 42.476 | 0.150 | 2.19 | 100 | -3.23 | 100 | 85 | -0.050 | 4.87 | 0.67 |
| 289 | 42.622 | 0.146 | 2.22 | 100 | -1.53 | 98 | 84 | -0.050 | 4.73 | 0.68 |
| 290 | 42.772 | 0.150 | 2.21 | 100 | -1.42 | 100 | 84 | -0.050 | 4.69 | 0.69 |
| 291 | 42.917 | 0.145 | 2.20 | 100 | -1.01 | 97 | 84 | -0.020 | 4.73 | 0.65 |
| 292 | 43.067 | 0.150 | 2.20 | 100 | -2.06 | 100 | 85 | -0.050 | 4.73 | 0.67 |
| 293 | 43.213 | 0.146 | 2.20 | 100 | -1.82 | 98 | 85 | -0.040 | 4.63 | 0.68 |
| 294 | 43.363 | 0.150 | 2.19 | 100 | -1.28 | 100 | 86 | -0.050 | 4.66 | 0.66 |
| 295 | 43.509 | 0.146 | 2.21 | 100 | -2.21 | 98 | 85 | -0.040 | 4.51 | 0.65 |
| 296 | 43.658 | 0.149 | 2.21 | 100 | -0.94 | 100 | 85 | -0.040 | 4.63 | 0.64 |
| 297 | 43.805 | 0.147 | 2.22 | 100 | -2.15 | 98 | 85 | -0.040 | 4.48 | 0.66 |
| 298 | 43.954 | 0.149 | 2.21 | 100 | -3.36 | 100 | 84 | -0.050 | 4.69 | 0.61 |
| 299 | 44.100 | 0.146 | 2.20 | 100 | -1.08 | 98 | 84 | -0.040 | 4.54 | 0.59 |
| 300 | 44.250 | 0.150 | 2.19 | 100 | -0.97 | 100 | 85 | -0.040 | 4.49 | 0.61 |
| 301 | 44.398 | 0.148 | 2.21 | 100 | -0.87 | 99 | 85 | -0.030 | 4.39 | 0.64 |
| 302 | 44.546 | 0.148 | 2.21 | 100 | -3.27 | 99 | 86 | -0.040 | 4.41 | 0.63 |
| 303 | 44.694 | 0.148 | 2.20 | 100 | -3.18 | 99 | 85 | -0.030 | 4.57 | 0.59 |
| 304 | 44.842 | 0.148 | 2.21 | 100 | -0.84 | 99 | 85 | -0.030 | 4.51 | 0.62 |
| 305 | 44.990 | 0.148 | 2.20 | 100 | -0.84 | 99 | 84 | -0.040 | 4.41 | 0.63 |
| 306 | 45.138 | 0.148 | 2.20 | 100 | -1.92 | 99 | 84 | -0.060 | 4.50 | 0.59 |
| 307 | 45.286 | 0.148 | 2.18 | 100 | -3.25 | 99 | 85 | -0.050 | 4.39 | 0.61 |
| 308 | 45.434 | 0.148 | 2.21 | 100 | -1 | 99 | 85 | -0.040 | 4.47 | 0.60 |
| 309 | 45.583 | 0.149 | 2.20 | 100 | -1.56 | 100 | 85 | -0.030 | 4.48 | 0.63 |
| 310 | 45.729 | 0.146 | 2.21 | 100 | -1.46 | 98 | 86 | -0.040 | 4.57 | 0.60 |
| 311 | 45.878 | 0.149 | 2.21 | 100 | -2.61 | 100 | 85 | -0.040 | 4.40 | 0.63 |
| 312 | 46.024 | 0.146 | 2.20 | 100 | -2.99 | 98 | 85 | -0.040 | 4.62 | 0.61 |
| 313 | 46.174 | 0.150 | 2.21 | 100 | -1.56 | 100 | 84 | -0.030 | 4.43 | 0.63 |
| 314 | 46.320 | 0.146 | 2.21 | 100 | -1.38 | 98 | 84 | -0.040 | 4.36 | 0.62 |
| 315 | 46.470 | 0.150 | 2.20 | 100 | -0.94 | 100 | 85 | -0.040 | 4.50 | 0.59 |
| 316 | 46.616 | 0.146 | 2.20 | 100 | -2.46 | 98 | 85 | -0.040 | 4.42 | 0.60 |
| 317 | 46.766 | 0.150 | 2.19 | 100 | -3.51 | 100 | 86 | -0.040 | 4.44 | 0.56 |
| 318 | 46.911 | 0.145 | 2.20 | 100 | -1.03 | 97 | 86 | -0.040 | 4.51 | 0.60 |
| 319 | 47.063 | 0.152 | 2.21 | 100 | -0.87 | 102 | 85 | -0.040 | 4.45 | 0.59 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 320 | 47.208 | 0.145 | 2.19 | 99 | -3.3 | 97 | 85 | -0.040 | 4.36 | 0.61 |
| 321 | 47.359 | 0.151 | 2.20 | 99 | -0.96 | 101 | 85 | -0.020 | 4.46 | 0.60 |
| 322 | 47.504 | 0.145 | 2.21 | 99 | -1.09 | 97 | 84 | -0.050 | 4.38 | 0.63 |
| 323 | 47.654 | 0.150 | 2.20 | 99 | -3.29 | 100 | 84 | -0.030 | 4.44 | 0.60 |
| 324 | 47.800 | 0.146 | 2.20 | 99 | -1.5 | 98 | 85 | -0.040 | 4.56 | 0.59 |
| 325 | 47.951 | 0.151 | 2.19 | 99 | -2.53 | 101 | 85 | -0.020 | 4.57 | 0.56 |
| 326 | 48.096 | 0.145 | 2.22 | 99 | -0.85 | 97 | 86 | -0.030 | 4.43 | 0.63 |
| 327 | 48.247 | 0.151 | 2.21 | 99 | -0.84 | 101 | 86 | -0.040 | 4.51 | 0.58 |
| 328 | 48.392 | 0.145 | 2.21 | 99 | -1.97 | 97 | 85 | -0.040 | 4.59 | 0.57 |
| 329 | 48.541 | 0.149 | 2.21 | 99 | -3.33 | 100 | 85 | -0.040 | 4.42 | 0.60 |
| 330 | 48.687 | 0.146 | 2.21 | 99 | -1.36 | 98 | 85 | -0.030 | 4.60 | 0.56 |
| 331 | 48.837 | 0.150 | 2.20 | 99 | -1.06 | 100 | 84 | -0.040 | 4.53 | 0.56 |
| 332 | 48.983 | 0.146 | 2.21 | 99 | -1.39 | 98 | 84 | -0.030 | 4.54 | 0.60 |
| 333 | 49.133 | 0.150 | 2.21 | 99 | -1.46 | 100 | 85 | -0.050 | 4.65 | 0.58 |
| 334 | 49.279 | 0.146 | 2.22 | 99 | -3.42 | 98 | 85 | -0.030 | 4.55 | 0.61 |
| 335 | 49.428 | 0.149 | 2.20 | 99 | -0.95 | 100 | 85 | -0.040 | 4.56 | 0.57 |
| 336 | 49.575 | 0.147 | 2.19 | 99 | -2.75 | 98 | 86 | -0.040 | 4.61 | 0.58 |
| 337 | 49.724 | 0.149 | 2.20 | 99 | -2.87 | 100 | 85 | -0.040 | 4.69 | 0.58 |
| 338 | 49.872 | 0.148 | 2.21 | 99 | -2.43 | 99 | 85 | -0.050 | 4.46 | 0.62 |
| 339 | 50.020 | 0.148 | 2.20 | 99 | -3.27 | 99 | 84 | -0.030 | 4.43 | 0.64 |
| 340 | 50.168 | 0.148 | 2.21 | 99 | -0.93 | 99 | 84 | -0.040 | 4.49 | 0.64 |
| 341 | 50.316 | 0.148 | 2.21 | 99 | -0.84 | 99 | 85 | -0.030 | 4.34 | 0.68 |
| 342 | 50.464 | 0.148 | 2.20 | 99 | -1.89 | 99 | 85 | -0.040 | 4.29 | 0.67 |
| 343 | 50.611 | 0.147 | 2.20 | 99 | -0.9 | 98 | 85 | -0.040 | 4.21 | 0.67 |
| 344 | 50.760 | 0.149 | 2.20 | 99 | -0.81 | 100 | 86 | -0.040 | 4.33 | 0.63 |
| 345 | 50.907 | 0.147 | 2.21 | 99 | -2.42 | 98 | 86 | -0.040 | 4.33 | 0.62 |
| 346 | 51.056 | 0.149 | 2.21 | 99 | -0.85 | 100 | 85 | -0.050 | 4.09 | 0.64 |
| 347 | 51.203 | 0.147 | 2.22 | 99 | -3.32 | 98 | 85 | -0.040 | 4.18 | 0.65 |
| 348 | 51.351 | 0.148 | 2.21 | 99 | -2.39 | 99 | 84 | -0.050 | 4.21 | 0.62 |
| 349 | 51.497 | 0.146 | 2.21 | 99 | -1.57 | 98 | 84 | -0.040 | 4.23 | 0.62 |
| 350 | 51.647 | 0.150 | 2.21 | 99 | -3.24 | 100 | 84 | -0.040 | 4.35 | 0.61 |
| 351 | 51.793 | 0.146 | 2.21 | 99 | -2.6 | 98 | 85 | -0.040 | 4.32 | 0.61 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 352 | 51.943 | 0.150 | 2.21 | 99 | -2.99 | 100 | 85 | -0.040 | 4.38 | 0.60 |
| 353 | 52.088 | 0.145 | 2.21 | 99 | -2.89 | 97 | 86 | -0.040 | 4.32 | 0.58 |
| 354 | 52.238 | 0.150 | 2.21 | 99 | -2.83 | 100 | 85 | -0.040 | 4.24 | 0.61 |
| 355 | 52.384 | 0.146 | 2.21 | 99 | -0.9 | 98 | 85 | -0.020 | 4.30 | 0.60 |
| 356 | 52.534 | 0.150 | 2.18 | 99 | -0.89 | 100 | 85 | -0.040 | 4.18 | 0.61 |
| 357 | 52.680 | 0.146 | 2.21 | 99 | -1.58 | 98 | 84 | -0.030 | 4.40 | 0.60 |
| 358 | 52.831 | 0.151 | 2.21 | 99 | -3.03 | 101 | 84 | -0.030 | 4.37 | 0.61 |
| 359 | 52.976 | 0.145 | 2.20 | 99 | -2.26 | 97 | 84 | -0.050 | 4.21 | 0.64 |
| 360 | 53.127 | 0.151 | 2.21 | 99 | -3.31 | 101 | 85 | -0.030 | 4.24 | 0.61 |
| 361 | 53.272 | 0.145 | 2.20 | 99 | -1.38 | 97 | 85 | -0.030 | 4.31 | 0.66 |
| 362 | 53.422 | 0.150 | 2.21 | 99 | -1.04 | 100 | 85 | -0.040 | 4.38 | 0.63 |
| 363 | 53.567 | 0.145 | 2.21 | 99 | -1.03 | 97 | 85 | -0.040 | 4.38 | 0.63 |
| 364 | 53.718 | 0.151 | 2.20 | 99 | -1.62 | 101 | 85 | -0.030 | 4.30 | 0.63 |
| 365 | 53.864 | 0.146 | 2.21 | 99 | -3.41 | 98 | 84 | -0.030 | 4.39 | 0.65 |
| 366 | 54.014 | 0.150 | 2.20 | 99 | -1.1 | 100 | 84 | -0.040 | 4.31 | 0.65 |
| 367 | 54.159 | 0.145 | 2.22 | 99 | -0.96 | 97 | 85 | -0.050 | 4.24 | 0.69 |
| 368 | 54.308 | 0.149 | 2.21 | 99 | -0.98 | 100 | 85 | -0.040 | 4.44 | 0.65 |
| 369 | 54.454 | 0.146 | 2.22 | 99 | -3.14 | 98 | 85 | -0.030 | 4.37 | 0.66 |
| 370 | 54.604 | 0.150 | 2.20 | 99 | -1.74 | 100 | 86 | -0.040 | 4.38 | 0.65 |
| 371 | 54.750 | 0.146 | 2.21 | 99 | -1.81 | 98 | 85 | -0.030 | 4.35 | 0.68 |
| 372 | 54.900 | 0.150 | 2.19 | 99 | -1.09 | 100 | 85 | -0.050 | 4.28 | 0.68 |
| 373 | 55.046 | 0.146 | 2.20 | 99 | -3.4 | 98 | 84 | -0.040 | 4.29 | 0.68 |
| 374 | 55.195 | 0.149 | 2.20 | 99 | -1.71 | 100 | 84 | -0.040 | 4.34 | 0.68 |
| 375 | 55.341 | 0.146 | 2.20 | 99 | -1.04 | 98 | 84 | -0.040 | 4.46 | 0.68 |
| 376 | 55.490 | 0.149 | 2.21 | 99 | -1.9 | 100 | 85 | -0.040 | 4.31 | 0.68 |
| 377 | 55.638 | 0.148 | 2.22 | 99 | -2.21 | 99 | 85 | -0.030 | 4.28 | 0.66 |
| 378 | 55.786 | 0.148 | 2.20 | 99 | -3.08 | 99 | 85 | -0.040 | 4.30 | 0.67 |
| 379 | 55.934 | 0.148 | 2.20 | 99 | -1.82 | 99 | 85 | -0.040 | 4.11 | 0.68 |
| 380 | 56.082 | 0.148 | 2.21 | 99 | -2.89 | 99 | 85 | -0.050 | 4.26 | 0.65 |
| 381 | 56.230 | 0.148 | 2.19 | 99 | -1.32 | 99 | 84 | -0.030 | 4.36 | 0.66 |
| 382 | 56.377 | 0.147 | 2.20 | 99 | -3.22 | 98 | 84 | -0.040 | 4.31 | 0.64 |
| 383 | 56.526 | 0.149 | 2.20 | 99 | -3.33 | 100 | 84 | -0.040 | 4.28 | 0.64 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 384 | 56.673 | 0.147 | 2.18 | 99 | -0.91 | 98 | 85 | -0.030 | 4.12 | 0.71 |
| 385 | 56.822 | 0.149 | 2.21 | 99 | -2.58 | 100 | 85 | -0.030 | 4.33 | 0.68 |
| 386 | 56.969 | 0.147 | 2.21 | 99 | -2.34 | 98 | 85 | -0.040 | 4.33 | 0.66 |
| 387 | 57.118 | 0.149 | 2.22 | 99 | -2.4 | 100 | 85 | -0.040 | 4.14 | 0.70 |
| 388 | 57.264 | 0.146 | 2.22 | 99 | -1.28 | 98 | 85 | -0.040 | 4.37 | 0.67 |
| 389 | 57.413 | 0.149 | 2.21 | 99 | -2.8 | 100 | 84 | -0.040 | 4.38 | 0.65 |
| 390 | 57.559 | 0.146 | 2.19 | 99 | -0.91 | 98 | 84 | -0.040 | 4.16 | 0.71 |
| 391 | 57.709 | 0.150 | 2.21 | 99 | -1.5 | 100 | 84 | -0.040 | 4.18 | 0.69 |
| 392 | 57.854 | 0.145 | 2.22 | 99 | -3.02 | 97 | 84 | -0.040 | 4.15 | 0.69 |
| 393 | 58.004 | 0.150 | 2.20 | 99 | -2.19 | 100 | 85 | -0.040 | 4.20 | 0.67 |
| 394 | 58.150 | 0.146 | 2.20 | 99 | -3.05 | 98 | 85 | -0.040 | 4.22 | 0.64 |
| 395 | 58.300 | 0.150 | 2.20 | 99 | -1.6 | 100 | 85 | -0.040 | 4.26 | 0.64 |
| 396 | 58.445 | 0.145 | 2.20 | 99 | -0.94 | 97 | 85 | -0.030 | 4.32 | 0.63 |
| 397 | 58.596 | 0.151 | 2.19 | 99 | -2.86 | 101 | 85 | -0.040 | 4.25 | 0.65 |
| 398 | 58.742 | 0.146 | 2.21 | 99 | -0.89 | 98 | 84 | -0.040 | 4.23 | 0.64 |
| 399 | 58.892 | 0.150 | 2.20 | 99 | -3.28 | 100 | 84 | -0.030 | 4.25 | 0.64 |
| 400 | 59.037 | 0.145 | 2.21 | 99 | -0.89 | 97 | 84 | -0.040 | 4.33 | 0.65 |
| 401 | 59.188 | 0.151 | 2.21 | 99 | -3.12 | 101 | 85 | -0.040 | 4.32 | 0.66 |
| 402 | 59.333 | 0.145 | 2.20 | 99 | -3.31 | 97 | 85 | -0.030 | 4.30 | 0.68 |
| 403 | 59.483 | 0.150 | 2.20 | 99 | -2.94 | 100 | 85 | -0.050 | 4.34 | 0.63 |
| 404 | 59.628 | 0.145 | 2.20 | 99 | -2.93 | 97 | 85 | -0.040 | 4.28 | 0.63 |
| 405 | 59.779 | 0.151 | 2.19 | 99 | -1.67 | 101 | 85 | -0.050 | 4.26 | 0.65 |
| 406 | 59.924 | 0.145 | 2.21 | 99 | -3.28 | 97 | 84 | -0.050 | 4.22 | 0.67 |
| 407 | 60.074 | 0.150 | 2.20 | 99 | -3.27 | 100 | 84 | -0.050 | 4.41 | 0.66 |
| 408 | 60.219 | 0.145 | 2.21 | 99 | -2.81 | 97 | 84 | -0.030 | 4.38 | 0.63 |
| 409 | 60.369 | 0.150 | 2.22 | 99 | -1.04 | 100 | 85 | -0.040 | 4.43 | 0.65 |
| 410 | 60.514 | 0.145 | 2.22 | 98 | -1.82 | 97 | 85 | -0.040 | 4.34 | 0.62 |
| 411 | 60.664 | 0.150 | 2.19 | 98 | -1.67 | 100 | 85 | -0.040 | 4.39 | 0.63 |
| 412 | 60.810 | 0.146 | 2.21 | 98 | -2.8 | 98 | 85 | -0.030 | 4.37 | 0.63 |
| 413 | 60.960 | 0.150 | 2.20 | 98 | -0.89 | 100 | 85 | -0.040 | 4.41 | 0.65 |
| 414 | 61.106 | 0.146 | 2.19 | 98 | -3.2 | 98 | 84 | -0.040 | 4.49 | 0.62 |
| 415 | 61.254 | 0.148 | 2.21 | 98 | -2.8 | 99 | 84 | -0.040 | 4.45 | 0.65 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 416 | 61.401 | 0.147 | 2.21 | 98 | -0.93 | 98 | 84 | -0.050 | 4.36 | 0.65 |
| 417 | 61.550 | 0.149 | 2.19 | 98 | -2.48 | 100 | 85 | -0.040 | 4.48 | 0.62 |
| 418 | 61.697 | 0.147 | 2.21 | 98 | -1.16 | 98 | 85 | -0.040 | 4.49 | 0.61 |
| 419 | 61.846 | 0.149 | 2.21 | 98 | -0.9 | 100 | 85 | -0.030 | 4.57 | 0.60 |
| 420 | 61.993 | 0.147 | 2.20 | 98 | -0.86 | 98 | 85 | -0.040 | 4.43 | 0.62 |
| 421 | 62.141 | 0.148 | 2.20 | 98 | -0.91 | 99 | 85 | -0.040 | 4.57 | 0.59 |
| 422 | 62.289 | 0.148 | 2.21 | 98 | -3.43 | 99 | 84 | -0.040 | 4.53 | 0.61 |
| 423 | 62.437 | 0.148 | 2.19 | 98 | -2.33 | 99 | 84 | -0.040 | 4.41 | 0.63 |
| 424 | 62.585 | 0.148 | 2.19 | 98 | -1.84 | 99 | 85 | -0.040 | 4.57 | 0.60 |
| 425 | 62.732 | 0.147 | 2.19 | 98 | -1.28 | 98 | 85 | -0.030 | 4.53 | 0.60 |
| 426 | 62.880 | 0.148 | 2.19 | 98 | -3.37 | 99 | 85 | -0.050 | 4.28 | 0.62 |
| 427 | 63.027 | 0.147 | 2.20 | 98 | -2.86 | 98 | 85 | -0.030 | 4.46 | 0.60 |
| 428 | 63.176 | 0.149 | 2.21 | 98 | -3.31 | 100 | 85 | -0.040 | 4.32 | 0.61 |
| 429 | 63.323 | 0.147 | 2.20 | 98 | -1.63 | 98 | 85 | -0.030 | 4.46 | 0.60 |
| 430 | 63.471 | 0.148 | 2.21 | 98 | -0.86 | 99 | 84 | -0.040 | 4.34 | 0.61 |
| 431 | 63.617 | 0.146 | 2.21 | 98 | -0.98 | 98 | 84 | -0.040 | 4.16 | 0.64 |
| 432 | 63.766 | 0.149 | 2.20 | 98 | -3.15 | 100 | 85 | -0.040 | 4.07 | 0.64 |
| 433 | 63.912 | 0.146 | 2.19 | 98 | -1.85 | 98 | 85 | -0.040 | 3.96 | 0.64 |
| 434 | 64.062 | 0.150 | 2.21 | 98 | -1.33 | 100 | 86 | -0.030 | 4.22 | 0.60 |
| 435 | 64.207 | 0.145 | 2.20 | 98 | -1.05 | 97 | 86 | -0.040 | 4.05 | 0.60 |
| 436 | 64.357 | 0.150 | 2.19 | 98 | -0.94 | 100 | 85 | -0.040 | 4.03 | 0.62 |
| 437 | 64.502 | 0.145 | 2.21 | 98 | -1.96 | 97 | 85 | -0.050 | 4.10 | 0.61 |
| 438 | 64.652 | 0.150 | 2.21 | 98 | -3.42 | 100 | 84 | -0.030 | 4.01 | 0.65 |
| 439 | 64.797 | 0.145 | 2.20 | 98 | -0.92 | 97 | 84 | -0.050 | 4.06 | 0.62 |
| 440 | 64.948 | 0.151 | 2.20 | 98 | -3.35 | 101 | 84 | -0.040 | 4.13 | 0.62 |
| 441 | 65.093 | 0.145 | 2.19 | 98 | -2.31 | 97 | 85 | -0.030 | 4.02 | 0.63 |
| 442 | 65.244 | 0.151 | 2.20 | 98 | -1.63 | 101 | 85 | -0.030 | 3.96 | 0.66 |
| 443 | 65.389 | 0.145 | 2.20 | 98 | -3.33 | 97 | 85 | -0.050 | 3.91 | 0.66 |
| 444 | 65.539 | 0.150 | 2.20 | 98 | -3.15 | 100 | 85 | -0.040 | 4.02 | 0.63 |
| 445 | 65.684 | 0.145 | 2.21 | 98 | -1.86 | 97 | 85 | -0.040 | 4.04 | 0.59 |
| 446 | 65.834 | 0.150 | 2.20 | 98 | -2.83 | 100 | 85 | -0.040 | 3.84 | 0.63 |
| 447 | 65.979 | 0.145 | 2.21 | 98 | -2.25 | 97 | 84 | -0.040 | 3.88 | 0.65 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 448 | 66.130 | 0.151 | 2.21 | 98 | -1.64 | 101 | 84 | -0.040 | 3.97 | 0.62 |
| 449 | 66.275 | 0.145 | 2.19 | 98 | -1.4 | 97 | 85 | -0.040 | 3.95 | 0.63 |
| 450 | 66.425 | 0.150 | 2.19 | 98 | -0.85 | 100 | 85 | -0.030 | 4.07 | 0.61 |
| 451 | 66.571 | 0.146 | 2.22 | 98 | -1.91 | 98 | 85 | -0.030 | 3.97 | 0.60 |
| 452 | 66.721 | 0.150 | 2.19 | 98 | -1.47 | 100 | 85 | -0.040 | 4.03 | 0.60 |
| 453 | 66.866 | 0.145 | 2.20 | 98 | -1.85 | 97 | 85 | -0.040 | 3.84 | 0.62 |
| 454 | 67.015 | 0.149 | 2.20 | 98 | -2.44 | 100 | 85 | -0.040 | 4.01 | 0.60 |
| 455 | 67.161 | 0.146 | 2.21 | 98 | -3.27 | 98 | 84 | -0.030 | 3.92 | 0.59 |
| 456 | 67.310 | 0.149 | 2.21 | 98 | -3.28 | 100 | 84 | -0.050 | 4.06 | 0.60 |
| 457 | 67.456 | 0.146 | 2.20 | 98 | -3.12 | 98 | 85 | -0.040 | 3.93 | 0.62 |
| 458 | 67.606 | 0.150 | 2.21 | 98 | -2.53 | 100 | 85 | -0.030 | 3.86 | 0.62 |
| 459 | 67.752 | 0.146 | 2.21 | 98 | -1.03 | 98 | 85 | -0.040 | 3.80 | 0.60 |
| 460 | 67.901 | 0.149 | 2.20 | 98 | -1.64 | 100 | 85 | -0.050 | 3.83 | 0.61 |
| 461 | 68.047 | 0.146 | 2.20 | 98 | -1.68 | 98 | 85 | -0.030 | 3.86 | 0.58 |
| 462 | 68.195 | 0.148 | 2.19 | 98 | -1.04 | 99 | 85 | -0.030 | 3.86 | 0.59 |
| 463 | 68.342 | 0.147 | 2.21 | 98 | -3.22 | 98 | 84 | -0.040 | 3.90 | 0.60 |
| 464 | 68.491 | 0.149 | 2.19 | 98 | -2.81 | 100 | 85 | -0.030 | 3.85 | 0.60 |
| 465 | 68.639 | 0.148 | 2.20 | 98 | -3.33 | 99 | 85 | -0.030 | 3.93 | 0.61 |
| 466 | 68.787 | 0.148 | 2.20 | 98 | -2.31 | 99 | 85 | -0.040 | 3.86 | 0.60 |
| 467 | 68.934 | 0.147 | 2.19 | 98 | -1.27 | 98 | 86 | -0.030 | 3.83 | 0.61 |
| 468 | 69.082 | 0.148 | 2.19 | 98 | -3.07 | 99 | 85 | -0.040 | 3.89 | 0.62 |
| 469 | 69.230 | 0.148 | 2.19 | 98 | -0.91 | 99 | 85 | -0.040 | 3.86 | 0.60 |
| 470 | 69.377 | 0.147 | 2.20 | 98 | -0.9 | 98 | 84 | -0.040 | 3.71 | 0.62 |
| 471 | 69.525 | 0.148 | 2.20 | 98 | -3.18 | 99 | 84 | -0.040 | 3.85 | 0.60 |
| 472 | 69.673 | 0.148 | 2.20 | 98 | -0.92 | 99 | 84 | -0.030 | 3.88 | 0.61 |
| 473 | 69.821 | 0.148 | 2.19 | 98 | -2.5 | 99 | 85 | -0.040 | 3.86 | 0.59 |
| 474 | 69.968 | 0.147 | 2.23 | 98 | -3.34 | 98 | 85 | -0.040 | 3.81 | 0.61 |
| 475 | 70.117 | 0.149 | 2.19 | 98 | -3.2 | 100 | 86 | -0.040 | 3.81 | 0.61 |
| 476 | 70.263 | 0.146 | 2.20 | 98 | -0.86 | 98 | 86 | -0.040 | 3.76 | 0.62 |
| 477 | 70.412 | 0.149 | 2.21 | 98 | -2.38 | 100 | 85 | -0.040 | 3.82 | 0.59 |
| 478 | 70.557 | 0.145 | 2.20 | 98 | -3.28 | 97 | 85 | -0.020 | 3.90 | 0.60 |
| 479 | 70.706 | 0.149 | 2.19 | 98 | -1.25 | 100 | 84 | -0.040 | 3.73 | 0.62 |

BOX B TEST DATA - ASTM E3053 / ASTM E2515

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 480 | 70.853 | 0.147 | 2.19 | 98 | -3.29 | 98 | 84 | -0.030 | 3.72 | 0.64 |
| 481 | 71.002 | 0.149 | 2.21 | 98 | -1.28 | 100 | 85 | -0.040 | 3.81 | 0.60 |
| 482 | 71.148 | 0.146 | 2.21 | 98 | -0.88 | 98 | 85 | -0.030 | 3.90 | 0.58 |
| 483 | 71.297 | 0.149 | 2.19 | 98 | -1.58 | 100 | 86 | -0.040 | 3.77 | 0.59 |
| 484 | 71.443 | 0.146 | 2.21 | 98 | -3.31 | 98 | 86 | -0.040 | 3.71 | 0.62 |
| 485 | 71.592 | 0.149 | 2.21 | 98 | -1.05 | 100 | 85 | -0.030 | 3.84 | 0.57 |
| 486 | 71.738 | 0.146 | 2.19 | 98 | -1.1 | 98 | 85 | -0.040 | 3.81 | 0.60 |
| 487 | 71.888 | 0.150 | 2.20 | 98 | -0.88 | 100 | 84 | -0.040 | 3.78 | 0.59 |
| 488 | 72.033 | 0.145 | 2.20 | 98 | -0.96 | 97 | 84 | -0.050 | 3.69 | 0.60 |
| 489 | 72.184 | 0.151 | 2.20 | 98 | -3.08 | 101 | 85 | -0.040 | 3.63 | 0.60 |
| 490 | 72.329 | 0.145 | 2.21 | 98 | -1.32 | 97 | 85 | -0.040 | 3.63 | 0.60 |
| Avg/Tot | 72.329 | 0.148 | 2.21 | 97 | -2.04 | 100 | | | 6.60 | 0.58 |

WOODSTOVE SURFACE TEMPERATURE DATA

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Temperature Data (°F) | | | | | | |
|--------------------|-----------------------|----------|---------|--------|-----------|-----------------------|---------------|
| | FB Left | FB Right | FB Back | FB Top | FB Bottom | Stove Surface Average | Catalyst Exit |
| 0 | 569 | 527 | 304 | 616 | 358 | 474.8 | N/A |
| 1 | 564 | 524 | 326 | 598 | 359 | 474.2 | N/A |
| 2 | 560 | 521 | 340 | 626 | 360 | 481.4 | N/A |
| 3 | 555 | 515 | 351 | 674 | 361 | 491.2 | N/A |
| 4 | 552 | 509 | 363 | 721 | 363 | 501.6 | N/A |
| 5 | 548 | 501 | 372 | 756 | 364 | 508.2 | N/A |
| 6 | 544 | 494 | 380 | 786 | 365 | 513.8 | N/A |
| 7 | 541 | 487 | 389 | 807 | 365 | 517.8 | N/A |
| 8 | 538 | 482 | 395 | 831 | 365 | 522.2 | N/A |
| 9 | 535 | 477 | 402 | 848 | 366 | 525.6 | N/A |
| 10 | 534 | 473 | 408 | 860 | 367 | 528.4 | N/A |
| 11 | 531 | 470 | 413 | 867 | 367 | 529.6 | N/A |
| 12 | 529 | 468 | 418 | 875 | 367 | 531.4 | N/A |
| 13 | 528 | 465 | 423 | 880 | 367 | 532.6 | N/A |
| 14 | 526 | 463 | 427 | 883 | 367 | 533.2 | N/A |
| 15 | 524 | 462 | 431 | 881 | 367 | 533.0 | N/A |
| 16 | 523 | 460 | 435 | 880 | 366 | 532.8 | N/A |
| 17 | 522 | 457 | 439 | 875 | 366 | 531.8 | N/A |
| 18 | 520 | 456 | 441 | 873 | 365 | 531.0 | N/A |
| 19 | 518 | 455 | 444 | 870 | 364 | 530.2 | N/A |
| 20 | 517 | 454 | 446 | 869 | 363 | 529.8 | N/A |
| 21 | 515 | 453 | 400 | 862 | 361 | 518.2 | N/A |
| 22 | 514 | 452 | 384 | 861 | 360 | 514.2 | N/A |
| 23 | 512 | 452 | 367 | 855 | 358 | 508.8 | N/A |
| 24 | 511 | 451 | 356 | 849 | 357 | 504.8 | N/A |
| 25 | 509 | 449 | 348 | 844 | 356 | 501.2 | N/A |
| 26 | 508 | 449 | 338 | 839 | 354 | 497.6 | N/A |
| 27 | 507 | 449 | 332 | 832 | 352 | 494.4 | N/A |
| 28 | 504 | 447 | 328 | 827 | 350 | 491.2 | N/A |
| 29 | 503 | 447 | 323 | 817 | 348 | 487.6 | N/A |
| 30 | 502 | 446 | 320 | 807 | 346 | 484.2 | N/A |
| 31 | 500 | 444 | 321 | 797 | 345 | 481.4 | N/A |
| 32 | 498 | 443 | 314 | 790 | 342 | 477.4 | N/A |
| 33 | 496 | 442 | 310 | 785 | 340 | 474.6 | N/A |
| 34 | 495 | 441 | 308 | 775 | 338 | 471.4 | N/A |
| 35 | 492 | 438 | 305 | 767 | 336 | 467.6 | N/A |
| 36 | 491 | 438 | 302 | 763 | 334 | 465.6 | N/A |
| 37 | 488 | 436 | 301 | 757 | 332 | 462.8 | N/A |
| 38 | 486 | 435 | 297 | 753 | 330 | 460.2 | N/A |
| 39 | 484 | 434 | 297 | 750 | 328 | 458.6 | N/A |
| 40 | 482 | 432 | 295 | 743 | 326 | 455.6 | N/A |
| 41 | 480 | 430 | 293 | 739 | 324 | 453.2 | N/A |
| 42 | 477 | 428 | 291 | 736 | 322 | 450.8 | N/A |
| 43 | 475 | 427 | 290 | 727 | 320 | 447.8 | N/A |
| 44 | 473 | 426 | 290 | 726 | 318 | 446.6 | N/A |
| 45 | 472 | 424 | 288 | 725 | 316 | 445.0 | N/A |
| 46 | 470 | 423 | 286 | 721 | 314 | 442.8 | N/A |
| 47 | 468 | 422 | 286 | 717 | 313 | 441.2 | N/A |

WOODSTOVE SURFACE TEMPERATURE DATA

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Temperature Data (°F) | | | | | | |
|--------------------|-----------------------|----------|---------|--------|-----------|-----------------------|---------------|
| | FB Left | FB Right | FB Back | FB Top | FB Bottom | Stove Surface Average | Catalyst Exit |
| 48 | 466 | 422 | 287 | 714 | 311 | 440.0 | N/A |
| 49 | 464 | 420 | 284 | 707 | 309 | 436.8 | N/A |
| 50 | 462 | 419 | 283 | 706 | 307 | 435.4 | N/A |
| 51 | 461 | 419 | 284 | 704 | 305 | 434.6 | N/A |
| 52 | 459 | 418 | 283 | 703 | 304 | 433.4 | N/A |
| 53 | 458 | 417 | 282 | 699 | 302 | 431.6 | N/A |
| 54 | 456 | 416 | 281 | 700 | 300 | 430.6 | N/A |
| 55 | 454 | 416 | 282 | 697 | 299 | 429.6 | N/A |
| 56 | 453 | 415 | 280 | 695 | 298 | 428.2 | N/A |
| 57 | 452 | 415 | 281 | 696 | 296 | 428.0 | N/A |
| 58 | 451 | 416 | 282 | 690 | 294 | 426.6 | N/A |
| 59 | 450 | 414 | 279 | 690 | 293 | 425.2 | N/A |
| 60 | 449 | 415 | 280 | 693 | 291 | 425.6 | N/A |
| 61 | 448 | 414 | 280 | 691 | 290 | 424.6 | N/A |
| 62 | 447 | 415 | 279 | 693 | 288 | 424.4 | N/A |
| 63 | 446 | 415 | 279 | 692 | 287 | 423.8 | N/A |
| 64 | 446 | 414 | 279 | 692 | 286 | 423.4 | N/A |
| 65 | 446 | 414 | 282 | 694 | 285 | 424.2 | N/A |
| 66 | 446 | 414 | 280 | 691 | 283 | 422.8 | N/A |
| 67 | 445 | 415 | 280 | 694 | 282 | 423.2 | N/A |
| 68 | 446 | 415 | 281 | 692 | 281 | 423.0 | N/A |
| 69 | 445 | 415 | 283 | 696 | 280 | 423.8 | N/A |
| 70 | 445 | 416 | 282 | 697 | 278 | 423.6 | N/A |
| 71 | 446 | 416 | 283 | 697 | 277 | 423.8 | N/A |
| 72 | 445 | 417 | 284 | 698 | 276 | 424.0 | N/A |
| 73 | 445 | 417 | 284 | 699 | 275 | 424.0 | N/A |
| 74 | 445 | 416 | 284 | 698 | 274 | 423.4 | N/A |
| 75 | 445 | 416 | 285 | 699 | 273 | 423.6 | N/A |
| 76 | 445 | 416 | 285 | 697 | 272 | 423.0 | N/A |
| 77 | 445 | 418 | 285 | 693 | 271 | 422.4 | N/A |
| 78 | 445 | 417 | 286 | 694 | 270 | 422.4 | N/A |
| 79 | 445 | 417 | 288 | 695 | 270 | 423.0 | N/A |
| 80 | 445 | 417 | 288 | 692 | 269 | 422.2 | N/A |
| 81 | 444 | 417 | 289 | 696 | 268 | 422.8 | N/A |
| 82 | 444 | 418 | 289 | 693 | 267 | 422.2 | N/A |
| 83 | 444 | 417 | 288 | 697 | 266 | 422.4 | N/A |
| 84 | 445 | 418 | 291 | 700 | 266 | 424.0 | N/A |
| 85 | 444 | 419 | 291 | 700 | 265 | 423.8 | N/A |
| 86 | 444 | 420 | 292 | 707 | 264 | 425.4 | N/A |
| 87 | 445 | 421 | 293 | 718 | 263 | 428.0 | N/A |
| 88 | 446 | 421 | 295 | 724 | 263 | 429.8 | N/A |
| 89 | 446 | 422 | 296 | 730 | 262 | 431.2 | N/A |
| 90 | 446 | 422 | 297 | 733 | 262 | 432.0 | N/A |
| 91 | 446 | 424 | 299 | 727 | 261 | 431.4 | N/A |
| 92 | 446 | 424 | 297 | 718 | 261 | 429.2 | N/A |
| 93 | 445 | 424 | 298 | 711 | 260 | 427.6 | N/A |
| 94 | 445 | 424 | 297 | 710 | 260 | 427.2 | N/A |
| 95 | 445 | 424 | 297 | 701 | 259 | 425.2 | N/A |

WOODSTOVE SURFACE TEMPERATURE DATA

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Temperature Data (°F) | | | | | | Catalyst Exit |
|--------------------|-----------------------|----------|---------|--------|-----------|-----------------------|---------------|
| | FB Left | FB Right | FB Back | FB Top | FB Bottom | Stove Surface Average | |
| 96 | 444 | 423 | 296 | 699 | 259 | 424.2 | N/A |
| 97 | 444 | 423 | 297 | 696 | 259 | 423.8 | N/A |
| 98 | 444 | 422 | 297 | 690 | 258 | 422.2 | N/A |
| 99 | 442 | 422 | 296 | 688 | 258 | 421.2 | N/A |
| 100 | 442 | 421 | 296 | 684 | 257 | 420.0 | N/A |
| 101 | 442 | 421 | 297 | 683 | 257 | 420.0 | N/A |
| 102 | 442 | 420 | 295 | 679 | 257 | 418.6 | N/A |
| 103 | 442 | 420 | 295 | 677 | 257 | 418.2 | N/A |
| 104 | 441 | 419 | 295 | 673 | 256 | 416.8 | N/A |
| 105 | 441 | 418 | 295 | 666 | 256 | 415.2 | N/A |
| 106 | 440 | 418 | 294 | 661 | 255 | 413.6 | N/A |
| 107 | 440 | 417 | 293 | 656 | 256 | 412.4 | N/A |
| 108 | 439 | 417 | 293 | 655 | 255 | 411.8 | N/A |
| 109 | 438 | 416 | 291 | 646 | 255 | 409.2 | N/A |
| 110 | 437 | 415 | 291 | 643 | 255 | 408.2 | N/A |
| 111 | 437 | 414 | 290 | 640 | 255 | 407.2 | N/A |
| 112 | 435 | 414 | 289 | 634 | 255 | 405.4 | N/A |
| 113 | 435 | 413 | 288 | 629 | 255 | 404.0 | N/A |
| 114 | 434 | 413 | 288 | 628 | 255 | 403.6 | N/A |
| 115 | 433 | 412 | 287 | 623 | 254 | 401.8 | N/A |
| 116 | 433 | 412 | 286 | 623 | 255 | 401.8 | N/A |
| 117 | 432 | 411 | 287 | 618 | 254 | 400.4 | N/A |
| 118 | 431 | 411 | 285 | 614 | 254 | 399.0 | N/A |
| 119 | 430 | 410 | 285 | 609 | 254 | 397.6 | N/A |
| 120 | 429 | 410 | 284 | 610 | 254 | 397.4 | N/A |
| 121 | 428 | 410 | 283 | 606 | 254 | 396.2 | N/A |
| 122 | 428 | 409 | 284 | 607 | 254 | 396.4 | N/A |
| 123 | 427 | 409 | 283 | 602 | 254 | 395.0 | N/A |
| 124 | 427 | 408 | 282 | 600 | 254 | 394.2 | N/A |
| 125 | 426 | 408 | 282 | 594 | 254 | 392.8 | N/A |
| 126 | 425 | 407 | 281 | 589 | 254 | 391.2 | N/A |
| 127 | 424 | 408 | 280 | 583 | 254 | 389.8 | N/A |
| 128 | 424 | 407 | 279 | 579 | 254 | 388.6 | N/A |
| 129 | 422 | 407 | 278 | 577 | 253 | 387.4 | N/A |
| 130 | 422 | 407 | 277 | 573 | 253 | 386.4 | N/A |
| 131 | 421 | 407 | 277 | 568 | 253 | 385.2 | N/A |
| 132 | 420 | 407 | 276 | 565 | 254 | 384.4 | N/A |
| 133 | 419 | 407 | 276 | 561 | 253 | 383.2 | N/A |
| 134 | 418 | 408 | 275 | 557 | 253 | 382.2 | N/A |
| 135 | 417 | 407 | 274 | 553 | 253 | 380.8 | N/A |
| 136 | 416 | 407 | 273 | 548 | 253 | 379.4 | N/A |
| 137 | 415 | 407 | 272 | 545 | 254 | 378.6 | N/A |
| 138 | 414 | 407 | 272 | 539 | 254 | 377.2 | N/A |
| 139 | 412 | 406 | 271 | 536 | 254 | 375.8 | N/A |
| 140 | 412 | 405 | 270 | 531 | 254 | 374.4 | N/A |
| 141 | 411 | 404 | 269 | 530 | 254 | 373.6 | N/A |
| 142 | 410 | 404 | 269 | 526 | 254 | 372.6 | N/A |
| 143 | 410 | 403 | 269 | 524 | 254 | 372.0 | N/A |

WOODSTOVE SURFACE TEMPERATURE DATA

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Temperature Data (°F) | | | | | | Catalyst Exit |
|--------------------|-----------------------|----------|---------|--------|-----------|-----------------------|---------------|
| | FB Left | FB Right | FB Back | FB Top | FB Bottom | Stove Surface Average | |
| 144 | 409 | 402 | 267 | 519 | 254 | 370.2 | N/A |
| 145 | 408 | 401 | 266 | 518 | 254 | 369.4 | N/A |
| 146 | 407 | 400 | 263 | 511 | 254 | 367.0 | N/A |
| 147 | 406 | 398 | 263 | 508 | 255 | 366.0 | N/A |
| 148 | 406 | 397 | 261 | 504 | 255 | 364.6 | N/A |
| 149 | 406 | 396 | 261 | 501 | 255 | 363.8 | N/A |
| 150 | 405 | 394 | 258 | 498 | 255 | 362.0 | N/A |
| 151 | 405 | 393 | 256 | 496 | 255 | 361.0 | N/A |
| 152 | 405 | 392 | 254 | 494 | 255 | 360.0 | N/A |
| 153 | 406 | 390 | 253 | 492 | 256 | 359.4 | N/A |
| 154 | 406 | 390 | 252 | 488 | 256 | 358.4 | N/A |
| 155 | 406 | 388 | 250 | 487 | 256 | 357.4 | N/A |
| 156 | 405 | 387 | 249 | 484 | 256 | 356.2 | N/A |
| 157 | 406 | 386 | 248 | 481 | 256 | 355.4 | N/A |
| 158 | 404 | 386 | 246 | 480 | 257 | 354.6 | N/A |
| 159 | 404 | 384 | 246 | 476 | 257 | 353.4 | N/A |
| 160 | 403 | 384 | 245 | 473 | 257 | 352.4 | N/A |
| 161 | 402 | 383 | 245 | 472 | 257 | 351.8 | N/A |
| 162 | 402 | 381 | 245 | 469 | 257 | 350.8 | N/A |
| 163 | 401 | 381 | 244 | 469 | 258 | 350.6 | N/A |
| 164 | 400 | 381 | 244 | 466 | 258 | 349.8 | N/A |
| 165 | 399 | 380 | 244 | 462 | 259 | 348.8 | N/A |
| 166 | 398 | 380 | 244 | 462 | 259 | 348.6 | N/A |
| 167 | 398 | 379 | 244 | 460 | 259 | 348.0 | N/A |
| 168 | 397 | 379 | 244 | 458 | 260 | 347.6 | N/A |
| 169 | 396 | 379 | 243 | 457 | 260 | 347.0 | N/A |
| 170 | 396 | 378 | 244 | 456 | 260 | 346.8 | N/A |
| 171 | 394 | 378 | 243 | 454 | 261 | 346.0 | N/A |
| 172 | 394 | 378 | 242 | 452 | 261 | 345.4 | N/A |
| 173 | 394 | 377 | 243 | 452 | 261 | 345.4 | N/A |
| 174 | 393 | 378 | 242 | 450 | 262 | 345.0 | N/A |
| 175 | 392 | 378 | 241 | 448 | 262 | 344.2 | N/A |
| 176 | 391 | 378 | 240 | 445 | 262 | 343.2 | N/A |
| 177 | 390 | 378 | 237 | 440 | 263 | 341.6 | N/A |
| 178 | 389 | 376 | 235 | 434 | 263 | 339.4 | N/A |
| 179 | 387 | 377 | 232 | 429 | 263 | 337.6 | N/A |
| 180 | 385 | 376 | 230 | 425 | 263 | 335.8 | N/A |
| 181 | 382 | 376 | 226 | 421 | 264 | 333.8 | N/A |
| 182 | 380 | 375 | 224 | 417 | 264 | 332.0 | N/A |
| 183 | 378 | 375 | 222 | 413 | 265 | 330.6 | N/A |
| 184 | 377 | 374 | 219 | 409 | 265 | 328.8 | N/A |
| 185 | 375 | 374 | 218 | 407 | 265 | 327.8 | N/A |
| 186 | 374 | 374 | 215 | 402 | 265 | 326.0 | N/A |
| 187 | 372 | 374 | 214 | 400 | 265 | 325.0 | N/A |
| 188 | 371 | 374 | 212 | 397 | 266 | 324.0 | N/A |
| 189 | 370 | 374 | 210 | 394 | 266 | 322.8 | N/A |
| 190 | 369 | 374 | 209 | 392 | 266 | 322.0 | N/A |
| 191 | 368 | 374 | 207 | 392 | 266 | 321.4 | N/A |

WOODSTOVE SURFACE TEMPERATURE DATA

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Temperature Data (*F) | | | | | | Stove Surface Average | Catalyst Exit |
|--------------------|-----------------------|----------|---------|--------|-----------|-------|-----------------------|---------------|
| | FB Left | FB Right | FB Back | FB Top | FB Bottom | | | |
| 192 | 367 | 374 | 206 | 387 | 267 | 320.2 | N/A | |
| 193 | 367 | 374 | 204 | 385 | 267 | 319.4 | N/A | |
| 194 | 366 | 374 | 203 | 383 | 267 | 318.6 | N/A | |
| 195 | 366 | 374 | 202 | 382 | 268 | 318.4 | N/A | |
| 196 | 365 | 374 | 201 | 378 | 268 | 317.2 | N/A | |
| 197 | 364 | 373 | 200 | 377 | 268 | 316.4 | N/A | |
| 198 | 364 | 372 | 200 | 375 | 269 | 316.0 | N/A | |
| 199 | 364 | 371 | 199 | 373 | 269 | 315.2 | N/A | |
| 200 | 363 | 370 | 198 | 371 | 269 | 314.2 | N/A | |
| 201 | 363 | 369 | 198 | 371 | 270 | 314.2 | N/A | |
| 202 | 362 | 368 | 197 | 368 | 270 | 313.0 | N/A | |
| 203 | 362 | 367 | 196 | 366 | 271 | 312.4 | N/A | |
| 204 | 361 | 366 | 195 | 364 | 271 | 311.4 | N/A | |
| 205 | 361 | 364 | 195 | 362 | 272 | 310.8 | N/A | |
| 206 | 361 | 363 | 194 | 361 | 272 | 310.2 | N/A | |
| 207 | 361 | 361 | 194 | 360 | 272 | 309.6 | N/A | |
| 208 | 361 | 361 | 193 | 360 | 273 | 309.6 | N/A | |
| 209 | 361 | 359 | 194 | 358 | 273 | 309.0 | N/A | |
| 210 | 361 | 359 | 192 | 357 | 273 | 308.4 | N/A | |
| 211 | 361 | 357 | 192 | 356 | 274 | 308.0 | N/A | |
| 212 | 361 | 356 | 192 | 356 | 275 | 308.0 | N/A | |
| 213 | 361 | 355 | 191 | 356 | 275 | 307.6 | N/A | |
| 214 | 362 | 354 | 191 | 354 | 275 | 307.2 | N/A | |
| 215 | 361 | 353 | 191 | 353 | 276 | 306.8 | N/A | |
| 216 | 362 | 352 | 190 | 352 | 276 | 306.4 | N/A | |
| 217 | 362 | 350 | 190 | 351 | 277 | 306.0 | N/A | |
| 218 | 361 | 350 | 190 | 351 | 277 | 305.8 | N/A | |
| 219 | 361 | 349 | 189 | 350 | 277 | 305.2 | N/A | |
| 220 | 361 | 348 | 190 | 350 | 278 | 305.4 | N/A | |
| 221 | 361 | 347 | 189 | 348 | 278 | 304.6 | N/A | |
| 222 | 360 | 347 | 189 | 347 | 279 | 304.4 | N/A | |
| 223 | 360 | 346 | 189 | 346 | 279 | 304.0 | N/A | |
| 224 | 360 | 344 | 189 | 347 | 279 | 303.8 | N/A | |
| 225 | 359 | 344 | 189 | 346 | 279 | 303.4 | N/A | |
| 226 | 359 | 343 | 189 | 345 | 280 | 303.2 | N/A | |
| 227 | 358 | 343 | 189 | 345 | 280 | 303.0 | N/A | |
| 228 | 358 | 342 | 188 | 344 | 280 | 302.4 | N/A | |
| 229 | 357 | 341 | 189 | 345 | 280 | 302.4 | N/A | |
| 230 | 357 | 341 | 188 | 344 | 281 | 302.2 | N/A | |
| 231 | 357 | 340 | 188 | 343 | 281 | 301.8 | N/A | |
| 232 | 356 | 340 | 188 | 344 | 281 | 301.8 | N/A | |
| 233 | 356 | 339 | 188 | 342 | 281 | 301.2 | N/A | |
| 234 | 355 | 339 | 188 | 343 | 282 | 301.4 | N/A | |
| 235 | 355 | 339 | 188 | 341 | 282 | 301.0 | N/A | |
| 236 | 355 | 337 | 188 | 342 | 282 | 300.8 | N/A | |
| 237 | 355 | 338 | 188 | 342 | 282 | 301.0 | N/A | |
| 238 | 355 | 337 | 188 | 341 | 282 | 300.6 | N/A | |
| 239 | 354 | 337 | 187 | 340 | 283 | 300.2 | N/A | |

WOODSTOVE SURFACE TEMPERATURE DATA

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Temperature Data (*F) | | | | | | Catalyst Exit |
|--------------------|-----------------------|----------|---------|--------|-----------|-----------------------|---------------|
| | FB Left | FB Right | FB Back | FB Top | FB Bottom | Stove Surface Average | |
| 240 | 354 | 337 | 187 | 339 | 283 | 300.0 | N/A |
| 241 | 353 | 336 | 187 | 338 | 283 | 299.4 | N/A |
| 242 | 353 | 336 | 187 | 339 | 283 | 299.6 | N/A |
| 243 | 353 | 336 | 187 | 337 | 283 | 299.2 | N/A |
| 244 | 353 | 335 | 187 | 337 | 283 | 299.0 | N/A |
| 245 | 352 | 335 | 186 | 335 | 283 | 298.2 | N/A |
| 246 | 352 | 335 | 186 | 335 | 283 | 298.2 | N/A |
| 247 | 352 | 334 | 186 | 334 | 283 | 297.8 | N/A |
| 248 | 352 | 334 | 186 | 333 | 283 | 297.6 | N/A |
| 249 | 352 | 334 | 186 | 333 | 283 | 297.6 | N/A |
| 250 | 351 | 334 | 186 | 332 | 283 | 297.2 | N/A |
| 251 | 351 | 334 | 186 | 331 | 283 | 297.0 | N/A |
| 252 | 350 | 333 | 186 | 331 | 283 | 296.6 | N/A |
| 253 | 351 | 333 | 185 | 330 | 283 | 296.4 | N/A |
| 254 | 350 | 333 | 186 | 330 | 283 | 296.4 | N/A |
| 255 | 350 | 333 | 185 | 329 | 283 | 296.0 | N/A |
| 256 | 350 | 332 | 185 | 329 | 283 | 295.8 | N/A |
| 257 | 350 | 332 | 185 | 328 | 283 | 295.6 | N/A |
| 258 | 350 | 331 | 184 | 327 | 283 | 295.0 | N/A |
| 259 | 349 | 331 | 185 | 327 | 283 | 295.0 | N/A |
| 260 | 349 | 331 | 185 | 325 | 283 | 294.6 | N/A |
| 261 | 349 | 330 | 185 | 326 | 283 | 294.6 | N/A |
| 262 | 349 | 329 | 184 | 325 | 283 | 294.0 | N/A |
| 263 | 349 | 329 | 184 | 325 | 283 | 294.0 | N/A |
| 264 | 349 | 329 | 184 | 323 | 282 | 293.4 | N/A |
| 265 | 349 | 329 | 183 | 324 | 282 | 293.4 | N/A |
| 266 | 349 | 328 | 184 | 323 | 282 | 293.2 | N/A |
| 267 | 349 | 328 | 183 | 321 | 282 | 292.6 | N/A |
| 268 | 349 | 327 | 183 | 321 | 282 | 292.4 | N/A |
| 269 | 349 | 327 | 183 | 320 | 282 | 292.2 | N/A |
| 270 | 349 | 326 | 183 | 320 | 282 | 292.0 | N/A |
| 271 | 349 | 326 | 183 | 320 | 282 | 292.0 | N/A |
| 272 | 349 | 325 | 183 | 319 | 282 | 291.6 | N/A |
| 273 | 349 | 325 | 183 | 319 | 282 | 291.6 | N/A |
| 274 | 349 | 323 | 183 | 318 | 282 | 291.0 | N/A |
| 275 | 349 | 324 | 183 | 318 | 282 | 291.2 | N/A |
| 276 | 348 | 323 | 184 | 318 | 282 | 291.0 | N/A |
| 277 | 348 | 323 | 184 | 319 | 282 | 291.2 | N/A |
| 278 | 348 | 322 | 183 | 318 | 282 | 290.6 | N/A |
| 279 | 348 | 322 | 183 | 319 | 282 | 290.8 | N/A |
| 280 | 347 | 322 | 183 | 318 | 282 | 290.4 | N/A |
| 281 | 347 | 322 | 183 | 319 | 282 | 290.6 | N/A |
| 282 | 347 | 321 | 183 | 318 | 282 | 290.2 | N/A |
| 283 | 346 | 321 | 184 | 317 | 282 | 290.0 | N/A |
| 284 | 346 | 321 | 183 | 317 | 282 | 289.8 | N/A |
| 285 | 345 | 321 | 183 | 316 | 282 | 289.4 | N/A |
| 286 | 345 | 320 | 183 | 316 | 282 | 289.2 | N/A |
| 287 | 344 | 320 | 183 | 316 | 282 | 289.0 | N/A |

WOODSTOVE SURFACE TEMPERATURE DATA

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Temperature Data (*F) | | | | | | |
|--------------------|-----------------------|----------|---------|--------|-----------|-----------------------|---------------|
| | FB Left | FB Right | FB Back | FB Top | FB Bottom | Stove Surface Average | Catalyst Exit |
| 288 | 344 | 320 | 182 | 316 | 282 | 288.8 | N/A |
| 289 | 343 | 320 | 182 | 316 | 282 | 288.6 | N/A |
| 290 | 343 | 319 | 182 | 315 | 282 | 288.2 | N/A |
| 291 | 342 | 319 | 182 | 315 | 282 | 288.0 | N/A |
| 292 | 342 | 319 | 182 | 314 | 282 | 287.8 | N/A |
| 293 | 341 | 319 | 182 | 313 | 282 | 287.4 | N/A |
| 294 | 341 | 319 | 182 | 313 | 282 | 287.4 | N/A |
| 295 | 340 | 319 | 182 | 312 | 281 | 286.8 | N/A |
| 296 | 340 | 318 | 181 | 312 | 281 | 286.4 | N/A |
| 297 | 339 | 317 | 181 | 311 | 281 | 285.8 | N/A |
| 298 | 339 | 317 | 181 | 311 | 281 | 285.8 | N/A |
| 299 | 338 | 317 | 182 | 309 | 281 | 285.4 | N/A |
| 300 | 337 | 316 | 181 | 308 | 281 | 284.6 | N/A |
| 301 | 337 | 316 | 181 | 308 | 281 | 284.6 | N/A |
| 302 | 337 | 316 | 180 | 307 | 281 | 284.2 | N/A |
| 303 | 336 | 316 | 180 | 307 | 280 | 283.8 | N/A |
| 304 | 336 | 315 | 180 | 305 | 280 | 283.2 | N/A |
| 305 | 335 | 315 | 179 | 305 | 280 | 282.8 | N/A |
| 306 | 334 | 315 | 179 | 304 | 280 | 282.4 | N/A |
| 307 | 335 | 315 | 179 | 302 | 280 | 282.2 | N/A |
| 308 | 333 | 314 | 179 | 302 | 280 | 281.6 | N/A |
| 309 | 334 | 314 | 178 | 302 | 279 | 281.4 | N/A |
| 310 | 333 | 314 | 178 | 300 | 279 | 280.8 | N/A |
| 311 | 332 | 314 | 178 | 301 | 279 | 280.8 | N/A |
| 312 | 332 | 313 | 178 | 300 | 279 | 280.4 | N/A |
| 313 | 331 | 313 | 178 | 299 | 278 | 279.8 | N/A |
| 314 | 331 | 312 | 177 | 299 | 278 | 279.4 | N/A |
| 315 | 331 | 312 | 177 | 299 | 278 | 279.4 | N/A |
| 316 | 330 | 311 | 177 | 297 | 278 | 278.6 | N/A |
| 317 | 329 | 311 | 176 | 297 | 278 | 278.2 | N/A |
| 318 | 329 | 311 | 176 | 296 | 277 | 277.8 | N/A |
| 319 | 329 | 311 | 176 | 295 | 277 | 277.6 | N/A |
| 320 | 329 | 311 | 176 | 295 | 277 | 277.6 | N/A |
| 321 | 328 | 310 | 176 | 295 | 277 | 277.2 | N/A |
| 322 | 328 | 310 | 176 | 293 | 277 | 276.8 | N/A |
| 323 | 327 | 310 | 175 | 294 | 276 | 276.4 | N/A |
| 324 | 327 | 310 | 175 | 293 | 276 | 276.2 | N/A |
| 325 | 327 | 309 | 175 | 292 | 276 | 275.8 | N/A |
| 326 | 326 | 309 | 175 | 291 | 276 | 275.4 | N/A |
| 327 | 325 | 308 | 175 | 291 | 275 | 274.8 | N/A |
| 328 | 325 | 308 | 175 | 292 | 275 | 275.0 | N/A |
| 329 | 325 | 308 | 175 | 291 | 275 | 274.8 | N/A |
| 330 | 324 | 307 | 175 | 290 | 275 | 274.2 | N/A |
| 331 | 324 | 308 | 174 | 291 | 274 | 274.2 | N/A |
| 332 | 324 | 308 | 174 | 289 | 274 | 273.8 | N/A |
| 333 | 323 | 307 | 174 | 290 | 274 | 273.6 | N/A |
| 334 | 324 | 308 | 174 | 289 | 274 | 273.8 | N/A |
| 335 | 323 | 307 | 174 | 289 | 273 | 273.2 | N/A |

WOODSTOVE SURFACE TEMPERATURE DATA

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Temperature Data (*F) | | | | | | |
|--------------------|-----------------------|----------|---------|--------|-----------|-----------------------|---------------|
| | FB Left | FB Right | FB Back | FB Top | FB Bottom | Stove Surface Average | Catalyst Exit |
| 336 | 322 | 308 | 174 | 289 | 273 | 273.2 | N/A |
| 337 | 322 | 307 | 174 | 289 | 273 | 273.0 | N/A |
| 338 | 322 | 307 | 175 | 288 | 273 | 273.0 | N/A |
| 339 | 322 | 307 | 175 | 289 | 273 | 273.2 | N/A |
| 340 | 321 | 307 | 174 | 288 | 273 | 272.6 | N/A |
| 341 | 322 | 307 | 174 | 288 | 272 | 272.6 | N/A |
| 342 | 322 | 307 | 175 | 288 | 272 | 272.8 | N/A |
| 343 | 321 | 307 | 174 | 287 | 272 | 272.2 | N/A |
| 344 | 321 | 307 | 174 | 286 | 272 | 272.0 | N/A |
| 345 | 321 | 307 | 174 | 287 | 272 | 272.2 | N/A |
| 346 | 321 | 307 | 175 | 287 | 272 | 272.4 | N/A |
| 347 | 321 | 307 | 175 | 287 | 271 | 272.2 | N/A |
| 348 | 321 | 307 | 174 | 286 | 271 | 271.8 | N/A |
| 349 | 321 | 307 | 174 | 285 | 271 | 271.6 | N/A |
| 350 | 320 | 306 | 174 | 285 | 271 | 271.2 | N/A |
| 351 | 320 | 307 | 174 | 285 | 271 | 271.4 | N/A |
| 352 | 321 | 307 | 174 | 285 | 271 | 271.6 | N/A |
| 353 | 320 | 307 | 174 | 283 | 271 | 271.0 | N/A |
| 354 | 320 | 307 | 174 | 283 | 271 | 271.0 | N/A |
| 355 | 320 | 307 | 174 | 283 | 271 | 271.0 | N/A |
| 356 | 320 | 306 | 174 | 282 | 271 | 270.6 | N/A |
| 357 | 320 | 306 | 174 | 283 | 270 | 270.6 | N/A |
| 358 | 320 | 306 | 173 | 283 | 270 | 270.4 | N/A |
| 359 | 320 | 307 | 174 | 282 | 270 | 270.6 | N/A |
| 360 | 319 | 305 | 174 | 282 | 270 | 270.0 | N/A |
| 361 | 320 | 305 | 174 | 282 | 270 | 270.2 | N/A |
| 362 | 319 | 305 | 175 | 281 | 270 | 270.0 | N/A |
| 363 | 319 | 305 | 174 | 281 | 270 | 269.8 | N/A |
| 364 | 319 | 305 | 174 | 281 | 270 | 269.8 | N/A |
| 365 | 319 | 305 | 174 | 281 | 270 | 269.8 | N/A |
| 366 | 318 | 305 | 175 | 280 | 270 | 269.6 | N/A |
| 367 | 318 | 305 | 175 | 279 | 270 | 269.4 | N/A |
| 368 | 318 | 305 | 175 | 280 | 270 | 269.6 | N/A |
| 369 | 318 | 304 | 175 | 280 | 269 | 269.2 | N/A |
| 370 | 317 | 304 | 175 | 279 | 269 | 268.8 | N/A |
| 371 | 317 | 305 | 175 | 278 | 270 | 269.0 | N/A |
| 372 | 317 | 304 | 175 | 279 | 270 | 269.0 | N/A |
| 373 | 317 | 304 | 176 | 279 | 269 | 269.0 | N/A |
| 374 | 316 | 304 | 175 | 278 | 269 | 268.4 | N/A |
| 375 | 316 | 304 | 176 | 278 | 269 | 268.6 | N/A |
| 376 | 316 | 304 | 176 | 277 | 269 | 268.4 | N/A |
| 377 | 316 | 304 | 176 | 278 | 269 | 268.6 | N/A |
| 378 | 315 | 303 | 176 | 278 | 269 | 268.2 | N/A |
| 379 | 315 | 303 | 177 | 278 | 270 | 268.6 | N/A |
| 380 | 314 | 303 | 178 | 277 | 270 | 268.4 | N/A |
| 381 | 314 | 303 | 178 | 278 | 270 | 268.6 | N/A |
| 382 | 314 | 303 | 178 | 277 | 270 | 268.4 | N/A |
| 383 | 314 | 303 | 178 | 278 | 270 | 268.6 | N/A |

WOODSTOVE SURFACE TEMPERATURE DATA

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Temperature Data (°F) | | | | | | Catalyst Exit |
|--------------------|-----------------------|----------|---------|--------|-----------|-----------------------|---------------|
| | FB Left | FB Right | FB Back | FB Top | FB Bottom | Stove Surface Average | |
| 384 | 314 | 302 | 178 | 277 | 270 | 268.2 | N/A |
| 385 | 313 | 302 | 179 | 277 | 270 | 268.2 | N/A |
| 386 | 313 | 302 | 179 | 277 | 270 | 268.2 | N/A |
| 387 | 313 | 302 | 179 | 276 | 270 | 268.0 | N/A |
| 388 | 312 | 302 | 179 | 276 | 270 | 267.8 | N/A |
| 389 | 312 | 301 | 180 | 277 | 270 | 268.0 | N/A |
| 390 | 312 | 301 | 180 | 277 | 270 | 268.0 | N/A |
| 391 | 312 | 301 | 179 | 277 | 270 | 267.8 | N/A |
| 392 | 312 | 301 | 180 | 276 | 270 | 267.8 | N/A |
| 393 | 311 | 300 | 180 | 275 | 270 | 267.2 | N/A |
| 394 | 312 | 300 | 180 | 277 | 270 | 267.8 | N/A |
| 395 | 312 | 300 | 180 | 276 | 271 | 267.8 | N/A |
| 396 | 312 | 299 | 180 | 276 | 271 | 267.6 | N/A |
| 397 | 312 | 299 | 181 | 276 | 271 | 267.8 | N/A |
| 398 | 312 | 299 | 181 | 276 | 271 | 267.8 | N/A |
| 399 | 312 | 298 | 181 | 276 | 271 | 267.6 | N/A |
| 400 | 312 | 298 | 182 | 275 | 271 | 267.6 | N/A |
| 401 | 312 | 298 | 182 | 276 | 271 | 267.8 | N/A |
| 402 | 312 | 297 | 182 | 276 | 271 | 267.6 | N/A |
| 403 | 312 | 297 | 182 | 276 | 271 | 267.6 | N/A |
| 404 | 313 | 296 | 183 | 276 | 271 | 267.8 | N/A |
| 405 | 313 | 297 | 184 | 277 | 271 | 268.4 | N/A |
| 406 | 313 | 296 | 184 | 276 | 271 | 268.0 | N/A |
| 407 | 313 | 296 | 185 | 276 | 271 | 268.2 | N/A |
| 408 | 314 | 296 | 186 | 276 | 271 | 268.6 | N/A |
| 409 | 314 | 295 | 185 | 277 | 271 | 268.4 | N/A |
| 410 | 314 | 296 | 186 | 277 | 271 | 268.8 | N/A |
| 411 | 314 | 295 | 187 | 277 | 271 | 268.8 | N/A |
| 412 | 314 | 295 | 187 | 278 | 271 | 269.0 | N/A |
| 413 | 315 | 295 | 187 | 278 | 271 | 269.2 | N/A |
| 414 | 315 | 295 | 187 | 278 | 271 | 269.2 | N/A |
| 415 | 315 | 295 | 189 | 279 | 271 | 269.8 | N/A |
| 416 | 315 | 295 | 190 | 279 | 271 | 270.0 | N/A |
| 417 | 316 | 294 | 190 | 279 | 271 | 270.0 | N/A |
| 418 | 316 | 295 | 190 | 280 | 271 | 270.4 | N/A |
| 419 | 317 | 294 | 192 | 279 | 271 | 270.6 | N/A |
| 420 | 317 | 294 | 192 | 280 | 271 | 270.8 | N/A |
| 421 | 317 | 295 | 192 | 280 | 271 | 271.0 | N/A |
| 422 | 317 | 294 | 193 | 280 | 271 | 271.0 | N/A |
| 423 | 318 | 294 | 193 | 280 | 271 | 271.2 | N/A |
| 424 | 318 | 294 | 193 | 281 | 271 | 271.4 | N/A |
| 425 | 318 | 294 | 194 | 281 | 271 | 271.6 | N/A |
| 426 | 318 | 294 | 194 | 281 | 271 | 271.6 | N/A |
| 427 | 318 | 294 | 195 | 280 | 271 | 271.6 | N/A |
| 428 | 318 | 294 | 195 | 281 | 271 | 271.8 | N/A |
| 429 | 318 | 294 | 195 | 282 | 271 | 272.0 | N/A |
| 430 | 319 | 294 | 195 | 280 | 271 | 271.8 | N/A |
| 431 | 319 | 295 | 195 | 280 | 271 | 272.0 | N/A |

WOODSTOVE SURFACE TEMPERATURE DATA

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Elapsed Time (min) | Temperature Data (°F) | | | | | | Stove Surface Average | Catalyst Exit |
|--------------------|-----------------------|----------|---------|--------|-----------|-------|-----------------------|---------------|
| | FB Left | FB Right | FB Back | FB Top | FB Bottom | | | |
| 432 | 318 | 294 | 194 | 281 | 271 | 271.6 | N/A | |
| 433 | 319 | 294 | 194 | 280 | 272 | 271.8 | N/A | |
| 434 | 318 | 294 | 193 | 280 | 271 | 271.2 | N/A | |
| 435 | 318 | 294 | 193 | 280 | 271 | 271.2 | N/A | |
| 436 | 317 | 293 | 193 | 280 | 271 | 270.8 | N/A | |
| 437 | 317 | 293 | 193 | 280 | 271 | 270.8 | N/A | |
| 438 | 317 | 294 | 193 | 279 | 271 | 270.8 | N/A | |
| 439 | 317 | 294 | 192 | 279 | 271 | 270.6 | N/A | |
| 440 | 316 | 293 | 192 | 279 | 271 | 270.2 | N/A | |
| 441 | 316 | 293 | 192 | 278 | 271 | 270.0 | N/A | |
| 442 | 315 | 292 | 192 | 278 | 271 | 269.6 | N/A | |
| 443 | 315 | 293 | 192 | 278 | 271 | 269.8 | N/A | |
| 444 | 315 | 292 | 191 | 277 | 271 | 269.2 | N/A | |
| 445 | 315 | 293 | 192 | 276 | 271 | 269.4 | N/A | |
| 446 | 314 | 293 | 191 | 276 | 271 | 269.0 | N/A | |
| 447 | 314 | 292 | 191 | 275 | 271 | 268.6 | N/A | |
| 448 | 314 | 292 | 190 | 276 | 271 | 268.6 | N/A | |
| 449 | 314 | 292 | 191 | 275 | 271 | 268.6 | N/A | |
| 450 | 313 | 292 | 189 | 274 | 271 | 267.8 | N/A | |
| 451 | 314 | 292 | 190 | 274 | 271 | 268.2 | N/A | |
| 452 | 313 | 291 | 189 | 273 | 271 | 267.4 | N/A | |
| 453 | 312 | 291 | 189 | 273 | 270 | 267.0 | N/A | |
| 454 | 313 | 291 | 188 | 273 | 270 | 267.0 | N/A | |
| 455 | 312 | 291 | 188 | 272 | 270 | 266.6 | N/A | |
| 456 | 313 | 291 | 188 | 272 | 270 | 266.8 | N/A | |
| 457 | 312 | 290 | 187 | 270 | 270 | 265.8 | N/A | |
| 458 | 312 | 290 | 187 | 271 | 269 | 265.8 | N/A | |
| 459 | 311 | 290 | 187 | 270 | 269 | 265.4 | N/A | |
| 460 | 311 | 290 | 188 | 270 | 269 | 265.6 | N/A | |
| 461 | 311 | 289 | 186 | 269 | 269 | 264.8 | N/A | |
| 462 | 311 | 290 | 187 | 269 | 269 | 265.2 | N/A | |
| 463 | 310 | 290 | 186 | 269 | 269 | 264.8 | N/A | |
| 464 | 310 | 289 | 186 | 268 | 268 | 264.2 | N/A | |
| 465 | 310 | 289 | 186 | 268 | 268 | 264.2 | N/A | |
| 466 | 311 | 289 | 186 | 268 | 268 | 264.4 | N/A | |
| 467 | 310 | 289 | 185 | 267 | 268 | 263.8 | N/A | |
| 468 | 310 | 288 | 185 | 267 | 267 | 263.4 | N/A | |
| 469 | 309 | 288 | 185 | 266 | 267 | 263.0 | N/A | |
| 470 | 309 | 287 | 185 | 266 | 267 | 262.8 | N/A | |
| 471 | 310 | 288 | 185 | 267 | 267 | 263.4 | N/A | |
| 472 | 309 | 287 | 185 | 265 | 267 | 262.6 | N/A | |
| 473 | 309 | 287 | 185 | 266 | 267 | 262.8 | N/A | |
| 474 | 309 | 286 | 184 | 265 | 267 | 262.2 | N/A | |
| 475 | 308 | 287 | 184 | 265 | 266 | 262.0 | N/A | |
| 476 | 308 | 286 | 184 | 265 | 266 | 261.8 | N/A | |
| 477 | 307 | 286 | 184 | 264 | 266 | 261.4 | N/A | |
| 478 | 307 | 286 | 184 | 265 | 266 | 261.6 | N/A | |
| 479 | 306 | 285 | 183 | 264 | 266 | 260.8 | N/A | |

WOODSTOVE SURFACE TEMPERATURE DATA

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

| Temperature Data (°F) | | | | | | | |
|-----------------------|---------|----------|---------|--------|-----------|-----------------------|---------------|
| Elapsed Time (min) | FB Left | FB Right | FB Back | FB Top | FB Bottom | Stove Surface Average | Catalyst Exit |
| 480 | 307 | 285 | 183 | 264 | 266 | 261.0 | N/A |
| 481 | 306 | 285 | 184 | 263 | 265 | 260.6 | N/A |
| 482 | 306 | 285 | 184 | 263 | 265 | 260.6 | N/A |
| 483 | 305 | 285 | 183 | 262 | 265 | 260.0 | N/A |
| 484 | 305 | 284 | 184 | 262 | 265 | 260.0 | N/A |
| 485 | 305 | 284 | 183 | 261 | 265 | 259.6 | N/A |
| 486 | 305 | 284 | 183 | 262 | 265 | 259.8 | N/A |
| 487 | 304 | 283 | 183 | 261 | 264 | 259.0 | N/A |
| 488 | 304 | 283 | 183 | 260 | 264 | 258.8 | N/A |
| 489 | 304 | 284 | 182 | 260 | 264 | 258.8 | N/A |
| 490 | 304 | 283 | 182 | 260 | 264 | 258.6 | N/A |
| Average | 376 | 354 | 226 | 434 | 279 | 334 | N/A |

LAB SAMPLE DATA - ASTM E2515

Client: FPI
 Model: F2450
 Run #: 3

Job #: 19-460
 Tracking #: 0022
 Technician: SJB
 Date: 2/28/2019

TRAIN A (1st Hour)

| Sample Component | Sample Type | Filter, Probe, or O-Ring # | Weights | | |
|-----------------------|-------------|----------------------------|-----------|----------|-----------------|
| | | | Final, mg | Tare, mg | Particulate, mg |
| A. Front filter catch | Filter | T121, T122 | 180.7 | 176.1 | 4.6 |
| B. Rear filter catch | Filter | | | | 0.0 |
| C. Probe catch* | Probe | | | | 0.0 |
| D. O-Ring catch* | O-Ring | | | | 0.0 |

Sub-Total Total Particulate, mg: 4.6

TRAIN A (Post 1st hour)

| Sample Component | Sample Type | Filter, Probe, or O-Ring # | Weights | | |
|-----------------------|-------------|----------------------------|-----------|----------|-----------------|
| | | | Final, mg | Tare, mg | Particulate, mg |
| A. Front filter catch | Filter | T128 | 177.9 | 88.8 | 1.7 |
| B. Rear filter catch | Filter | T123 | | 87.4 | |
| C. Probe catch* | Probe | 9A | 116713.5 | 116713.6 | 0.0 |
| D. O-Ring catch* | O-Ring | 9A | 3577.2 | 3577.1 | 0.1 |

Sub-Total Total Particulate, mg: 1.8

Train A Aggregate Total Particulate, mg: **6.4**

TRAIN B

| Sample Component | Reagent | Filter, Probe, or O-Ring # | Weights | | |
|-----------------------|---------|----------------------------|-----------|----------|-----------------|
| | | | Final, mg | Tare, mg | Particulate, mg |
| A. Front filter catch | Filter | T124, T127 | 269.3 | 176.1 | 6.1 |
| B. Rear filter catch | Filter | T125 | | 87.1 | |
| C. Probe catch* | Probe | 9B | 117135.2 | 117135.4 | 0.0 |
| D. O-Ring catch* | O-Ring | 9B | 3520.1 | 3519.9 | 0.2 |

Total Particulate, mg: **6.3**

AMBIENT

| Sample Component | Reagent | Filter, Probe, or O-Ring # | Weights | | |
|------------------|---------|----------------------------|-----------|----------|-----------------|
| | | | Final, mg | Tare, mg | Particulate, mg |
| A. Filter catch* | Filter | T126 | 88.0 | 87.9 | 0.1 |

Total Particulate, mg: **0.1**

*Particulate catch that results in a negative number, is assumed to be zero for probes and O-rings, negative numbers for filters are assumed to be part of the O-Ring weight.

ASTM E3053 Wood Heater Run Sheets

Client: FPI Job Number: 19-460 Tracking #: 0022
 Model: F2450 Run Number: 3 Test Date: 2/28/2019

Wood Heater Run Notes

Pre-Test Notes

Pre-Test Start Time: 7:53
 Air Control Setting: Fully Open

| Time | Notes |
|---------|---|
| 0 min | 2.0 lbs of kindling and scrap paper loaded in stove, propane torch for 20 seconds; door cracked open ~3" |
| 1 min | Door closed down to 1" open |
| 2 min | Door closed |
| 5 min | @0.5 lbs, added remaining kindling (1.0 lb) of kindling and 1.3 lbs of start-up fuel, door open 40 seconds, then closed but not engaged |
| 6.5 min | Door latch engaged |
| 15 min | @0.8 lbs, added remaining start-up fuel (3.0 lbs), door open 40 seconds |
| 20 min | @2.3 lbs, leveled coal bed and loaded high fire fuel load, door open 1 minute |
| 40 min | Fan turned on high (20 minutes after fuel loading) per manufacturer's instructions |
| 80 min | @6.0 lbs, brought unburnt pieces forward for more uniform charcoalization |
| 98 min | @4.1 lbs, leveled coal bed, turned off fan, zeroed scale in preparation of medium fire fuel loading |

Test Notes

Test Burn Start Time: 9:32
 Air Control Setting: Medium Test Setting (See pictures/drawings is test file)

| Time | Notes |
|---------|---|
| 0 min | Loaded Medium fire test fuel, door closed @ 60 seconds. |
| 3 min | Set air to medium test setting |
| 6 min | Changed both front filters due to plugging |
| 20 min | Fan turned on low (20 minutes after fuel loading) per manufacturer's instructions |
| 60 min | Changed 1-hour filter on Train A |
| 490 min | End of Test |

Test Burn End Time: 17:42

Flue Gas Concentration Measurement

Calibration Gas Values: Span Gas CO₂ (%): 16.93 CO (%): 4.330
 Mid Gas CO₂ (%): 10.00 CO (%): 2.51

Calibration Results:

| | Pre Test | | | Post Test | | |
|-----------------|----------|-------|-------|-------------|-------------|-------------|
| | Zero | Mid | Span | Zero | Mid | Span |
| Time | 7:04 | 7:09 | 7:06 | 3/1 – 11:17 | 3/1 – 11:15 | 3/1 – 11:20 |
| CO ₂ | 0.00 | 10.07 | 16.93 | 0.00 | 10.09 | 16.96 |
| CO | 0.000 | 2.500 | 4.330 | -0.025 | 2.472 | 4.300 |

Flue Gas Probe Leak Check: Initial: No Leakage Final: No Leakage

Technician Signature: 

Date: 3/1/2019

ASTM E3053 Wood Heater Run Sheets

Client: FPI Job Number: 19-460 Tracking #: 0022
Model: F2450 Run Number: 3 Test Date: 2/28/2019

Test Photos




Kindling Fuel Load



Start-up Fuel Load



High Fire Fuel Load



Residual Start-up Fuel Coal Bed

Technician Signature: 

Date: 3/1/2019

ASTM E3053 Wood Heater Run Sheets

Client: FPI
Model: F2450

Job Number: 19-460
Run Number: 3

Tracking #: 0022
Test Date: 2/28/2019




High Fire Fuel Loaded



Residual High Fire Load Coal Bed



Medium Fire Fuel Load



Medium Fire Fuel Loaded

Technician Signature: 

Date: 3/1/2019
Page 3 of 3

Sample Pre-Test Tare Sheet: Probes

TX40 Filters

O-Rings

Date/Time In Desiccator: 1/17/2019 - 16:00 Balance ID#: 107 Audit Weight ID# / Weight(mg): 109A-100mg

| Sample ID | Date/Time | Weight (mg) | Date/Time | Weight (mg) | Date/Time | Weight (mg) | Date/Time | Weight (mg) | Tech. Initials | Project/Run # |
|-----------|------------|-------------|------------|-------------|-----------|-------------|-----------|-------------|----------------|---------------|
| T091 | 2/20-17:00 | 88.8 | 2/22-15:30 | 88.4 | 2/25-8:00 | 88.5 | - | - | SB | 19-460 #1 SS1 |
| T092 | ↓ | 89.2 | ↓ | 89.0 | - | - | - | - | SB | 19-460 #1 SS1 |
| T093 | ↓ | 87.4 | ↓ | 87.4 | - | - | - | - | SB | 19-460 #1 SS1 |
| T094 | ↓ | 87.4 | ↓ | 87.5 | - | - | - | - | SB | 19-460 #1 SS2 |
| T095 | ↓ | 87.3 | ↓ | 87.2 | - | - | - | - | SB | ↓ |
| T096 | ↓ | 87.8 | ↓ | 87.8 | - | - | - | - | SB | ↓ |
| T097 | ↓ | 87.3 | ↓ | 87.5 | - | - | - | - | SB | ↓ |
| T098 | ↓ | 86.4 | ↓ | 86.5 | - | - | - | - | SB | ↓ |
| T099 | ↓ | 87.7 | ↓ | 87.6 | - | - | - | - | SB | ↓ |
| T100 | ↓ | 88.0 | ↓ | 88.0 | - | - | - | - | SB | ↓ |
| T101 | ↓ | 87.3 | ↓ | 87.4 | - | - | - | - | SB | ↓ |
| T102 | ↓ | 88.0 | ↓ | 87.9 | - | - | - | - | SB | ↓ |
| T103 | ↓ | 87.9 | ↓ | 87.8 | - | - | - | - | SB | 19-460 #1 |
| T104 | 2/25-12:30 | 87.5-88.7 | 2/26-9:00 | 88.7 | - | - | - | - | SB | ↓ |
| T105 | ↓ | 88.5 | ↓ | 88.3 | - | - | - | - | SB | ↓ |
| T106 | ↓ | 88.6 | ↓ | 88.5 | - | - | - | - | SB | ↓ |
| T107 | ↓ | 88.2 | ↓ | 88.1 | - | - | - | - | SB | ↓ |
| T108 | ↓ | 88.4 | ↓ | 88.4 | - | - | - | - | SB | ↓ |
| T109 | ↓ | 89.1 | ↓ | 89.2 | - | - | - | - | SB | ↓ |
| T110 | ↓ | 88.8 | ↓ | 88.9 | - | - | - | - | SB | ↓ |
| T111 | ↓ | 89.1 | 2/27-9:00 | 89.1 | - | - | - | - | SB | ↓ |
| T112 | ↓ | 89.3 | ↓ | 89.2 | - | - | - | - | SB | ↓ |
| T113 | ↓ | 88.8 | ↓ | 88.8 | - | - | - | - | SB | 19-460 #2 #1 |
| T114 | ↓ | 88.2 | ↓ | 88.3 | - | - | - | - | SB | 19-460 #2 |
| T115 | ↓ | 89.3 | ↓ | 89.3 | - | - | - | - | SB | ↓ |
| T116 | ↓ | 89.3 | ↓ | 89.3 | - | - | - | - | SB | ↓ |
| T117 | ↓ | 88.9 | ↓ | 89.0 | - | - | - | - | SB | ↓ |
| T118 | ↓ | 82.3 | ↓ | 82.2 | - | - | - | - | SB | ↓ |
| T119 | ↓ | 91.9 | ↓ | 91.9 | - | - | - | - | SB | ↓ |
| T120 | ↓ | 91.2 | ↓ | 91.1 | - | - | - | - | SB | ↓ |

Sample Post-Test Analysis Sheet: Probes

TX40 Filters

O-Rings

Balance ID#: 107 Audit Weight ID# / Weight (mg): 109A-100mg

| Sample ID | Tare (mg) | Date/Time in Desiccator | Date/Time | Weight (mg) | Date/Time | Weight (mg) | Date/Time | Weight (mg) | Date/Time | Weight (mg) | Tech. Initials |
|-----------|-----------|-------------------------|------------|--|-----------|------------------|------------------|-------------|-----------|-------------|----------------|
| T091 | 88.5 | 2/25-14:00 | 2/27-13:30 | 88.7 | 2/28-6:30 | 88.7 | - | - | - | - | SB |
| T092 | 89.0 | ↓ | ↓ | * weighed as set with T089 + T090 * | | _____ | | | | | SB |
| T093 | 87.4 | | | * weighed as pair with T088 * | | | | | | | SB |
| T094 | 87.5 | 2/27/19-7:30 | 3/1-10:00 | 190.6 | 3/4-8:00 | 190.5 | _____ | | | | SB |
| T095 | 87.2 | ↓ | | | | | | | | | SB |
| T096 | 87.8 | ↓ | | 183.5 | | 183.5 | _____ | | | | SB |
| T097 | 87.5 | ↓ | | ↓ | | ↓ | | ↓ | | SB | |
| T098 | 86.5 | ↓ | | 376.9 | | 377.0 | _____ | | | | SB |
| T099 | 87.6 | ↓ | | 87.8 | | 87.8 | _____ | | | | SB |
| T100 | 88.0 | ↓ | | * weighed as set with T097, T102, T098 * | | _____ | | | | | SB |
| T101 | 87.4 | ↓ | | * weighed as a pair with T096 * | | _____ | | | | | SB |
| T102 | 87.9 | ↓ | | * weighed as set with T097, T098, T100 * | | _____ | | | | | SB |
| T103 | 87.8 | 2/27/19-12:00 | | 363.1 | 3/4-8:00 | 363.0 | _____ | | | | SB |
| T104 | 88.7 | ↓ | | | | | | | | | SB |
| T105 | 88.3 | ↓ | | 178.9 | | 178.9 | _____ | | | | SB |
| T106 | 88.5 | ↓ | | ↓ | | ↓ | | ↓ | | SB | |
| T107 | 88.1 | ↓ | | 364.4 | | 364.2 | _____ | | | | SB |
| T108 | 88.4 | ↓ | | 88.5 | | 88.5 | _____ | | | | SB |
| T109 | 84.2 | ↓ | | * weighed as a set with T106, T07, and T111 * | | _____ | | | | | SB |
| T110 | 88.9 | ↓ | | * weighed as a set with T103, T104, and T112 * | | _____ | | | | | SB |
| T111 | 89.1 | ↓ | | * weighed as a set with T106, T107, and T109 * | | _____ | | | | | SB |
| T112 | 89.2 | ↓ | | * weighed as a set with T103, T104, and T110 * | | _____ | | | | | SB |
| T113 | 88.8 | ↓ | | * weighed as a pair with T105 * | | _____ | | | | | SB |
| T114 | 88.3 | 2/28-7:00 | | 90.7 | 3/4-8:00 | 90.7 | _____ | | | | SB |
| T115 | 89.3 | ↓ | | ↓ | | ↓ | | ↓ | | SB | |
| T116 | 89.3 | ↓ | | 190.3 | | 190.3 | _____ | | | | SB |
| T117 | 89.0 | ↓ | | ↓ | | ↓ | | ↓ | | SB | |
| T118 | 82.2 | ↓ | | 275.5 | | 275.5 | _____ | | | | SB |
| T119 | 91.9 | ↓ | | 92.0 | | 92.0 | _____ | | | | SB |
| T120 | 91.1 | ↓ | | * weighed as a set with T117 + T118 * | | _____ | | | | | SB |

Sample Pre-Test Tare Sheet: Probes

TX40 Filters

O-Rings

Date/Time In Desiccator: 2/22-16:00 Balance ID#: 107 Audit Weight ID# / Weight(mg): 109A-100mg

| Sample ID | Date/Time | Weight (mg) | Date/Time | Weight (mg) | Date/Time | Weight (mg) | Date/Time | Weight (mg) | Tech. Initials | Project/Run # |
|-----------|------------|-------------|-----------|-------------|-----------|-------------|-----------|-------------|----------------|---------------|
| T121 | 2/22-16:00 | 87.6 | 2/28-6:30 | 87.6 | - | - | - | - | SB | 19.460 #3 |
| T122 | | 88.4 | | 88.5 | - | - | - | - | SB | |
| T123 | | 87.3 | | 87.4 | - | - | - | - | SB | |
| T124 | | 87.5 | | 87.3 | - | - | - | - | SB | |
| T125 | | 87.1 | | 87.1 | - | - | - | - | SB | |
| T126 | | 87.8 | | 87.9 | - | - | - | - | SB | |
| T127 | | 88.9 | | 88.8 | - | - | - | - | SB | |
| T128 | | 88.9 | | 88.8 | - | - | - | - | SB | |
| T129 | | 88.5 | | 88.6 | - | - | - | - | SB | |
| T130 | | 89.7 | | 89.6 | - | - | - | - | SB | |
| T131 | | 88.8 | | 88.9 | - | - | - | - | SB | |
| T132 | | 88.2 | | 88.3 | - | - | - | - | SB | |
| T133 | | 87.5 | | 87.6 | - | - | - | - | SB | |
| T134 | | 86.7 | | 86.7 | - | - | - | - | SB | |
| T135 | | | | | | | | | | |
| T136 | | | | | | | | | | |
| T137 | | | | | | | | | | |
| T138 | | | | | | | | | | |
| T139 | | | | | | | | | | |
| T140 | | | | | | | | | | |
| T141 | | | | | | | | | | |
| T142 | | | | | | | | | | |
| T143 | | | | | | | | | | |
| T144 | | | | | | | | | | |
| T145 | | | | | | | | | | |
| T146 | | | | | | | | | | |
| T147 | | | | | | | | | | |
| T148 | | | | | | | | | | |
| T149 | | | | | | | | | | |
| T150 | | | | | | | | | | |

Sample Post-Test Analysis Sheet: Probes TX40 Filters O-Rings

Balance ID#: 107 Audit Weight ID# / Weight (mg): 109A-100mg

| Sample ID | Tare (mg) | Date/Time in Desiccator | Date/Time | Weight (mg) | Date/Time | Weight (mg) | Date/Time | Weight (mg) | Date/Time | Weight (mg) | Tech. Initials | |
|-----------|-----------|--------------------------------|-----------|-------------|-----------|-------------|-----------|-------------|-----------|-------------|----------------|----|
| T121 | 87.6 | 3/1-10:30 | 3/4-8:00 | > 180.8 | 3/5-8:00 | > 180.7 | - | - | - | - | SB | |
| T122 | 88.3 | ↓ | ↓ | 180.0 | ↓ | 177.9 | - | - | - | - | SB | |
| T123 | 87.4 | | | - | | - | - | - | - | - | - | SB |
| T124 | 87.3 | | | - | | - | - | - | - | - | - | SB |
| T125 | 87.1 | | | > 269.2 | | > 269.3 | - | - | - | - | - | SB |
| T126 | 87.9 | | | 88.0 | | 88.0 | - | - | - | - | - | SB |
| T127 | 88.8 | * weighed as a pair with T127* | | | | | | | | | SB | |
| T128 | 88.8 | * weighed as a pair with T123* | | | | | | | | | SB | |
| T129 | | | | | | | | | | | | |
| T130 | | | | | | | | | | | | |
| T131 | | | | | | | | | | | | |
| T132 | | | | | | | | | | | | |
| T133 | | | | | | | | | | | | |
| T134 | | | | | | | | | | | | |
| T135 | | | | | | | | | | | | |
| T136 | | | | | | | | | | | | |
| T137 | | | | | | | | | | | | |
| T138 | | | | | | | | | | | | |
| T139 | | | | | | | | | | | | |
| T140 | | | | | | | | | | | | |
| T141 | | | | | | | | | | | | |
| T142 | | | | | | | | | | | | |
| T143 | | | | | | | | | | | | |
| T144 | | | | | | | | | | | | |
| T145 | | | | | | | | | | | | |
| T146 | | | | | | | | | | | | |
| T147 | | | | | | | | | | | | |
| T148 | | | | | | | | | | | | |
| T149 | | | | | | | | | | | | |
| T150 | | | | | | | | | | | | |

Sample Pre-Test Tare Sheet: Probes

Filters

O-Rings

Date/Time In Desiccator: 1/17/19-8:00 Balance ID#: 107 Audit Weight ID# / Weight(mg): 109A/B - 100/200mg

| Sample ID | Date/Time | Weight (mg) | Date/Time | Weight (mg) | Date/Time | Weight (mg) | Date/Time | Weight (mg) | Tech. Initials | Project/Run # |
|-----------|------------|-------------|--------------|-------------|------------|-------------|-----------|-------------|----------------|---------------|
| 1A | 1/24-10:00 | 115627.8 | 1/24-8:00 | 115627.7 | - | - | - | - | JD | 18-447 #1 |
| 1B | | 115902.3 | | 115902.3 | - | - | - | - | SD | 18-447 #1 |
| 2A | | 116239.5 | | 116239.6 | - | - | - | - | SB | 18-447 #2 |
| 2B | | 116329.5 | | 116329.4 | - | - | - | - | SB | 18-447 #2 |
| 3A | | 116072.9 | | 116072.9 | - | - | - | - | JP | 18-447 #3 |
| 3B | | 116339.8 | | 116339.7 | - | - | - | - | JD | 18-447 #3 |
| 4A | | 116182.2 | 2/11/19-8:45 | 116182.3 | - | - | - | - | SB | 18-439 #1 |
| 4B | | 116365.2 | 2/1-8:45 | 116365.3 | - | - | - | - | SB | 18-439 #1 |
| 5A | 2/20-17:00 | 116768.2 | 2/21-13:00 | 116768.1 | - | - | - | - | SB | 19-460 #Ass.1 |
| 5B | | 116876.5 | | 116876.2 | 2/22-15:30 | 116876.1 | - | - | SB | 19-460 #Ass.1 |
| 6A | | 116543.9 | | 116543.8 | - | - | - | - | SB | 19-460 #Ass.2 |
| 6B | | 116117.0 | | 116116.9 | - | - | - | - | SB | 19-460 #Ass.2 |
| 7A | | 116739.9 | | 116739.9 | - | - | - | - | SB | 19-460 #1 |
| 7B | | 117287.7 | | 117287.7 | - | - | - | - | SB | 19-460 #1 |
| 8A | 2/26-15:00 | 116824.0 | 2/27-7:00 | 116824.1 | - | - | - | - | SB | 19-460 #2 |
| 8B | 2/26-15:00 | 116826.3 | 2/27-7:00 | 116826.1 | - | - | - | - | SB | 19-460 #2 |
| 9A | 2/26-15:00 | 116713.8 | 2/27-7:00 | 116713.6 | - | - | - | - | SB | 19-460 #3 |
| 9B | 2/26-15:00 | 117135.5 | 2/27-7:00 | 117135.4 | - | - | - | - | SB | 19-460 #3 |
| 10A | | | | | | | | | | |
| 10B | | | | | | | | | | |
| 11A | | | | | | | | | | |
| 11B | | | | | | | | | | |
| 12A | | | | | | | | | | |
| 12B | | | | | | | | | | |
| 13A | | | | | | | | | | |
| 13B | | | | | | | | | | |
| 14A | | | | | | | | | | |
| 14B | | | | | | | | | | |
| 15A | | | | | | | | | | |
| 15B | | | | | | | | | | |

Sample Post-Test Analysis Sheet: Probes

Filters

O-Rings

Balance ID#: 107 Audit Weight ID# / Weight (mg): 109A/B - 100/200mg

| Sample ID | Tare (mg) | Date/ Time in Desiccator | Date/ Time | Weight (mg) | Date/ Time | Weight (mg) | Date/ Time | Weight (mg) | Date/ Time | Weight (mg) | Tech. Initials |
|-----------|-----------|--------------------------|--------------|-------------|-------------|-------------|------------|-------------|------------|-------------|----------------|
| 1A | 115627.7 | 1/28 - 15:10 | 1/30 - 7:30 | 115628.7 | 1/31 - 8:00 | 115628.5 | - | - | - | - | SB |
| 1B | 115902.3 | 1/28 - 15:10 | 1/30 - 7:30 | 115903.0 | 1/31 - 8:00 | 115902.8 | - | - | - | - | SB |
| 2A | 116239.6 | 1/30 - 8:00 | 1/31 - 8:00 | 116239.8 | 2/1 - 8:45 | 116239.9 | - | - | - | - | SB |
| 2B | 116329.4 | 1/30 - 8:00 | 1/31 - 8:00 | 116329.9 | 2/1 - 8:45 | 116330.0 | - | - | - | - | SB |
| 3A | 116072.9 | 1/31 - 8:30 | 2/1 - 8:45 | 116073.4 | 2/2 - 7:30 | 116073.5 | - | - | - | - | SB |
| 3B | 116339.7 | 1/31 - 8:30 | 2/1 - 8:45 | 116340.1 | 2/2 - 7:30 | 116340.1 | - | - | - | - | SB |
| 4A | 116182.3 | 2/4 - 15:45 | 2/6 - 8:30 | 116182.4 | 2/7 - 8:00 | 116182.3 | - | - | - | - | SB |
| 4B | 116365.3 | 2/4 - 15:45 | 2/6 - 8:30 | 116365.1 | 2/7 - 8:00 | 116365.2 | - | - | - | - | SB |
| 5A | 116766.1 | 2/25 - 14:00 | 2/27 - 13:30 | 116768.7 | 2/28 - 6:30 | 116768.5 | - | - | - | - | SB |
| 5B | 116876.1 | 2/25 - 14:00 | 2/27 - 13:30 | 116876.2 | 2/28 - 6:30 | 116876.2 | - | - | - | - | SB |
| 6A | 116543.0 | 2/27 - 7:30 | 3/1 - 10:00 | 116544.4 | 3/4 - 8:00 | 116544.2 | - | - | - | - | SB |
| 6B | 116116.9 | 2/27 - 7:30 | 3/1 - 10:00 | 116117.6 | 3/4 - 8:00 | 116117.5 | - | - | - | - | SB |
| 7A | 116739.9 | 2/27 - 12:00 | 3/1 - 10:00 | 116740.2 | 3/4 - 8:00 | 116740.1 | - | - | - | - | SB |
| 7B | 117287.7 | 2/27 - 12:00 | 3/1 - 10:00 | 117287.9 | 3/4 - 8:00 | 117288.0 | - | - | - | - | SB |
| 8A | 116824.1 | 2/28 - 7:00 | 3/1 - 10:00 | 116824.3 | 3/4 - 8:00 | 116824.2 | - | - | - | - | SB |
| 8B | 116826.1 | 2/28 - 7:00 | 3/1 - 10:00 | 116826.1 | 3/4 - 8:00 | 116826.0 | - | - | - | - | SB |
| 9A | 116713.6 | 3/1 - 10:30 | 3/4 - 8:00 | 116713.6 | 3/5 - 8:00 | 116713.5 | - | - | - | - | SB |
| 9B | 117135.4 | 3/1 - 10:30 | 3/4 - 8:00 | 117135.4 | 3/5 - 8:00 | 117135.2 | - | - | - | - | SB |
| 10A | | | | | | | | | | | |
| 10B | | | | | | | | | | | |
| 11A | | | | | | | | | | | |
| 11B | | | | | | | | | | | |
| 12A | | | | | | | | | | | |
| 12B | | | | | | | | | | | |
| 13A | | | | | | | | | | | |
| 13B | | | | | | | | | | | |
| 14A | | | | | | | | | | | |
| 14B | | | | | | | | | | | |
| 15A | | | | | | | | | | | |
| 15B | | | | | | | | | | | |

Sample Pre-Test Tare Sheet: Probes

Filters

O-Rings

Date/Time In Desiccator: 1/17/2019 - 8:00 Balance ID#: 107 Audit Weight ID# / Weight(mg): 109B-200mg

| Sample ID | Date/Time | Weight (mg) | Date/Time | Weight (mg) | Date/Time | Weight (mg) | Date/Time | Weight (mg) | Tech. Initials | Project/Run # |
|-----------|------------|-------------|------------|-------------|-----------|-------------|-----------|-------------|----------------|----------------|
| 1A | 1/24-10:00 | 3562.0 | 1/24-16:30 | 3562.0 | - | - | - | - | SB | 18-447 #1 |
| 1B | ↓ | 3550.9 | ↓ | 3550.8 | - | - | - | - | SB | 18-447 #1 |
| 2A | ↓ | 3548.0 | ↓ | 3547.9 | - | - | - | - | SB | 18-447 #2 |
| 2B | ↓ | 3566.4 | ↓ | 3566.5 | - | - | - | - | SB | 18-447 #2 |
| 3A | ↓ | 3575.4 | ↓ | 3575.2 | - | - | - | - | SB | 18-447 #3 |
| 3B | ↓ | 3563.8 | ↓ | 3563.8 | - | - | - | - | SB | 18-447 #3 |
| 4A | ↓ | 3588.8 | 2/1-8:45 | 3588.4 | 2/2-7:30 | 3588.3 | - | - | SB | 18-439 #1 |
| 4B | ↓ | 3576.4 | 2/1-8:45 | 3575.7 | 2/2-7:30 | 3575.7 | - | - | SB | 18-439 #1 |
| 5A | 2/20-17:00 | 3529.7 | 2/21-13:00 | 3529.7 | - | - | - | - | SB | 19-460 # Ass.1 |
| 5B | ↓ | 3526.4 | ↓ | 3526.3 | - | - | - | - | SB | 19-460 # Ass.1 |
| 6A | ↓ | 3610.3 | ↓ | 3610.2 | - | - | - | - | SB | 19-460 # Ass.2 |
| 6B | ↓ | 3379.9 | ↓ | 3380.0 | - | - | - | - | SB | 19-460 # Ass.2 |
| 7A | ↓ | 3569.0 | ↓ | 3569.1 | - | - | - | - | SB | 19-460 #1 |
| 7B | ↓ | 3517.8 | ↓ | 3517.8 | - | - | - | - | SB | 19-460 #1 |
| 8A | 2/26-15:00 | 3547.0 | 2/27-7:00 | 3547.0 | - | - | - | - | SB | 19-460 #2 |
| 8B | ↓ | 3580.2 | ↓ | 3580.3 | - | - | - | - | SB | 19-460 #2 |
| 9A | ↓ | 3577.1 | ↓ | 3577.1 | - | - | - | - | SB | 19-460 #3 |
| 9B | ↓ | 3520.0 | ↓ | 3519.9 | - | - | - | - | SB | 19-460 #3 |
| 10A | | | | | | | | | | |
| 10B | | | | | | | | | | |
| 11A | | | | | | | | | | |
| 11B | | | | | | | | | | |
| 12A | | | | | | | | | | |
| 12B | | | | | | | | | | |
| 13A | | | | | | | | | | |
| 13B | | | | | | | | | | |
| 14A | | | | | | | | | | |
| 14B | | | | | | | | | | |
| 15A | | | | | | | | | | |
| 15B | | | | | | | | | | |

Sample Post-Test Analysis Sheet: Probes

Filters

O-Rings

Balance ID#: 107 Audit Weight ID# / Weight (mg): 109B-200mg

| Sample ID | Tare (mg) | Date/ Time in Desiccator | Date/ Time | Weight (mg) | Date/ Time | Weight (mg) | Date/ Time | Weight (mg) | Date/ Time | Weight (mg) | Tech. Initials |
|-----------|-----------|--------------------------|------------|-------------|------------|-------------|------------|-------------|------------|-------------|----------------|
| 1A | 3562.0 | 1/28-15:10 | 1/30-7:30 | 3562.3 | 1/31-8:00 | 3562.0 | 2/1-8:45 | 3562.0 | - | - | SB |
| 1B | 3550.8 | 1/28-15:10 | 1/30-7:30 | 3551.1 | 1/31-8:00 | 3550.9 | - | - | - | - | SB |
| 2A | 3547.9 | 1/30-8:00 | 1/31-8:00 | 3548.5 | 2/1-8:45 | 3548.2 | 2/2-7:30 | 3548.2 | - | - | SB |
| 2B | 3566.5 | 1/30-8:00 | 1/31-8:00 | 3566.8 | 2/1-8:45 | 3566.6 | - | - | - | - | SB |
| 3A | 3575.2 | 1/31-8:30 | 2/1-8:45 | 3575.9 | 2/2-7:30 | 3575.8 | - | - | - | - | SB |
| 3B | 3563.8 | 1/31-8:30 | 2/1-8:45 | 3564.0 | 2/2-7:30 | 3563.8 | - | - | - | - | SB |
| 4A | 3588.3 | 2/4-15:45 | 2/6-8:30 | 3588.4 | 2/7-8:00 | 3588.4 | - | - | - | - | SB |
| 4B | 3575.7 | 2/4-15:45 | 2/6-8:30 | 3576.1 | 2/7-8:00 | 3576.0 | - | - | - | - | SB |
| 5A | 3529.7 | 2/25-14:00 | 2/27-13:30 | 3529.9 | 2/28-6:30 | 3530.0 | - | - | - | - | SB |
| 5B | 3526.3 | 2/25-14:00 | 2/27-13:30 | 3527.0 | 2/28-6:30 | 3526.8 | - | - | - | - | SB |
| 6A | 3610.2 | 2/27-7:30 | 3/1-10:00 | 3611.0 | 3/4-8:00 | 3610.9 | - | - | - | - | SB |
| 6B | 3380.0 | 2/27-7:30 | | 3380.5 | 3/4-8:00 | 3380.5 | - | - | - | - | SB |
| 7A | 3569.1 | 2/27-12:00 | | 3569.2 | 3/4-8:00 | 3569.2 | - | - | - | - | SB |
| 7B | 3517.8 | 2/27-12:00 | | 3517.9 | 3/4-8:00 | 3517.9 | - | - | - | - | SB |
| 8A | 3547.0 | 2/28-7:00 | | 3547.2 | 3/4-8:00 | 3547.2 | - | - | - | - | SB |
| 8B | 3580.3 | 2/28-7:00 | | 3581.0 | 3/4-8:00 | 3581.1 | - | - | - | - | SB |
| 9A | 3577.1 | 3/1-10:30 | 3/4-8:00 | 3577.2 | 3/5-8:00 | 3577.2 | - | - | - | - | SB |
| 9B | 3519.9 | 3/1-10:30 | 3/4-8:00 | 3520.0 | 3/5-8:00 | 3520.1 | - | - | - | - | SB |
| 10A | | | | | | | | | | | |
| 10B | | | | | | | | | | | |
| 11A | | | | | | | | | | | |
| 11B | | | | | | | | | | | |
| 12A | | | | | | | | | | | |
| 12B | | | | | | | | | | | |
| 13A | | | | | | | | | | | |
| 13B | | | | | | | | | | | |
| 14A | | | | | | | | | | | |
| 14B | | | | | | | | | | | |
| 15A | | | | | | | | | | | |
| 15B | | | | | | | | | | | |

Sample Calculations – ASTM E3053 & E2515

Client: FPI
 Model: F2450
 Run: 2

Equations used to calculate the parameters listed below are described in this appendix. Sample calculations are provided for each equation. The raw data and printout results from a sample run are also provided for comparison to the sample calculations.

M_{Fdb} – Weight of test fuel load, dry basis, lb (kg)

M_{SUdb} – Weight of start-up fuel, dry basis, lb (kg)

M_{Kdb} - Weight of kindling, dry basis, lb (kg)

M_{FREHdb} - Total weight of all remaining fuel at end of high fire test run, lb (kg)

M_{TFBHdb} - Total weight of all fuel burned during high fire test run, lb (kg), dry basis

BR_H – Dry burn rate for high fire test run, from time when test fuel load is added to end of test run, lb/h (kg/h)

M_{TFBdb} - Total weight of fuel burned during low or medium fire test run, lb (kg), dry basis

BR - Dry burn rate for low and medium fire test runs, lb/h (kg/h)

V_s – Average gas velocity in the dilution tunnel, ft/sec

Q_{sd} – Average gas flow rate in dilution tunnel, dscf/hr

$V_{m(std)}$ – Volume of gas sampled, corrected to dry standard conditions, dscf

m_n – Total particulate matter collected, mg

C_s - Concentration of particulate matter in tunnel gas, dry basis, corrected to STP, g/dscf

E_T – Total particulate emissions, g

PR - Proportional rate variation

PM_{RH} - Particulate emission rate for high fire test run, g/hr

PM_{FH} - Particulate emission factor for high fire test run, g/dry kg of fuel burned

PM_R – Particulate emission rate for low or medium fire test run, g/hr

PM_F – Particulate emission factor for low or medium fire test run, g/dry kg of fuel burned

M_{Fldb} – Weight of test fuel load, dry basis, lb (kg)

ASTM E3053 equation (1)

$$M_{Fldb} = \sum((M_{FLnwb})(100/(100 + MC_{FLn})))$$

Where,

- M_{FLnwb} = Weight of each test fuel piece, n, in test fuel load per 8.4.1, wet basis, lb (kg)
- MC_{FLn} = Average fuel moisture of test fuel piece, n, in test fuel load, % dry basis
- n = individual test fuel pieces that comprise the test fuel load, as applicable.

Sample Calculation:

| n | M _{FLnwb} | MC _{FLn} | (M _{FLnwb})(100/(100 + MC _{FLn})) | |
|---------------------|--------------------|-------------------|---|-----------|
| 1 | 5.53 | 20.4 | 5.53 (100) / (100+ 20.4)) = | 4.59 |
| 2 | 5.18 | 22.8 | 5.18 (100) / (100+ 22.8)) = | 4.22 |
| 3 | 5.07 | 20.9 | 5.07 (100) / (100+ 20.9)) = | 4.19 |
| 4 | 3.70 | 21.9 | 3.7 (100) / (100+ 21.9)) = | 3.04 |
| 5 | 6.48 | 23.5 | 6.48 (100) / (100+ 23.5)) = | 5.25 |
| 6 | 0.00 | NA | N/A | - |
| 7 | 0.00 | | N/A | - |
| | | | SUM | 21.29 lbs |
| M _{Fldb} = | 21.29 | lbs | | |
| M _{Fldb} = | 9.66 | kg | | |

M_{SUdb} – Weight of start-up fuel, dry basis, lb (kg)

ASTM E3053 equation (2)

$$M_{SUdb} = (M_{SUwb}) \left(\frac{100}{100 + MC_{SU}} \right)$$

Where,

M_{SUwb} = Total weight of start-up fuel pieces, wet basis, lb (kg)

MC_{SU} = Average fuel moisture of the piece(s) from which start-up fuel was split, % dry basis

Sample Calculation:

M_{SUwb} = N/A - Applicable to High Fire Tests Only

MC_{SU} = N/A - Applicable to High Fire Tests Only

M_{SUdb} = N/A (100/(100+ N/A)

M_{SUdb} = **N/A** lbs

= **N/A** kg

M_{Kdb} - Weight of kindling, dry basis, lb (kg)

ASTM E3053 equation (3)

$$M_{Kdb} = (M_{Kwb}) \left(\frac{100}{100 + MC_K} \right)$$

Where,

M_{Kwb} = Weight of kindling per 8.5.6, wet basis, lb (kg);

MC_K = Average moisture of kindling (may be assumed 10%), % dry basis.

Sample calculation:

M_{Kwb} = N/A - Applicable to High Fire Tests Only

MC_K = N/A - Applicable to High Fire Tests Only

$$M_{Kdb} = N/A \left(\frac{100}{100 + N/A} \right)$$

M_{Kdb} = **N/A** lbs

= **N/A** kgs

M_{FREHdb} - Total weight of all remaining fuel at end of high fire test run, lb (kg)

ASTM E3053 equation (4)

$$M_{FREHdb} = M_{RSUBdb} + M_{FLEHdb}$$

Where,

M_{RSUBdb} = Weight of residual start-up fuel bed when high fire test load added, lb (kg)

M_{FLEHdb} = Weight of unburned portion of test fuel load at the end of the high fire test run, lb (kg)

Sample calculation:

M_{RSUBdb} = N/A - Applicable to High Fire Tests Only

M_{FLEHdb} = N/A - Applicable to High Fire Tests Only

$$M_{FREHdb} = N/A + N/A$$

$$M_{FREHdb} = \mathbf{N/A} \text{ lbs}$$

$$= \mathbf{N/A} \text{ kg}$$

M_{TFBHdb} - Total weight of all fuel burned during high fire test run, lb (kg), dry basis

ASTM E3053 equation (5)

$$M_{TFBHdb} = M_{Kdb} + M_{SUdb} + M_{FLdb} - M_{FREHdb}$$

Sample Calculation:

$$M_{Kdb} = N/A$$

$$M_{SUdb} = N/A$$

$$M_{FLdb} = N/A$$

$$M_{FREHdb} = N/A$$

$$M_{TFBHdb} = N/A + N/A + N/A - N/A$$

$$= \mathbf{N/A} \text{ lbs}$$

$$= \mathbf{N/A} \text{ kg}$$

BR_H – Dry burn rate for high fire test run, from time when test fuel load is added to end of test run, lb/h (kg/h)

ASTM E3053 equation (6)

$$BR_H = 60 (M_{FLdb} - M_{FLEHdb})/\theta_{H1}$$

Where,

θ_{H1} = Total duration of high fire test run, from time when test fuel load is added to end of test run, min.

Sample calculation:

M_{FLdb} = N/A - Applicable to High Fire Tests Only

M_{FLEHdb} = N/A - Applicable to High Fire Tests Only

θ_{H1} = N/A - Applicable to High Fire Tests Only

$$BR_H = \frac{60 (N/A - N/A)}{N/A}$$

BR_H = **N/A** lb/hr

= **N/A** kg/hr

M_{TFBdb} - Total weight of fuel burned during low or medium fire test run, lb (kg), dry basis
ASTM E3053 equation (7)

$$M_{TFBdb} = M_{FLdb} - M_{FREdb}$$

Where,

M_{FLdb} = Total weight of fuel burned during low or medium fire test run, lb (kg), dry basis

M_{FREdb} = Weight of remaining fuel at end of low or medium fire test run, lb (kg)

Sample Calculation:

$$M_{FLdb} = 21.29$$

$$M_{FREdb} = 0.00$$

$$\begin{aligned} M_{TFBdb} &= 21.29 - 0.00 \\ &= \mathbf{21.29} \text{ lbs} \\ &= \mathbf{9.66} \text{ kg} \end{aligned}$$

BR - Dry burn rate for low and medium fire test runs, lb/h (kg/h)

ASTM E3053 equation (8)

$$BR = \frac{60 M_{TFBdb}}{\theta}$$

Where,

θ = Total test run duration for low or medium fire test run, min.

Sample Calculation:

$$M_{TFBdb} = 21.29$$

$$\theta = 573$$

$$BR = \frac{60 \times 21.29}{573}$$

$$BR = \mathbf{2.23} \text{ lb/hr}$$

$$= \mathbf{1.01} \text{ kg/hr}$$

V_s – Average gas velocity in the dilution tunnel, ft/sec

ASTM E2515 equation (9)

$$V_s = F_p \times k_p \times C_p \times (\sqrt{\Delta P})_{avg} \times \sqrt{\frac{T_{s(avg)}}{P_s \times M_s}}$$

Where:

- F_p = Adjustment factor for pitot tube center point reading = $\frac{V_{strav}}{V_{scent}}$, ASTM E2515 Equation (1)
 V_{scent} = Dilution tunnel velocity calculated after the multi-point pitot traverse at the center, ft/sec
 V_{strav} = Dilution tunnel velocity calculated after the multi-point pitot traverse, ft/sec
 k_p = Pitot tube constant, 85.49
 C_p = Pitot tube coefficient: 0.99, unitless
 ΔP^* = Velocity pressure in the dilution tunnel, in H₂O
 T_s = Absolute average gas temperature in the dilution tunnel, °R; (°R = °F + 460)
 P_s = Absolute average gas static pressure in dilution tunnel, = $P_{bar} + P_g$, in Hg
 P_{bar} = Barometric pressure at test site, in. Hg
 P_g = Static pressure of tunnel, in. H₂O; (in Hg = in H₂O/13.6)
 M_s = **The dilution tunnel wet molecular weight; $M_s = 28.78$ assuming a dry weight of 29 lb/lb-mole

Sample calculation:

$$F_p = \frac{16.04}{17.85} = 0.899$$

$$V_s = 0.899 \times 85.49 \times 0.99 \times 0.265 \times \left(\frac{97.3 + 460}{\left(29.77 + \frac{-0.20}{13.6} \right) \times 28.78} \right)^{1/2}$$

$$V_s = \mathbf{16.24 \text{ ft/s}}$$

*The ASTM test standard mistakenly has the square root of the average delta p instead of the average of the square root of delta p. The current EPA Method 2 is also incorrect. This was verified by Mike Toney at EPA.

**The ASTM test standard mistakenly identifies M_s as the dry molecular weight. It should be the wet molecular weight as indicated in EPA Method 2.

Q_{sd} – Average gas flow rate in dilution tunnel, dscf/hr

ASTM E2515 equation (3)

$$Q_{sd} = 3600 \times (1 - B_{ws}) \times v_s \times A \times \frac{T_{std}}{T_{s(avg)}} \times \frac{P_s}{P_{std}}$$

Where:

- 3600 = Conversion from seconds to hours (ASTM method uses 60 to convert in minutes)
- B_{ws} = Water vapor in gas stream, proportion by volume; assume 2%
- A = Cross sectional area of dilution tunnel, ft²
- T_{std} = Standard absolute temperature, 528 °R
- P_s = Absolute average gas static pressure in dilution tunnel, = P_{bar} + P_g, in Hg
- T_{s(avg)} = Absolute average gas temperature in the dilution tunnel, °R; (°R = °F + 460)
- P_{std} = Standard absolute pressure, 29.92 in Hg

Sample calculation:

$$Q_{sd} = 3600 \times (1 - 0.02) \times 16.24 \times 0.1963 \times \frac{528}{97.3 + 460} \times \frac{29.77 + \frac{-0.20}{13.6}}{29.92}$$

Q_{sd} = **10596.8** dscf/hr

$V_{m(std)}$ – Volume of Gas Sampled Corrected to Dry Standard Conditions, dscf
 ASTM E2515 equation (6)

$$V_{m(std)} = K_1 V_m Y \frac{P_{bar} + \frac{\Delta H}{13.6}}{T_m}$$

Where:

- K_1 = 17.64 °R/in. Hg
- V_m = Volume of gas sample measured at the dry gas meter, dcf
- Y = Dry gas meter calibration factor, dimensionless
- P_{bar} = Barometric pressure at the testing site, in. Hg
- ΔH = Average pressure differential across the orifice meter, in. H₂O
- T_m = Absolute average dry gas meter temperature, °R

Sample Calculation:

Using equation for Train 1:

$$V_{m(std)} = 17.64 \times 88.189 \times 1.004 \times \frac{(29.77 + \frac{2.31}{13.6})}{(103.1 + 460)}$$

$V_{m(std)} = \mathbf{83.051}$ dscf

Using equation for Train 2:

$$V_{m(std)} = 17.64 \times 86.702 \times 1 \times \frac{(29.77 + \frac{2.29}{13.6})}{(##### + 460)}$$

$V_{m(std)} = \mathbf{81.434}$ dscf

Using equation for ambient train:

$$V_{m(std)} = 17.64 \times 69.31 \times 0.999 \times \frac{(29.77 + \frac{0.00}{13.6})}{(74.9 + 460)}$$

$V_{m(std)} = \mathbf{67.977}$ dscf

m_n – Total Particulate Matter Collected, mg

ASTM E2515 Equation (12)

$$m_n = m_p + m_f + m_g$$

Where:

m_p = mass of particulate matter from probe, mg

m_f = mass of particulate matter from filters, mg

m_g = mass of particulate matter from filter seals, mg

Sample Calculation:

Using equation for Train A (first hour):

$$m_n = 0.0 + 2.4 + 0.0$$

$$m_n = 2.4 \text{ mg}$$

Using equation for Train A (post-first hour):

$$m_n = 0.1 + 11.7 + 0.2$$

$$m_n = 12.0 \text{ mg}$$

Train A aggregate:

$$m_n = 2.4 + 12.0$$

$$m_n = \mathbf{14.4 \text{ mg}}$$

Using equation for Train B:

$$m_n = 0 + 13.2 + 0.8$$

$$m_n = \mathbf{14.0 \text{ mg}}$$

C_s - Concentration of particulate matter in tunnel gas, dry basis, corrected to STP, g/dscf
ASTM E2515 equation (13)

$$C_s = K_2 \times \frac{m_n}{V_{m(\text{std})}}$$

Where:

- K₂ = Constant, 0.001 g/mg
- m_n = Total mass of particulate matter collected in the sampling train, mg
- V_{m(std)} = Volume of gas sampled corrected to dry standard conditions, dscf

Sample calculation:

For Train 1:

$$C_s = 0.001 \times \frac{14.4}{83.05}$$

$$C_s = \mathbf{0.00017} \text{ g/dscf}$$

For Train 2

$$C_s = 0.001 \times \frac{14.0}{81.43}$$

$$C_s = \mathbf{0.00017} \text{ g/dscf}$$

For Ambient Train

$$C_r = 0.001 \times \frac{0.1}{67.98}$$

$$C_r = \mathbf{0.000001} \text{ g/dscf}$$

E_T – Total Particulate Emissions, g

ASTM E2515 equation (15)

$$E_T = (C_s - C_r) \times Q_{std} \times \theta$$

Where:

- C_s = Concentration of particulate matter in tunnel gas, g/dscf
- C_r = Concentration particulate matter room air, g/dscf
- Q_{std} = Average dilution tunnel gas flow rate, dscf/hr
- θ = Total time of test run, minutes

Sample calculation:

For Train 1

$$E_T = (0.000173 - 0.000001) \times 10596.8 \times 573 /60$$

$$E_T = \mathbf{17.40} \text{ g}$$

For Train 2

$$E_T = (0.000172 - 0.000001) \times 10596.8 \times 573 /60$$

$$E_T = \mathbf{17.25} \text{ g}$$

Average

$$E = \mathbf{17.32} \text{ g}$$

Total emission values shall not differ by more than 7.5% from the total average emissions

$$7.5\% \text{ of the average} = 1.30$$

$$\text{Train 1 difference} = 0.07$$

$$\text{Train 2 difference} = 0.07$$

PR - Proportional Rate Variation

ASTM E2515 equation (16)

$$PR = \left[\frac{\theta \times V_{mi} \times V_s \times T_m \times T_{si}}{\theta_i \times V_m \times V_{si} \times T_{mi} \times T_s} \right] \times 100$$

Where:

- θ = Total sampling time, min
- θ_i = Length of recording interval, min
- V_{mi} = Volume of gas sample measured by the dry gas meter during the "ith" time interval, dcf
- V_m = Volume of gas sample as measured by dry gas meter, dcf
- V_{si} = Average gas velocity in the dilution tunnel during the "ith" time interval, ft/sec
- V_s = Average gas velocity in the dilution tunnel, ft/sec
- T_{mi} = Absolute average dry gas meter temperature during the "ith" time interval, °R
- T_m = Absolute average dry gas meter temperature, °R
- T_{si} = Absolute average gas temperature in the dilution tunnel during the "ith" time interval, °R
- T_s = Absolute average gas temperature in the dilution tunnel, °R

Sample calculation (for the first 1 minute interval of Train 1):

$$PR = \left(\frac{573 \times 0.15 \times 16.24 \times (130.0 + 460) \times (#### + 460)}{1 \times 88.189 \times 16.70 \times (97.3 + 460) \times (#### + 460)} \right) \times 100$$

PR = **101** %

PM_{RH} - Particulate emission rate for high fire test run, g/hr;
ASTM E3053 equation (9)

$$PM_{RH} = 60(E_{TH}/\theta_{H2})$$

Where,

- E_{TH} = Total particulate emissions for high fire test run including kindling and start-up, g
- θ_{H2} = Total duration of high fire test run, from ignition of kindling to end of test run, min.

Sample Calculation:

- E_{TH} = N/A - Applicable to High Fire Tests Only
- θ_{H2} = N/A - Applicable to High Fire Tests Only

$$PM_{RH} = 60(N/A / N/A)$$

$$PM_{RH} = \mathbf{N/A} \text{ g/hr}$$

PM_{FH} - Particulate emission factor for high fire test run, g/dry kg of fuel burned.
ASTM E3053 equation (10)

$$PM_{FH} = E_{TH}/M_{TFBHdb}$$

Sample Calculation:

- E_{TH} = N/A - Applicable to High Fire Tests Only
- M_{TFBHdb} = N/A - Applicable to High Fire Tests Only

$$PM_{FH} = N/A / N/A$$
$$= \mathbf{N/A} \text{ g/kg}$$

PM_R - Particulate emission rate for low or medium fire test runs, g/hr

ASTM E3053 equation (12)

$$PM_R = 60(E_T/\theta)$$

Where,

E_T = Total particulate emissions for low or medium fire test runs from Test Method E2515, g

Sample Calculation:

$$E_T = 17.32$$

$$\theta = 573$$

$$PM_R = 60(17.32 / 573)$$

$$PM_{RH} = 1.81 \text{ g/hr}$$

PM_{FH} - Particulate emission factor for high fire test run, g/dry kg of fuel burned.

ASTM E3053 equation (13)

$$PM_F = E_T/M_{TFBdb}$$

Sample Calculation:

$$E_T = 17.32$$

$$M_{TFBdb} = 9.66$$

$$PM_{FH} = 17.32 / 9.66$$
$$= 1.79 \text{ g/kg}$$

Sample Calculations – ASTM E3053 & E2515

Client: FPI
 Model: F2450
 Run: 1

Equations used to calculate the parameters listed below are described in this appendix. Sample calculations are provided for each equation. The raw data and printout results from a sample run are also provided for comparison to the sample calculations.

M_{Fdb} – Weight of test fuel load, dry basis, lb (kg)

M_{SUdb} – Weight of start-up fuel, dry basis, lb (kg)

M_{Kdb} - Weight of kindling, dry basis, lb (kg)

M_{FREHdb} - Total weight of all remaining fuel at end of high fire test run, lb (kg)

M_{TFBHdb} - Total weight of all fuel burned during high fire test run, lb (kg), dry basis

BR_H – Dry burn rate for high fire test run, from time when test fuel load is added to end of test run, lb/h (kg/h)

M_{TFBdb} - Total weight of fuel burned during low or medium fire test run, lb (kg), dry basis

BR - Dry burn rate for low and medium fire test runs, lb/h (kg/h)

V_s – Average gas velocity in the dilution tunnel, ft/sec

Q_{sd} – Average gas flow rate in dilution tunnel, dscf/hr

$V_{m(std)}$ – Volume of gas sampled, corrected to dry standard conditions, dscf

m_n – Total particulate matter collected, mg

C_s - Concentration of particulate matter in tunnel gas, dry basis, corrected to STP, g/dscf

E_T – Total particulate emissions, g

PR - Proportional rate variation

PM_{RH} - Particulate emission rate for high fire test run, g/hr

PM_{FH} - Particulate emission factor for high fire test run, g/dry kg of fuel burned

PM_R – Particulate emission rate for low or medium fire test run, g/hr

PM_F – Particulate emission factor for low or medium fire test run, g/dry kg of fuel burned

M_{Fldb} – Weight of test fuel load, dry basis, lb (kg)

ASTM E3053 equation (1)

$$M_{Fldb} = \Sigma((M_{FLnwb})(100/(100 + MC_{FLn})))$$

Where,

- M_{FLnwb} = Weight of each test fuel piece, n, in test fuel load per 8.4.1, wet basis, lb (kg)
- MC_{FLn} = Average fuel moisture of test fuel piece, n, in test fuel load, % dry basis
- n = individual test fuel pieces that comprise the test fuel load, as applicable.

Sample Calculation:

| n | M _{FLnwb} | MC _{FLn} | (M _{FLnwb})(100/(100 + MC _{FLn})) | |
|---------------------|--------------------|-------------------|---|-----------|
| 1 | 3.44 | 22.8 | 3.44 (100) / (100+ 22.8)) = | 2.80 |
| 2 | 4.32 | 21.5 | 4.32 (100) / (100+ 21.5)) = | 3.56 |
| 3 | 4.61 | 19.3 | 4.61 (100) / (100+ 19.3)) = | 3.87 |
| 4 | 3.22 | 19.2 | 3.22 (100) / (100+ 19.2)) = | 2.70 |
| 5 | 2.25 | 24.4 | 2.25 (100) / (100+ 24.4)) = | 1.81 |
| 6 | 3.53 | 18.9 | 3.53 (100) / (100+ 18.9)) = | 2.97 |
| 7 | N/A | N/A | N/A | - |
| | | | SUM | 17.70 lbs |
| M _{Fldb} = | 17.70 | lbs | | |
| M _{Fldb} = | 8.03 | kg | | |

M_{SUdb} – Weight of start-up fuel, dry basis, lb (kg)

ASTM E3053 equation (2)

$$M_{SUdb} = (M_{SUwb}) \left(\frac{100}{100 + MC_{SU}} \right)$$

Where,

M_{SUwb} = Total weight of start-up fuel pieces, wet basis, lb (kg)

MC_{SU} = Average fuel moisture of the piece(s) from which start-up fuel was split, % dry basis

Sample Calculation:

$$M_{SUwb} = 4.19$$

$$MC_{SU} = 20.1$$

$$M_{SUdb} = 4.2 \left(\frac{100}{100 + 20.1} \right)$$

$$M_{SUdb} = \mathbf{3.49} \text{ lbs}$$

$$= \mathbf{1.58} \text{ kg}$$

M_{Kdb} - Weight of kindling, dry basis, lb (kg)

ASTM E3053 equation (3)

$$M_{Kdb} = (M_{Kwb}) \left(\frac{100}{100 + MC_K} \right)$$

Where,

M_{Kwb} = Weight of kindling per 8.5.6, wet basis, lb (kg);

MC_K = Average moisture of kindling (may be assumed 10%), % dry basis.

Sample calculation:

$$M_{Kwb} = 3.02$$

$$MC_K = 10.0$$

$$M_{Kdb} = 3.02 \left(\frac{100}{100 + 10.0} \right)$$

$$M_{Kdb} = \mathbf{2.75} \text{ lbs}$$

$$= \mathbf{1.25} \text{ kgs}$$

M_{FREHdb} - Total weight of all remaining fuel at end of high fire test run, lb (kg)

ASTM E3053 equation (4)

$$M_{\text{FREHdb}} = M_{\text{RSUBdb}} + M_{\text{FLEHdb}}$$

Where,

M_{RSUBdb} = Weight of residual start-up fuel bed when high fire test load added, lb (kg)

M_{FLEHdb} = Weight of unburned portion of test fuel load at the end of the high fire test run, lb (kg)

Sample calculation:

$$M_{\text{RSUBdb}} = 2.2$$

$$M_{\text{FLEHdb}} = 2.1$$

$$M_{\text{FREHdb}} = 2.20 + 2.1$$

$$M_{\text{FREHdb}} = \mathbf{4.30} \text{ lbs}$$

$$= \mathbf{1.95} \text{ kg}$$

M_{TFBHdb} - Total weight of all fuel burned during high fire test run, lb (kg), dry basis

ASTM E3053 equation (5)

$$M_{\text{TFBHdb}} = M_{\text{Kdb}} + M_{\text{SUdb}} + M_{\text{FLdb}} - M_{\text{FREHdb}}$$

Sample Calculation:

$$M_{\text{Kdb}} = 2.75$$

$$M_{\text{SUdb}} = 3.49$$

$$M_{\text{FLdb}} = 17.70$$

$$M_{\text{FREHdb}} = 4.30$$

$$M_{\text{TFBHdb}} = 2.75 + 3.49 + 17.70 - 4.30$$

$$= \mathbf{19.64} \text{ lbs}$$

$$= \mathbf{8.91} \text{ kg}$$

BR_H – Dry burn rate for high fire test run, from time when test fuel load is added to end of test run, lb/h (kg/h)

ASTM E3053 equation (6)

$$BR_H = 60 (M_{FLdb} - M_{FLEHdb})/\theta_{H1}$$

Where,

θ_{H1} = Total duration of high fire test run, from time when test fuel load is added to end of test run, min.

Sample calculation:

$$\begin{aligned} M_{FLdb} &= 17.70 \\ M_{FLEHdb} &= 2.10 \\ \theta_{H1} &= 97 \end{aligned}$$

$$BR_H = \frac{60 (17.70 - 2.10)}{97}$$

$$\begin{aligned} BR_H &= \mathbf{9.65} \text{ lb/hr} \\ &= \mathbf{4.38} \text{ kg/hr} \end{aligned}$$

M_{TFBdb} - Total weight of fuel burned during low or medium fire test run, lb (kg), dry basis
ASTM E3053 equation (7)

$$M_{TFBdb} = M_{FLdb} - M_{FREdb}$$

Where,

M_{FLdb} = Total weight of fuel burned during low or medium fire test run, lb (kg), dry basis

M_{FREdb} = Weight of remaining fuel at end of low or medium fire test run, lb (kg)

Sample Calculation:

M_{FLdb} = N/A - Applicable to Low/Medium Fire Tests Only

M_{FREdb} = N/A - Applicable to Low/Medium Fire Tests Only

$$\begin{aligned} M_{TFBdb} &= \text{N/A} - \text{N/A} \\ &= \text{N/A} \quad \text{lbs} \\ &= \text{N/A} \quad \text{kg} \end{aligned}$$

BR - Dry burn rate for low and medium fire test runs, lb/h (kg/h)

ASTM E3053 equation (8)

$$BR = \frac{60 M_{TFBdb}}{\theta}$$

Where,

θ = Total test run duration for low or medium fire test run, min.

Sample Calculation:

M_{TFBdb} = N/A - Applicable to Low/Medium Fire Tests Only

θ = N/A - Applicable to Low/Medium Fire Tests Only

$$BR = \frac{60 \times N/A}{N/A}$$

BR = **N/A** lb/hr

= **N/A** kg/hr

V_s – Average gas velocity in the dilution tunnel, ft/sec

ASTM E2515 equation (9)

$$V_s = F_p \times k_p \times C_p \times (\sqrt{\Delta P})_{avg} \times \sqrt{\frac{T_{s(avg)}}{P_s \times M_s}}$$

Where:

- F_p = Adjustment factor for pitot tube center point reading = $\frac{V_{strav}}{V_{scent}}$, ASTM E2515 Equation (1)
 V_{scent} = Dilution tunnel velocity calculated after the multi-point pitot traverse at the center, ft/sec
 V_{strav} = Dilution tunnel velocity calculated after the multi-point pitot traverse, ft/sec
 k_p = Pitot tube constant, 85.49
 C_p = Pitot tube coefficient: 0.99, unitless
 ΔP^* = Velocity pressure in the dilution tunnel, in H₂O
 T_s = Absolute average gas temperature in the dilution tunnel, °R; (°R = °F + 460)
 P_s = Absolute average gas static pressure in dilution tunnel, = $P_{bar} + P_g$, in Hg
 P_{bar} = Barometric pressure at test site, in. Hg
 P_g = Static pressure of tunnel, in. H₂O; (in Hg = in H₂O/13.6)
 M_s = **The dilution tunnel wet molecular weight; $M_s = 28.78$ assuming a dry weight of 29 lb/lb-mole

Sample calculation:

$$F_p = \frac{16.07}{17.88} = 0.899$$

$$V_s = 0.899 \times 85.49 \times 0.99 \times 0.265 \times \left(\frac{134.0 + 460}{\left(\frac{29.78 + \frac{-0.20}{13.6}}{28.78} \right)^{1/2}} \right)$$

$$V_s = \mathbf{16.76 \text{ ft/s}}$$

*The ASTM test standard mistakenly has the square root of the average delta p instead of the average of the square root of delta p. The current EPA Method 2 is also incorrect. This was verified by Mike Toney at EPA.

**The ASTM test standard mistakenly identifies M_s as the dry molecular weight. It should be the wet molecular weight as indicated in EPA Method 2.

Q_{sd} – Average gas flow rate in dilution tunnel, dscf/hr

ASTM E2515 equation (3)

$$Q_{sd} = 3600 \times (1 - B_{ws}) \times v_s \times A \times \frac{T_{std}}{T_{s(avg)}} \times \frac{P_s}{P_{std}}$$

Where:

- 3600 = Conversion from seconds to hours (ASTM method uses 60 to convert in minutes)
- B_{ws} = Water vapor in gas stream, proportion by volume; assume 2%
- A = Cross sectional area of dilution tunnel, ft²
- T_{std} = Standard absolute temperature, 528 °R
- P_s = Absolute average gas static pressure in dilution tunnel, = P_{bar} + P_g, in Hg
- T_{s(avg)} = Absolute average gas temperature in the dilution tunnel, °R; (°R = °F + 460)
- P_{std} = Standard absolute pressure, 29.92 in Hg

Sample calculation:

$$Q_{sd} = 3600 \times (1 - 0.02) \times 16.76 \times 0.1963 \times \frac{528}{134.0 + 460} \times \frac{29.78 + \frac{-0.20}{13.6}}{29.92}$$

Q_{sd} = **10264.9** dscf/hr

$V_{m(std)}$ – Volume of Gas Sampled Corrected to Dry Standard Conditions, dscf
 ASTM E2515 equation (6)

$$V_{m(std)} = K_1 V_m Y \frac{P_{bar} + \frac{\Delta H}{13.6}}{T_m}$$

Where:

- K_1 = 17.64 °R/in. Hg
- V_m = Volume of gas sample measured at the dry gas meter, dcf
- Y = Dry gas meter calibration factor, dimensionless
- P_{bar} = Barometric pressure at the testing site, in. Hg
- ΔH = Average pressure differential across the orifice meter, in. H₂O
- T_m = Absolute average dry gas meter temperature, °R

Sample Calculation:

Using equation for Train 1:

$$V_{m(std)} = 17.64 \times 18.725 \times 1.004 \times \frac{(29.78 + \frac{2.26}{13.6})}{(91.7 + 460)}$$

$V_{m(std)} = \mathbf{17.999}$ dscf

Using equation for Train 2:

$$V_{m(std)} = 17.64 \times 18.214 \times 1 \times \frac{(29.78 + \frac{2.20}{13.6})}{(91.2 + 460)}$$

$V_{m(std)} = \mathbf{17.452}$ dscf

Using equation for ambient train:

$$V_{m(std)} = 17.64 \times 15.01 \times 0.999 \times \frac{(29.78 + \frac{0.00}{13.6})}{(73.9 + 460)}$$

$V_{m(std)} = \mathbf{14.747}$ dscf

m_n – Total Particulate Matter Collected, mg

ASTM E2515 Equation (12)

$$m_n = m_p + m_f + m_g$$

Where:

m_p = mass of particulate matter from probe, mg

m_f = mass of particulate matter from filters, mg

m_g = mass of particulate matter from filter seals, mg

Sample Calculation:

Using equation for Train A (first hour):

$$m_n = 0.0 + 8.4 + 0.0$$

$$m_n = 8.4 \text{ mg}$$

Using equation for Train A (post-first hour):

$$m_n = 0.2 + 1.8 + 0.1$$

$$m_n = 2.1 \text{ mg}$$

Train A aggregate:

$$m_n = 8.4 + 2.1$$

$$m_n = \mathbf{10.5} \text{ mg}$$

Using equation for Train B:

$$m_n = 0.3 + 9.3 + 0.1$$

$$m_n = \mathbf{9.7} \text{ mg}$$

C_s - Concentration of particulate matter in tunnel gas, dry basis, corrected to STP, g/dscf
ASTM E2515 equation (13)

$$C_s = K_2 \times \frac{m_n}{V_{m(std)}}$$

Where:

- K₂ = Constant, 0.001 g/mg
- m_n = Total mass of particulate matter collected in the sampling train, mg
- V_{m(std)} = Volume of gas sampled corrected to dry standard conditions, dscf

Sample calculation:

For Train 1:

$$C_s = 0.001 \times \frac{10.5}{18.00}$$

$$C_s = \mathbf{0.00058} \text{ g/dscf}$$

For Train 2

$$C_s = 0.001 \times \frac{9.7}{17.45}$$

$$C_s = \mathbf{0.00056} \text{ g/dscf}$$

For Ambient Train

$$C_r = 0.001 \times \frac{0.1}{14.75}$$

$$C_r = \mathbf{0.000007} \text{ g/dscf}$$

E_T – Total Particulate Emissions, g

ASTM E2515 equation (15)

$$E_T = (C_s - C_r) \times Q_{std} \times \theta$$

Where:

- C_s = Concentration of particulate matter in tunnel gas, g/dscf
- C_r = Concentration particulate matter room air, g/dscf
- Q_{std} = Average dilution tunnel gas flow rate, dscf/hr
- θ = Total time of test run, minutes

Sample calculation:

For Train 1

$$E_T = (0.000583 - 0.000007) \times 10264.9 \times 124 /60$$

$$E_T = \mathbf{12.23} \text{ g}$$

For Train 2

$$E_T = (0.000556 - 0.000007) \times 10264.9 \times 124 /60$$

$$E_T = \mathbf{11.65} \text{ g}$$

Average

$$E = \mathbf{11.94} \text{ g}$$

Total emission values shall not differ by more than 7.5% from the total average emissions

$$7.5\% \text{ of the average} = 0.90$$

$$\text{Train 1 difference} = 0.29$$

$$\text{Train 2 difference} = 0.29$$

PR - Proportional Rate Variation

ASTM E2515 equation (16)

$$PR = \left[\frac{\theta \times V_{mi} \times V_s \times T_m \times T_{si}}{\theta_i \times V_m \times V_{si} \times T_{mi} \times T_s} \right] \times 100$$

Where:

- θ = Total sampling time, min
- θ_i = Length of recording interval, min
- V_{mi} = Volume of gas sample measured by the dry gas meter during the "ith" time interval, dcf
- V_m = Volume of gas sample as measured by dry gas meter, dcf
- V_{si} = Average gas velocity in the dilution tunnel during the "ith" time interval, ft/sec
- V_s = Average gas velocity in the dilution tunnel, ft/sec
- T_{mi} = Absolute average dry gas meter temperature during the "ith" time interval, °R
- T_m = Absolute average dry gas meter temperature, °R
- T_{si} = Absolute average gas temperature in the dilution tunnel during the "ith" time interval, °R
- T_s = Absolute average gas temperature in the dilution tunnel, °R

Sample calculation (for the first 1 minute interval of Train 1):

$$PR = \left(\frac{124 \times 0.112 \times 16.76 \times (92.0 + 460) \times (91.7 + 460)}{1 \times 18.725 \times 16.16 \times (134.0 + 460) \times (79.0 + 460)} \right) \times 100$$

PR = 73 %

PM_{RH} - Particulate emission rate for high fire test run, g/hr;

ASTM E3053 equation (9)

$$PM_{RH} = 60(E_{TH}/\theta_{H2})$$

Where,

E_{TH} = Total particulate emissions for high fire test run including kindling and start-up, g

θ_{H2} = Total duration of high fire test run, from ignition of kindling to end of test run, min.

Sample Calculation:

$$E_{TH} = 11.94$$

$$\theta_{H2} = 124$$

$$PM_{RH} = 60(11.94 / 124)$$

$$PM_{RH} = 5.78 \text{ g/hr}$$

PM_{FH} - Particulate emission factor for high fire test run, g/dry kg of fuel burned.

ASTM E3053 equation (10)

$$PM_{FH} = E_{TH}/M_{TFBHdb}$$

Sample Calculation:

$$E_{TH} = 11.94$$

$$M_{TFBHdb} = 8.91$$

$$PM_{FH} = 11.94 / 8.91$$

$$= 1.34 \text{ g/kg}$$

PM_R - Particulate emission rate for low or medium fire test runs, g/hr

ASTM E3053 equation (12)

$$PM_R = 60(E_T/\theta)$$

Where,

E_T = Total particulate emissions for low or medium fire test runs from Test Method E2515, g

Sample Calculation:

E_T = N/A - Applicable to Low/Medium Fire Tests Only

θ = N/A - Applicable to Low/Medium Fire Tests Only

$$PM_R = 60(N/A / N/A)$$

$$PM_{RH} = N/A \text{ g/hr}$$

PM_{FH} - Particulate emission factor for high fire test run, g/dry kg of fuel burned.

ASTM E3053 equation (13)

$$PM_F = E_T/M_{TFBdb}$$

Sample Calculation:

E_T = N/A - Applicable to Low/Medium Fire Tests Only

M_{TFBdb} = N/A - Applicable to Low/Medium Fire Tests Only

$$PM_{FH} = N/A / N/A$$
$$= N/A \text{ g/kg}$$



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
RESEARCH TRIANGLE PARK, NC 27711

FEB 28 2018

Mr. Justin White
Hearthstone QHPP, Inc.
#17 Stafford Ave.
Morrisville, VT 05661

OFFICE OF
AIR QUALITY PLANNING
AND STANDARDS

Dear Mr. White,

I am writing in response to your letter dated January 12, 2018, regarding wood heaters manufactured by Hearthstone QHPP, Inc. (Hearthstone). This response, dated February 28, 2018, supercedes our previous response (dated February 26, 2018) to correct an inaccuracy regarding required changes to ASTM E3053-17.

You are requesting to use an alternative test method, using cord wood, as referenced in section 60.532(c) of 40 CFR part 60, Subpart AAA, Standards of Performance for New Residential Wood Heaters (Subpart AAA) to meet the 2020 cord wood alternative compliance option. The 2020 cord wood alternative compliance option states that each affected wood heater manufactured or sold at retail for use in the United States on or after May 15, 2020, must not discharge into the atmosphere any gases that contain particulate matter in excess of 2.5 g/hr. Compliance must be determined by a cord wood test method approved by the Administrator along with the procedures in 40 CFR 60.534. You have requested approval to use the procedures and specifications found in ASTM Method E3053-17, a cord wood test method titled, "Standard Test Method for Determining Particulate Matter Emissions from Wood Heaters using Cordwood Test Fuel," in conjunction with ASTM E2515-11 and Canadian Standards Administration (CSA) Method CSA-B415.1-10, which are specified in 40 CFR 60.534.

We understand that Hearthstone is also requesting that the alternative method proposed above be approved to apply broadly to all wood heaters manufactured by Hearthstone meeting the requirements of Subpart AAA, from the approval date of this request until such time that Subpart AAA is revised or replaced to require a different cord wood certification method, providing all requirements of section 60.533 of Subpart AAA are met.

With the caveats set forth below, we approve your alternative test method request for certifying wood heaters using ASTM E3053-17 in conjunction with section 60.534 of Subpart AAA to meet the 2020 cord wood compliance option until such time that Subpart AAA is revised or replaced to require a different cord wood certification method. We also approve application of this alternative method to all wood heaters manufactured by Hearthstone meeting the requirements of Subpart AAA.

As required in Subpart AAA, section 60.354(d), you or your approved test laboratory must also measure the first hour of particulate matter emissions for each test run using a separate filter in one of the two parallel sampling trains. These results must be reported separately and also included in the total particulate matter emissions per run. Also, as required by Subpart AAA, section 60.534(e), you must have your approved laboratory measure the efficiency, heat output, and carbon monoxide emissions of the tested wood heater using CSA-B415.1-10. For measurement of particulate matter emission concentrations, ASTM 2515-11 must be used.

The following change to ASTM E3053-17 must be followed:

1. Coal bed conditions prior to loading test fuel. The coal bed shall be a level plane without valleys or ridges for all test runs in the high, low, and medium burn rate categories.

The following changes to ASTM E2515-11 must be followed:


1. The filter temperature must be maintained between 80 and 90 degrees F during testing.
2. Filters must be weighed in pairs to reduce weighing error propagation; see ASTM 2515-11, Section 10.2.1 Analytical Procedure.
3. Sample filters must be Pall TX-40 or equivalent Teflon-coated glass fiber, and of 47 mm, 90 mm, 100 mm, or 110 mm in diameter.
4. Only one point is allowed outside the +/- 10 percent proportionality range per test run.

A copy of this letter must be included in each certification test report where this alternative test method is utilized.

It is reasonable that this alternative test method approval be broadly applicable to all wood heaters subject to the requirements of 40 CFR part 60, Subpart AAA. For this reason, we will post this letter as ALT-125 on our website at <http://www3.epa.gov/ttn/emc/approalt.html> for use by other interested parties. As noted earlier in this letter, this alternative method approval is valid until such time that Subpart AAA is revised or replaced to require a different cord wood certification method, and at such time, this alternative will be reconsidered and possibly withdrawn.

If you have additional questions regarding this approval, please contact Michael Toney of my staff at 919-541-5247 or toney.mike@epa.gov.

Sincerely,



Steffan M. Johnson, Group Leader
Measurement Technology Group

cc: Amanda Aldridge, EPA/OAQPS/OID
Adam Baumgart-Getz, EPA/OAQPS/OID
Rafael Sanchez, EPA/OECA
Michael Toney, EPA/OAQPS/AQAD

duplicate serial number

512



0219WS026S

LISTED SPACE HEATER, SOLID FUEL TYPE, ALSO SUITABLE FOR MOBILE HOME INSTALLATION / APPAREIL DE CHAUFFAGE AMBIANT HOMOLOGUÉ À COMBUSTIBLE SOLIDE, CONVenant AUSSI POUR INSTALLATION DANS UNE MAISON MOBILE

MODEL: **REGENCY MEDIUM FREESTANDING STOVE - F2450**

TESTED TO: ULC S627-00 / UL 1482-2011 (R2015) / UL 737-2011 (R2015)

This appliance is not approved for mobile home installations in Canada (USA only)

Cet appareil n'est pas homologué pour être installé dans une maison mobile au Canada (États-Unis seulement)

DO NOT REMOVE THIS LABEL / NE RETIREZ PAS CETTE ÉTIQUETTE

512

U.S. ENVIRONMENTAL PROTECTION AGENCY Certified to comply with 2020 particulate emission standards using cord wood.* Tested to ASTM E3053. Model Regency F2450 - 2.3g /hr. This wood heater needs periodic inspection and repair for proper operation. Consult the owner's manual for further information. It is against federal regulations to operate this wood heater in a manner inconsistent with the operating instructions in the owner's manual.

Certifié conforme aux normes 2020 du U.S. ENVIRONMENTAL PROTECTION AGENCY en matière d'émission de particules de bois avec du bois de corde*. Approuvé ASTM E3053. Modèle Regency F2450 - 2,3 g/h. Cet appareil de chauffage au bois doit être inspecté périodiquement et réparé pour fonctionner correctement. Consulter le manuel d'installation pour plus d'information. La réglementation fédérale interdit de faire fonctionner un tel appareil si les consignes d'utilisation contenues dans le présent manuel ne sont pas respectées.

INSTALL AND USE ONLY IN ACCORDANCE WITH THE MANUFACTURER'S INSTALLATION AND OPERATING INSTRUCTIONS. CONTACT LOCAL BUILDING OR FIRE OFFICIALS ABOUT RESTRICTIONS AND INSTALLATION INSPECTION IN YOUR AREA. USE 150 MM (6 IN.) DIAMETER MINIMUM 24 MSG BLACK OR 26 MSG BLUED STEEL CONNECTOR WITH LISTED UL103 HT FACTORY-BUILT CHIMNEY SUITABLE FOR USE WITH SOLID FUELS OR MASONRY CHIMNEY.

SEE LOCAL BUILDING CODE AND MANUFACTURER'S INSTRUCTIONS FOR PRECAUTIONS REQUIRED FOR PASSING A CHIMNEY THROUGH A COMBUSTIBLE WALL OR CEILING. DO NOT PASS CHIMNEY CONNECTOR THROUGH COMBUSTIBLE WALL OR CEILING. DO NOT CONNECT THIS UNIT TO A CHIMNEY FLUE SERVING ANOTHER APPLIANCE.

INSTALLER ET UTILISER SEULEMENT SELON LES CONSIGNES D'INSTALLATION ET D'UTILISATION DU FABRICANT. CONTACTER LES RESPONSABLES DU BÂTIMENT OU DU SERVICE INCENDIE DE VOTRE RÉGION POUR CONNAÎTRE LES RESTRICTIONS ET EXIGENCES D'INSPECTION DANS VOTRE RÉGION.

UTILISER UN CONNECTEUR D'UN DIAMÈTRE MINIMAL DE 150 MM (6 PO) 24 MSG EN ACIER NOIR OU 26 MSG EN ACIER BRONZÉ AVEC CHEMINÉE PRÉFABRIQUÉE HOMOLOGUÉE UL103 HT ET LE CONJONCTEUR POUR ÊTRE UTILISÉE AVEC DES COMBUSTIBLES SOLIDES OU UNE CHEMINÉE EN MAÇONNERIE.

VOIR LE CODE DU BÂTIMENT LOCAL ET LES INSTRUCTIONS DU FABRICANT CONCERNANT LES PRÉCAUTIONS D'INSTALLATION D'UNE CHEMINÉE TRAVERSANT UN MUR OU UN PLAFOND EN MATÉRIAUX COMBUSTIBLES. NE PAS FAIRE TRAVERSER LE CONNECTEUR DE CHEMINÉE DANS UN MUR OU UN PLAFOND EN MATÉRIAUX COMBUSTIBLES. NE PAS RACCORDER CE POÈLE À BOIS À UN CONDUIT DE CHEMINÉE DESSERVANT UN AUTRE APPAREIL.

MINIMUM ALCOVE CEILING HEIGHT: 2109 MM / 83" MAXIMUM ALCOVE DEPTH 1219 MM / 48".

MINIMUM CLEARANCES FOR HORIZONTAL CONNECTOR TO CEILING: 405 MM / 16"

THE SPACE BENEATH THE HEATER MUST NOT BE OBSTRUCTED. OPERATE ONLY WITH FIREBRICKS IN PLACE.

FOR USE WITH SOLID WOOD FUEL ONLY. USE OF OTHER FUELS MAY DAMAGE HEATER AND CREATE A HAZARDOUS CONDITION. DO NOT OBSTRUCT COMBUSTION AIR OPENINGS. OPERATE ONLY WITH FIREBRICKS IN PLACE. RISK OF SMOKE AND FLAME SPILLAGE. OPERATE ONLY WITH DOORS FULLY CLOSED. IF INSTALLED IN A MOBILE HOME OPERATE ONLY WITH DOORS FULLY CLOSED - OPEN FEED DOOR TO FEED FIRE ONLY. DO NOT USE GRATE OR ELEVATE FIRE. BUILD WOOD FIRE DIRECTLY ON HEARTH. DO NOT OVERFIRE - IF HEATER OR CHIMNEY CONNECTOR GLOWS YOU ARE OVERFIRING. INSPECT AND CLEAN CHIMNEY AND CONNECTOR FREQUENTLY. UNDER CERTAIN CONDITIONS OF USE CREOSOTE BUILDUP MAY OCCUR RAPIDLY. KEEP FURNISHINGS AND OTHER COMBUSTIBLE MATERIAL AWAY FROM HEATER. REPLACE GLASS ONLY WITH NEOCERAM GLASS. COMBUSTIBLE FLOOR MUST BE PROTECTED BY NON-COMBUSTIBLE MATERIAL EXTENDING BENEATH THE HEATER AND TO THE FRONT AND SIDES AS INDICATED OR TO THE NEAREST PERMITTED COMBUSTIBLE MATERIAL.

OPTIONAL COMPONENT: FAN PART #075-917, ELECTRICAL RATING: VOLTS 115, 60 HZ, 2 AMPS / SCREEN

DANGER: RISK OF ELECTRIC SHOCK. DISCONNECT POWER BEFORE SERVICING UNIT. DO NOT ROUTE POWER CORD UNDER OR IN FRONT OF APPLIANCE.

COMPONENTS REQUIRED FOR MOBILE HOME INSTALLATION: OUTSIDE AIR KIT

IN CANADA: LISTED ULC629 CHIMNEY. USE CHIMNEY COMPONENTS AS SPECIFIED IN INSTALLATION INSTRUCTIONS

IN USA: LISTED UL 103 HT CHIMNEY

WARNING: ONLY USE LISTED REGENCY OPTIONS SUCH AS LEGS, AIRMATE, FAN AS SHOWN IN THE INSTALLATION MANUAL.

CAUTION: MOVING PARTS MAY CAUSE INJURY.

HAUTEUR MINIMALE DU PLAFOND DE L'ALCOÛVE : 2109 MM / 83 PO PROFONDEUR MAXIMALE DE L'ALCOÛVE : 1219 MM / 48 PO

DÉGAGEMENT MINIMAL DU PLAFOND POUR UN CONNECTEUR HORIZONTAL : 405 MM / 16 PO.

L'ESPACE SOUS LE POÈLE NE DOIT PAS ÊTRE OBSTRUÉ. UTILISER SEULEMENT AVEC LES BRIQUES RÉFRACTAIRES EN PLACE.

À UTILISER AVEC DU BOIS SOLIDE SEULEMENT. L'UTILISATION D'AUTRES COMBUSTIBLES PEUT ENDOMMAGER LE POÈLE ET CRÉER UNE CONDITION DANGEREUSE. NE PAS OBSTRUER LES OUVERTURES D'AIR DE COMBUSTION. UTILISER SEULEMENT AVEC LA PORTE FERMÉE - OUVRIRE SEULEMENT LA PORTE DE CHARGEMENT POUR ALIMENTER LE FEU. NE PAS UTILISER DE GRILLE À BÛCHES NI SURÉLÉVER LE FEU. MONTER LE FEU DE BOIS DIRECTEMENT SUR L'ÂTRE. NE PAS SURCHAUFFER - SI LE POÈLE OU LE CONNECTEUR DE CHEMINÉE SE MET À ROUGIR, RISQUE DE SURCHAUFFAGE. INSPECTER ET NETTOYER FRÉQUEMMENT LA CHEMINÉE ET LE CONNECTEUR. DANS CERTAINES CONDITIONS D'UTILISATION, UN DÉPÔT DE CRÉOSOTE PEUT SE FORMER RAPIDEMENT. GARDER LES MEUBLES ET AUTRES MATÉRIAUX COMBUSTIBLES ÉLOIGNÉS DU POÈLE. REMPLACER LA VITRE SEULEMENT PAR DU VERRE EN NEOGERAM. LE PLANCHER COMBUSTIBLE DOIT ÊTRE PROTÉGÉ PAR DES MATÉRIAUX NON COMBUSTIBLES DÉPASSANT SUR LE DESSOUS, LE DEVANT ET LES CÔTÉS DU POÈLE, TEL QU'INDIQUÉ, OU JUSQU'AU MATÉRIAU COMBUSTIBLE LE PLUS PRÈS PERMIS.

COMPOSANTS EN OPTION : VENTILATEUR PIÈCE N°075-917, ALIMENTATION ÉLECTRIQUE : 115 VOLTS, 60 HZ, 2 AMP.

DANGER: RISQUE D'ÉLECTROCOUSSION. DÉCONNECTER L'ALIMENTATION ÉLECTRIQUE AVANT D'EFFECTUER L'ENTRETIEN DU POÈLE. NE PAS INSTALLER LE CORDON ÉLECTRIQUE SOUS OU DEVANT L'APPAREIL.

COMPOSANTS EXIGÉS POUR INSTALLATION DANS UNE MAISON MOBILE : KIT DE PRISE D'AIR EXTÉRIEUR.

AU CANADA : CHEMINÉE HOMOLOGUÉE ULC 629. UTILISER LES PIÈCES DE LA CHEMINÉE TEL QUE SPÉCIFIÉ DANS LES CONSIGNES D'INSTALLATION.

AUX ÉTATS-UNIS : CHEMINÉE HOMOLOGUÉE UL 103 HT.

AVERTISSEMENT : UTILISER SEULEMENT LES OPTIONS HOMOLOGUÉES PAR REGENCY COMME LES PATTES, LE DIFFUSEUR AIRMATE, LE VENTILATEUR COMME ILLUSTRÉ DANS LE MANUEL D'INSTALLATION.

ATTENTION : LE DÉPLACEMENT DES PIÈCES PEUT ENTRAÎNER DES BLESSURES.

HAUTEUR MINIMALE DU PLAFOND DE L'ALCOÛVE : 2109 MM / 83 PO PROFONDEUR MAXIMALE DE L'ALCOÛVE : 1219 MM / 48 PO

DÉGAGEMENT MINIMAL DU PLAFOND POUR UN CONNECTEUR HORIZONTAL : 405 MM / 16 PO.

L'ESPACE SOUS LE POÈLE NE DOIT PAS ÊTRE OBSTRUÉ. UTILISER SEULEMENT AVEC LES BRIQUES RÉFRACTAIRES EN PLACE.

À UTILISER AVEC DU BOIS SOLIDE SEULEMENT. L'UTILISATION D'AUTRES COMBUSTIBLES PEUT ENDOMMAGER LE POÈLE ET CRÉER UNE CONDITION DANGEREUSE. NE PAS OBSTRUER LES OUVERTURES D'AIR DE COMBUSTION. UTILISER SEULEMENT AVEC LA PORTE FERMÉE - OUVRIRE SEULEMENT LA PORTE DE CHARGEMENT POUR ALIMENTER LE FEU. NE PAS UTILISER DE GRILLE À BÛCHES NI SURÉLÉVER LE FEU. MONTER LE FEU DE BOIS DIRECTEMENT SUR L'ÂTRE. NE PAS SURCHAUFFER - SI LE POÈLE OU LE CONNECTEUR DE CHEMINÉE SE MET À ROUGIR, RISQUE DE SURCHAUFFAGE. INSPECTER ET NETTOYER FRÉQUEMMENT LA CHEMINÉE ET LE CONNECTEUR. DANS CERTAINES CONDITIONS D'UTILISATION, UN DÉPÔT DE CRÉOSOTE PEUT SE FORMER RAPIDEMENT. GARDER LES MEUBLES ET AUTRES MATÉRIAUX COMBUSTIBLES ÉLOIGNÉS DU POÈLE. REMPLACER LA VITRE SEULEMENT PAR DU VERRE EN NEOGERAM. LE PLANCHER COMBUSTIBLE DOIT ÊTRE PROTÉGÉ PAR DES MATÉRIAUX NON COMBUSTIBLES DÉPASSANT SUR LE DESSOUS, LE DEVANT ET LES CÔTÉS DU POÈLE, TEL QU'INDIQUÉ, OU JUSQU'AU MATÉRIAU COMBUSTIBLE LE PLUS PRÈS PERMIS.

COMPOSANTS EN OPTION : VENTILATEUR PIÈCE N°075-917, ALIMENTATION ÉLECTRIQUE : 115 VOLTS, 60 HZ, 2 AMP.

DANGER: RISQUE D'ÉLECTROCOUSSION. DÉCONNECTER L'ALIMENTATION ÉLECTRIQUE AVANT D'EFFECTUER L'ENTRETIEN DU POÈLE. NE PAS INSTALLER LE CORDON ÉLECTRIQUE SOUS OU DEVANT L'APPAREIL.

COMPOSANTS EXIGÉS POUR INSTALLATION DANS UNE MAISON MOBILE : KIT DE PRISE D'AIR EXTÉRIEUR.

AU CANADA : CHEMINÉE HOMOLOGUÉE ULC 629. UTILISER LES PIÈCES DE LA CHEMINÉE TEL QUE SPÉCIFIÉ DANS LES CONSIGNES D'INSTALLATION.

AUX ÉTATS-UNIS : CHEMINÉE HOMOLOGUÉE UL 103 HT.

AVERTISSEMENT : UTILISER SEULEMENT LES OPTIONS HOMOLOGUÉES PAR REGENCY COMME LES PATTES, LE DIFFUSEUR AIRMATE, LE VENTILATEUR COMME ILLUSTRÉ DANS LE MANUEL D'INSTALLATION.

ATTENTION : LE DÉPLACEMENT DES PIÈCES PEUT ENTRAÎNER DES BLESSURES.

HAUTEUR MINIMALE DU PLAFOND DE L'ALCOÛVE : 2109 MM / 83 PO PROFONDEUR MAXIMALE DE L'ALCOÛVE : 1219 MM / 48 PO

DÉGAGEMENT MINIMAL DU PLAFOND POUR UN CONNECTEUR HORIZONTAL : 405 MM / 16 PO.

L'ESPACE SOUS LE POÈLE NE DOIT PAS ÊTRE OBSTRUÉ. UTILISER SEULEMENT AVEC LES BRIQUES RÉFRACTAIRES EN PLACE.

À UTILISER AVEC DU BOIS SOLIDE SEULEMENT. L'UTILISATION D'AUTRES COMBUSTIBLES PEUT ENDOMMAGER LE POÈLE ET CRÉER UNE CONDITION DANGEREUSE. NE PAS OBSTRUER LES OUVERTURES D'AIR DE COMBUSTION. UTILISER SEULEMENT AVEC LA PORTE FERMÉE - OUVRIRE SEULEMENT LA PORTE DE CHARGEMENT POUR ALIMENTER LE FEU. NE PAS UTILISER DE GRILLE À BÛCHES NI SURÉLÉVER LE FEU. MONTER LE FEU DE BOIS DIRECTEMENT SUR L'ÂTRE. NE PAS SURCHAUFFER - SI LE POÈLE OU LE CONNECTEUR DE CHEMINÉE SE MET À ROUGIR, RISQUE DE SURCHAUFFAGE. INSPECTER ET NETTOYER FRÉQUEMMENT LA CHEMINÉE ET LE CONNECTEUR. DANS CERTAINES CONDITIONS D'UTILISATION, UN DÉPÔT DE CRÉOSOTE PEUT SE FORMER RAPIDEMENT. GARDER LES MEUBLES ET AUTRES MATÉRIAUX COMBUSTIBLES ÉLOIGNÉS DU POÈLE. REMPLACER LA VITRE SEULEMENT PAR DU VERRE EN NEOGERAM. LE PLANCHER COMBUSTIBLE DOIT ÊTRE PROTÉGÉ PAR DES MATÉRIAUX NON COMBUSTIBLES DÉPASSANT SUR LE DESSOUS, LE DEVANT ET LES CÔTÉS DU POÈLE, TEL QU'INDIQUÉ, OU JUSQU'AU MATÉRIAU COMBUSTIBLE LE PLUS PRÈS PERMIS.

COMPOSANTS EN OPTION : VENTILATEUR PIÈCE N°075-917, ALIMENTATION ÉLECTRIQUE : 115 VOLTS, 60 HZ, 2 AMP.

DANGER: RISQUE D'ÉLECTROCOUSSION. DÉCONNECTER L'ALIMENTATION ÉLECTRIQUE AVANT D'EFFECTUER L'ENTRETIEN DU POÈLE. NE PAS INSTALLER LE CORDON ÉLECTRIQUE SOUS OU DEVANT L'APPAREIL.

COMPOSANTS EXIGÉS POUR INSTALLATION DANS UNE MAISON MOBILE : KIT DE PRISE D'AIR EXTÉRIEUR.

AU CANADA : CHEMINÉE HOMOLOGUÉE ULC 629. UTILISER LES PIÈCES DE LA CHEMINÉE TEL QUE SPÉCIFIÉ DANS LES CONSIGNES D'INSTALLATION.

AUX ÉTATS-UNIS : CHEMINÉE HOMOLOGUÉE UL 103 HT.

AVERTISSEMENT : UTILISER SEULEMENT LES OPTIONS HOMOLOGUÉES PAR REGENCY COMME LES PATTES, LE DIFFUSEUR AIRMATE, LE VENTILATEUR COMME ILLUSTRÉ DANS LE MANUEL D'INSTALLATION.

ATTENTION : LE DÉPLACEMENT DES PIÈCES PEUT ENTRAÎNER DES BLESSURES.

MANUFACTURED BY / FABRIQUÉ PAR :

FPI FIREPLACE PRODUCTS INTERNATIONAL LTD.


6988 VENTURE ST.

DELTA, BC V4G 1H4



| MINIMUM CLEARANCES TO COMBUSTIBLE MATERIALS DÉGAGEMENTS MINIMAUX PAR RAPPORT AUX MATÉRIAUX COMBUSTIBLES | | | | | |
|--|--------------------|--------------------|---|--------------------|--------------------|
| F2500M WITH AIRMATE SHIELD | | | F2500M WITH REAR DEFLECTOR | | |
| MEASURE FROM | HEATER | FLUE CENTER-LINE | MEASURE FROM | HEATER | FLUE CENTER-LINE |
| RESIDENTIAL INSTALLATION USING SINGLE WALL CONNECTOR | | | RESIDENTIAL INSTALLATION USING SINGLE WALL CONNECTOR | | |
| SIDEWALL | A 406 mm / 16 in | D 711 mm / 28 in | SIDEWALL | A 406 mm / 16 in | D 711 mm / 28 in |
| BACKWALL | B 267 mm / 10.5 in | E 432 mm / 17 in | BACKWALL | B 317 mm / 12.5 in | E 483 mm / 19 in |
| CORNER | C 229 mm / 9 in | F 533 mm / 21 in | CORNER | C 229 mm / 9 in | F 533 mm / 21 in |
| INSTALLATION USING LISTED DOUBLE WALL CONNECTOR - MOBILE HOME | | | INSTALLATION USING LISTED DOUBLE WALL CONNECTOR - MOBILE HOME | | |
| SIDEWALL | A 381 mm / 15 in | D 686 mm / 27 in | SIDEWALL | A 381 mm / 15 in | D 686 mm / 27 in |
| BACKWALL | B 229 mm / 9 in | E 394 mm / 15.5 in | BACKWALL | B 279 mm / 11 in | E 444 mm / 17.5 in |
| CORNER | C 178 mm / 7 in | F 483 mm / 19 in | CORNER | C 178 mm / 7 in | F 483 mm / 19 in |
| INSTALLATION USING LISTED DOUBLE WALL CONNECTOR - RESIDENTIAL CLOSE CLEARANCE | | | INSTALLATION USING LISTED DOUBLE WALL CONNECTOR - RESIDENTIAL CLOSE CLEARANCE | | |
| SIDEWALL | A 381 mm / 15 in | D 686 mm / 27 in | SIDEWALL | A 381 mm / 15 in | D 686 mm / 27 in |
| BACKWALL | B 229 mm / 9 in | E 394 mm / 15.5 in | BACKWALL | B 279 mm / 11 in | E 444 mm / 17.5 in |
| CORNER | C 178 mm / 7 in | F 483 mm / 19 in | CORNER | C 178 mm / 7 in | F 483 mm / 19 in |
| INSTALLATION USING LISTED DOUBLE WALL CONNECTOR - ALCOVE | | | INSTALLATION USING LISTED DOUBLE WALL CONNECTOR - ALCOVE | | |
| SIDEWALL | G 380 mm / 15 in | J 686 mm / 27 in | SIDEWALL | G 380 mm / 15 in | J 686 mm / 27 in |
| BACKWALL | H 229 mm / 9 in | I 394 mm / 15.5 in | BACKWALL | H 279 mm / 11 in | I 444 mm / 17.5 in |




FLOOR PROTECTION*
PROTECTION DE PLANCHER*



- A 1245 mm / 49 in (Canada)
- A 1194 mm / 47 in (USA)
- B 457 mm / 18 in*
- C 855 mm / 33-11/16 in
- D 200 mm / 8 in

* In Canada, floor protection must extend 18" (457mm) to the front (16" for USA) and 8" (200mm) to each side and back of the stove.

* Au Canada, la protection de plancher doit dépasser de 18 po (457 mm) à l'avant (16 po aux États-Unis) et de 8 po (200 mm) de chaque côté du poêle et derrière le poêle.



CAUTION

HOT WHILE IN OPERATION DO NOT TOUCH. KEEP CHILDREN, CLOTHING AND FURNITURE AWAY. CONTACT MAY CAUSE SKIN BURNS. READ NAMEPLATE AND INSTRUCTIONS.

ATTENTION

CHAUD DURANT LE FONCTIONNEMENT. NE TOUCHEZ PAS. ÉLOIGNEZ LES ENFANTS, LES VÊTEMENTS ET LES MEUBLES. LE CONTACT PEUT CAUSER DES BRÛLURES. LISEZ LA PLAQUE SIGNALÉTIQUE ET LES INSTRUCTIONS



MADE IN CANADA / FABRIQUÉ AU CANADA

920-037

DATE OF MANUFACTURE
2018 2019 2020 2021 2022
JAN FEB MAR APR MAY JUN JUL AUG SEPT OCT NOV DEC



Classic™ Freestanding Woodstove F2450M

Owners &
Installation Manual



French Manual Download: <https://bit.ly/3rAsDW7>
Manuel en Français : <https://bit.ly/3rAsDW7>

www.regency-fire.com

MODEL: F2450M

Tested by:



0219WS026S

Installer: Please complete the details on the back cover
and leave this manual with the homeowner.

Homeowner: Please keep these instructions for future reference.

Thank-you for purchasing a
REGENCY FIREPLACE PRODUCT.

The pride of workmanship that goes into each of our products will give you years of trouble-free enjoyment. Should you have any questions about your product that are not covered in this manual, please contact the **REGENCY DEALER** in your area.

"This wood heater has a manufacturer set minimum low burn rate that must not be altered. It is against federal regulations to alter this setting or otherwise operate this wood heater in a manner inconsistent with operating instructions in this manual." Failure to follow the manual details can lead to smoke and CO emissions spilling into the home. It is recommended to have monitors in areas that are expected to generate CO such as heater fueling areas.

"U.S. ENVIRONMENTAL PROTECTION AGENCY Certified to comply with 2020 particulate emission standards using cord wood." Tested to ASTM E3053. Model Regency F2450M – 2.3g/hr.

"This manual describes the installation and operation of the Regency F2450M wood heater. This heater meets the 2020 U.S. Environmental Protection Agency's cord wood emission limits for wood heaters. Under specific test conditions this heater has been shown to deliver heat at rates ranging from 14,200 BTU/hr to 53,600 BTU/hr." Efficiency is determined using the B415 method resulting in lower and higher heat values. This heater generates the best efficiency when operated using well-seasoned wood and installed in the main living areas where the majority of the chimney is within the building envelope. "This wood heater needs periodic inspection and repair for proper operation.

It is against federal regulation to operate this wood heater in a manner inconsistent with operating instructions in this manual."

CAUTION: BURN UNTREATED WOOD ONLY. OTHER MATERIALS SUCH AS WOOD PRESERVATIVES, METAL FOILS, COAL, PLASTIC, GARBAGE, SULPHUR OR OIL MAY DAMAGE THE STOVE.

"This heater is designed to burn natural wood only. Higher efficiencies and lower emissions generally result when burning air dried seasoned hardwoods, as compared to softwoods or to green or freshly cut hardwoods."

DO NOT BURN:

- Treated wood
- Coal
- Garbage
- Cardboard
- Solvents
- Colored Paper
- Trash
- **Lawn clippings or yard waste**
- **Materials containing rubber including tires**
- **Materials containing plastic**
- **Waste petroleum products , paints or paint thinners or asphalt products**
- **Materials containing asbestos**
- **Construction or demolition debris**
- **Railroad ties**
- **Manure or animal remains**
- **Saltwater driftwood or other previously salt water saturated materials**
- **Unseasoned wood**
- **Paper products, cardboard, plywood or particle board. The prohibition against burning these materials does not prohibit the use of fire starters made from paper, cardboard, saw dust, wax and similar substances for the purpose of starting a fire in a wood heater.**

Burning these materials may result in release of toxic fumes or render the heater ineffective and cause smoke.

The authority having jurisdiction (such as Municipal Building Department, Fire Department, Fire Prevention Bureau, etc.) should be consulted before installation to determine the need to obtain a permit.

This unit must be connected to either a listed factory built chimney suitable for use with solid fuels and conforming to, ULC629 in Canada or UL-103HT in the United States of America. or code approved masonry chimney with flue liner.

F2450M is tested and certified to ULC-S627-00 and UL1482-2011 (R2015).

SAVE THESE INSTRUCTIONS





table of contents

| | |
|-------------------------------|---|
| Safety Decal for F2450M | 4 |
|-------------------------------|---|

Dimensions

| | |
|------------------------------|---|
| Unit Dimensions | 5 |
| Outside Air Dimensions | 5 |

Installation

| | |
|--|----|
| Modular Installation Options | 6 |
| Stove Assembly Prior To Installation..... | 7 |
| Airmate Assembly for F2450M | 7 |
| Rear Heat Deflector Assembly for F2450M | 7 |
| Side Shield Adjustment | 7 |
| Pedestal Assembly Installation | 8 |
| Logo Installation | 8 |
| Bottom Heat Shield and Legs Installation..... | 8 |
| Room Air - Important | 9 |
| Minimum Clearance To Combustible Materials..... | 9 |
| Minimum Alcove Clearance and Clearance to Combustible Materials | 10 |
| Floor Protection | 10 |
| Floor Protection (Corner Installation) | 11 |
| Step-By-Step Chimney And Connector Installation | 12 |
| Masonry Chimney..... | 13 |
| Masonry Fireplace | 13 |
| Factory Built Chimney..... | 13 |
| Combustible Wall Chimney Connector Pass-throughs | 14 |
| Mobile Home Installation | 15 |
| Mobile Home Kit for Canada | 16 |
| Installing Outside Air from Pedestal Base | 17 |
| Installing Outside Air Using Bottom Heat Shield/Legs..... | 17 |
| Recommended Heights For Woodstove Flue | 18 |
| Optional Outside Air Kit | 19 |
| Brick Installation | 20 |
| Wood Handle & Door Assembly | 21 |

| | |
|---|----|
| Flue Baffle & Secondary Air Tube Installation | 22 |
| Fan Installation | 23 |
| Stainless Steel Smoke Deflector Installation | 24 |

Operation

| | |
|---------------------------------------|----|
| Seasoned Firewood..... | 25 |
| Operating Instructions | 25 |
| Draft Control | 25 |
| First Fire | 26 |
| Fan Operation..... | 27 |
| Ash Disposal..... | 27 |
| Ash Drawer Operating Guidelines | 27 |
| Safety Guidelines and Warnings | 27 |

Maintenance

| | |
|--|----|
| Classic Door Handle Replacement..... | 28 |
| Glass Replacement | 28 |
| Maintenance | 29 |
| Creosote | 29 |
| Ways to Prevent and Keep Unit Free of Creosote | 29 |
| Door Gasket | 29 |
| Glass Maintenance..... | 29 |
| Wood Storage..... | 29 |
| Secondary Air Tube Removal/Installation | 30 |
| Annual Maintenance..... | 30 |
| Vertical Stainless Deflector Replacement..... | 31 |

Parts

| | |
|---------------------|----|
| Main Assembly | 32 |
| Bases..... | 34 |
| Brick Kit | 35 |

Warranty

| | |
|----------------|----|
| Warranty | 36 |
|----------------|----|

CAUTION: To avoid burns or wood splinters, when opening/closing the fuel door or adding wood to the fire, You should always wear appropriate protective gloves to protect your hands from the heat being emitted from this fireplace.

safety decal

This is a copy of the label that accompanies each Regency Freestanding Woodstove (F2450M). We have printed a copy of the contents here for your review.

NOTE: Regency units are constantly being improved. Check the label on the unit and if there is a difference, the label on the unit is the correct one.

duplicate serial number

512

DO NOT REMOVE THIS LABEL / NE RETIREZ PAS CETTE ÉTIQUETTE

512

DATE OF MANUFACTURE

2021 2022 2023 2024

JAN FEB MAR APR MAY JUN JUL AUG SEPT OCT NOV DEC

LISTED SPACE HEATER, SOLID FUEL TYPE, ALSO SUITABLE FOR MOBILE HOME INSTALLATION / APPAREIL DE CHAUFFAGE AMBIANT HOMOLOGUÉ À COMBUSTIBLE SOLIDE, CONVENUENT AUSSI POUR INSTALLATION DANS UNE MAISON MOBILE

MODEL: **REGENCY MEDIUM FREESTANDING STOVE - F2450M**

TESTED TO: ULC S627-00 / UL 1482-2011 (R2015)

This appliance is approved for mobile home installations in Canada and the USA. Cet appareil est homologué pour être installé dans une maison mobile au Canada et aux États-Unis.

U.S. ENVIRONMENTAL PROTECTION AGENCY Certified to comply with 2020 particulate emission standards using cord wood* Tested to ASTM E2053. Model Regency F2450M - 2.3g/hr. This wood heater needs periodic inspection and repair for proper operation. Consult the owner's manual for further information. It is against federal regulations to operate this wood heater in a manner inconsistent with the operating instructions in the owner's manual.

Certifié conforme aux normes 2020 de l'U.S. ENVIRONMENTAL PROTECTION AGENCY en matière d'émission de particules de bois en utilisant le bois de corde. Approuvé ASTM E2053. Modèle Regency F2450M - 2,3 g/h. Cet appareil de chauffage au bois doit être inspecté périodiquement et réparé pour fonctionner correctement. Consulter le manuel d'installation pour plus d'information. La réglementation fédérale interdit de faire fonctionner un tel appareil si les consignes d'utilisation contenues dans le présent manuel ne sont pas respectées.

INSTALL USE ONLY IN ACCORDANCE WITH THE MANUFACTURER'S INSTALLATION AND OPERATING INSTRUCTIONS. CONTACT LOCAL BUILDING OR FIRE OFFICIALS ABOUT RESTRICTIONS AND INSTALLATION INSPECTION IN YOUR AREA. USE 150 MM (6 IN) DIAMETER MINIMUM 24 MSG BLACK OR 26 MSG BLUED STEEL CONNECTOR WITH LISTED UL103 HT FACTORY-BUILT CHIMNEY SUITABLE FOR USE WITH SOLID FUELS OR MASONRY CHIMNEY.

SEEL LOCAL BUILDING CODE AND MANUFACTURER'S INSTRUCTIONS FOR PRECAUTIONS REQUIRED FOR PASSING A CHIMNEY THROUGH A COMBUSTIBLE WALL OR CEILING. DO NOT PASS CHIMNEY CONNECTOR THROUGH COMBUSTIBLE WALL OR CEILING. DO NOT CONNECT THIS UNIT TO A CHIMNEY FLUE SERVING ANOTHER APPLIANCE.

INSTALLER ET UTILISER SEULEMENT SELON LES CONSIGNES D'INSTALLATION ET D'UTILISATION DU FABRICANT. CONTACTER LES RESPONSABLES DU BÂTIMENT OU DU SERVICE INCENDIE DE VOTRE RÉGION POUR CONNÂTRE LES RESTRICTIONS ET EXIGENCES D'INSPECTION DANS VOTRE RÉGION. UTILISER UN CONNECTEUR D'UN DIAMÈTRE MINIMAL DE 150 MM (6 PO) 24 MSG EN ACIER NOIR OU 26 MSG EN ACIER BRONZÉ AVEC CHEMINÉE PRÉFA-BRIQUÉE HOMOLOGUÉE UL103 HT CONÇUE POUR ÊTRE UTILISÉE AVEC DES COMBUSTIBLES SOLIDES OU UNE CHEMINÉE EN MÂÇONNERIE.

VOIR LE CODE DU BÂTIMENT LOCAL ET LES INSTRUCTIONS DU FABRICANT CONCERNANT LES PRÉCAUTIONS D'INSTALLATION D'UNE CHEMINÉE TRAVERSANT UN MUR OU UN PLAFOND EN MATÉRIEL COMBUSTIBLES. NE PAS FAIRE TRAVERSER LE CONNECTEUR DE CHEMINÉE DANS UN MUR OU PLAFOND EN MATÉRIEL COMBUSTIBLES. NE PAS RACCORDER CE POÈLE À BOIS À UN CONDUIT DE CHEMINÉE DESSERVANT UN AUTRE APPAREIL.

MINIMUM ALLOWCE CEILING HEIGHT: 2109 MM / 83" MAXIMUM ALLOWCE DEPTH 1219 MM / 48"

MINIMUM CLEARANCES FOR HORIZONTAL CONNECTOR TO CEILING: 405 MM / 16"

THE SPACE BENEATH THE HEATER MUST NOT BE OBSTRUCTED. OPERATE ONLY WITH FIREBRICKS IN PLACE.

FOR USE WITH SOLID WOOD FUEL ONLY. USE OF OTHER FUELS MAY DAMAGE HEATER AND CREATE A HAZARDOUS CONDITION. DO NOT OBSTRUCT COMBUSTION AIR OPENINGS. OPERATE ONLY WITH FIREBRICKS IN PLACE. RISK OF SMOKE AND/OR SPILLAGE. OPERATE ONLY WITH DOORS FULLY CLOSED. IF INSTALLED IN MOBILE HOME OPERATE ONLY WITH DOORS FULLY CLOSED. OPEN/FEED DOOR TO FEED FUEL ONLY. DO NOT USE GRATE OR ELEVATE FIRE. BUILD WOOD FIRE DIRECTLY ON HEARTH. DO NOT OVERFIRE. IF HEATER OR CHIMNEY CONNECTOR GLOWS YOU ARE OVERFIRING. INSPECT AND CLEAN CHIMNEY AND CONNECTOR FREQUENTLY. UNDER CERTAIN CONDITIONS OF USE CREOSOTE BUILDUP MAY OCCUR RAPIDLY. KEEP FURNISHINGS AND OTHER COMBUSTIBLE MATERIAL AWAY FROM HEATER. REPLACE GLASS ONLY WITH NECESSARY GLASS. COMBUSTIBLE FLOOR MUST BE PROTECTED BY NON-COMBUSTIBLE MATERIAL EXTENDING BENEATH THE HEATER AND TO THE FRONT AND SIDES AS INDICATED OR TO THE NEAREST PERMITTED COMBUSTIBLE MATERIAL.

OPTIONAL COMPONENT: FAN PART #075-917. ELECTRICAL RATING: VOLTS 115, 60 HZ, 2 AMP.

DANGER: RISK OF ELECTRIC SHOCK. DISCONNECT POWER BEFORE SERVICE UNIT. DO NOT ROUTE POWER CORD UNDER OR IN FRONT OF APPLIANCE.

COMPONENTS REQUIRED FOR MOBILE HOME INSTALLATION: OUTSIDE AIR KIT

IN CANADA LISTED ULCS 629 CHIMNEY USE CHIMNEY COMPONENTS AS SPECIFIED IN INSTALLATION INSTRUCTIONS

IN USA: LISTED UL 103 HT CHIMNEY

WARNING: ONLY USE LISTED REGENCY OPTIONS SUCH AS LEGS, ARMATE, FAN AS SHOWN IN THE INSTALLATION MANUAL. CAUTION: BURNING OF MATERIALS OTHER THAN SPECIFIED MAY CAUSE DAMAGE TO THE UNIT.

CAUTION: MOVING PARTS MAY CAUSE INJURY.

HAUTEUR MINIMALE DU PLAFOND DE L'ALCÔVE: 2109 MM / 83 PO PROFONDEUR MAXIMALE DE L'ALCÔVE: 1219 MM / 48 PO

DÉGAGEMENT MINIMAL DU PLAFOND POUR UN CONNECTEUR HORIZONTAL: 405 MM / 16 PO

L'ESPACE SOUS LE POÈLE NE DOIT PAS ÊTRE OBSTRUÉ. UTILISER SEULEMENT AVEC LES BRIQUES RÉFRACTAIRES EN PLACE.

À UTILISER AVEC DU BOIS SOLIDE SEULEMENT. L'UTILISATION D'AUTRES COMBUSTIBLES PEUT ENDOMMAGER LE POÈLE ET CRÉER UNE CONDITION DANGEREUSE. NE PAS OBSTRUER LES OUVERTURES D'AIR DE COMBUSTION. UTILISER SEULEMENT AVEC LA PORTE FERMÉE. OUVRIRE SEULEMENT LA PORTE DE CHARGEMENT POUR ALIMENTER LE FEU. NE PAS UTILISER DE GRILLE À BûCHES NI SURÉLÉVER LE FEU. MONTER LE FEU DE BOIS DIRECTEMENT SUR LÂTRE. NE PAS SURCHAUFFER - SI LE POÈLE OU LE CONNECTEUR DE CHEMINÉE SE MET À ROUGIR, RISQUE DE SURCHAUFFAGE. INSPECTER ET NETTOYER FRÉQUEMMENT LA CHEMINÉE ET LE CONNECTEUR. DANS CERTAINES CONDITIONS D'UTILISATION, UN DÉPÔT DE CRÉOSOTE PEUT SE FORMER RAPIDEMENT. GARDER LES MEUBLES ET AUTRES MATÉRIEL COMBUSTIBLES ÉLOIGNÉS DU POÈLE. REMPLACER LA VITRE SEULEMENT PAR DU VERRE EN NECESSAIRE. LE PLANCHER COMBUSTIBLE DOIT ÊTRE PROTÉGÉ PAR DES MATÉRIEL NON COMBUSTIBLES DÉPASSANT SUR LE DESSOUS, LE DEVANT ET LES CÔTÉS DU POÈLE, TEL QU'UN QUINQUOÛ, OU AUSSU AU MATÉRIEL COMBUSTIBLE LE PLUS PRÈS PERMIS.

COMPOSANTS EN OPTION: VENTILATEUR PIÈCE N°075-917. ALIMENTATION ÉLECTRIQUE: 115 VOLTS, 60 HZ, 2 AMP.

DANGER: RISQUE D'ÉLECTROCUTION. DÉCONNECTER L'ALIMENTATION ÉLECTRIQUE AVANT D'EFFECTUER L'ENTRETIEN DU POÈLE. NE PAS INSTALLER LE CORDON ÉLECTRIQUE SOUS OU DEVANT L'APPAREIL.

COMPOSANTS EXIGÉS POUR INSTALLATION DANS UNE MAISON MOBILE: KIT DE PRISE D'AIR EXTÉRIEUR.

AU CANADA: CHEMINÉE HOMOLOGUÉE ULCS 629. UTILISER LES PIÈCES DE LA CHEMINÉE TEL QUE SPÉCIFIÉ DANS LES CONSIGNES D'INSTALLATION.

AUX ÉTATS-UNIS: CHEMINÉE HOMOLOGUÉE UL103HT.

AVERTISSEMENT: UTILISER SEULEMENT LES OPTIONS HOMOLOGUÉES PAR REGENCY COMME LES PATTES, LE DIFFUSEUR AIRMATE, LE VENTILATEUR COMME ILLUSTRÉ DANS LE MANUEL D'INSTALLATION.

ATTENTION: COMBUSTION DE TOUT MATÉRIEL NON SPÉCIFIÉ PEUT ENDOMMAGER L'APPAREIL.

ATTENTION: LE DÉPLACEMENT DES PIÈCES PEUT ENTRÂNER DES BLESSURES.

MINIMUM CLEARANCES TO COMBUSTIBLE MATERIALS / DÉGAGEMENTS MINIMAUX PAR RAPPORT AUX MATÉRIEL COMBUSTIBLES

| F2450M WITH AIRMATE SHIELD | | | | F2450M WITH REAR DEFLECTOR | | | |
|---|-------------------|--------------------|----------|----------------------------|--------------------|------------------|--|
| MEASURE FROM | | FLUE CENTER-LINE | | MEASURE FROM | | FLUE CENTER-LINE | |
| RESIDENTIAL INSTALLATION USING SINGLE WALL CONNECTOR | | | | | | | |
| SIDEWALL | A 406 mm / 16 in | D 711 mm / 28 in | SIDEWALL | A 406 mm / 16 in | D 711 mm / 28 in | | |
| BACKWALL | B 241 mm / 9.5 in | E 406 mm / 16 in | BACKWALL | B 292 mm / 11.5 in | E 457 mm / 18 in | | |
| CORNER | C 203 mm / 8 in | F 508 mm / 20 in | CORNER | C 203 mm / 8 in | F 508 mm / 20 in | | |
| INSTALLATION USING LISTED DOUBLE WALL CONNECTOR - MOBILE HOME | | | | | | | |
| SIDEWALL | A 381 mm / 15 in | D 686 mm / 27 in | SIDEWALL | A 381 mm / 15 in | D 686 mm / 27 in | | |
| BACKWALL | B 203 mm / 8 in | E 368 mm / 14.5 in | BACKWALL | B 254 mm / 10 in | E 419 mm / 16.5 in | | |
| CORNER | C 152 mm / 6 in | F 457 mm / 18 in | CORNER | C 152 mm / 6 in | F 457 mm / 18 in | | |
| INSTALLATION USING LISTED DOUBLE WALL CONNECTOR - RESIDENTIAL CLOSE CLEARANCE | | | | | | | |
| SIDEWALL | A 381 mm / 15 in | D 686 mm / 27 in | SIDEWALL | A 381 mm / 15 in | D 686 mm / 27 in | | |
| BACKWALL | B 203 mm / 8 in | E 368 mm / 14.5 in | BACKWALL | B 254 mm / 10 in | E 419 mm / 16.5 in | | |
| CORNER | C 152 mm / 6 in | F 457 mm / 18 in | CORNER | C 152 mm / 6 in | F 457 mm / 18 in | | |
| INSTALLATION USING LISTED DOUBLE WALL CONNECTOR - ALCOVE | | | | | | | |
| SIDEWALL | G 380 mm / 15 in | I 686 mm / 27 in | SIDEWALL | G 380 mm / 15 in | I 686 mm / 27 in | | |
| BACKWALL | H 203 mm / 8 in | J 368 mm / 14.5 in | BACKWALL | H 254 mm / 10 in | J 419 mm / 16.5 in | | |

FLOOR PROTECTION* / PROTECTION DE PLANCHER*

A 1245 mm / 49 in (Canada)

A 1194 mm / 47 in (USA)

B 457 mm / 18 in

C 406 mm / 16 in

D 856 mm / 33-11/16 in

E 203 mm / 8 in

* In Canada, floor protection must extend 18" (457mm) to the front (16" for USA) and 8" (203mm) to each side and back of the stove.

* Au Canada, la protection de plancher doit dépasser de 18 po (457 mm) à l'avant (16 po aux États-Unis) et de 8 po (203 mm) de chaque côté du poêle et derrière le poêle.

CAUTION

HOT WHILE IN OPERATION DO NOT TOUCH. KEEP CHILDREN, CLOTHING AND FURNITURE AWAY. CONTACT MAY CAUSE SKIN BURNS. READ NAMEPLATE AND INSTRUCTIONS.

ATTENTION

CHAUD DURANT LE FONCTIONNEMENT. NE TOUCHEZ PAS. ÉLOIGNEZ LES ENFANTS, LES VÊTEMENTS ET LES MEUBLES. LE CONTACT PEUT CAUSER DES BRÛLURES. LISEZ LA PLAQUE SIGNALÉTIQUE ET LES INSTRUCTIONS

MANUFACTURED BY / FABRIQUÉ PAR :

FPI FIREPLACE PRODUCTS INTERNATIONAL LTD.




6988 VENTURE ST.

DELTA, BC V4G 1H4



MADE IN CANADA / FABRIQUÉ AU CANADA

920-037a

Unit Dimensions



Outside Air Dimensions



installation

1. Please read this entire manual before you install and use your new woodstove. Failure to follow instructions may result in property damage, bodily injury or even death. Be aware that local Codes and Regulations may override some items in this manual. Check with your local inspector.
2. Select a position for your Regency Stove. Consult the minimum clearance chart for your model and set the stove in place. For installation use listed double wall connector systems only.
3. To insure vertical alignment, suspend a plumb bob from the ceiling over the exact center of your stove flue and mark a spot on the ceiling to indicate the center of the chimney.
4. Check that the area above the ceiling is clear for cutting. Re-confirm the clearance from the stove to combustibles to ensure that they are within the prescribed limits.
5. This woodstove must be connected to a UL 103 HT (ULC S629) listed chimney or a code approved masonry chimney with a flue liner.

Space heater is to be connected to a factory built chimney conforming to CAN/ULC-5629 standard for 650C factory built chimneys. The chimney requirement is 6", refer to appropriate sections in this manual for specifics.

6. Install chimney according to chimney manufacturers instructions. The performance of your woodstove is governed to a very large part by the chimney system. Too short a chimney can cause difficult start-up, dirty glass, back smoking when door is open, and even reduced heat output.

WHEN THIS ROOM HEATER IS NOT PROPERLY INSTALLED, A HOUSE FIRE MAY RESULT. TO REDUCE THE RISK OF FIRE, FOLLOW THE INSTALLATION INSTRUCTIONS. CONTACT LOCAL BUILDING OR FIRE OFFICIALS ABOUT RESTRICTIONS AND INSTALLATION INSPECTION REQUIREMENTS IN YOUR AREA.

Too tall a chimney may prompt excessive draft which can result in very short burn times and excessive heat output. The use of an inexpensive flue pipe damper may be helpful in reducing excessive draft.

CAUTION: The chimney should be the same size as the 6" flue outlet on the stove. The chimney must be listed as suitable for use with solid fuels. For other types of chimneys check with your local building code officials. Do not confuse a chimney with a type "B" Venting System used for gas appliances as suitable for a wood burning appliance. For Mobile Home installations refer to that section within this manual.

7. Mark the location of the pedestal base or legs on the floor, then move the stove aside and mark the position of the floor protector.
8. The floor protector must be of non-combustible material and must extend 16" (406mm) (USA) in front of the door opening and 8" (203mm) to the sides and rear of the unit. Some areas may require a larger size floor protector. See your local inspector. For outside air installation refer to Mobile Home installation instructions within this manual.
9. When the floor protection is complete, position the stove with the flue collar centered under the installed chimney.
10. In areas with frequent seismic activity, Regency recommends that your unit is secured to the floor by using the bolt down holes inside the pedestal (the same ones used in Mobile Home installations).

NOTE: In Canada, floor protection must extend 18" (450mm) to the front and 8" (203mm) to each side and back of the stove.

11. For residential installations 6" (single wall OK) double wall chimney, the chimney connector must be at least 24 gauge steel. Do not use galvanized pipe. For Mobile Home installation refer to the Mobile Home installation instructions within this manual.

12. DO NOT CONNECT THIS UNIT TO A CHIMNEY SERVING ANOTHER APPLIANCE.

13. A chimney connector cannot pass through an attic or roof space, closet or similar concealed space, or a floor, ceiling, wall or partition of combustible construction. In Canada, if passage through a wall, or partition of combustible construction is desired, the installation shall conform to CAN/CSA-B365, Installation Code for Solid-Fuel-Burning Appliances and Equipment.

14. Your Regency Woodstove is not to be connected to any air distribution duct.

CAUTION:
Do not alter or makeshift chimney or install. Install as per Manual.

IMPORTANT:
During the first few fires, a white film may develop on the glass front as part of the curing process. **The glass should be cleaned** or the film will bake on and become very difficult to remove. Use a non-abrasive cleaner and **NEVER** clean the glass while it is hot.

IMPORTANT:
Smoke and CO Detectors:
Make sure your home has a working smoke and CO detector, especially near any bedrooms. We recommend having a smoke and CO detector in the same room as the wood appliance for additional safety. Location of both detectors should be chosen wisely to avoid false alarms when reloading the appliance.

Fire Extinguisher:
A fire extinguisher should be installed in the home. The location of the fire extinguisher should be known by all family members.

Modular Installation Options

WARNING: ONLY USE SPECIFIED COMPONENTS.

The following items are required when assembling your Regency Stove. F2450M unit - the Rear Heat Deflector is supplied with the stove, but if you choose not to use it you must use the Airmate instead

| | |
|---------------------------------------|---|
| Modular Part | See the Minimum Clearance to Combustible Materials chart in the Installation section of this manual |
| F2450M Airmate OR Rear Heat Deflector | Convection heat with Airmate vs. Radiant Heat with Rear Heat Deflector. The Airmate pushes heat forward out into the room, the Rear Heat Deflector deflects the heat upward. Refer to the Installation sections within this manual. |
| OPTIONS : | |
| Blower/ Fan | Adding the blower will increase the area heated by the stove, it can move warm air beyond the room where the stove |
| Ash Drawer Kit | Adding the Ash Drawer Kit makes cleaning ashes out of the stove easier and cleaner (refer to Bottom Shield Ash Drawer Kit, Installation section) |
| Outside Air Kit | Allows outside combustion air to enter firebox |
| Bottom heat shield + legs | Used instead of pedestal |
| Pedestal | Used instead of heat shield and legs |

Stove Assembly Prior to Installation

The F2450M unit requires the pedestal (or heat shield and legs) to be attached to the base. The F2450M stove requires either the Airmate or Rear Heat Deflector on top of the stove. Clearances to combustible materials vary depending on whether the Airmate or rear heat deflector is installed, so be sure to check the Minimum Clearances, Installation section.

Airmate Assembly for F2450M

1. The Airmate sits on top of the stove with the slots in the sides fitting over the curved deflector on the rear stove top. See diagram 1. Discard the Rear Heat Deflector that is supplied with the unit, it is not required if the Airmate is installed.
2. Center the Airmate and push it forward to the front of the stove. The back of the Airmate should be level with the back and sides of the rear heat shield. See Diagrams 2 & 3.




Diagram 1




Diagram 2




Diagram 3

Rear Heat Deflector Assembly for F2450M

The rear heat deflector is supplied with the stove and must be installed unless the optional Airmate has been selected. It stops the heat radiated from the flue collar from overheating the rear wall. The rear heat deflector is installed on top of the rear heat shield, as shown in Diagram 4.




Diagram 4

Side Shield Adjustment

The left and right side shields are lowered for shipping and handling. It allows for a handhold on the top of the stove. Before placing the stove in its final position, the side shields must be raised.

Loosen the screws on the rear on the stove (3 per side), slide the side panel up as far as possible and then secure by tightening the screws.




Diagram 5


installation

Pedestal Assembly Installation

1. For easier assembly, tip the stove on its back (onto a soft surface to prevent scratching) and remove the front cover.

Hint: If you have chosen the Ash Drawer option, remove the ash dump cover plates before attaching the pedestal (refer to the Ash drawer Kit Installation section).


2. Important: Remove the blanking plate if:
 - a) you are not installing outside combustion air or
 - b) outside air is to be brought in from the rear of the stove (see below).
3. Using the 4 supplied 5/16" bolts in the under-side of the stove, insert the bolts loosely onto the threads located at all 4 corners at the base of the unit. Align the holes in the corners of the pedestal top with the corresponding bolts in the base of the stove. Tighten each bolt from inside the pedestal.



Shown with Classic door

Logo Installation

1. Push the Regency logo into the two holes in the bottom left corner of the pedestal cover plate.



Note: Any paint touch up should be done prior to placing logo on pedestal.



2. If not using ash drawer, then the front cover must remain in place. If using ash drawer, then remove the front cover.

Bottom Heat Shield and Legs Installation

The instructions below apply to the painted cast leg. It will be easier to attach the legs to the stove if the stove is tipped on its back (preferably on a soft surface to prevent scratching). Ensure to be extremely careful when tipping stove.

Important: Prior to installing the bottom heat shield, remove the 4 inch blanking plate. See below. This must be removed for combustion air to enter the appliance.

1. Remove the 4 bolts from underside of the base of the pedestal and discard. Also remove cover plate and put to the side.
2. Line up the heat shield with the bottom of the unit.
3. Add fibre washers and washers.
4. Start threading the bolt and washer (supplied with the bottom shield) for about 1/4 of the way through the leg with the washers being underneath the legs. Ensure that the legs are properly aligned with heat shield and tighten the bolts.
5. Level the stove by adjusting the levelling bolts in the bottom of each leg.



6. Reinstall cover plate if not using ash drawer option.
7. Install logo plate onto heat shield by placing in 2 holes as shown in diagram.

If you are installing outside combustion air, bend the tabs out 90 degrees. Pipe fresh air into the bottom shield by using a minimum 4" duct pipe with a mesh grill at the outside termination. Attach the pipe to the 2 tabs with screws.

Room Air - Important

For installation using room air for combustion, remove knockout from the pedestal, and/or from the bottom if using a heat shield.

Mobile home installations require the use of outside air.

On pedestal units there are two locations where outside air may be adapted to the unit. If using the bottom of the pedestal, do not remove knockout from the rear of the pedestal. Only remove rear knockout if outside air will be brought in from the rear.

On leg units outside air can only be brought in from the bottom of the heat shield.

Note: Once the knockout is removed there are two tabs remaining. Bend both tabs out for ease of installation when attaching outside air.

Minimum Clearance To Combustible Materials

Please read the section below carefully as clearances depend on whether the airmate or the rear heat deflector is installed on the stove.


Measurements "From Unit" are from the top plate of the stove to a side wall or to a corner, and from the rear heat shield to a back wall.

Clearances may only be reduced by means approved by the regulatory authority.

Minimum ceiling height - 83" (2108mm)

NOTE: This clearance is also required for air space between the appliance and wall/ceiling.

NOTE: Be aware that local Codes and Regulations may override some clearances listed in this manual. Check with your local inspector.



| Residential Installation "C" Vent (Single Wall) | | | | | | |
|---|-------------|---------------|-------------|-------------|-----------------------|-------------|
| Unit | From Unit | | From Corner | | From Flue Center-Line | |
| | A | B | C | D | E | F |
| Medium F2450M with Airmate | 16" (406mm) | 9.5" (241mm) | 8" (203mm) | 28" (711mm) | 16" (406mm) | 20" (508mm) |
| with Rear Deflector | 16" (406mm) | 11.5" (292mm) | 8" (203mm) | 28" (711mm) | 18" (457mm) | 20" (508mm) |
| Residential Close Clearance (To be installed with required pipe components) | | | | | | |
| When the stove is installed as a close clearance residential unit, a listed double wall connector is required from the stove collar to the ceiling level. | | | | | | |
| Unit | From Unit | | From Corner | | From Flue Center-Line | |
| | A | B | C | D | E | F |
| Medium F2450M with Airmate | 15" (381mm) | 8" (203mm) | 6" (152mm) | 27" (686mm) | 14.5" (368mm) | 18" (457mm) |
| with Rear Deflector | 15" (381mm) | 10" (254mm) | 6" (152mm) | 27" (686mm) | 16.5" (419mm) | 18" (457mm) |
| Mobile Home Close Clearance (To be installed with required pipe components) | | | | | | |
| "C" Vent single wall pipe is not approved for Mobile Home installations. (Refer to Mobile Home Instructions.) | | | | | | |
| Unit | From Unit | | From Corner | | From Flue Center-Line | |
| | A | B | C | D | E | F |
| Medium F2450M with Airmate | 15" (381mm) | 8" (203mm) | 6" (152mm) | 27" (686mm) | 14.5" (368mm) | 18" (457mm) |
| with Rear Deflector | 15" (381mm) | 10" (254mm) | 6" (152mm) | 27" (686mm) | 16.5" (419mm) | 18" (457mm) |


installation

Minimum Alcove Clearance and Clearance to Combustible Materials

The Regency Freestanding models have been alcove approved and must be installed with a listed double wall connector to the ceiling level.

Note: Minimum alcove ceiling height - 83"
Maximum depth of alcove - 48"

NOTE: This clearance is also required for air space between the appliance and wall/ceiling. Where the appliance is installed less than 8" from a rear wall, the ember pad only needs to extend to the base of the wall based on the clearances noted in this manual.



| Unit | From Unit | | From Flue Center-Line | | From Wall |
|-----------------------------------|-------------|-------------|-----------------------|---------------|--------------|
| | G | H | I | J | K |
| Medium F2450M with Airmate | 15" (381mm) | 8" (203mm) | 27" (686mm) | 14.5" (368mm) | 54" (1372mm) |
| with Rear Deflector | 15" (381mm) | 10" (254mm) | 27" (686mm) | 16.5" (419mm) | 54" (1372mm) |


Floor Protection

(Ember Protection only required)

A combustible floor must be protected by a non-combustible material (like tile, concrete board, or certified to UL-1618 Type 1, or as defined by local codes).

Canada: Beneath the heater and extending to at least 18" on the fuel loading side and at least 8" on the sides and back.

USA: Beneath the heater and extending to at least 16" beyond the fuel loading side and ash removal opening and at least 8" on the sides and back and under the chimney connector extending 2" beyond each side for horizontal applications.



| Minimum Overall Depth (Y) of Floor Protector | | | | | |
|--|--------|---|-------------|--|------------|
| Unit | | Edge of Fuel door opening to edge of hearth | | Edge of Fuel Door Opening (Both Sides) | |
| | | A | B | C | D |
| F2450M | Canada | 49" (1245mm) | 18" (457mm) | 33 11/16" (856 mm) | 8" (203mm) |
| | USA | 47" (1194mm) | 16" (406mm) | 33 11/16" (856 mm) | 8" (203mm) |

| Minimum Overall Depth (Y) of Floor Protector | | | | | |
|--|--------|------------------|---|-------------------|--|
| Reference only when hearth pad is installed to rear wall at minimum pipe clearances. | | Hearth Depth | Edge of Fuel door opening to edge of hearth | Hearth Width | Edge of Fuel Door Opening (Both Sides) |
| Residential Installation "C" Vent (Single Wall) | | | | | |
| Unit | | A | B | C | D |
| F2450M with Airmate | Canada | 50-1/2" (1283mm) | 18" (457mm) | 33-11/16" (856mm) | 8" (203mm) |
| | USA | 48-1/2" (1232mm) | 16" (406mm) | 33-11/16" (856mm) | 8" (203mm) |
| F2450M with Rear Deflector | Canada | 52-1/2" (1334mm) | 18" (457mm) | 33-11/16" (856mm) | 8" (203mm) |
| | USA | 50-1/2" (1283mm) | 16" (406mm) | 33-11/16" (856mm) | 8" (203mm) |
| Residential Close Clearance (To be installed with required pipe components) | | | | | |
| Unit | | A | B | C | D |
| F2450M with Airmate | Canada | 48" (1219mm) | 18" (457mm) | 33-11/16" (856mm) | 8" (203mm) |
| | USA | 46" (1168mm) | 16" (406mm) | 33-11/16" (856mm) | 8" (203mm) |
| F2450M with Rear Deflector | Canada | 50" (1270mm) | 18" (457mm) | 33-11/16" (856mm) | 8" (203mm) |
| | USA | 48" (1219mm) | 16" (406mm) | 33-11/16" (856mm) | 8" (203mm) |

Floor Protection (Corner Installation)


A combustible floor must be protected by non-combustible material (like tile, concrete board, or certified to UL-1618 or as defined by local codes) extending beneath the heater and a minimum of 8" (203mm) from each side and minimum 16" (406mm)** from the front face of the stove and minimum 6" (152mm)** (or the rear clearance to combustibles whichever is smaller) from the rear of the stove.

When installed with horizontal venting, non-combustible floor protection must beneath the flue pipe and extend 2" (51mm) beyond each side.

Minimum Overall Width (X) of Floor Protector for all installations:

| | | |
|-------|--------|-------------------|
| Stove | F2450M | 33-11/16" (856mm) |
|-------|--------|-------------------|


for angled corners



****NOTE: In Canada, floor protection must extend 18" (450mm) to the front and 8" (203mm) to back of the stove.**

| Minimum Overall Depth (Y) of Floor Protector | | | |
|--|---|--------------|--------------------------------|
| Unit | Residential "C" Vent | | From Edge of Fuel Door Opening |
| | Y | Z | W |
| Medium F2450M | Canada - 49" (1245mm) USA - 47" (1194mm) | **6" (152mm) | 8" (203mm) |

| Minimum Overall Depth (Y) of Floor Protector - Corner Hearth | | | | |
|--|-------------------|-------------------|------------------|------------------|
| Reference only when hearth pad is installed to rear wall at minimum pipe clearances. | | | | |
| | Hearth Depth | | | |
| F2450M | L | M | N | O |
| Residential Installation "C" Vent (Single Wall) | | | | |
| Canada | 33-11/16" (856mm) | 62-7/8" (1596mm) | 52-1/8" (1324mm) | 28-5/16" (727mm) |
| USA | 33-11/16" (856mm) | 60-7/8" (1545mm) | 50-3/4" (1289mm) | 26-7/8" (681mm) |
| Residential Close Clearance (To be installed with required pipe components) | | | | |
| Canada | 33-11/16" (856mm) | 60-1/16" (1527mm) | 50-1/8" (1273mm) | 26-5/16" (676mm) |
| USA | 33-11/16" (856mm) | 58-1/16" (1475mm) | 48-3/4" (1238mm) | 24-7/8" (610mm) |



installation

This stove may be connected to a lined masonry chimney or a listed factory built chimney suitable for use with solid fuels and conforming to ULC629 in Canada or UL-103HT in the USA. Do not connect it to a chimney serving another appliance. To do so will affect the safe operation of both appliances, and will void the stove warranty. You must comply with the local authority having jurisdiction and/or in Canada, CSA installation standard B365-M87.


The chimney connector must be 6" diameter, 24 MSG Black/Blue steel. Do not use aluminum or galvanized steel, they cannot properly withstand the extreme temperatures of a wood fire. The chimney connector between the stove and the chimney should be as short and direct as possible.

The chimney connector must be attached to either an approved masonry chimney or one of the listed factory built chimneys suitable for use with solid wood fuel. All joints must be tight and fastened with sheet metal screws.

Step-By-Step Chimney And Connector Installation

Note: These are a generic set of chimney installation instructions. Always follow the manufacturers own instructions explicitly. Check the Minimum Recommended Flue Heights section (Table 1).

1. With your location already established, cut and frame the roof hole. It is recommended that no ceiling support member be cut for chimney and support box installation. If it is necessary to cut them, the members must be made structurally sound.
2. Install radiant shield and support from above.
3. Stack the insulated pipe onto your finish support to a minimum height of 3 feet above the roof penetration, or 2 feet above any point within 10 feet measured horizontally. There must be at least 3 feet of chimney above the roof level.





Note: Increasing the chimney height above this minimum level will sometimes help your unit to "breathe" better by allowing a greater draft to be created. This greater draft can decrease problems such as, difficult startups, back-smoking when door is open, and dirty glass. It might be sufficient to initially try with the minimum required height, and then if problems do arise add additional height at a later date.

4. Slide the roof flashing over your chimney and seal the flashing to the roof with roofing compound. Secure the flashing to your roof with nails or screws.
5. Place the storm collar over the flashing, sealing the joints with a silicone caulking.
6. Fasten the raincap with spark screens (if required) to the top of your chimney.
7. To complete your chimney installation, install the double wall connector pipe from the stove's flue collar to the chimney support device.

8. If you are using a horizontal connector, the chimney connector should be as high as possible while still maintaining the 18" (457mm) minimum distance from the horizontal connector to the ceiling.

NOTE: Residential Close Clearance and Alcove installations require a listed double wall connector from the stove collar to the ceiling level.

The diagrams below illustrate one way to install your unit into a standard ceiling or with a horizontal connector. Check with your dealer or installer for information on other options available to you.



⚠ WARNING

THE CHIMNEY CONNECTOR IS TO BE USED ONLY WITHIN THE ROOM, BETWEEN THE STOVE AND CEILING/ WALL. NEVER USE A CHIMNEY CONNECTOR TO PASS THROUGH AN ATTIC OR ROOF SPACE, CLOSET OR SIMILAR CONCEALED SPACE, OR A FLOOR, OR CEILING. AN EFFECTIVE VAPOR BARRIER MUST BE MAINTAINED AT THE LOCATION WHERE THE CHIMNEY OR COMPONENT PENETRATES TO THE EXTERIOR OF THE STRUCTURE. ALWAYS MAINTAIN THE MINIMUM CLEARANCES TO COMBUSTIBLES AS REQUIRED BY THE APPLICABLE BUILDING CODES.


Masonry Chimney

Ensure that a masonry chimney meets the minimum standards of the National Fire Protection Association (NFPA) by having it inspected by a professional. Make sure there are no cracks, loose mortar or other signs of deterioration and blockage. Have the chimney cleaned before the stove is installed and operated. When connecting the stove through a combustible wall to a masonry chimney, special methods are needed.

Ensure that an effective vapour barrier at the location where the chimney or other component penetrates to the exterior of the structure.

When referencing installation or connection to masonry fireplaces or chimneys, the masonry construction must or shall be code complying.

This unit is designed to use either a 5.5" (140mm) or 6" (152mm) flue liner only in the confines of the masonry chimney.




Masonry Fireplace

There are listed kits available to connect a stove to a masonry fireplace. The kit is an adapter that is installed at the location of the fireplace damper. The existing damper may have to be removed to allow installation.

Ensure that an effective vapour barrier at the location where the chimney or other component penetrates to the exterior of the structure.

This unit is designed to use either a 5.5" (140mm) or 6" (152mm) flue liner only in the confines of the masonry chimney as shown.

When referencing installation or connection to masonry fireplaces or chimneys, the masonry construction must or shall be code complying.



Factory Built Chimney


When a metal prefabricated chimney is used, the manufacturer's installation instructions must be followed. You must also purchase and install the ceiling support package or wall pass-through and "T" section package, firestops (where needed), insulation shield, roof flashing, chimney cap, etc. Maintain proper clearance to the structure as recommended by the manufacturer. The chimney must be the required height above the roof or other obstructions for safety and proper draft operation. The space heater is to be connected to a factory-built chimney conforming to CAN/ULC-S629, Standard for 650°C Factory-Built Chimneys.

installation

Combustible Wall Chimney Connector Pass-throughs


Method A: 12" (304.8 mm) Clearance to Combustible Wall Member:

Using a minimum thickness 3.5" (89 mm) brick and a 5/8" (15.9 mm) minimum wall thickness clay liner, construct a wall pass-through. The clay liner must conform to ASTM C315 (Standard Specification for Clay Fire Linings) or its equivalent. Keep a minimum of 12" (304.8 mm) of brick masonry between the clay liner and wall combustibles. The clay liner shall run from the brick masonry outer surface to the inner surface of the chimney flue liner but not past the inner surface. Firmly grout or cement the clay liner in place to the chimney flue liner.




Method B: 9" (228.6 mm) Clearance to Combustible Wall Member:

Using a 6" (152.4 mm) inside diameter, listed, factory-built Solid-Pak chimney section with insulation of 1" (25.4 mm) or more, build a wall pass-through with a minimum 9" (228.6 mm) air space between the outer wall of the chimney length and wall combustibles. Use sheet metal supports fastened securely to wall surfaces on all sides, to maintain the 9" (228.6 mm) air space. When fastening supports to chimney length, do not penetrate the chimney liner (the inside wall of the Solid-Pak chimney). The inner end of the Solid-Pak chimney section shall be flush with the inside of the masonry chimney flue, and sealed with a non-water soluble refractory cement. Use this cement to also seal to the brick masonry penetration.




Method C: 6" (152.4 mm) Clearance to Combustible Wall Member:

Starting with a minimum 24 gage (.024" [61 mm]) 6" (152.4 mm) metal chimney connector, and a minimum 24 gage ventilated wall thimble which has two air channels of 1" (25.4 mm) each, construct a wall pass-through. There shall be a minimum 6" (152.4 mm) separation area containing fiberglass insulation, from the outer surface of the wall thimble to wall combustibles. Support the wall thimble, and cover its opening with a 24-gage minimum sheet metal support. Maintain the 6" (152.4 mm) space. There should also be a support sized to fit and hold the metal chimney connector. See that the supports are fastened securely to wall surfaces on all sides. Make sure fasteners used to secure the metal chimney connector do not penetrate chimney flue liner.



Method D: 2" (50.8 mm) Clearance to Combustible Wall Member:

Start with a solid-pak listed factory built chimney section at least 12" (304 mm) long, with insulation of 1" (25.4 mm) or more, and an inside diameter of 6" (2 inches [51 mm] larger than the 6" [152.4 mm] chimney connector). Use this as a pass-through for a minimum 24-gage single wall steel chimney connector. Keep solid-pak section concentric with and spaced 1" (25.4 mm) off the chimney connector by way of sheet metal support plates at both ends of chimney section. Cover opening with and support chimney section on both sides with 24 gage minimum sheet metal supports. See that the supports are fastened securely to wall surfaces on all sides. Make sure fasteners used to secure the metal chimney connector do not penetrate chimney flue liner.



Mobile Home Installation

For Canadian Installations : see Outside Air Kit - Part # 846-502.

There are further requirements when installing this unit into a mobile home in Canada only.

Once you have properly marked the position of your unit and the floor protection as outlined in the Residential Installation items #1 through #8, a supply of fresh air has to be supplied to your unit.


See Optional Outside Air Kit instructions in this manual.

Place your unit in position and secure it to the floor using two lag bolts 3/8" (10mm) x 3-1/2" (89mm) through the two holes inside the pedestal base. It is important to maintain the structural integrity of the Mobile Home floor, walls and roof when installing your unit.

For Mobile Home units installed in the U.S. the unit must be grounded using a #8 ground wire with approved termination and star washer.

CAUTION: At no time use unlabelled parts, or substitute parts made for another chimney system.

Install as per chimney manufacturer's installation instructions.



WARNING: Operate only with door fully closed - open feed door to feed fire only.

1. Identify the position of the outside air damper by the orientation of the metal handle that rests outside the galvanized pipe. The metal handle and the damper disc are in line with each other. This means that if the metal handle is in a horizontal position, the damper is flat and fully open.
2. Open the damper fully whenever you start a fire. This will allow the outside air to be drawn in the pedestal base eliminating any potential smoke escaping the stove and entering the room. (Negative air pressure)

In addition to standard installation instructions the following requirements are mandatory for installation in a mobile home.

1. **The stove must be permanently bolted to the floor of the Mobile Home using the floor screws provided.**
2. The stove must have a permanent outside air source for combustion.
3. The stove must be electrically grounded to the steel chassis of the Mobile Home.
4. A listed double-wall connector chimney system, roof thimble, spark arrestor and roof flashing kit suitable for use in Mobile Homes must be used.
5. If the chimney exits the Mobile Home at a location other than through the roof, and exits at a point 7ft. (2130mm) or less above the ground level on which the Mobile Home is positioned a guard or method of enclosing the chimney shall be fitted at the point of exit for a height up to 7ft. (2130mm).
6. The chimney shall be attached directly to the room heater and shall extend at least 3 ft. (914mm) above the part of the roof through which it passes. The top of the chimney should project at least 2ft. (610mm) above the highest elevation of any part of the Mobile Home within 10 ft. (3048mm) of the chimney.
7. The chimney system shall comply with Local Requirements.
8. Any openings in a chimney guard where required must not permit the entrance of 3/4" (19mm) diameter rod.
9. **CAUTION: THE STRUCTURAL INTEGRITY OF THE MOBILE HOME ROOF, FLOOR, WALLS AND CEILING MUST BE MAINTAINED.**
10. Check any other local building code as other local codes may apply.
11. **WARNING: DO NOT INSTALL IN A SLEEPING ROOM OF A MOBILE HOME.**
12. Use silicone to create an effective vapour barrier at the location where the chimney or other component penetrates to the exterior of the structure.

installation

Mobile Home Kit - for Canada

Note: The optional ashdrawer cannot be used when using the Mobile Home Kit.

The Mobile Home kit contains:

- 1 Bottom metal cover - only used when air is drawn from the floor.
- 1 Flex
- 1 Collar
- 1 Mobile home box
- 1 Square transition box (used when installing bottom heat shield/ legs)
- Screws

5. Attach flex to rear pedestal using supplied screws or the 4" clamp.
6. Bring pedestal base near the base of the firebox and secure flex to the Mobile Home box.
7. Secure pedestal base and Mobile Home Box to firebox as shown in diagram 3 using the screws that were previously removed/ loosened in step 1. See pedestal instructions. The Mobile Home Box and firebox use the same screws.

1. Lay unit on its back. Remove two front 7/16 bolts. Loosen rear two 7/16" bolts. See diagram 1.




Diagram 1

2. If using outside air from the rear of the pedestal, follow instructions noted below. If using outside air from the pedestal base, follow instructions from step 10 to 16. For bottom heat shield/ legs, follow instructions from step 17 to 22. The Mobile Home Box is always mounted in between the firebox and pedestal or bottom heat shield.

3. Remove the 4" knock out from the rear pedestal.

4. Install rear collar to the rear pedestal using 4 screws.




Diagram 2

Install rear collar to the rear pedestal using 4 screws.




Diagram 3




Diagram 4

8. Install blanking plate to the front of the pedestal with 4 screws.





Diagram 5

9. Place unit into position and install the mandatory outside air kit. See «Mobile Home installation» section in this manual.


Installing Outside Air from Pedestal Base

If installing outside air from pedestal base, do not remove knock out from rear of pedestal. This must remain in place.



10. Secure collar to base of unit with 4 screws.
11. Install bottom metal cover over collar installed in step 10 and rest cover on pedestal base.
12. Secure flex to collar with supplied screws or the 4" clamp.
13. Bring pedestal base near the base of the firebox and secure flex to mobile home box with supplied screws.
14. Secure Mobile Home Box and pedestal to the firebox base using the screws that were previously removed in step 1. See pedestal instructions.
15. Install blanking plate to the front of the pedestal with 4 screws. Use picture from step 8.
16. Install the mandatory outside air kit. See «Mobile Home Installation» section in this manual. Place unit into its final position to complete install.

Installing Outside Air Using Bottom Heat Shield/Legs



17. Remove knock out from the bottom heat shield and bend tabs left over when the knock out was removed to the side.
18. Secure collar to base of bottom heat shield as shown with 4 screws.
19. Secure transition box on top of round collar installed in step 18 and secure with 3 screws.
20. Install blanking plate if not already installed.
21. Secure Mobile Home Box and bottom heat shield. See bottom heat shield/leg instructions.
22. Install the mandatory outside air kit. See «Mobile Home Installation» section in this manual. Place unit into its final position to complete install.

TABLE 1

| MINIMUM RECOMMENDED FLUE HEIGHTS IN FEET | | | | | | | |
|--|--------------------|---------|---------|---------|---------|---------|---------|
| <small>(Measured from the top of the unit)</small> | | | | | | | |
| ELEVATION (FT) ABOVE SEA LEVEL | # OF ELBOWS | | | | | | |
| | 0 | 2 x 15° | 4 x 15° | 2 x 30° | 4 x 30° | 2 x 45° | 4 x 45° |
| 0-1000 | 12.0 | 13.0 | 14.0 | 15.0 | 18.0 | 16.0 | 20.0 |
| 1000-2000 | 12.5 | 13.5 | 14.5 | 15.5 | 19.0 | 16.5 | 21.0 |
| 2000-3000 | 13.0 | 14.0 | 15.0 | 16.0 | 19.5 | 17.0 | 21.5 |
| 3000-4000 | 13.5 | 14.5 | 15.5 | 17.0 | 20.0 | 18.0 | 22.5 |
| 4000-5000 | 14.0 | 15.0 | 16.0 | 17.5 | 21.0 | 18.5 | 23.0 |
| 5000-6000 | 14.5 | 15.5 | 17.0 | 18.0 | 21.5 | 19.0 | 24.0 |
| 6000-7000 | 15.0 | 16.0 | 17.5 | 18.5 | 22.5 | 20.0 | 25.0 |
| 7000-8000 | 15.5 | 16.5 | 18.0 | 19.0 | 23.0 | 20.5 | 25.5 |
| 8000-9000 | 16.0 | 17.0 | 18.5 | 20.0 | 24.0 | 21.0 | 26.5 |
| 9000-10000 | 16.5 | 17.5 | 19.0 | 20.5 | 24.5 | 22.0 | 27.0 |

NOTE: No more than two offsets (four elbows) allowed. Two 45° elbows equal one 90° elbow.

Recommended Heights For Woodstove Flue

Simple rules on draft. See Table 1.

- 1) At sea level minimum height is 12' straight.
- 2) Add the following vertical height to compensate for:
 45 deg. elbow = 1 ft.
 90 deg. elbow = 2 ft.
 "T" = 3 ft.
 Each foot of horizontal run = 2 ft.
- 3) Add 4% overall for each 1000' above sea level.

Example: a)
 1-1/2 ft. of horizontal run = 3 ft.
 one "T" = 3 ft.
 Total Addition (at sea level) = 6 ft.

Example: b)
 One 90 deg. elbow = 2 ft.
 2 ft. of horizontal run = 4 ft.
 one "T" = 3 ft.
 Total Addition (at sea level) = 9 ft.

Draft is the force which moves air from the appliance up through the chimney. The amount of draft in your chimney depends on the length of the chimney, local geography, nearby obstructions and other factors. Too much draft may cause excessive temperatures in the appliance and may cause damage. An uncontrollable burn or excessive temperature indicates excessive draft. Inadequate draft may cause back puffing into the room and plugging of the chimney. Inadequate draft will cause the appliance to leak smoke into the room through appliance and chimney connector joints. Ensure the heater is installed in areas that are not too close to neighbors or in valleys that would cause unhealthy air quality or nuisance conditions.

Recommended Flue Height

| Elevation | Example a) | Example b) |
|-----------|------------|------------|
| 0' | 18' | 21' |
| 1000' | 18.72' | 21.84' |
| 2000' | 19.44' | 22.68' |
| 5000' | 21.60' | 25.20' |
| 8000' | 23.76' | 27.72' |

WARNING:
DO NOT INSTALL IN SLEEPING ROOM

CAUTION: The structural integrity of the mobile home floor, wall and ceiling/roof must be maintained.

Optional Outside Air Kit

The Outside Air Kit is an option for Freestanding Stoves. Outside air for combustion can be brought in either through the bottom of the pedestal or through the rear plate of the pedestal.

For both bottom and rear outside air the Pedestal Cover Plate must be installed. Loosen the 4 screws on the rear of the pedestal and slide the cover plate over them. Slide the plate to the left to center it and tighten down the 4 screws.


Damper Installation

NOTE: The damper cannot be installed if attaching outside air to the bottom of the appliance.

Supplied damper allows the combustion air to be closed off when unit is not in operation.

Install the damper within the round pipe in an easily accessible location.


1. Drill a 5/16" hole in the desired location.
2. Insert damper with threaded section out.
3. Install damper handle and secure with wing nut.



Outside Air Through Pedestal Rear


Remove the blanking plate from the rear of the pedestal and bend the two tabs out 90 degrees. Pipe fresh air into the pedestal area by using a minimum 4" metallic duct pipe with a mesh grill at the outside termination.

Fasten the pipe to the cover plate using the tabs and 2 screws.



Outside Air Through Pedestal Bottom

Mark the position of your unit as outlined in the "General Information" and "Clearances to Combustibles" section of the manual. Pipe fresh air into the pedestal area by using a minimum 4" duct pipe with a mesh grill at the outside termination.




installation

Brick Installation


Firebrick is included to extend the life of your stove and radiate heat more evenly. Check to see that all firebricks are in their correct positions and have not become misaligned during shipping. Install all firebricks (if bricks were removed at install) per the diagram below and place in their correct positions.

Do not use a grate.



Order of firebrick install:

- Rear Firebrick
- Firebox floor - install brick over LyTherm Sheet
- Right and left side Firebricks



| | |
|-----|---|
| 70) | Brick - Regular Full Size: 1-1/4" x 4-1/2" x 9" |
| 72) | Brick Partial: 1-1/4" x 2" x 4-1/2" |
| 74) | Brick Partial: 1-1/4" x 4-1/2" x 3-1/2" |
| 76) | Brick Partial: 1-1/4" x 2" x 9" |

NOTE: The "AD" brick in the drawings above is the brick covering the Ash Dump hole that is used when the Ash Drawer Kit is installed (refer to the Listed Components for Mobile Home Installation section).

Wood Handle & Door Assembly

1. In preparation of installing the door handle, the nuts, cam, washers and spacer must be removed as shown in Diagram 1.




Diagram 1

LATCH ADJUSTMENT

The door latch may require adjustment as the door gasket material compresses over time. Removal of 1 or 2 washers will allow the latch to move closer to the door frame, causing a tighter seal. (Refer to Diagram 1)

2. Place the door onto the hinges and then place the door handle through the opening on the door, as shown in Diagram 2.

Re-assemble and secure the door handle components in reverse order as removed in step 1, refer to Diagram 1.

3. Put the hinge cover caps on top of hinges to complete the door installation.

Note: The bottom of the door may scrape the ashlip. In this case place the spacers provided on the door hinges of the unit before placing the door.

4. Close door and ensure there is a tight seal. If door is too tight, a washer can be added. If the door is not creating a tight seal, a washer can be removed. Recheck door to ensure there is still a tight seal. Repeat steps if door seal is still not tight until a tight seal has been achieved. The handle should be approximately in the 8 o'clock position when door is fully closed. (Diagram 3)




Diagram 2




Diagram 3

installation


Flue Baffle & Secondary Air Tube Installation

The flue baffle system located in the upper area of the firebox is removable to make cleaning your chimney system easier. The baffles must be installed prior to your first fire. **Smoke spillage and draft problems may occur if the baffles are improperly positioned.** Check the position of the baffles on a regular basis as they can be dislodged if too much fuel is forced into the firebox.


Freestanding Stove F2450M

The unit arrives with the 2 baffles and 2 air tubes on the floor of the firebox.


1. Open the door and remove stainless steel smoke deflector - See smoke deflector instructions in this manual.
2. Remove the front secondary air tube with pliers as shown below.



2. Slide the left baffle over the 2 remaining air tubes from the front and then push it to the back.




3. Tilt the left baffle up on top of the side channel and it will leave enough room to position the right baffle in the same manner as Step 1 above. Then reposition the left baffle flat on the air tubes.




Front View

Important: push both baffles so they are tight against the side walls.



Front View

4. Install the 2 front secondary air tubes with pliers and hammer to lock them into place, as shown below.





5. Reverse Step 1.

Fan Installation

1. Remove the two screws from the top of the fan housing.
2. Slide the fan up into the rear heat shield.
3. After aligning holes, secure the fan to the rear heat shield using the two screws removed earlier.

Note: The connection cord should not be in contact with any hot surfaces.

WARNING: FAN ASSEMBLY MUST BE DISCONNECTED FROM THE SOURCE OF ELECTRICAL SUPPLY BEFORE ATTEMPTING THE INSTALLATION.



AUTOMATIC

To operate the fan automatically, push the bottom switch on the side of the fan housing to "AUTO" and the top switch to either "HIGH" or "LOW" for fan speed.

This will allow the fan to turn on as the stove has come up to operating temperature. It will also shut the fan system off after the fire has gone out and the unit cooled to below a useful heat output range.

If the fan cycles on and off continuously the thermo switch sensor is not making contact with the stove body. Remove the fan, bend the bracket closer to the stove and re-install the fan.


MANUAL

To manually operate the fan system push the bottom switch to "MAN" and the top switch to either "HIGH" or "LOW". This will bypass the sensing device and allow full control of the fan.

Switching from "AUTO" to "MAN" or "HIGH" to "LOW" may be done anytime.

WARNING: Electrical Grounding Instructions
 This appliance is equipped with a three pronged (grounding) plug for your protection against shock hazard and should be plugged directly into a properly grounded three-prong receptacle. Do not cut or remove the grounding prong from this plug.

CAUTION: Label all wires prior to disconnection when servicing controls. Wiring errors can cause improper and dangerous operation.




Wiring Diagram


installation

Stainless Steel Smoke Deflector Installation

The stainless smoke deflector is located in the upper front area of the firebox. The deflector is held in place with 2 bolts. Prior to the first fire, ensure deflector is seated properly and secured with 2 hand tightened bolts.



Smoke deflector Smoke deflector is installed through the door opening in location shown in diagram



Smoke deflector installed with 2 bolts.

Note: This is a view from the back of the unit through the top.

To replace the deflector, loosen off both bolts and slide deflector upward and out. Install new deflector and hand tighten bolts. Ensure positive location of the deflector prior to hand tightening.

WARNING: Operation of the unit with out proper installation of smoke deflector will void warranty.



Ensure deflector is seated so bolts are situated at the top of the keyhole before tightening.

Seasoned Firewood

Whether you burn wood in a fireplace, stove or insert, good quality firewood is the key to convenience, efficiency and safety. Wet wood and pieces that are not the right size and shape for your wood burner can be frustrating, burn inefficiently and deposit creosote that can fuel a dangerous chimney fire. Good planning, seasoning and storage of the firewood supply are essential to successful wood burning.

- Stack the wood in separate rows in an open location where the summer sun can warm it and breezes can carry away the moisture. Do not stack unseasoned wood tightly in an unvented storage area.
- Do not allow firewood to lie on the ground for more than a couple of days before stacking. Mould and rot can set in quickly.
- Stack the wood up off the ground on poles, lumber rails or pallets.
- The top of the pile can be covered to keep off rain, but do not cover the sides.

Softer woods like pine, spruce and poplar/aspen that is cut, split and stacked properly in the early spring maybe be ready for burning in the fall. Extremely hard woods like oak and maple, and large pieces of firewood, may take a minimum of a full year to dry enough. Drying may also take longer in damp climates.

There are a few ways to tell if wood is dry enough to burn efficiently. Use as many indicators as possible to judge the dryness of the firewood your are considering. Here are ways to judge firewood moisture.

- Using a moisture meter, select the species of fuel and then penetrate the pins into a split piece. Ideal moisture and seasoned firewood should be less than 20% moisture content.
- Checks or cracks in the end grain can be an indication of dryness, but may not be a reliable indicator. Some wet wood has checks and some dry wood has no checks.
- The wood tends to darken from white or cream colour to grey or yellow as it dries.
- Two dry pieces banged together sound hollow; wet pieces sound solid and dull.
- Dry wood weighs much less than wet wood.
- Split a piece of wood. If the exposed surface feels damp, the wood is too wet to burn.

Operating Instructions

With your unit now correctly installed and safety inspected by your local authority, you are now ready to start a fire. Before establishing your first fire, it is important that you fully understand the operation of your draft control.

WARNING

Fireplace Stoves equipped with doors should be operated only with doors fully closed. If doors are left partly open, gas and flame may be drawn out of the fireplace stove opening, creating risks from both fire and smoke.

Draft Control

Both the primary and air wash drafts are controlled by the control slide located on the front left side of the unit, below the ashlip (when facing the unit). To increase your draft - slide to the left to open, and to decrease - slide to the right to close. The F2450M unit has a secondary draft system that continually allows combustion air to the induction ports at the top of the firebox.

Draft is the force which moves air from the appliance up through the chimney. The amount of draft in your chimney depends on the length of the chimney, local geography, nearby obstructions and other factors. Too much draft may cause excessive temperatures in the appliance. Inadequate draft may cause back puffing into the room and plugging of the chimney.



Primary Air Damper
Left - Open Right - Closed

WARNING: To build a fire in ignorance or to disregard the information contained in this section can cause serious permanent damage to the unit and void your warranty!!

operating instructions

First Fire

When your installation is completed and inspected you are ready for your first fire.

THIS UNIT IS DESIGNED TO BURN SEASONED CORDWOOD ONLY. COAL, BRIQUETTES AND ALL OTHERS LISTED ON PAGE 2 ARE NOT APPROVED.

SEASONED CORDWOOD SHOULD BE LESS THAN 20% MOISTURE CONTENT.

START UP AND OPERATING PROCEDURES:

1. For the first few days, the wood stove will give off an odour from the paint. This is to be expected as the high temperature paint becomes seasoned. Windows and/or doors should be left open to provide adequate ventilation while this temporary condition exists. Burning the wood stove at a very high temperature the first few times may damage the paint. During the first few fires, keep the combustion rate at a moderate level and avoid a large fire. Only after 5 or 6 such fires can you operate the wood stove at its maximum setting, and only after the metal has been warmed.
2. Do not place anything on the wood stove top during the curing process. This may result in damage to your paint finish.
3. When starting the fire, ensure the air control is in the fully open position (far left). To start a good and clean fire you will need approx. 3 lb kindling and 4 lb start up fuel, wood split slightly larger than kindling, approx. 2 inches thick.
4. Load few pieces of crumpled paper on the bottom and 2 lb of the kindling on top, stacked in a manner that allows air flow on the firebrick hearth (Tee pee style or other). **DO NOT USE A GRATE TO ELEVATE THE FIRE.**
5. Light the paper and adjust the door to establish fire and for less smoke roll out. Wait 2 - 3 minutes for a good updraft in the flue to establish the fire, then close the door. (Leaving the door slightly open will help your fire start more rapidly.)
6. Once most of the kindling has burned down but there are still good flames add the remainder of the kindling and 4-5 pieces of start up wood. Keep the door slightly open until flames are reestablished. (approx. 2 min).
When a good fire is established, add the remainder of the startup wood (5 - 6 more pieces) and keep the door ajar for 1 - 2 minutes.

NOTE: These steps are crucial to ensure proper charcoaling and coal bed prior to loading High, Med and Low fire loads.

7. Once a nice coal bed is established and there are still good sized flames, the main load of larger logs can be loaded into the firebox. Rake the coals to create a uniform charcoal bed. Load 5 - 6 pieces of 17" long logs cord wood front to back, North/South orientation, parallel with the longest firebox dimension, which is the depth of the firebox 20 1/8 inches. Once loaded, keep the door ajar until the flames are established then close the door. Burn on high setting (air control to the far left when facing the unit) for 15 - 30 minutes. After the 15 - 30 minutes, adjust the air control to your desired position. After 20 minutes the fan can be set on high setting.
High Fire: Air control to far left.
Low Fire: Air control to far right.
Med Fire: Air control slightly left of low fire setting. For low and medium fire, adjust the air gradually from high to the desired position.

WARNING: Never build a roaring fire in a cold wood stove. Always warm your wood stove up slowly!

From the start up of a cold stove, a medium to high firing rate must be maintained for 30 min. This ensures that the stove, and fuel are all stabilized at proper operating temperatures. Even though it is possible to have high temperatures within minutes after a fire has been started, if the fire is allowed to die down immediately it may go out. During re-fueling and rekindling of the cool fire, or a fire that has burned down to the charcoal phase, operate the stove at a medium to high firing rate for about 15 - 30 minutes to ensure to reach operating temperatures.

8. During the first few days it may be more difficult to start the fire. As you dry out your firebrick and your masonry flue, your draft will increase.
9. For those units installed at higher elevations or into sub-standard masonry fireplaces, drafting problems may occur. Consult an experienced dealer or mason on methods of increasing your draft.
10. Some cracking and popping noises may be experienced during the heating up process. These noises will be minimal when your unit reaches temperature.
11. All fuel burning appliances consume oxygen during operation. It is important that you supply a source of fresh air to your unit while burning. A slightly opened window is sufficient for the purpose. If you also have another fireplace in your home, a downdraft may be created by your Regency Stove causing a draft down your chimney. If this occurs, slightly open a window near your unit.

WARNING: If the body of your unit, or any part of the chimney connector starts to glow, you are over firing. Stop loading fuel immediately and close the draft control until the glow has completely subsided.

12. Green or wet wood is not recommended for your unit. If you must add wet or green fuel, open the draft control fully until all moisture has been dispersed by the intense fire. Once all moisture has been removed, the draft control may be adjusted to maintain the fire.
13. If you have been burning your stove on a low draft, use caution when opening the door. Open the door a crack, and allow the fire to adjust before fully opening the door.
14. The controls of your unit or the air supply passages should not be altered to increase firing for any reason.
15. If you burn the unit too slowly or at too low a setting your unit will not be operating as efficiently as it can. An easy rule of thumb says that if your glass is clean, then your flue is clean and your exhaust is clean. Burn the stove hot enough to keep your glass clean and you won't need to clean your flue as often.

HOT WHILE IN OPERATION. KEEP CHILDREN, CLOTHING AND FURNITURE AWAY. CONTACT MAY CAUSE SKIN BURNS.

NOTE: Always stir the coal approximately half way through a burn cycle to ensure proper charcoaling.



How to Light and Maintain a Wood Stove Fire

Fan Operation

Automatic

To operate the fan - turn on the rheostat.

This will allow the fan to turn on as the stove has come up to operating temperature. It will also shut the fan system off after the fire has gone out and the unit cooled to below a useful heat output range.

Operate the fan in the low speed position when burning in the LOW-MED LOW heat output ranges and operate in the high setting for MED-HIGH to HIGH heat outputs.

Route power cord to either left or right behind unit.

Ash Disposal


During constant use, ashes should be removed every few days. The Ash Drawer option features a convenient ash dump for easy removal of ash, refer to Modular Installation Options section.

Safety Precautions

1. Do not allow ashes to build up to the loading doors! Only remove ashes when the fire has died down. Even then, expect to find a few hot embers.
2. Please take care to prevent the build-up of ash around the start-up air housing located inside the stove box, under the loading door lip.
3. Never start a fire if the ash plug and ash drawer are not in place. This will cause over firing which can cause excessive warping of the stove. Evidence of over firing can void the warranty on your stove.
4. The firebricks are brittle and can be damaged if the plug is replaced carelessly or pieces that are too large are forced through the hole.


Ash Drawer Operating Guidelines

1. Only clean ashes out of the stove when the unit has cooled down. Remove the plug by lifting on the handle using the tool provided. The plug may still be warm, use caution. Push the ashes down the hole into the ash drawer, the large pieces can be left in the firebox and burned during the next fire or removed through the door opening.
2. Always leave 1/2 to 1 inch of ash in the bottom of the firebox. This helps in easier starting and a more uniform burn of your fire. Replace ash plug when ashes have been removed.



3. Pedestal Units:

To remove the drawer, lift slightly and slide it out. When the drawer is completely out, slide the cover plate over the ash drawer and carry away.



CAUTION: HOT WHILE IN OPERATION. KEEP CHILDREN, CLOTHING AND FURNITURE AWAY. CONTACT MAY CAUSE SKIN BURNS.

4. When emptying the ash drawer, make sure the ashes are cold. Ashes should be placed in a metal container with a tight fitting lid. The closed container of ashes should be placed on a non-combustible floor or on the ground, well away from all combustible materials, pending final disposal. If the ashes are disposed of by burial in soil or otherwise locally dispersed, they should be retained in the closed container until all cinders have thoroughly cooled. Other waste should not be placed in the ash container.
5. Before putting the ash drawer back into place, make sure the ash plug is back in place.

Pedestal Units: make sure the cover lid is off.

Safety Guidelines and Warnings

CAUTION: do not use chemicals or fluids to start fire.

1. **CAUTION:** Never use gasoline, gasoline type lantern fuels, kerosene, charcoal lighter fuel, or similar liquids to start or 'freshen up' a fire in your heater. Keep all such liquids well away from the heater while it is in use.
2. Keep the door closed during operation and maintain all seals in good condition.
3. Do not burn any quantities of paper, garbage, and never burn flammable fluids such as gasoline, naphtha or engine oil in your stove.
4. Do not store solid fuels by the appliance.
5. If you have smoke detectors, prevent smoke spillage as this may set off a false alarm.
6. Do not overfire heater. If the chimney connector, flue baffle or the stove top begin to glow, you are over firing. Stop adding fuel and close the draft control. Over firing can cause extensive damage to your stove including warping and premature steel corrosion. Over firing will void your warranty.
7. Do not permit creosote or soot build-up in the chimney system. Check and clean chimney at regular intervals. Failure to do so can result in a serious chimney fire.
8. Your Regency stove can be very hot. You may be seriously burned if you touch the stove while it is operating, keep children, clothing and furniture away. Warn children of the burn hazard.
9. The stove consumes air while operating, provide adequate ventilation with an air duct or open a window while the stove is in use.
10. Do not connect this unit to a chimney flue serving another appliance.
11. Do not use grates or andirons or other methods for supporting fuel. Burn directly on the bricks.
12. Open the draft control fully for 10 to 15 seconds prior to slowly opening the door when refuelling the fire.
13. Do not connect your unit to any air distribution duct.
14. This heater is designed to burn natural wood only. Higher efficiencies and lower emissions generally result when burning air dried seasoned hardwoods, as compared to softwoods or to green or freshly cut hardwoods.
15. Do not store any fuel closer than 2 feet from your unit. Do not place wood, paper, furniture, drapes or other combustibles near the appliance.

maintenance

16. **WARNING:** Do not operate without either the Ash Plug properly seated or the Ash Dump Plates screwed in place, excessive temperatures will result.
17. **CAUTION:** Do not operate with broken glazing.
18. **WARNING:** Do not use abrasive cleaners to clean the glass window.
19. **WARNING:** Avoid impact on glass doors such as striking or slamming shut.

DO NOT BURN:

- Treated wood
- Coal
- Garbage
- Cardboard
- Solvents
- Colored Paper
- Trash
- Salt drift wood
- Cut lumber, plywood, mill ends
- Kiln dried wood

CAUTION: DO NOT BURN GARBAGE OR FLAMMABLE LIQUIDS SUCH AS GASOLINE, NAPHTHA OR ENGINE OIL. SOME FUELS COULD GENERATE CARBON MONOXIDE AND ARE VERY DANGEROUS.

CAUTION: DO NOT CONNECT TO, OR USE IN CONJUNCTION WITH ANY AIR DISTRIBUTION DUCT WORK UNLESS SPECIFICALLY APPROVED FOR SUCH INSTALLATION.

Classic Door Handle Replacement

1. To remove the wooden door handle from unit—locate the 7/64" Allen key hole at the bottom of wooden handle.




2. Turn the 7/64" Allen key counter-clockwise to loosen the screw. When screw is completely loosened, drop handle down off door shaft and replace with new handle.



Glass Replacement

Your Regency stove is supplied with 5 mm Neoceram ceramic glass that will withstand the highest heat that your unit will produce. In the event that you break your glass by impact, purchase your replacement from an authorized Regency dealer only.

Remove the door from the stove and remove the screws securing the glass retainer. Position the glass in the door, make sure that the glass gasketing will properly seal your unit, and replace the retainer, it should rest on the gasket not the glass. Tighten securely, but do not wrench down on the glass as this may cause the glass to break.



Maintenance

It is very important to carefully maintain your fire-place stove, including burning seasoned wood and maintaining a clean stove and chimney system. Have the chimney cleaned before the burning season and as necessary during the season, as creosote deposits may build up rapidly. Moving parts of your stove require no lubrication.

Creosote

When wood is burned slowly, it produces tar and other organic vapours combine with moisture to form creosote. The creosote vapours condense in the relatively cool chimney flue of a slow burning fire. As a result, creosote residue accumulates on the flue lining. When ignited, this creosote can result in an extremely hot fire.

The chimney connector and chimney should be inspected at least once every two months during the heating season to determine if creosote build up has occurred. If creosote has accumulated it should be removed to reduce the risk of chimney fire.

CAUTION: Things to remember in case of a chimney fire:

1. Close all draft and damper controls.
2. CALL THE FIRE DEPARTMENT.

Ways to Prevent and Keep Unit Free of Creosote

1. Burn stove with the draft control wide open for about 10-15 minutes every morning during burning season.
2. Burn stove with draft control wide open for about 10-15 minutes every time you apply fresh wood. This allows the wood to achieve the charcoal stage faster and burns up any unburned gas vapours which might otherwise be deposited within the system.
3. Only burn seasoned wood! Avoid burning wet or green wood. Seasoned wood has been dried at least one year.
4. A small hot fire is preferable to a large smouldering one that can deposit creosote within the system.
5. Establish a routine for the fuel, wood burner and firing technique. Check daily for creosote buildup.
6. The chimney and chimney connector should be inspected at least once every two months during the heating season to determine if a creosote buildup has occurred.
7. **Have chimney system and unit cleaned by competent chimney sweeps twice a year during the first year of use and at least once a year thereafter or when a significant layer of creosote has accumulated (3 mm/1/8" or more) it should be removed to reduce the risk of a chimney fire.**

- WARNING:** Do not clean the glass when it is hot.
WARNING: Do not use abrasive cleaners, a damp cloth and glass cleaner is effective.
WARNING: Do not use substitute materials.
WARNING: Do not abuse the glass door, such as striking or slamming shut.
WARNING: Do not operate with broken glass.

Wood Storage

Store wood under cover, such as in a shed, or covered with a tarp, plastic, tar paper, sheets of scrap plywood, etc., as uncovered wood can absorb water from rain or snow, delaying the seasoning process.



Door Gasket

If the door gasket requires replacement 7/8" diameter material must be used. Regency uses a 7/8" gasket rope (Part #846-570). A proper high temperature gasket adhesive is required. See your Regency Dealer.

The door catch may require adjustment as the door gasket compresses after a few fires. The door latch compression may require adjustment to renew seal. Removal of a shim, (see section in this manual), will allow the latch to be moved closer to the door frame, causing a tighter seal.

Glass Maintenance


Your Regency stove is supplied with 5mm Neoceram ceramic glass (Part #846-306) that will withstand the highest heat that your unit will produce. In the event that you break your glass by impact, purchase your replacement from an authorized Regency dealer only, and follow our step-by-step instructions for replacement (refer to Glass Replacement section).

Allow the stove to cool down before cleaning the glass. Cleaning the glass will prevent build up of carbon and allow full view of the fire.


maintenance

Secondary Air Tube Removal/Installation

1. Allow the stove to burn out and cool down, until cool to touch.
2. Open stove door to access secondary air tubes.



3. Grasp front secondary air tube firmly with vise grips, using a hammer tap vise grips from right to left until air tube is released from grip. Remove. Repeat step to remove second airtube from front.
4. Remove the fragile two piece Baffles, then remove the remaining 2 tubes.




5. To reinstall or replace, first slide left side of tube into hole on left side air channel. Align tab on right side air channel with notch on right hand end of air tube. Firmly grip center of air tube with vise grips, use hammer to tap vise grips from left to right until the tube bottoms out into the air channel on right.

| Annual Maintenance | |
|--|--|
| Completely clean out entire unit | Annually |
| Inspect air tube, and bricks | Replace any damaged parts. |
| Adjust door catch assembly | If unable to obtain a tight seal on the door - replace door gasket seal. Readjust door catch after new gasket installed. |
| Inspect condition and seal of: Glass Gasket Door Gasket | Perform paper test - replace gasket if required |
| Paper Test | Test the seal on the loading door with a paper bill. Place a paper bill in the gasket area of the door on a cold stove. Close the door. Try to remove the paper by pulling. The paper should not pull out easily, if it does, try adjusting the door latch, if that doesn't solve the problem replace the door gasket. |
| Check and lubricate door hinge + latch | Use only high temperature anti seize lube. (ie. never seize) |
| Check glass for cracks | Replace if required. |
| Clean blower motor | Disconnect power supply. Remove and clean blower. *DO NOT LUBRICATE* |
| Inspect and clean chimney | Annual professional chimney cleaning recommended. |
| NOTE: Chimney Cleaning We highly recommend that the chimney cleaning be done by a professional as they will have the necessary tools such as a proper sized brush and special vacuum cleaner designed to deal with fine particles. | |

IMPORTANT

Before attempting to loosen or remove any bolt from the interior of a wood stove, insert or factory built fireplace, we highly recommend to liberally spray the bolt with a good-quality penetrating oil, one that does not have flammable properties contained within the penetrating oil being used. Allow it to set, then tap or vibrate the bolt to help loosen it before attempting to remove it. For best results, follow the instructions that are provided with the penetrating oil.

Vertical Stainless Deflector Replacement



1. Remove 2 front secondary air tubes / vermiculite baffles as per page 22.
2. Loosen the two 7/16" bolts + nuts to remove / replace vertical deflector.
3. Repeat steps to install new vertical deflector.


NOTE: ENSURE THAT VERTICAL DEFLECTOR IS PUSHED UP AS FAR AS POSSIBLE. TIGHT TO TOP OF FIREBOX.

parts list

Main Assembly

| | Part # | Description |
|-----|-----------|--|
| 1 | 021-006 | Left Side Heat Shield |
| 2 | 021-007 | Right Side Heat Shield |
| 3 | 021-018 | SS Smoke Deflector |
| 4 | 021-020 | Draft Control Lever |
| 6 | 815-557 | Rear Air Deflector |
| 7 | 020-957 | Baffle Bricks Complete (Set Of 2) |
| 8 | 033-953 | 3/4 OD x 19-1/4 Air tube 4 Per Unit (Each) |
| 11 | 846-570 | 7/8" Door Gasket Repair Kit |
| 12 | 846-306 | Replacement Glass - Small (Size :9 1/8" X 15 5/8") |
| 13 | 936-241 | Tape 7/8 Window Adhesive Sold per foot (4 Feet required) |
| 14 | 075-077F | Glass Retainer |
| 15 | 021-973 | Door Handle Assembly Complete |
| 16 | 948-079BN | Hinge Cap Brush Nickel (Each) |
| 17 | 948-146 | Long Black Handle |
| 18 | 850-241 | Black Door - Complete |
| 18 | 850-243 | Black with Nickel Accent Door - Complete |
| 19 | 846-515 | Fan Assembly Complete |
| 20 | 910-138 | 2 Way Switch |
| 21 | 910-140 | 3 way Switch |
| 22 | 850-105 | Airmate |
| 23 | 075-051 | SS Slide Holder |
| 8 | 075-073F | Tool Hanger |
| N/S | 948-223 | Regency Logo Plate |
| N/S | 910-157/P | Fan Motor Only With Squirrel cage |
| N/S | 910-142 | Fan Thermodisc |
| N/S | 021-032/P | Vertical Stainless Deflector |
| N/S | 021-022 | Firebox Floor Gasket |


N/S = Not Shown




parts list

Bases


| | Part # | Description |
|-----|----------|---|
| 40 | 021-911 | Bottom heat Shield |
| 41 | 850-126 | Black Cast legs (Set Of 4) |
| 41 | 850-128 | Nickel Cast legs (Set Of 4) |
| 42 | 075-914 | Ashdrawer Bottom Heat Shield |
| 43 | 942-110 | Ashplug |
| 44 | 820-249 | Ashplug Tool |
| 45 | 021-024 | Blanking Plate |
| N/S | 904-100 | 5/16" x 5 1/2 " Long Hex Head Bolt (Each) |
| N/S | 820-468F | Metal Washer |
| N/S | 820-456 | Metal Spacer/Support Bracket (Each) |



| | Part # | Description |
|-----|---------|-----------------------------------|
| 50 | 021-915 | Pedestal Complete |
| 51 | 075-069 | Pedestal Door |
| 52 | 904-257 | Magnetic Catch (Each) |
| 53 | 075-910 | Ashdrawer |
| N/S | 904-023 | 5/16 x 1-1/2 Hex Head Bolt (Each) |



| 020-960 Brick Kit Complete | |
|--|---|
| 70) | Brick - Regular Full Size: 1-1/4" x 4-1/2" x 9" |
| 72) | Brick Partial: 1-1/4" x 2" x 4-1/2" |
| 74) | Brick Partial: 1-1/4" x 4-1/2" x 3-1/2" |
| 76) | Brick Partial: 1-1/4" x 2" x 9" |
| NOTE: This kit contains one spare brick in case of breakage. | |



warranty

Limited Lifetime Warranty

FPI Fireplace Products International Ltd. (for Canadian customers) and Fireplace Products U.S., Inc. (for U.S. customers) (collectively referred to herein as “FPI”) extends this Limited Lifetime Warranty to the original purchaser of this appliance provided the product remains in the original place of installation. The items covered by this limited warranty and the period of such coverage is set forth in the table below.

Some conditions apply (see below).

The policy is not transferable, amendable, or negotiable under any circumstances.

| Wood Products | Component Coverage | | | | | Labor Coverage (Years) |
|---|--------------------|---------|---------|--------|--------------------|------------------------|
| | Limited Lifetime | 5 years | 2 years | 1 year | Warranty | |
| Welded Firebox Steel | ✓ | | | | | 5 |
| All Stainless Steel Components, Smoke Deflectors, Heat Shields etc. | ✓ | | | | | 3 |
| Air Tubes | ✓ | | | | | 3 |
| Airmate | ✓ | | | | | 3 |
| Door handle and latch assembly, all hardware | ✓ | | | | | 3 |
| Glass Thermal Breakage Only | ✓ | | | | | 3 |
| Steel Faceplates, Accessory Housings | ✓ | | | | | 3 |
| All Plating | ✓ | | | | | 3 |
| Ash Drawer, Heatshields, Pedestal | ✓ | | | | | |
| All Baffles, Steel, Ceramic, Vermiculite C-Baffles | ✓ | | | | | |
| All castings, firebox, surrounds, doors, panels etc. | | ✓ | | | | 3 |
| All Electrical, Blower, wiring, switches etc. | | | ✓ | | | 2 |
| Glass - Crazing | | | | ✓ | | 1 |
| Catalyst Combustor | | | | | *10 Years Prorated | |
| Venting/Chimney | | | | ✓ | | 1 |
| Screens | | | | ✓ | | 1 |

*See specific warranty details in regards to the catalyst combustor in unit manual.

Conditions:

Warranty protects against defect in manufacture or FPI factory assembled components only, unless herein specified otherwise.

Any part(s) found to be defective during the warranty period as outlined above will be repaired or replaced at FPI’s option through an accredited distributor, dealer or pre-approved and assigned agent provided that the defective part is returned to the distributor, dealer or agent for inspection if requested by FPI. Alternatively, FPI may at its own discretion fully discharge all of its obligations under the warranty by refunding the verified purchase price of the product to the original purchaser. The purchase price must be confirmed by the original Bill of Sale.

The authorized selling dealer, or an alternative authorized FPI dealer if pre-approved by FPI, is responsible for all in-field diagnosis and service work related to all warranty claims. FPI is not responsible for results or costs of workmanship of unauthorized FPI dealers or agents in the negligence of their service work.

At all times FPI reserves the right to inspect reported complaints on location in the field claimed to be defective prior to processing or authorizing of any claim. Failure to allow this upon request will void the warranty.

All warranty claims must be submitted by the dealer servicing the claim, including a copy of the Bill of Sale (proof of purchase by you). All claims must be complete and provide full details as requested by FPI to receive consideration for evaluation. Incomplete claims may be rejected.

Replacement units are limited to one per warranty term. Airtube and baffle replacements are limited to one replacement per term.

Unit must be installed according to all manufacturers' instructions as per the manual.

All Local and National required codes must be met.

The installer is responsible to ensure the unit is operating as designed at the time of installation.

The original purchaser is responsible for annual maintenance of the unit, as outlined in the owner's manual. As outlined below, the warranty may be voided due to problems caused by lack of maintenance.

Repair/replacement parts purchased by the consumer from FPI after the original coverage has expired on the unit will carry a 90 day warranty, valid with a receipt only. Any item shown to be defective will be repaired or replaced at our discretion. No labor coverage is included with these parts.

Exclusions:

This Limited Lifetime Warranty does not extend to rust or corrosion of any kind due to: a lack of maintenance or improper venting, lack of combustion air provision, or exposure to corrosive chemicals (i.e. chlorine, salt, air, etc.).

This Limited Lifetime Warranty also does not extend to: paint, firebricks (rear, sides, or bottom), door gasketing, glass gasketing (or any other additional factory fitted gasketing), vermiculite floor bricks, andiron assemblies, and flue damper rods.

Malfunction, damage or performance based issues as a result of environmental conditions, location, chemical damages, downdrafts, installation error, installation by an unqualified installer, incorrect chimney components (including but not limited to cap size or type), operator error, abuse, misuse, use of improper fuels (such as unseasoned cordwood, mill-ends, construction lumber or debris, off-cuts, treated or painted lumber, metal or foil, plastics, garbage, solvents, cardboard, coal or coal products, oil based products, waxed cartons, compressed pre-manufactured logs, kiln dried wood), lack of regular maintenance and upkeep, acts of God, weather related problems from hurricanes, tornados, earthquakes, floods, lightning strikes/bolts or acts of terrorism or war, which result in malfunction of the appliance are not covered under the terms of this Limited Lifetime Warranty.

FPI has no obligation to enhance or modify any unit once manufactured (i.e. as products evolve, field modifications or upgrades will not be performed on existing appliances).

This warranty does not cover dealer travel costs for diagnostic or service work. All labor rates paid to authorized dealers are subsidized, pre-determined rates. Dealers may charge homeowner for travel and additional time beyond their subsidy.

Any unit showing signs of neglect or misuse will not be covered under the terms of this warranty policy and may void this warranty. This includes units with rusted or corroded fireboxes which have not been reported as rusted or corroded within three (3) months of installation/purchase.

Units which show evidence of being operated while damaged, or with problems known to the purchaser and causing further damages will void this warranty.

Units where the serial no. has been altered, deleted, removed or made illegible will void this warranty.

Minor movement, expansion and contraction of the steel is normal and is not covered under the terms of this warranty.

FPI is not liable for the removal or replacement of facings or finishing in order to repair or replace any appliance in the field.

Freight damages for products or parts are not covered under the terms of the warranty.

Products made or provided by other manufacturers and used in conjunction with the FPI appliance without prior authorization from FPI may void this warranty.

warranty

Limitations of Liability:

The original purchaser's exclusive remedy under this warranty, and FPI's sole obligation under this warranty, express or implied, in contract or in tort, shall be limited to replacement, repair, or refund, as outlined above. IN NO EVENT WILL FPI BE LIABLE UNDER THIS WARRANTY FOR ANY INCIDENTAL OR CONSEQUENTIAL COMMERCIAL DAMAGES OR DAMAGES TO PROPERTY. TO THE EXTENT PERMITTED BY APPLICABLE LAW, FPI MAKES NO EXPRESS WARRANTIES OTHER THAN THE WARRANTY SPECIFIED HEREIN. THE DURATION OF ANY IMPLIED WARRANTY IS LIMITED TO DURATION OF THE EXPRESSED WARRANTY SPECIFIED ABOVE. IF IMPLIED WARRANTIES CANNOT BE DISCLAIMED, THEN SUCH WARRANTIES ARE LIMITED IN DURATION TO THE DURATION OF THIS WARRANTY.

Some U.S. states do not allow limitations on how long an implied warranty lasts, or allow exclusion or limitation of incidental or consequential damages, so the above limitations or exclusions may not apply to you.

Customers located outside the U.S. should consult their local, provincial or national legal codes for additional terms which may be applicable to this warranty.

How to Obtain Warranty Service:

Customers should contact the authorized selling dealer to obtain all warranty and service. In the event the authorized selling dealer is unable to provide warranty / service, please contact FPI by mail at the address listed on the next page. Please include a brief description of the problem and your address, email and telephone contact information. A representative will contact you to make arrangements for an inspection and/or warranty service, by an alternative dealer.

Product Registration and Customer Support:

Thank you for choosing a Regency Fireplace. Regency strives to be a world leader in the design, manufacture, and marketing of hearth products. To provide the best support for your product, we request that you complete a product registration form at <http://www.regency-fire.com/Customer-Care/Warranty-Registration.aspx> within ninety (90) days of purchase.



Product Registration and Customer Support:

Thank you for choosing a Regency Fireplace. Regency strives to be a world leader in the design, manufacture, and marketing of hearth products. To provide the best support for your product, we request that you complete a product registration form found on our Web Site under Customer Care within ninety (90) days of purchase.

For purchases made in **CANADA or the UNITED STATES:**

<http://www.regency-fire.com/Customer-Care/Warranty-Registration.aspx>

For purchases made in AUSTRALIA:

<http://www.regency-fire.com.au/Customer-Care/Warranty-Registration.aspx>

You may also complete the warranty registration form below to register your Regency Fireplace Product and mail and/or fax it back to us, and we will register the warranty for you. It is important you provide us with all the information below in order for us to serve you better.

Warranty Registration Form (or Register online immediately at the above Web Site):

| | |
|--|--|
| Warranty Details | |
| Serial Number (required): | |
| Purchase Date (required) (mm/dd/yyyy): | |
| Product Details | |
| Product Model (required): | |
| Dealer Details | |
| Dealer Name (required): | |
| Dealer Address: | |
| Dealer Phone #: | |
| Installer: | |
| Date Installed (mm/dd/yyyy): | |
| Your Contact Details (required) | |
| Name: | |
| Address: | |
| Phone: | |
| Email: | |

For purchases made in CANADA:

**FPI Fireplace Products
International Ltd.**
6988 Venture St.
Delta, British Columbia
Canada, V4G 1H4

Phone: 604-946-5155
Fax: 1-866-393-2806

For purchases made in the UNITED STATES:

Fireplace Products US, Inc.
PO Box 2189 PMB 125
Blaine, WA
United States, 98231

Phone: 604-946-5155
Fax: 1-866-393-2806

For purchases made in AUSTRALIA:

**Fireplace Products Australia Pty
Ltd**
1- 3 Conquest Way
Hallam, VIC
Australia, 3803

Phone: +61 3 9799 7277
Fax: +61 3 9799 7822

For fireplace care and tips and answers to most common questions please visit our Customer Care section on our Web Site. Please feel free to contact your selling dealer if you have any questions about your Regency product.

warranty

notes

Lined writing area consisting of 22 horizontal lines.

Installer: Please complete the following information

Dealer Name & Address: _____

Installer: _____

Phone #: _____

Date Installed: _____

Serial #: _____



QUALITY CONTROL SERVICES

LABORATORY EQUIPMENT • SALES • SERVICE • CALIBRATION • REPAIRS
2340 SE 11TH Ave. Portland, Oregon 97214 • Box 14831 Portland, Oregon 97293
(503) 236-2712 • FAX (503) 235-2535 • www.qc-services.com



PFS Teco
11785 SE Hwy 212 STE#305
Clackamas, OR 97015

Report Number: DIRI01A05026181218

A2LA ACCREDITED CERTIFICATE OF CALIBRATION WITH DATA

INSTRUMENT INFORMATION

| Item | Make | Model | Serial Number | Customer ID | Location |
|-------|-------------|-------------------|---------------|---------------|--------------|
| Scale | Rice Lake | IQ+355E-2A x 100l | A05026 | #041 | Lab |
| Units | Readability | SOP | Cal Date | Last Cal Date | Cal Due Date |
| lbs | 0.1 | QC033 | 12/18/18 | 6/13/18 | 12/2019 |

FUNCTIONAL CHECKS

| SHIFT TEST | | LINEARITY | | REPEATABILITY | | ENVIRONMENTAL CONDITIONS |
|---|--------------------------------|---|--------------------------------|---|--------------------------------|---|
| Test Wt: | Tol: | Test Wt: | Tol: | Test Wt: | Tol: | <input type="checkbox"/> Good <input checked="" type="checkbox"/> Fair <input type="checkbox"/> Poor Temperature: 16.9°C |
| 250 | 1 | HB44 | HB44 | 100 | 1 | |
| As-Found: | | As-Found: | | As-Found: | | |
| Pass: <input checked="" type="checkbox"/> | Fail: <input type="checkbox"/> | Pass: <input checked="" type="checkbox"/> | Fail: <input type="checkbox"/> | Pass: <input checked="" type="checkbox"/> | Fail: <input type="checkbox"/> | |
| As-Left: | | As-Left: | | As-Left: | | |
| Pass: <input checked="" type="checkbox"/> | Fail: <input type="checkbox"/> | Pass: <input checked="" type="checkbox"/> | Fail: <input type="checkbox"/> | Pass: <input checked="" type="checkbox"/> | Fail: <input type="checkbox"/> | |

CALIBRATION DATA

| Standard | As-Found | As-Left | Expanded Uncertainty |
|----------|----------|---------|----------------------|
| 1000 | 999.3 | 1000.2 | 0.12 |
| 700 | 699.7 | 700.1 | 0.12 |
| 500 | 499.7 | 500.1 | 0.08 |
| 300 | 299.8 | 300.1 | 0.08 |
| 100 | 99.9 | 100.0 | 0.05 |
| 50 | 50.0 | 50.0 | 0.05 |

CALIBRATION STANDARDS

| Item | Make | Model | Serial Number | Cal Date | Cal Due Date | NIST ID |
|--------------------|-----------|-------------|---------------|----------|--------------|----------|
| Avoirdupois Cast W | Rice Lake | 25 and 50lb | PWO990-CA | 11/24/17 | 11/2019 | 20172265 |

Permanent Information Concerning this Equipment:

12 month calibration cycle. 2000lb platform.

Comments/Information Concerning this Calibration

12/18 - RH = 67%. Adjusted span.

Report prepared/reviewed by: ServiceTechDC Date: 12/28/18

Technician: R. Kauble

Signature: [Signature]

THIS CERTIFICATE SHALL NOT BE REPRODUCED, EXCEPT IN FULL, WITHOUT THE APPROVAL OF QUALITY CONTROL SERVICES, INC.

The uncertainty is calculated according to the ISO Guide to the Expression of Uncertainty in Measurement and includes the uncertainty of standards used combined with the observed standard deviation of the unit under test. The uncertainty is expanded with a k factor of 2 for an approximate 95% level of confidence. Instruments listed above were calibrated using standards traceable to the National Institute of Standards and Technology (NIST). Calibration data reflect results at the time and location of calibration. Calibration data should be reviewed to insure that the instrument is performing to its required accuracy.



QUALITY CONTROL SERVICES

LABORATORY EQUIPMENT • SALES • SERVICE • CALIBRATION • REPAIRS
 2340 SE 11TH Ave. Portland, Oregon 97214 • Box 14831 Portland, Oregon 97293
 (503) 236-2712 • FAX (503) 235-2535 • www.qc-services.com



PFS Teco
 11785 SE Hwy 212 STE#305
 Clackamas, OR 97015

Report Number: DIRI0182484A0912013i181218

A2LA ACCREDITED CERTIFICATE OF CALIBRATION WITH DATA

INSTRUMENT INFORMATION

| Item | Make | Model | Serial Number | Customer ID | Location |
|-------|-------------|----------------|----------------|---------------|--------------|
| Scale | Digiweigh | DWP12i 400x.01 | 82484A0912013i | #050 | Lab |
| Units | Readability | SOP | Cal Date | Last Cal Date | Cal Due Date |
| lbs | 0.01 | QC033 | 12/18/18 | 6/13/18 | 12/2019 |

FUNCTIONAL CHECKS

| SHIFT TEST | LINEARITY | REPEATABILITY | ENVIRONMENTAL CONDITIONS |
|---|---|---|--|
| Test Wt: 50 Tol: 0.05 As-Found: Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/> As-Left: Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/> | Test Wt: HB44 Tol: HB44 As-Found: Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/> As-Left: Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/> | Test Wt: 50 Tol: 0.01 As-Found: Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/> As-Left: Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/> | <input type="checkbox"/> <input checked="" type="checkbox"/> <input type="checkbox"/> Good Fair Poor Temperature: 16.4°C |

CALIBRATION DATA

| Standard | As-Found | As-Left | Expanded Uncertainty |
|----------|----------|---------|----------------------|
| 400 | 399.99 | 399.99 | 0.058 |
| 300 | 300.00 | 300.00 | 0.058 |
| 200 | 200.03 | 200.03 | 0.058 |
| 100 | 100.01 | 100.01 | 0.012 |
| 50 | 50.00 | 50.00 | 0.012 |
| 20 | 20.00 | 20.00 | 0.012 |

CALIBRATION STANDARDS

| Item | Make | Model | Serial Number | Cal Date | Cal Due Date | NIST ID |
|--------------------|-----------|-------------|---------------|----------|--------------|----------|
| Avoirdupois Cast W | Rice Lake | 25 and 50lb | PWO990-CA | 11/24/17 | 11/2019 | 20172265 |

Permanent Information Concerning this Equipment:
 12 month calibration cycle.

Comments/Information Concerning this Calibration
 12/18 - RH = 64%. Adjusted span.

Report prepared/reviewed by: ServiceTech DC Date: 12/28/18

Technician: R. Kauble
 Signature:

THIS CERTIFICATE SHALL NOT BE REPRODUCED, EXCEPT IN FULL, WITHOUT THE APPROVAL OF QUALITY CONTROL SERVICES, INC.

The uncertainty is calculated according to the ISO Guide to the Expression of Uncertainty in Measurement and includes the uncertainty of standards used combined with the observed standard deviation of the unit under test. The uncertainty is expanded with a k factor of 2 for an approximate 95% level of confidence. Instruments listed above were calibrated using standards traceable to the National Institute of Standards and Technology (NIST). Calibration data reflect results at the time and location of calibration. Calibration data should be reviewed to insure that the instrument is performing to its required accuracy.

Dry Gas Meter Calibration

Meter Manufacturer: Apex
 Model: XC-60-ED
 Lab ID #: 53
 Serial #: 1902130
 Calibration Date: 12/17/2018
 Calibration Expiration: 6/17/2019
 Barometric Pressure: 29.87 in. Hg



| Reference Standard DGM | |
|------------------------------|----------|
| Manufacturer: | Apex |
| Model: | SK25DA |
| Lab ID#: | 47 |
| Serial #: | 1101001 |
| Calibration Expiration Date: | 3/5/2019 |
| Calibration γ Factor: | 0.998 |

| Unit Under Test Previous Calibration | |
|--------------------------------------|------------|
| Date | 12/13/2018 |
| γ Factor: | 1.002 |
| Allowable Deviation ($\pm 5\%$): | 0.0501 |
| Actual Deviation: | 0.00 |
| Result: | PASS |

| Calibration Data | Run 1 | Run 2 | Run 3 |
|--|---------|---------|---------|
| Standard DGM Initial Volume (L) | 0.000 | 0.000 | 0.000 |
| Standard DGM Final Volume (L) | 166.180 | 147.027 | 169.354 |
| Standard DGM Temperature ($^{\circ}$ F) | 71.7 | 72.5 | 73.0 |
| Standard DGM Pressure (in H ₂ O) | 0.00 | 0.00 | 0.0 |
| DGM Initial Volume (ft ³) | 0.000 | 0.000 | 0.000 |
| DGM Final Volume (ft ³) | 5.950 | 5.296 | 6.132 |
| DGM Temperature ($^{\circ}$ F) | 83.0 | 91.0 | 93.0 |
| DGM Pressure (in H ₂ O) | 2.60 | 2.00 | 1.5 |
| Time (min) | 37.0 | 37.0 | 49.0 |
| Net Volume for Standard DGM (ft ³) | 5.869 | 5.192 | 5.981 |
| Net Volume for DGM (ft ³) | 5.950 | 5.296 | 6.132 |
| Dry Gas Meter γ Factor | 0.999 | 1.007 | 1.006 |
| γ Factor Deviation From Average | 0.999 | 1.007 | 1.006 |

Average Gas Meter γ Factor 1.004

Calculations:

- Deviation = |Average value for all runs - current run value|
- $\gamma = [V_{std} \times (Y_{std}) \times (P_{bar} + P_{std}/13.6) \times (T_{DGM} + 460)] / [V_{DGM} \times (T_{std} + 460) \times (P_{bar} + P_{DGM}/13.6)]$

Standard Reference Meter is calibrated to NIST traceable standards. Uncertainty of measurement is $\pm 0.5\%$.

Dry Gas Meter Calibration

Meter Manufacturer: Apex
 Model: XC-60-ED
 Lab ID #: 54
 Serial #: 1902133
 Calibration Date: 12/17/2018
 Calibration Expiration: 6/17/2019
 Barometric Pressure: 29.87 in. Hg



| Reference Standard DGM | |
|------------------------------|----------|
| Manufacturer: | Apex |
| Model: | SK25DA |
| Lab ID#: | 47 |
| Serial #: | 1101001 |
| Calibration Expiration Date: | 3/5/2019 |
| Calibration γ Factor: | 0.998 |

| Unit Under Test Previous Calibration | |
|--------------------------------------|------------|
| Date | 12/13/2018 |
| γ Factor: | 0.997 |
| Allowable Deviation ($\pm 5\%$): | 0.04985 |
| Actual Deviation: | 0.00 |
| Result: | PASS |

| Calibration Data | Run 1 | Run 2 | Run 3 |
|--|---------|---------|---------|
| Standard DGM Initial Volume (L) | 0.000 | 0.000 | 0.000 |
| Standard DGM Final Volume (L) | 153.596 | 138.287 | 193.022 |
| Standard DGM Temperature ($^{\circ}$ F) | 73.0 | 73.0 | 74.0 |
| Standard DGM Pressure (in H ₂ O) | 0.00 | 0.00 | 0.0 |
| DGM Initial Volume (ft ³) | 0.000 | 0.000 | 0.000 |
| DGM Final Volume (ft ³) | 5.594 | 5.047 | 7.058 |
| DGM Temperature ($^{\circ}$ F) | 94.5 | 95.0 | 96.0 |
| DGM Pressure (in H ₂ O) | 2.60 | 2.00 | 1.5 |
| Time (min) | 35.0 | 36.0 | 57.0 |
| Net Volume for Standard DGM (ft ³) | 5.424 | 4.884 | 6.816 |
| Net Volume for DGM (ft ³) | 5.594 | 5.047 | 7.058 |
| Dry Gas Meter γ Factor | 1.000 | 1.001 | 1.000 |
| γ Factor Deviation From Average | 1.000 | 1.001 | 1.000 |

Average Gas Meter γ Factor 1.000

Calculations:

- Deviation = |Average value for all runs - current run value|
- $\gamma = [V_{std} \times (Y_{std}) \times (P_{bar} + P_{std}/13.6) \times (T_{DGM} + 460)] / [V_{DGM} \times (T_{std} + 460) \times (P_{bar} + P_{DGM}/13.6)]$

Standard Reference Meter is calibrated to NIST traceable standards. Uncertainty of measurement is $\pm 0.5\%$.

Dry Gas Meter Calibration

Meter Manufacturer: Apex
 Model: Apex-AK-600
 Lab ID #: 055
 Serial #: 810016
 Calibration Date: 6/15/2018
 Calibration Expiration: 6/15/2019
 Barometric Pressure: 29.83 in. Hg



| Reference Standard DGM | |
|------------------------------|----------|
| Manufacturer: | Apex |
| Model: | SK25DA |
| Lab ID#: | 047 |
| Serial #: | 1101001 |
| Calibration Expiration Date: | 3/5/2019 |
| Calibration γ Factor: | 0.998 |

| Unit Under Test Previous Calibration | |
|--------------------------------------|-----------|
| Date | 1/18/2017 |
| γ Factor: | 0.997 |
| Allowable Deviation ($\pm 5\%$): | 0.04985 |
| Actual Deviation: | 0.00 |
| Result: | PASS |

| Calibration Data | Run 1 | Run 2 | Run 3 |
|--|---------|---------|---------|
| Standard DGM Initial Volume (L) | 0.000 | 0.000 | 0.000 |
| Standard DGM Final Volume (L) | 145.479 | 148.058 | 143.802 |
| Standard DGM Temperature ($^{\circ}$ F) | 71.0 | 71.0 | 71.0 |
| Standard DGM Pressure (in H ₂ O) | 0.00 | 0.00 | 0.0 |
| DGM Initial Volume (ft ³) | 0.000 | 0.000 | 0.000 |
| DGM Final Volume (ft ³) | 5.146 | 5.254 | 5.114 |
| DGM Temperature ($^{\circ}$ F) | 75.0 | 76.5 | 77.5 |
| DGM Pressure (in H ₂ O) | 1.80 | 1.80 | 1.8 |
| Time (min) | | | |
| Net Volume for Standard DGM (ft ³) | 5.138 | 5.229 | 5.078 |
| Net Volume for DGM (ft ³) | 5.146 | 5.254 | 5.114 |
| Dry Gas Meter γ Factor | 0.999 | 0.999 | 0.999 |
| γ Factor Deviation From Average | 0.999 | 0.999 | 0.999 |

Average Gas Meter γ Factor 0.999

Calculations:

- Deviation = |Average value for all runs - current run value|
- $\gamma = [V_{std} \times (\gamma_{std}) \times (P_{bar} + P_{std}/13.6) \times (T_{DGM} + 460)] / [V_{DGM} \times (T_{std} + 460) \times (P_{bar} + P_{DGM}/13.6)]$

Standard Reference Meter is calibrated to NIST traceable standards. Uncertainty of measurement is $\pm 0.5\%$.



QUALITY CONTROL SERVICES

LABORATORY EQUIPMENT • SALES • SERVICE • CALIBRATION • REPAIRS
2340 SE 11TH Ave. Portland, Oregon 97214 • Box 14831 Portland, Oregon 97293
(503) 236-2712 • FAX (503) 235-2535 • www.qc-services.com



Report of Calibration

Firm: Dirigo Laboratories
Address: 11785 SE Hwy 212, Ste 305
City/State/Zip: Clackamas, OR 97015

Test Completed: 03/21/17
Submitted By: John Steiner
Traceable Number: 20170468

Test Item: 200mg and 100mg Individual Weights
Serial No.: Listed in Table

Manufacturer: Troemner

| <u>Material</u> | <u>Assumed Density</u> | <u>Range</u> | <u>Tolerance Class</u> |
|-----------------|------------------------|---------------|------------------------|
| Stainless Steel | 7.95 g/cm ³ | 200mg & 100mg | ASTM Class 1 |

Method and Traceability

The procedure used for this calibration is NIST IR 6969 SOP 4 Double Substitution Weighing Design. Standards used for comparison are traceable to the National Institute of Standards and Technology (reports on file) and are part of a comprehensive measurement assurance program for ensuring continued accuracy and traceability within the level of uncertainty reported. The Traceable Number listed above is Traceable to National Standards through an unbroken chain of comparison each having stated uncertainties.

Standards Used:

100g to 1mg Working Standards Were Calibrated: 03/03/17 Due: 03/31/18 Standards ID: 723318
Mass Comparators Used: MET-05 Tested by: D. Thompson

Conventional Mass: “The conventional value of the result of weighing a body in air is equal to the mass of a standard, of conventionally chosen density, at a conventionally chosen temperature, which balances this body at this reference temperature in air of conventionally chosen density. International Recommendation 33 (OIML IR 33 1973, 1979). “Conventional Value of the Result of Weighing in Air” (Previously known as “Apparent Mass vs. 8.0g/cm³”).

Uncertainty Statement: The uncertainty conforms to the ISO Guide to the Expressions of Uncertainty in Measurement. Uncertainty as reported is based on a coverage factor k=2 for an approximate 95 percent level of uncertainty. Uncertainty components include the standard deviation of the process, the uncertainty of the standard used, an uncertainty component associated with the potential drift of the standard used, and the estimated uncertainty related to measuring and determining the air buoyancy effect.

Conventional Mass Values are listed on page 2 of this report.

page 1 of 2

Quality Control Services, Inc.
Metrology Laboratory Manager
E-mail dthompson@qc-services.com

Date: 03/21/17

Signature David S. Thompson

This document shall not be reproduced, except in full, without the written approval of Quality Control Services Mass Laboratory.

Member: National Conference of Standards Laboratories and Weights & Measures



QUALITY CONTROL SERVICES

LABORATORY EQUIPMENT • SALES • SERVICE • CALIBRATION • REPAIRS
2340 SE 11TH Ave. Portland, Oregon 97214 • Box 14831 Portland, Oregon 97293
(503) 236-2712 • FAX (503) 235-2535 • www.qc-services.com



Report of Calibration

Firm: Dirigo Laboratories
Address: 11785 SE Hwy 212, Ste 305
City/State/Zip: Clackamas, OR 97015

Test Completed: 03/21/17
Submitted By: John Steiner
Traceable Number: 20170468

Test Item: 200mg and 100mg Individual Weights
Serial No.: Listed in Table

Manufacturer: Troemner

Laboratory Environment at time of test

| Temperature °C | Pressure mmHg | Humidity %RH |
|----------------|---------------|--------------|
| 21.967 | 753.44 | 49.44 |

Conventional Mass Value

| Nominal Value | As Found grams | As Found Correction* (mg) | Uncertainty (mg) | Tolerance (mg) |
|---------------------|----------------|---------------------------|------------------|----------------|
| 200mg SN 1000101395 | 0.2000061 | 0.0061 | 0.0026 | 0.01 |
| 100mg SN 1000126267 | 0.1000046 | 0.0046 | 0.0028 | 0.01 |

*Correction is the difference between the conventional mass value of a weight and its nominal value.

Comments: These weights were new from the manufacturer and were within ASTM Class 1 tolerances As Found. No adjustments or changes were made so As Found values should be considered to be As Left values.

Accredited by the American Association for Laboratory Accreditation (A2LA) under Calibration Laboratory Code 115953 and Certificate Number 1550.01. This laboratory meets the requirements of ISO/IEC 17025:2005 *General Requirements for the Competence of Testing and Calibration Laboratories*. This laboratory also meets the requirements of ANSI/NCSL Z540-1-1994 and any additional program requirements in the field of calibration.

page 2 of 2

Quality Control Services, Inc.
Metrology Laboratory Manager
E-mail dthompson@qc-services.com

Date: 03/21/17

Signature David S. Thompson



QUALITY CONTROL SERVICES

LABORATORY EQUIPMENT • SALES • SERVICE • CALIBRATION • REPAIRS
2340 SE 11TH Ave. Portland, Oregon 97214 • Box 14831 Portland, Oregon 97293
(503) 236-2712 • FAX (503) 235-2535 • www.qc-services.com



Report of Calibration

Firm: Dirigo Laboratories
Address: 11785 SE Hwy 212, Ste 305
City/State/Zip: Clackamas, OR 97015

Test Completed: 01/15/16
Purchase Order: 1001
Traceable Number: 20152489

Test Item: 20lb and 10lb Individual Grip Handle Weights
Serial No.: Listed in Table

Manufacturer: Unknown

Laboratory Environment at time of test

| Temperature °C | Pressure mmHg | Humidity %RH |
|----------------|---------------|--------------|
| 21.448 | 760.64 | 44.58 |

Conventional Mass Value

| Nominal Value | As Found pounds | As Found Correction* (mg) | Uncertainty (mg) | Tolerance (mg) |
|---------------|-----------------|---------------------------|------------------|----------------|
| 20lb #098 | 19.9995450 | -206.4 | 6.4 | 910 |
| 10lb #097 | 10.0006510 | 295.3 | 5.1 | 450 |
| 10lb #051 | 10.0003421 | 155.2 | 5.1 | 450 |

*Correction is the difference between the conventional mass value of a weight and its nominal value.

Comments: These weights were received in good condition and were within NIST Handbook 105-1 Class F tolerances As Found. No adjustments or changes were made so As Found values should be considered to be As Left values.

Accredited by the American Association for Laboratory Accreditation (A2LA) under Calibration Laboratory Code 115953 and Certificate Number 1550.01. This laboratory meets the requirements of ISO/IEC 17025:2005 *General Requirements for the Competence of Testing and Calibration Laboratories*. This laboratory also meets the requirements of ANSI/NCSL Z540-1-1994 and any additional program requirements in the field of calibration.

page 2 of 2

Quality Control Services, Inc.
Metrology Laboratory Manager
E-mail dthompson@qc-services.com

Date: 01/15/16

Signature David S. Thompson



QUALITY CONTROL SERVICES

LABORATORY EQUIPMENT • SALES • SERVICE • CALIBRATION • REPAIRS
2340 SE 11TH Ave. Portland, Oregon 97214 • Box 14831 Portland, Oregon 97293
(503) 236-2712 • FAX (503) 235-2535 • www.qc-services.com



PFS Teco
11785 SE Hwy 212 STE#305
Clackamas, OR 97015

Report Number: DIRI0134307497181218

A2LA ACCREDITED CERTIFICATE OF CALIBRATION WITH DATA

INSTRUMENT INFORMATION

| Item | Make | Model | Serial Number | Customer ID | Location |
|---------|-------------|--------------|---------------|---------------|--------------|
| Balance | Sartorius | ENTRIS224-1S | 34307497 | #107 | Lab |
| Units | Readability | SOP | Cal Date | Last Cal Date | Cal Due Date |
| g | 0.0001 | QC012 | 12/18/18 | 6/13/18 | 12/2019 |

FUNCTIONAL CHECKS

| ECCENTRICITY | | LINEARITY | | STANDARD DEVIATION | | | ENVIRONMENTAL CONDITIONS |
|---|--------------------------------|---|--------------------------------|--------------------|-------------|---------------|---|
| Test Wt: | Tol: | Test Wt: | Tol: | Test Wt: | Tol: | | |
| 100 | 0.0003 | 50 x 4 | 0.0002 | 100 | 0.0001 | | <input type="checkbox"/> <input checked="" type="checkbox"/> <input type="checkbox"/> |
| As-Found: | | As-Found: | | 1. 100.0001 | 5. 100.0002 | 9. 100.0001 | Good Fair Poor |
| Pass: <input checked="" type="checkbox"/> | Fail: <input type="checkbox"/> | Pass: <input checked="" type="checkbox"/> | Fail: <input type="checkbox"/> | 2. 100.0001 | 6. 100.0001 | 10. 100.0001 | |
| As-Left: | | As-Left: | | 3. 100.0001 | 7. 100.0001 | <u>Result</u> | Temperature: 21.3°C |
| Pass: <input checked="" type="checkbox"/> | Fail: <input type="checkbox"/> | Pass: <input checked="" type="checkbox"/> | Fail: <input type="checkbox"/> | 4. 100.0001 | 8. 100.0002 | 0.00004 | |

A2LA ACCREDITED SECTION OF REPORT

| Standard | As-Found | As-Left | Expanded Uncertainty |
|----------|----------|----------|----------------------|
| 200 | 200.0002 | 200.0001 | 0.00014 |
| 100 | 100.0001 | 100.0001 | 0.00014 |
| 50 | 50.0003 | 50.0001 | 0.00014 |
| 20 | 20.0001 | 20.0001 | 0.00014 |
| 1 | 1.0001 | 1.0000 | 0.00014 |
| 0.1 | 0.1000 | 0.1000 | 0.00014 |

CALIBRATION STANDARDS

| Item | Make | Model | Serial Number | Cal Date | Cal Due Date | NIST ID |
|------------|---------------|-------------|---------------|----------|--------------|----------|
| Weight Set | R.L./Troemner | 10kg to 1mg | G782 | 1/3/18 | 1/2019 | 20172421 |

Permanent Information Concerning this Equipment:
12 month calibration cycle.

Comments/Info Concerning this Calibration:
12/18 - RH = 56%. Adjusted span.

Report prepared/reviewed by: ServiceTech X Date: 12/28/18

Technician: R. Kauble
Signature:

THIS CERTIFICATE SHALL NOT BE REPRODUCED WITHOUT THE APPROVAL OF QUALITY CONTROL SERVICES, INC.

The uncertainty is calculated according to the ISO Guide to the Expression of Uncertainty in Measurement and includes the uncertainty of standards used combined with the observed standard deviation and readability of the unit under test. The uncertainty is expanded with a k factor of 2 for an approximate 95% level of confidence. Instruments listed above were calibrated using standards traceable to the National Institute of Standards and Technology (NIST). Calibration data reflect results at the time and location of calibration. Calibration data should be reviewed to insure that the instrument is performing to its required accuracy. Calibrations comply with ISO/IEC 17025 and ANSI/Z540-1-1994 quality standards.

NIST Traceable
Calibration Report



Reference Number: 1200788
 PO Number: JSTEINERT013118

PFS-TECO
 11785 SE Highway 212
 Suite 305
 Clackamas, OR 97015 United States

Manufacturer: Dwyer Instruments Inc.
Model Number: 471
Description: Air Velocity, Digital Thermo Anemometer
Asset Number: #095
Serial Number: #095
Procedure: DS Universal Speed/Time/Temperature

Calibration Date: 02/14/2018
Calibration Due Date: 02/14/2019
Condition As Found: Limited In Tol See Comments
Condition As Left: Limited See Comments

Remarks:

NIST-traceable calibration performed on the unit referenced above in accordance with customer requirements, published specifications and the lab's standard operating procedures. No adjustments were made to the unit.

This calibration is considered limited due to the requested test range.

Standards Utilized

| Asset No. | Manufacturer | Model No. | Description | Cal. Date | Due Date |
|-----------|-------------------|-----------|-------------------------------------|------------|------------|
| CP105979 | Kanomax | X5602 | Air Velocity, Wind Tunnel, Open Jet | 01/06/2018 | 01/31/2019 |
| CP144554 | Fluke Corporation | 1551A EX | Temperature, Stik Thermometer | 01/08/2018 | 01/31/2019 |

Calibration Data

| FUNCTION TESTED | Nominal Value | As Found | Out of Tol | As Left | Out of Tol | CALIBRATION TOLERANCE |
|--------------------------------|---------------|----------|------------|---------|------------|--|
| Speed Accuracy Air Velocity | 50 ft/min | 43 | | Same | | 35 to 65 ft/min [EMU 1.3 ft/min][TUR 12:1] |
| Speed Accuracy Air Velocity | 100 ft/min | 90 | | Same | | 85 to 115 ft/min [EMU 1.5 ft/min][TUR 9.8:1] |
| Speed Accuracy Air Velocity | 150 ft/min | 140 | | Same | | 135 to 165 ft/min [EMU 1.8 ft/min][TUR 8.3:1] |
| Speed Accuracy Air Velocity | 200 ft/min | 192 | | Same | | 185 to 215 ft/min [EMU 2.1 ft/min][TUR 7.1:1] |
| Speed Accuracy Air Velocity | 250 ft/min | 240 | | Same | | 235 to 265 ft/min [EMU 2.4 ft/min][TUR 6.2:1] |
| Speed Accuracy Air Velocity | 300 ft/min | 288 | | Same | | 285 to 315 ft/min [EMU 2.7 ft/min][TUR 5.6:1] |
| Speed Accuracy Air Velocity | 400 ft/min | 395 | | Same | | 385 to 415 ft/min [EMU 3.3 ft/min][TUR 4.5:1] |
| Speed Accuracy Air Velocity | 500 ft/min | 485 | | Same | | 485 to 515 ft/min [EMU 3.9 ft/min][TUR 3.8:1] |
| Temperature Accuracy | 72.0 °F | 71.9 | | Same | | 70.0 to 74.0 °F [EMU 0.11 °F][TUR 18:1] |

Temperature: 23° C
Humidity: 20% RH
Rpt. No.: 1375092

| Calibration Performed By: | | | | Quality Reviewer: | |
|---------------------------|------|-------------|--------------|-------------------|------------|
| Name | ID # | Title | Phone | Name | Date |
| Mathews, Rich | 314 | Metrologist | 847-327-5314 | Szplit, Tony | 02/14/2018 |

This report may not be reproduced, except in full, without written permission of Innocal. The results stated in this report relate only to the items tested or calibrated. Measurements reported herein are traceable to SI units via national standards maintained by NIST and were performed in compliance with MIL-STD-45662A, ANSI/NCSL Z540-1-1994, 10CFR50, Appendix B, ISO 9002-94, and ISO 17025:2005. Guard Banding, if reported on this certificate, is applied at a Z-factor of 30% for test points with a test uncertainty ratio (TUR) below 4:1. In Tolerance conditions are based on test results falling within specified limits with no reduction by the uncertainty of the measurement. The estimated measurement uncertainty (EMU), if reported on this certificate, is being reported at a confidence level of 95% or K=2 unless otherwise noted in the remarks section.





Model 1430 Microtector® Electronic Point Gage

Installation and Operating Instructions



Model 1430 Microtector® Portable Electronic Point Gage combines modern, solid-state integrated circuit electronics with a time-proven point gage manometer to provide fast, accurate pressure measurements.

SPECIFICATIONS AND FEATURES

- Accurate and repeatable to $\pm .00025$ inches water column
- Pressure range: 0 - 2" w.c., positive, negative, or differential pressures
- Non-toxic and inexpensive gage fluid consists of distilled water mixed with a small amount of fluorescein green color concentrate
- Convenient, portable, lightweight and self-contained, the unit requires no external power connections and is operated by a 1.5 volt penlight cell
- A.C. detector current eliminates point plating, fouling and erosion
- Micrometers are manufactured in accordance with ASME B89.1.13-2001, and are traceable to a standard at the National Institute of Standards and Technology

- Three-point mounting, dual leveling adjustment, and circular level vial assure rapid setup
- Durablock® precision-machined acrylic gage body
- Sensitive 0 - 50 microamp D.C. meter acts as a detector and also indicates battery and probe condition
- Heavy 2" thick steel base plate provides steady mounting
- Top-quality glass epoxy circuit board and solid-state, integrated circuit electronics
- Electronic enclosure of tough, molded styrene acrylonitrile provides maximum protection to components yet allows easy access to battery compartment
- Rugged sheet steel cover and carrying case protects the entire unit when not in use
- Accessories included are (2) 3-foot lengths Tygon® tubing, (2) 1/8" pipe thread adapters and 3/4 oz. bottle of fluorescein green color concentrate with wetting agent

Maximum pressure: 100 psig with optional pipe thread connections.

Tygon® is a registered trademark of Saint-Gobain Corporation

DWYER INSTRUMENTS, INC.

P.O. BOX 373

MICHIGAN CITY, INDIANA 46361, U.S.A.

Phone: 219/879-8000

Fax: 219/872-9057

www.dwyer-inst.com

e-mail: info@dwyer-inst.com



Praxair
 5700 South Alameda Street
 Los Angeles, CA 90058
 Tel: (323) 585-2154 Fax: (714) 542-6689
 PGVPID: F22017

DocNumber: 000113537

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information:

PXPKG TUALATIN OR H
 10450 SW TUALATIN SHERWOOD
 TUALATIN OR 97062

Praxair Order Number: 70337802
 Customer P. O. Number:
 Customer Reference Number:

Fill Date: 8/7/2017
 Part Number: NI CD17C08E-AS
 Lot Number: 70086721903
 Cylinder Style & Outlet: AS CGA 590
 Cylinder Pressure & Volume: 1290 psig 99 cu ft.

Certified Concentration:

| | | |
|------------------|-----------------|-------------------------|
| Expiration Date: | 8/11/2025 | NIST Traceable |
| Cylinder Number: | CC700832 | Analytical Uncertainty: |
| 4.33 % | CARBON MONOXIDE | ± 0.5 % |
| 16.93 % | CARBON DIOXIDE | ± 0.3 % |
| 16.99 % | OXYGEN | ± 0.2 % |
| Balance | NITROGEN | |

Certification Information: Certification Date: 8/11/2017 Term: 96 Months Expiration Date: 8/11/2025
 This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Do Not Use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

1. Component: CARBON MONOXIDE

(R=Reference Standard, Z=Zero, Gas, C=Gas Candidate)
 Requested Concentration: 4.25 %
 Certified Concentration: 4.33 %
 Instrument Used: Horiba VIA-510 S/N UB9UCSYX
 Analytical Method: NDIR
 Last Multipoint Calibration: 7/23/2017

| | | | | | |
|-----------------------------|---------|---------|-------|------------------|-----------|
| First Analysis Data: | | | | Date: | 8/11/2017 |
| Z: 0 | R: 5 | C: 4.33 | Conc: | 4.333 | |
| R: 4.99 | Z: 0 | C: 4.33 | Conc: | 4.333 | |
| Z: 0 | C: 4.32 | R: 5 | Conc: | 4.323 | |
| UOM: % | | | | Mean Test Assay: | 4.33 % |

Reference Standard Type: GMIS
 Ref. Std. Cylinder #: CC242633
 Ref. Std. Conc: 5.00%
 Ref. Std. Traceable to SRM #: 2642a
 SRM Sample #: 51-D-23
 SRM Cylinder #: FF23106

| | | | | | |
|------------------------------|------|------|-------|------------------|-----|
| Second Analysis Data: | | | | Date: | |
| Z: 0 | R: 0 | C: 0 | Conc: | 0 | |
| R: 0 | Z: 0 | C: 0 | Conc: | 0 | |
| Z: 0 | C: 0 | R: 0 | Conc: | 0 | |
| UOM: % | | | | Mean Test Assay: | 0 % |

2. Component: CARBON DIOXIDE

Requested Concentration: 17 %
 Certified Concentration: 16.93 %
 Instrument Used: Horiba VIA-510 S/N 20C194WK
 Analytical Method: NDIR
 Last Multipoint Calibration: 7/20/2017

| | | | | | |
|-----------------------------|----------|----------|-------|------------------|-----------|
| First Analysis Data: | | | | Date: | 8/11/2017 |
| Z: 0 | R: 20.08 | C: 16.99 | Conc: | 16.936 | |
| R: 20.08 | Z: 0 | C: 16.99 | Conc: | 16.936 | |
| Z: 0 | C: 16.98 | R: 20.09 | Conc: | 16.926 | |
| UOM: % | | | | Mean Test Assay: | 16.933 % |

Reference Standard Type: GMIS
 Ref. Std. Cylinder #: SA10234
 Ref. Std. Conc: 20.02%
 Ref. Std. Traceable to SRM #: RGM#CC28
 SRM Sample #: N/A
 SRM Cylinder #: RGM#CC28033

| | | | | | |
|------------------------------|------|------|-------|------------------|-----|
| Second Analysis Data: | | | | Date: | |
| Z: 0 | R: 0 | C: 0 | Conc: | 0 | |
| R: 0 | Z: 0 | C: 0 | Conc: | 0 | |
| Z: 0 | C: 0 | R: 0 | Conc: | 0 | |
| UOM: % | | | | Mean Test Assay: | 0 % |

Information contained herein has been prepared at your request by qualified experts within Praxair Distribution, Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Praxair Distribution, Inc., arising out of the use of the information contained herein exceed the fee established for providing such information.



CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information

PXPKG TUALATIN OR H
10450 SW TUALATIN SHERWOOD ROAD
TUALATIN OR 97062

Certificate Modification Date: 09/05/2018
Praxair Order Number: 70716136
Part Number: NI CD10CO33E-AS

Fill Date: 08/31/2018
Lot Number: 70086824308
Cylinder Style & Outlet: AS CGA 590
Cylinder Pressure and Volume: 2000 psig 140 ft3

Certified Concentration

| | | | |
|------------------|-----------------|----------------------|--|
| Expiration Date: | 09/05/2026 | NIST Traceable | |
| Cylinder Number: | CC170624 | Expanded Uncertainty | |
| 10.00 % | Carbon dioxide | ± 0.3 % | |
| 2.51 % | Carbon monoxide | ± 0.7 % | |
| 10.50 % | Oxygen | ± 0.6 % | |
| Balance | Nitrogen | | |

ProSpec EZ Cert



Certification Information:

Certification Date: 09/05/2018 Term: 96 Months Expiration Date: 09/05/2026

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1.
Do Not Use this Standard if Pressure is less than 100 PSIG.

CO responses have been corrected for CO2 interference. CO2 responses have been corrected for Oxygen IR Broadening effect. O2 responses have been corrected for CO2 interference.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: Carbon dioxide

Requested Concentration: 10 %
Certified Concentration: 10.00 %
Instrument Used: Horiba VIA-510 S/N 20C194WK
Analytical Method: NDIR
Last Multipoint Calibration: 08/20/2018

Reference Standard: Type / Cylinder #: GMIS / CC141375
Concentration / Uncertainty: 14.02 % ± 0.3 %
Expiration Date: 06/11/2026

Traceable to: SRM # / Sample # / Cylinder #: SRM 1675b / 6-F-51 / CAL014538
SRM Concentration / Uncertainty: 13.963 % / ± 0.034 %
SRM Expiration Date: 05/16/2022

| First Analysis Data: | | | | Date |
|----------------------|----------|----------|----------|-----------------------|
| Z: 0 | R: 14.02 | C: 10 | Conc: 10 | 09/05/2018 |
| R: 14.02 | Z: 0 | C: 10 | Conc: 10 | |
| Z: 0 | C: 10 | R: 14.02 | Conc: 10 | |
| UOM: % | | | | Mean Test Assay: 10 % |

| Second Analysis Data: | | | | Date |
|-----------------------|------|------|---------|--------------------|
| Z: 0 | R: 0 | C: 0 | Conc: 0 | |
| R: 0 | Z: 0 | C: 0 | Conc: 0 | |
| Z: 0 | C: 0 | R: 0 | Conc: 0 | |
| UOM: % | | | | Mean Test Assay: % |

2. Component: Carbon monoxide

Requested Concentration: 2.5 %
Certified Concentration: 2.51 %
Instrument Used: Horiba VIA-510 S/N UB9UCSYX
Analytical Method: NDIR
Last Multipoint Calibration: 08/20/2018

Reference Standard: Type / Cylinder #: GMIS / CC102045
Concentration / Uncertainty: 2.48 % ± 0.448 %
Expiration Date: 04/03/2025

Traceable to: SRM # / Sample # / Cylinder #: SRM 2641a / 52-D-30 / CAL017193
SRM Concentration / Uncertainty: 4.009 % / ± 0.017 %
SRM Expiration Date: 07/15/2019

| First Analysis Data: | | | | Date |
|----------------------|---------|---------|------------|-------------------------|
| Z: 0 | R: 2.48 | C: 2.51 | Conc: 2.51 | 09/05/2018 |
| R: 2.48 | Z: 0 | C: 2.51 | Conc: 2.51 | |
| Z: 0 | C: 2.51 | R: 2.48 | Conc: 2.51 | |
| UOM: % | | | | Mean Test Assay: 2.51 % |

| Second Analysis Data: | | | | Date |
|-----------------------|------|------|---------|--------------------|
| Z: 0 | R: 0 | C: 0 | Conc: 0 | |
| R: 0 | Z: 0 | C: 0 | Conc: 0 | |
| Z: 0 | C: 0 | R: 0 | Conc: 0 | |
| UOM: % | | | | Mean Test Assay: % |

3. Component: Oxygen

Requested Concentration: 10.5 %
Certified Concentration: 10.50 %
Instrument Used: OXYMAT 5E
Analytical Method: Paramagnetic
Last Multipoint Calibration: 09/04/2018

Reference Standard: Type / Cylinder #: NTRM / DT0010402
Concentration / Uncertainty: 9.88 % ± 0.4 %
Expiration Date: 11/18/2022

Traceable to: SRM # / Sample # / Cylinder #: NTRM #170701 / N/A / NTRM #DT0010402
SRM Concentration / Uncertainty: 9.875 % / ± 0.040 %
SRM Expiration Date: 11/18/2022

| First Analysis Data: | | | | Date |
|----------------------|---------|----------|-------------|-------------------------|
| Z: 0 | R: 9.88 | C: 10.49 | Conc: 10.49 | 09/05/2018 |
| R: 9.88 | Z: 0 | C: 10.5 | Conc: 10.5 | |
| Z: 0 | C: 10.5 | R: 9.88 | Conc: 10.5 | |
| UOM: % | | | | Mean Test Assay: 10.5 % |

| Second Analysis Data: | | | | Date |
|-----------------------|------|------|---------|--------------------|
| Z: 0 | R: 0 | C: 0 | Conc: 0 | |
| R: 0 | Z: 0 | C: 0 | Conc: 0 | |
| Z: 0 | C: 0 | R: 0 | Conc: 0 | |
| UOM: % | | | | Mean Test Assay: % |

Analyzed By: Danielle Burns

Certified By: José Vasquez

Information contained herein has been prepared at your request by qualified experts within Praxair Distribution, Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Praxair Distribution, Inc., arising out of the use of the information contained herein exceed the fee established for providing such information.

Verification of Standardization

of

Tape Measure

by

Advanced Calibration Technologies
28111 S.E. Wally Road
Boring, OR 97009
1-800-259-5058



| | |
|--|---|
| Customer: PFS Teco, Inc | Street: 11785 Southeast Highway 212 Suite 305 |
| City: Clackamas State: OR | Zip: 97015 Location: In House |
| Machine Manufacturer: Dewalt | Model: 16' Tape Measure |
| Capacity: 0.000 - 192.000 inches 0.125 Divisions | Serial #: 090 |
| Calibration Cycle: 12 Months | Lab ID#: #090 |
| Previous Calibration Date: January 2019 | Calibration Procedure: Ad-Tek SR |
| Equipment Used: Gauge Blocks S/N: ADGB002 | Action Recommended: |
| If Other, Explain: | |

Verification Data

| Purpose: This method provides instructions for checking the critical dimensions of the equipment. | | | |
|---|-----------------------------------|----------------------------------|---------------------|
| Tolerance: Equipment shall meet the dimensional tolerances specified in the applicable test method. | | | |
| Procedure: Verified using manufacturer's procedures. | | | |
| Actual Dimensions (inches) | Unit Under Test As Found (inches) | Unit Under Test As Left (inches) | Difference (inches) |
| 0.0000 | 0.000 | 0.000 | 0.000 |
| 0.1250 | 0.050 | 0.050 | -0.075 |
| 0.2500 | 0.250 | 0.250 | 0.000 |
| 0.5000 | 0.500 | 0.500 | 0.000 |
| 0.7500 | 0.750 | 0.750 | 0.000 |
| 1.0000 | 1.000 | 1.000 | 0.000 |
| 3.0000 | 3.000 | 3.000 | 0.000 |
| 5.0000 | 5.000 | 5.000 | 0.000 |
| 7.0000 | 7.000 | 7.000 | 0.000 |
| 9.0000 | 9.000 | 9.000 | 0.000 |
| 12.0000 | 12.000 | 12.000 | 0.000 |
| The overall condition of the device as found: | | Within Specification | |
| The overall condition of the device as left: | | Within Specification | |
| The measurement of uncertainty (MU) was calculated to be: | | 0.00060 | |

File No: PFS-101666-0119D0120-AH-SR-090

Temperature: 72.1°F Humidity: 41.1%

The equipment used in the verification of this instrument has been calibrated and is NIST traceable.
The uncertainty of calibration was estimated at the 95% confidence level, coverage factor (k=2).

Remarks: _____

This certificate of verification is issued as a statement of fact that on the date of verification the above instrument had an accuracy as indicated and was calibrated to meet the requirements of the manufacturer's specifications. This certificate should not be construed or regarded as a guarantee or warranty of any kind that the instrument will retain the same percentage of accuracy as determined on the date when the verification was performed and reported. Ad-Tek, Inc. hereby expressly disclaims any and all liability for damage or loss by all parties arising or resulting from deterioration, obsolescence, malfunction, subsequent calibration performed by another agency or substandard performance of said instrument.

This report and certificate of verification shall not be reproduced except in full, without the written approval of Ad-Tek, Inc.

Service Technician: Alisa Houser Date of Service: January 16, 2019

Technical Manager: Nicole Ostrowski Date Next Due: January 2020

We sincerely appreciate your business and thank you for selecting Advanced Calibration Technologies, Inc. for servicing your equipment.
To reschedule, please call (800) 259-5058. Thank You.

Verification of Standardization

of Calipers

by
Advanced Calibration Technologies
28111 S.E. Wally Road
Boring, OR 97009
1-800-259-5058



| | |
|---|---|
| Customer: PFS Teco, Inc | Street: 11785 Southeast Highway 212 Suite 305 |
| City: Clackamas State: OR | Zip: 97015 Location: In House |
| Machine Manufacturer: General | Model: 6" Digital Caliper |
| Capacity: 0.0000 - 6.0000 inches 0.0005 Divisions | Serial #: 092 |
| Calibration Cycle: 12 Months | Lab ID#: 092 |
| Previous Calibration Date: January 2018 | Calibration Procedure: Ad-Tek DC |
| Equipment Used: Gauge Blocks S/N: ADGB002 | Action Recommended: |
| If Other, Explain: | |

Verification Data

| Purpose: This method provides instructions for checking the critical dimensions of the inside diameter of the equipment. | | | |
|--|-----------------------------------|----------------------------------|---------------------|
| Tolerance: Equipment shall meet the dimensional tolerances specified by the manufacturer for the inside diameter. | | | |
| Procedure: Verified using the procedure to meet manufacturer's tolerance for inside diameter. | | | |
| Actual Dimensions (inches) | Unit Under Test As Found (inches) | Unit Under Test As Left (inches) | Difference (inches) |
| 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 0.0500 | 0.0500 | 0.0500 | 0.0000 |
| 0.1000 | 0.1000 | 0.1000 | 0.0000 |
| 0.1010 | 0.1010 | 0.1010 | 0.0000 |
| 0.1050 | 0.1050 | 0.1050 | 0.0000 |
| 0.1100 | 0.1100 | 0.1100 | 0.0000 |
| 0.1500 | 0.1500 | 0.1500 | 0.0000 |
| 0.5000 | 0.5000 | 0.5000 | 0.0000 |
| 1.0000 | 1.0000 | 1.0000 | 0.0000 |
| 3.0000 | 2.9995 | 2.9995 | -0.0005 |
| 5.0000 | 4.9990 | 4.9990 | -0.0010 |
| The overall condition of the device as found: | | Within Specification | |
| The overall condition of the device as left: | | Within Specification | |
| The measurement of uncertainty (MU) was calculated to be: | | 0.00062 | |

This certificate does not reflect measurements for inside jaws, step height, or depth.

File No: PFS-101666-0119D0120-AH-DC-092

Temperature: 68.2°F Humidity: 41.6%

The equipment used in the verification of this instrument has been calibrated and is NIST traceable.
The uncertainty of calibration was estimated at the 95% confidence level, coverage factor (k=2).

Remarks: _____

This certificate of verification is issued as a statement of fact that on the date of verification the above instrument had an accuracy as indicated and was calibrated to meet the requirements of the manufacturer's specifications. This certificate should not be construed or regarded as a guarantee or warranty of any kind that the instrument will retain the same percentage of accuracy as determined on the date when the verification was performed and reported. Ad-Tek, Inc. hereby expressly disclaims any and all liability for damage or loss by all parties arising or resulting from deterioration, obsolescence, malfunction, subsequent calibration performed by another agency or substandard performance of said instrument.

This report and certificate of verification shall not be reproduced except in full, without the written approval of Ad-Tek, Inc.

Service Technician: Alisa Houser Date of Service: January 15, 2019

Technical Manager: Nicole Ostrowski Date Next Due: January 2020

We sincerely appreciate your business and thank you for selecting Advanced Calibration Technologies, Inc. for servicing your equipment.
To reschedule, please call (800) 259-5058. Thank You.

J-2000

owner's manual



DELMHORST[®]
INSTRUMENT CO.

WHEN ACCURACY IS THE POINT.[™]



Calibration complies with ISO/IEC 17025, ANSI/NCSL Z540-1, and 9001



Cert. No.: 4198-9765787

Traceable® Certificate of Calibration for Hand Held Barometer

Customer :PFS TECO Suite 305 ,11785 SE Highway 212 ,Clackamas ,OR-97015 ,U.S.A.

Instrument Identification:

Model: 4198, S/N: 80531676 Manufacturer: Control Company

Standards/Equipment:

Table with 4 columns: Description, Serial Number, Due Date, NIST Traceable Reference. Rows include Digital Barometer and Digital Thermometer.

Certificate Information:

Technician: 57 Procedure: CAL-32 Cal Date: 29 Aug 2018 Cal Due Date: 29 Aug 2019
Test Conditions: 62.73%RH 23.92°C 1018mBar

Calibration Data:

Table with 11 columns: Unit(s), Nominal, As Found, In Tol, Nominal, As Left, In Tol, Min, Max, ±U, TUR. Rows show calibration data for temperature and pressure.

This certificate indicates Traceability to standards provided by (NIST) National Institute of Standards and Technology and/or a National Standards Laboratory.

A Test Uncertainty Ratio of at least 4:1 is maintained unless otherwise stated and is calculated using the expanded measurement uncertainty. Uncertainty evaluation includes the instrument under test and is calculated in accordance with the ISO "Guide to the Expression of Uncertainty in Measurement : (GUM). The uncertainty represents an expanded uncertainty using a coverage factor k=2 to approximate a 95% confidence level.

Nominal=Standard's Reading; As Left=Instrument's Reading; In Tol=In Tolerance; Min/Max=Acceptance Range; ± U=Expanded Measurement Uncertainty; TUR=Test Uncertainty Ratio; Accuracy=±(Max-Min)/2; Min=As Left Nominal(Rounded) - Tolerance; Max= As Left Nominal(Rounded) + Tolerance;

Nicol Rodriguez, Quality Manager

Aaron Justice, Technical Manager

Note :

Maintaining Accuracy:

In our opinion once calibrated your Hand Held Barometer should maintain its accuracy. There is no exact way to determine how long calibration will be maintained. Hand Held Barometer change little, if any at all, but can be affected by aging, temperature, shock, and contamination.

Recalibration:

For factory calibration and re-certification traceable to National Institute of Standards and Technology contact Control Company.

CONTROL COMPANY 12554 Galveston RD Suite B230 Webster TX USA 77598
Phone 281 482-1714 Fax 281 482-9448 sales@control3.com www.control3.com

Control Company is an ISO/IEC 17025:2005 Calibration Laboratory Accredited by (A2LA) American Association for Laboratory Accreditation, Certificate No. 1750.01.
Control Company is ISO 9001:2008 Quality Certified by DNV GL, Certificate No. CERT-01805-2006-AQ-HOU-RvA.
International Laboratory Accreditation Cooperation (ILAC) - Multilateral Recognition Arrangement (MRA).